


| LCS Number | Date Reading Collected | Measured Liquid Level Below Ground Surface (feet) | Transducer Depth from Top of Casing (Ft.) | Base of Sump Elevation (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments                             |
|------------|------------------------|---|---|----------------------------------|-----------------------------------|-------------------------|--------------------------------------|
| LCS- 1D    | 1/7/15                 |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 1/14/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 1/21/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 1/28/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 2/4/15                 |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 2/11/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 2/18/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 2/25/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Tranducer is out                     |
| LCS- 1D    | 3/4/15                 |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Replaced, Cal in Progress |
| LCS- 1D    | 3/11/15                | 90.0  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@90ft   |
| LCS- 1D    | 3/17/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 3/24/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 3/31/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 4/7/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 4/14/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 4/21/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 4/28/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 5/5/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 5/12/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 5/19/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 5/26/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 6/2/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 6/9/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 6/16/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 6/23/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 6/30/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 7/7/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 7/14/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 7/21/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 7/28/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 8/4/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 8/11/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 8/18/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 8/25/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 9/1/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 9/8/15                 | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 9/15/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 9/22/15                | 92.4  | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Liquid Level Below Transducer@92.4'  |
| LCS- 1D    | 9/29/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 10/6/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 10/13/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 10/22/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 10/28/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 11/3/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 11/11/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 11/17/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 11/24/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 12/1/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 12/8/15                |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 12/15/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 12/22/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 12/29/15               |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |
| LCS- 1D    | 1/5/16                 |   | 97.0                                      | 252.22                           | Y                                 | Dedicated Transducer    | Transducer Outage, pump operational  |


# LCS-1D Liquid Level Below Ground Surface



| LCS Number | Date Reading Collected | Measured Liquid Level Above Transducer (Ft.) | Transducer Height above Floor of Quarry (Ft.) | Base of Sump Elevation (Ft. MSL) | Elevation of Leachate (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments                          |
|------------|------------------------|--|---|----------------------------------|---------------------------------|-----------------------------------|-------------------------|-----------------------------------|
| LCS- 2D    | 1/7/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 1/14/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 1/21/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 1/28/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 2/4/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 2/11/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 2/18/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 2/25/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 3/4/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 3/11/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 3/17/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 3/24/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 3/31/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 4/7/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 4/14/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 4/21/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 4/28/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 5/5/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 5/12/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 5/19/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 5/26/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 6/2/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 6/9/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 6/16/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 6/23/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 6/30/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 7/7/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 7/14/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 7/21/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 7/28/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 8/4/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 8/11/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 8/18/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 8/25/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 9/1/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 9/8/15                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 9/15/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | Pump Off - "Over Current" Error   |
| LCS- 2D    | 9/22/15                | N/A  | 14.4  | 235.92                           |                                 | Y                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 9/29/15                | N/A  | 14.4  | 235.92                           |                                 | Y                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 10/6/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 10/13/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 10/22/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 10/28/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 11/3/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 11/11/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 11/17/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 11/24/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 12/1/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 12/8/15                | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 12/15/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 12/22/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 12/29/15               | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |
| LCS- 2D    | 1/5/16                 | N/A  | 14.4  | 235.92                           |                                 | N                                 | Dedicated Transducer    | PCP Installed to depth of 62' BGS |


| LCS Number | Date Reading Collected | Measured Liquid Level Below Ground Surface (Ft.) | Transducer Depth from Top of Casing (Ft.) | Well Total Depth from Top of Casing (Ft.) (Ft. MSL) | Elevation of Leachate (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments                               |
|------------|------------------------|--|---|---|---------------------------------|-----------------------------------|-------------------------|--|
| LCS-3D     | 1/7/15                 |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 1/14/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 1/21/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 1/28/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 2/4/15                 |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 2/11/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 2/18/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Melted, seeking replacement |
| LCS-3D     | 2/25/15                |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Replaced, Cal in Progress   |
| LCS-3D     | 3/4/15                 |  |   | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer Replaced, Cal in Progress   |
| LCS-3D     | 3/11/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 3/17/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 3/24/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 3/31/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 4/7/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 4/14/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 4/21/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 4/28/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 5/5/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 5/12/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 5/19/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 5/26/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 6/2/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 6/9/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 6/16/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 6/23/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 6/30/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 7/7/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    |  |
| LCS-3D     | 7/14/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 7/21/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 7/28/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 8/4/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 8/11/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 8/18/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 8/25/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 9/1/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 9/8/15                 | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 9/15/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump pulled for regrading project      |
| LCS-3D     | 9/22/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Pump Re-installed.                     |
| LCS-3D     | 9/29/15                |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 10/6/15                |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 10/13/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 10/22/15               | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 10/28/15               | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 11/3/15                | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 11/11/15               | 5.0  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 11/17/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 11/24/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 12/1/15                |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 12/8/15                |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 12/15/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 12/22/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 12/29/15               |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |
| LCS-3D     | 1/5/16                 |  | 63.0                                      | 140   |                                 | Y                                 | Dedicated Transducer    | Transducer out, pump operational       |

### LCS-3D Liquid Level Below Ground Surface



| LCS Number | Date Reading Collected | Measured Liquid Level Below Ground Surface (Ft.) | Transducer Depth from Top of Casing (Ft.) | Base of Sump Elevation (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments   |
|------------|------------------------|--|---|----------------------------------|-----------------------------------|-------------------------|--|
| LCS- 4B    | 1/7/15                 |  |   | 244.00                           | N/A                               | N/A                     | Non-Operational  |
| LCS- 4B    | 1/14/15                |  |   | 244.00                           | N/A                               | N/A                     | Non-Operational  |
| LCS- 4B    | 1/21/15                |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 1/28/15                |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 2/4/15                 |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 2/11/15                |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 2/18/15                |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 2/25/15                |  |   | 244.00                           | Y                                 | N/A                     | No Transducer  |
| LCS- 4B    | 3/4/15                 |  |   | 244.00                           | Y                                 | N/A                     | Transducer Installed, Cal in Progress                      |
| LCS- 4B    | 3/11/15                | 63.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    |  |
| LCS- 4B    | 3/17/15                | 63.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    |  |
| LCS- 4B    | 3/24/15                | 63.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    |  |
| LCS- 4B    | 3/31/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 4/7/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 4/14/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 4/21/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 4/28/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 5/5/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 5/12/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 5/19/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 5/26/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 6/2/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 6/9/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 6/16/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 6/23/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 6/30/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 7/7/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 7/14/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 7/21/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 7/28/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 8/4/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 8/11/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 8/18/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 8/25/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 9/1/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 9/8/15                 | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 9/15/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 9/22/15                | 74.0   | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Liquid below pump and transducer depth from surface of 81' |
| LCS- 4B    | 9/29/15                |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 10/6/15                |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 10/13/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 10/22/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 10/28/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 11/3/15                |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 11/11/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 11/17/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 11/24/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 12/1/15                |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 12/8/15                |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 12/15/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 12/22/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 12/29/15               |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |
| LCS- 4B    | 1/5/16                 |  | 81.0                                      | 244.00                           | Y                                 | Dedicated Transducer    | Transducer out, pump operational                           |


# LCS-4B Liquid Level Below Ground Surface



| LCS Number | Date Reading Collected | Measured Liquid Level Above Transducer (Ft.) | Transducer Height above Floor of Quarry (Ft.) | Base of Sump Elevation (Ft. MSL) | Height of Liquid (Ft. ) | Elevation of Leachate (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments |
|------------|------------------------|--|---|----------------------------------|-------------------------|---------------------------------|-----------------------------------|-------------------------|----------|
| LCS- 5A    | 1/7/15                 | 10.0   | 15.0  | 235.4                            | 25.0                    | 260.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 1/14/15                | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 1/21/15                | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 1/28/15                | 10.2   | 15.0  | 235.4                            | 25.2                    | 260.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 2/4/15                 | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 2/11/15                | 10.2   | 15.0  | 235.4                            | 25.2                    | 260.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 2/18/15                | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 2/25/15                | 10.0   | 15.0  | 235.4                            | 25.0                    | 260.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 3/4/15                 | 10.2   | 15.0  | 235.4                            | 25.2                    | 260.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 3/11/15                | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 3/17/15                | 10.0   | 15.0  | 235.4                            | 25.0                    | 260.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 3/24/15                | 10.2   | 15.0  | 235.4                            | 25.2                    | 260.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 3/31/15                | 10.0   | 15.0  | 235.4                            | 25.0                    | 260.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 4/7/15                 | 10.1   | 15.0  | 235.4                            | 25.1                    | 260.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 4/14/15                | 33.4   | 15.0  | 235.4                            | 48.4                    | 283.80                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 4/21/15                | 33.3   | 15.0  | 235.4                            | 48.3                    | 283.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 4/28/15                | 33.7   | 15.0  | 235.4                            | 48.7                    | 284.10                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 5/5/15                 | 33.4   | 15.0  | 235.4                            | 48.4                    | 283.80                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 5/12/15                | 33.8   | 15.0  | 235.4                            | 48.8                    | 284.20                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 5/19/15                | 34.0   | 15.0  | 235.4                            | 49.0                    | 284.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 5/26/15                | 33.8   | 15.0  | 235.4                            | 48.8                    | 284.20                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 6/2/15                 | 34.2   | 15.0  | 235.4                            | 49.2                    | 284.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 6/9/15                 | 33.3   | 15.0  | 235.4                            | 48.3                    | 283.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 6/16/15                | 34.3   | 15.0  | 235.4                            | 49.3                    | 284.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 6/23/15                | 34.0   | 15.0  | 235.4                            | 49.0                    | 284.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 6/30/15                | 29.3   | 15.0  | 235.4                            | 44.3                    | 279.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 7/7/15                 | 23.9   | 15.0  | 235.4                            | 38.9                    | 274.30                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 7/14/15                | 23.4   | 15.0  | 235.4                            | 38.4                    | 273.80                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 7/21/15                | 23.3   | 15.0  | 235.4                            | 38.3                    | 273.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 7/28/15                | 23.7   | 15.0  | 235.4                            | 38.7                    | 274.10                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 8/4/15                 | 23.6   | 15.0  | 235.4                            | 38.6                    | 274.00                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 8/11/15                | 23.6   | 15.0  | 235.4                            | 38.6                    | 274.00                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 8/18/15                | 23.7   | 15.0  | 235.4                            | 38.7                    | 274.10                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 8/25/15                | 23.8   | 15.0  | 235.4                            | 38.8                    | 274.20                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 9/1/15                 | 24.2   | 15.0  | 235.4                            | 39.2                    | 274.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 9/8/15                 | 24.3   | 15.0  | 235.4                            | 39.3                    | 274.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 9/15/15                | 24.4   | 15.0  | 235.4                            | 39.4                    | 274.80                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 9/22/15                | 24.0   | 15.0  | 235.4                            | 39.0                    | 274.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 9/29/15                | 23.6   | 15.0  | 235.4                            | 38.6                    | 274.00                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 10/6/15                | 23.7   | 15.0  | 235.4                            | 38.7                    | 274.10                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 10/13/15               | 23.5   | 15.0  | 235.4                            | 38.5                    | 273.90                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 10/22/15               | 23.6   | 15.0  | 235.4                            | 38.6                    | 274.00                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 10/28/15               | 23.6   | 15.0  | 235.4                            | 38.6                    | 274.00                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 11/3/15                | 24.2   | 15.0  | 235.4                            | 39.2                    | 274.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 11/11/15               | 23.9   | 15.0  | 235.4                            | 38.9                    | 274.30                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 11/17/15               | 23.7   | 15.0  | 235.4                            | 38.7                    | 274.10                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 11/24/15               | 24.1   | 15.0  | 235.4                            | 39.1                    | 274.50                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 12/1/15                | 24.3   | 15.0  | 235.4                            | 39.3                    | 274.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 12/8/15                | 24.0   | 15.0  | 235.4                            | 39.0                    | 274.40                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 12/15/15               | 24.4   | 15.0  | 235.4                            | 39.4                    | 274.80                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 12/22/15               | 24.2   | 15.0  | 235.4                            | 39.2                    | 274.60                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 12/29/15               | 24.3   | 15.0  | 235.4                            | 39.3                    | 274.70                          | Y                                 | Dedicated Transducer    |          |
| LCS- 5A    | 1/5/16                 | 24.0   | 15.0  | 235.4                            | 39.0                    | 274.40                          | Y                                 | Dedicated Transducer    |          |



### LCS-5A Liquid Level Above Quarry Floor



| LCS Number | Date Reading Collected | Measured Liquid Level Above Transducer (Ft.) | Transducer Height above Floor of Quarry (Ft.) | Base of Sump Elevation (Ft. MSL) | Height of Liquid (Ft. ) | Elevation of Leachate (Ft. MSL) | Pump on during measurement? (Y/N) | Liquid level meter used | Comments  |
|------------|------------------------|--|---|----------------------------------|-------------------------|---------------------------------|-----------------------------------|-------------------------|---|
| LCS- 6B    | 1/7/15                 | 6.5  | 9.4   | 429.52                           | 15.9                    | 445.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 1/14/15                | 6.0  | 9.4   | 429.52                           | 15.4                    | 444.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 1/21/15                | 6.5  | 9.4   | 429.52                           | 15.9                    | 445.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 1/28/15                | 6.4  | 9.4   | 429.52                           | 15.8                    | 445.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 2/4/15                 | 6.3  | 9.4   | 429.52                           | 15.7                    | 445.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 2/11/15                | 6.4  | 9.4   | 429.52                           | 15.8                    | 445.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 2/18/15                | 6.4  | 9.4   | 429.52                           | 15.8                    | 445.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 2/25/15                | 6.6  | 9.4   | 429.52                           | 16.0                    | 445.52                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 3/4/15                 | 6.3  | 9.4   | 429.52                           | 15.7                    | 445.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 3/11/15                | 6.4  | 9.4   | 429.52                           | 15.8                    | 445.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 3/17/15                | 6.5  | 9.4   | 429.52                           | 15.9                    | 445.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 3/24/15                | 7.0  | 9.4   | 429.52                           | 16.4                    | 445.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 3/31/15                | 7.2  | 9.4   | 429.52                           | 16.6                    | 446.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 4/7/15                 | 7.5  | 9.4   | 429.52                           | 16.9                    | 446.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 4/14/15                | 9.3  | 9.4   | 429.52                           | 18.7                    | 448.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 4/21/15                | 9.3  | 9.4   | 429.52                           | 18.7                    | 448.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 4/28/15                | 9.4  | 9.4   | 429.52                           | 18.8                    | 448.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 5/5/15                 | 9.4  | 9.4   | 429.52                           | 18.8                    | 448.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 5/12/15                | 9.6  | 9.4   | 429.52                           | 19.0                    | 448.52                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 5/19/15                | 10.0   | 9.4   | 429.52                           | 19.4                    | 448.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 5/26/15                | 10.2   | 9.4   | 429.52                           | 19.6                    | 449.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 6/2/15                 | 7.8  | 9.4   | 429.52                           | 17.2                    | 446.72                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 6/9/15                 | 7.9  | 9.4   | 429.52                           | 17.3                    | 446.82                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 6/16/15                | 7.9  | 9.4   | 429.52                           | 17.3                    | 446.82                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 6/23/15                | 9.0  | 9.4   | 429.52                           | 18.4                    | 447.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 6/30/15                | 10.0   | 9.4   | 429.52                           | 19.4                    | 448.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 7/7/15                 | 10.3   | 9.4   | 429.52                           | 19.7                    | 449.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 7/14/15                | 11.1   | 9.4   | 429.52                           | 20.5                    | 450.02                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 7/21/15                | 11.0   | 9.4   | 429.52                           | 20.4                    | 449.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 7/28/15                | 10.5   | 9.4   | 429.52                           | 19.9                    | 449.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 8/4/15                 | 10.4   | 9.4   | 429.52                           | 19.8                    | 449.32                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 8/11/15                | 10.3   | 9.4   | 429.52                           | 19.7                    | 449.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 8/18/15                | 10.0   | 9.4   | 429.52                           | 19.4                    | 448.92                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 8/25/15                | 10.3   | 9.4   | 429.52                           | 19.7                    | 449.22                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 9/1/15                 | 10.1   | 9.4   | 429.52                           | 19.5                    | 449.02                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 9/8/15                 | 10.2   | 9.4   | 429.52                           | 19.6                    | 449.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 9/15/15                | 10.5   | 9.4   | 429.52                           | 19.9                    | 449.42                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 9/22/15                | 10.7   | 9.4   | 429.52                           | 20.1                    | 449.62                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 9/29/15                | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 10/6/15                | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 10/13/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | Y                                 | Dedicated Transducer    |   |
| LCS- 6B    | 10/22/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    |   |
| LCS- 6B    | 10/28/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    |   |
| LCS- 6B    | 11/3/15                | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    |   |
| LCS- 6B    | 11/11/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    |   |
| LCS- 6B    | 11/17/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 11/24/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 12/1/15                | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 12/8/15                | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 12/15/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 12/22/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 12/29/15               | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |
| LCS- 6B    | 1/5/16                 | 9.2  | 9.4   | 429.52                           | 18.6                    | 448.12                          | N                                 | Dedicated Transducer    | Pump Overcurrent Fault, Liquid Level still maintained |

# LCS-6B Liquid Level Above Quarry Floor

