STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law (Chapter 644 RSMo, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No.:	MO-0021440
Owner:	City of Monett
Address:	217 5 th Street, Monett, MO 65708
Continuing Authority:	Same as above
Address:	Same as above
Facility Name:	Monett WWTP
Facility Address:	0.25 miles northeast of S. Eisenhower St. & Hwy 60 intersection, Monett, MO 65708
Legal Description:	See Page 2
UTM Coordinates:	See Page 2
Receiving Stream:	See Page 2
First Classified Stream and ID:	See Page 2
USGS Basin & Sub-watershed No.:	See Page 2

authorizes activities pursuant to the terms and conditions of this permit in accordance with the Missouri Clean Water Law and/or the National Pollutant Discharge Elimination System; it does not apply to other regulated activities.

FACILITY DESCRIPTION

See Page 2

July 1, 2024 Effective Date

June 30, 2029 Expiration Date

John Hoke, Director, Water Protection Program

FACILITY DESCRIPTION (continued):

Outfall #001 - POTW

The use or operation of this facility shall be by or under the supervision of a Certified "A" Operator.

Influent screw pump lift station / 2 mechanical bar screens / bar screen / peak flow basin / aerated grit chamber / six anaerobic basins / four anoxic basins / 2 primary clarifiers (inactive) / 3 trickling filter towers / 2 oxidation ditches / 2 final clarifiers / 2 tertiary fabric filters / ultraviolet disinfection / concrete re-aeration steps / partial direct irrigation on golf course from effluent pump station / 4 aerobic digesters / 1 gravity belt sludge thickener / 10 sludge drying beds / biosolids are land applied / facility does not have materials stored or conduct operations in a manner that would cause the discharge of pollutants via stormwater

Design population equivalent is 74,000. Design flow is 6.0 million gallons per day. Actual flow is 2.7 million gallons per day. Design sludge production is 1,365 dry tons/year.

Legal Description:	Sec. 36, T26N, R28W, Barry County
UTM Coordinates:	X=416243, Y=4086034
Receiving Stream:	Clear Creek (C) (losing)
First Classified Stream and ID:	Presumed Use Streams (C) (5079) (losing)
USGS Basin & Sub-watershed No.:	(11070207-0704)

<u>Permitted Feature #003</u> – Irrigation of effluent on golf course Treated effluent pumped from facility directly to golf course irrigation system

Legal Description: UTM Coordinates: Sec. 6, T25N, R27W, Barry County X=417116, Y=4085447

Permitted Feature INF – Influent Monitoring Location – Headworks

Legal Description: UTM Coordinates: Sec. 36, T26N, R28W, Barry County X=416397, Y=4086097

OUTFALL <u>#001</u>

TABLE A-1. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the interim effluent limitations outlined in **Table A-2** must be achieved as soon as possible but no later than **July 1, 2029**. These interim effluent limitations in **Table A-1** are effective beginning **July 1, 2024** and remain in effect through **June 30, 2029**. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

	INTE	INTE L	CRIM EFFLU IMITATION	JENT IS	MONITORING REQUIREMENTS	
EFFLUENI PAKAMETEK(S)	UNIIS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
eDMR Limit Set: M						
Flow	MGD	*		*	once/day	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		15	10	twice/week	composite**
Total Suspended Solids	mg/L		20	15	twice/week	composite**
<i>E. coli</i> (Note 1, Page 5)	#/100mL	126		*	once/week	grab
Ammonia as N (January)	mg/L	11.3		2.1	twice/week	composite**
Ammonia as N (February)	mg/L	11.3		2.1	twice/week	composite**
Ammonia as N (March)	mg/L	11.3		2.1	twice/week	composite**
Ammonia as N (April)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (May)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (June)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (July)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (August)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (September)	mg/L	3.8		1.4	twice/week	composite**
Ammonia as N (October)	mg/L	11.3		2.1	twice/week	composite**
Ammonia as N (November)	mg/L	11.3		2.1	twice/week	composite**
Ammonia as N (December)	mg/L	11.3		2.1	twice/week	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/week	composite**
Nitrate + Nitrite	mg/L	*		*	once/week	composite**
Cyanide, amenable to chlorination (Note 3, Page 5)	µg/L	9.6		3.6	once/month	grab
Lead, Total Recoverable	μg/L	8.5		3.9	once/month	composite**
Hardness, Total	mg/L	*		*	once/month	grab
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.5		9.0	twice/week	grab
EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Dissolved Oxygen	mg/L	*		*	once/week	grab

MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE AUGUST 28, 2024.

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

*** pH is measured in pH units and is not to be averaged.

OUTFALL #001

TABLE A-1 (continued). INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the interim effluent limitations outlined in **Table A-2** must be achieved as soon as possible but no later than <u>July 1, 2029</u>. These interim effluent limitations in **Table A-1** are effective beginning <u>July 1, 2024</u> and remain in effect through <u>June 30, 2029</u>. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

eDMR Limit Set: M INTERIM EFFI			LUENT LIN	IITATIONS	MONITORING REQUIREMENTS	
EFFLUENT PARAMETER(S)				MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Biochemical Oxygen Demand ₅ – Percent	Removal (I	Note 2, Page 5)	%	85	once/month	calculated
Total Suspended Solids – Percent Remov	al (Note 2,	Page 5)	%	85	once/month	calculated
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		MONTHLY TOTAL §	MEASUREMENT FREQUENCY	SAMPLE TYPE
Total Phosphorus	mg/L	*			once/week	composite**
Total Phosphorus	lbs.			*	once/month	calculated
Total Nitrogen (Note 4, Page 5)	mg/L	*			once/week	calculated
Total Nitrogen (Note 4, Page 5)	lbs.			*	once/month	calculated
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE <u>AUGUST 28, 2024</u> .						
eDMR Limit Set: A						
EFFLUENT PARAMETER(S)	UNITS	ANNUAL AVERAGE ¥		ANNUAL TOTAL Φ	MEASUREMENT FREQUENCY	SAMPLE TYPE
	~				,	

Total Phosphorus	mg/L	*			once/year	calculated
Total Phosphorus	lbs.			*	once/year	calculated
Total Nitrogen (Note 4, Page 5)	mg/L	*			once/year	calculated
Total Nitrogen (Note 4, Page 5)	lbs.			*	once/year	calculated
MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY; THE FIRST REPORT IS DUE JANUARY 28, 2025.						

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

 \mathbf{Y} - Annual Average is calculated as the average of the 12 calendar months (January 1st through December 31st) of weekly samples in mg/L.

 Φ - Annual Total is calculated as the sum of the 12 calendar months (January 1st through December 31st) of monthly samples in pounds (lbs.).

\$ - The facility shall calculate pounds per month by using the monthly average concentration in mg/L multiplied by 8.34 and multiplied by the total monthly flow in Million Gallons.

OUTFALL #001

TABLE A-1 (continued). INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the interim effluent limitations outlined in **Table A-2** must be achieved as soon as possible but no later than <u>July 1, 2029</u>. These interim effluent limitations in **Table A-1** are effective beginning <u>July 1, 2024</u> and remain in effect through <u>June 30, 2029</u>. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS			
		DAILY MAXIMUM		MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE		
eDMR Limit Set: Q								
Beryllium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Cadmium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Selenium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Oil & Grease	mg/L	*		*	once/quarter****	grab		

MONITORING REPORTS SHALL BE SUBMITTED **<u>QUARTERLY</u>**; THE FIRST REPORT IS DUE <u>OCTOBER 28, 2024</u>.

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

**** See table below for quarterly sampling requirements.

Quarterly Minimum Sampling Requirements								
Quarter	Months	Report is Due						
First	January, February, March	Sample at least once during any month of the quarter	April 28th					
Second	April, May, June	Sample at least once during any month of the quarter	July 28th					
Third	July, August, September	Sample at least once during any month of the quarter	October 28th					
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th					

Note 1 - Effluent limits of 126 #/100 mL daily maximum and monitoring only for monthly average for *E. coli* are applicable year round due to losing stream designation. No more than 10% of samples over the course of a calendar year shall exceed the 126 #/100 mL daily maximum.

Note 2 - Influent sampling for $BOD_5/CBOD_5$ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

Note 3 - This effluent limit is below the accepted minimum quantification level (ML). The Department has determined the current acceptable ML of Cyanide Amenable to Chlorination to be 10 μ g/L when using SM 4500-CN⁻G. <u>Cyanides Amenable to Chlorination</u> <u>after Distillation</u> in *Standard Methods for the Examination of Water and Wastewater*, 22nd Edition. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 10 μ g/L will be considered violations of the permit and values less than the minimum quantification level of 10 μ g/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of Cyanide in excess of the effluent limits stated in the permit.

Note 4 - Total Nitrogen is calculated as; TN = Total Kjeldahl Nitrogen + Nitrate+Nitrite.

OUTFALL <u>#001</u>

TABLE A-2. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the final effluent limitations outlined in **Table A-3** must be achieved as soon as possible but no later than **December 31, 2032**. These interim effluent limitations in **Table A-2** are effective beginning **July 1, 2029** and remain in effect through **January 1, 2033**. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

		INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
eDMR Limit Set: M						
Flow	MGD	*		*	once/day	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		15	10	twice/week	composite**
Total Suspended Solids	mg/L		15	10	twice/week	composite**
<i>E. coli</i> (Note 1, Page 8)	#/100mL	126		*	once/week	grab
Ammonia as N (January)	mg/L	4.2		2.1	twice/week	composite**
Ammonia as N (February)	mg/L	4.2		2.1	twice/week	composite**
Ammonia as N (March)	mg/L	4.2		2.1	twice/week	composite**
Ammonia as N (April)	mg/L	2.8		1.4	twice/week	composite**
Ammonia as N (May)	mg/L	2.8		1.4	twice/week	composite**
Ammonia as N (June)	mg/L	2.8		1.4	twice/week	composite**
Ammonia as N (July)	mg/L	2.8		1.4	twice/week	composite**
Ammonia as N (August)	mg/L	2.6		1.3	twice/week	composite**
Ammonia as N (September)	mg/L	2.8		1.4	twice/week	composite**
Ammonia as N (October)	mg/L	4.2		2.1	twice/week	composite**
Ammonia as N (November)	mg/L	4.2		2.1	twice/week	composite**
Ammonia as N (December)	mg/L	4.2		2.1	twice/week	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/week	composite**
Nitrate + Nitrite	mg/L	*		*	once/week	composite**
Cyanide, amenable to chlorination (Note 3, Page 8)	μg/L	9.6		3.6	once/month	grab
Lead, Total Recoverable	μg/L	8.5		3.9	once/month	composite**
Hardness, Total	mg/L	*		*	once/month	grab
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.5		9.0	twice/week	grab
EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Dissolved Oxygen	mg/L	*		*	once/week	grab
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY: THE FIRST REPORT IS DUE AUGUST 28 2029						

OUTFALL #001

TABLE A-2 (continued). INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the final effluent limitations outlined in **Table A-3** must be achieved as soon as possible but no later than <u>December 31, 2032</u>. These interim effluent limitations in **Table A-2** are effective beginning <u>July 1, 2029</u> and remain in effect through <u>January 1, 2033</u>. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

eDMR Limit Set: M INTERIM EFFI			LUENT LIN	IITATIONS	MONITORING REQUIREMENTS	
EFFLUENT PARAMETER(S)				MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Biochemical Oxygen Demand ₅ – Percent Removal (Note 2, Page 8)				85	once/month	calculated
Total Suspended Solids – Percent Removal (Note 2, Page 8)			%	85	once/month	calculated
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		MONTHLY TOTAL §	MEASUREMENT FREQUENCY	SAMPLE TYPE
Total Phosphorus	mg/L	*			once/week	composite**
Total Phosphorus	lbs.			*	once/month	calculated
Total Nitrogen (Note 4, Page 8)	mg/L	*			once/week	calculated
Total Nitrogen (Note 4, Page 8)	lbs.			*	once/month	calculated

MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE AUGUST 28, 2029.

eDMR Limit Set: A							
EFFLUENT PARAMETER(S)	UNITS	ANNUAL AVERAGE¥		ANNUAL TOTAL Φ	MEASUREMENT FREQUENCY	SAMPLE TYPE	
Total Phosphorus	mg/L	*			once/year	calculated	
Total Phosphorus	lbs.			*	once/year	calculated	
Total Nitrogen (Note 4, Page 8)	mg/L	*			once/year	calculated	
Total Nitrogen (Note 4, Page 8)	lbs.			*	once/year	calculated	
MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY; THE FIRST REPORT IS DUE JANUARY 28, 2030.							

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

 \mathbf{Y} - Annual Average is calculated as the average of the 12 calendar months (January 1st through December 31st) of weekly samples in mg/L.

 Φ - Annual Total is calculated as the sum of the 12 calendar months (January 1st through December 31st) of monthly samples in pounds (lbs.).

 \S - The facility shall calculate pounds per month by using the monthly average concentration in mg/L multiplied by 8.34 and multiplied by the total monthly flow in Million Gallons.

OUTFALL #001

TABLE A-2 (continued). INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the final effluent limitations outlined in **Table A-3** must be achieved as soon as possible but no later than <u>December 31, 2032</u>. These interim effluent limitations in **Table A-2** are effective beginning <u>July 1, 2029</u> and remain in effect through <u>January 1, 2033</u>. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

EFFLUENT PARAMETER(S)	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS			
		DAILY MAXIMUM		MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE		
eDMR Limit Set: Q								
Beryllium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Cadmium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Selenium, Total Recoverable	μg/L	*		*	once/quarter****	composite**		
Oil & Grease	mg/L	*		*	once/quarter****	grab		

MONITORING REPORTS SHALL BE SUBMITTED **QUARTERLY**; THE FIRST REPORT IS DUE OCTOBER 28, 2029.

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

**** See table below for quarterly sampling requirements.

Quarterly Minimum Sampling Requirements								
Quarter	Months	Report is Due						
First	January, February, March	Sample at least once during any month of the quarter	April 28th					
Second	April, May, June	Sample at least once during any month of the quarter	July 28th					
Third	July, August, September	Sample at least once during any month of the quarter	October 28 th					
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th					

Note 1 - Effluent limits of 126 #/100 mL daily maximum and monitoring only for monthly average for *E. coli* are applicable year-round due to losing stream designation. No more than 10% of samples over the course of a calendar year shall exceed the 126 #/100 mL daily maximum.

Note 2 - Influent sampling for $BOD_5/CBOD_5$ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

Note 3 - This effluent limit is below the accepted minimum quantification level (ML). The Department has determined the current acceptable ML of Cyanide Amenable to Chlorination to be 10 μ g/L when using SM 4500-CN⁻G. <u>Cyanides Amenable to Chlorination</u> <u>after Distillation</u> in *Standard Methods for the Examination of Water and Wastewater*, 22nd Edition. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 10 μ g/L will be considered violations of the permit and values less than the minimum quantification level of 10 μ g/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of Cyanide in excess of the effluent limits stated in the permit.

Note 4 - Total Nitrogen is calculated as; TN = Total Kjeldahl Nitrogen + Nitrate+Nitrite.

OUTFALL <u>#001</u>

TABLE A-3. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in **Table A-3** shall become effective on **January 1**, **2033**, and remain in effect until expiration of the permit. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

		FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS		
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE	
eDMR Limit Set: M	ľ						
Flow	MGD	*		*	once/day	24 hr. total	
Carbonaceous Biochemical Oxygen Demand ₅	mg/L		5.9	3.9	twice/week	composite**	
Total Suspended Solids	mg/L		13.8	9.2	twice/week	composite**	
<i>E. coli</i> (Note 1, Page 11)	#/100mL	126		*	once/week	grab	
Ammonia as N (January)	mg/L	4.2		2.1	twice/week	composite**	
Ammonia as N (February)	mg/L	4.2		2.1	twice/week	composite**	
Ammonia as N (March)	mg/L	4.2		2.1	twice/week	composite**	
Ammonia as N (April)	mg/L	2.8		1.4	twice/week	composite**	
Ammonia as N (May)	mg/L	2.8		1.4	twice/week	composite**	
Ammonia as N (June)	mg/L	2.8		1.4	twice/week	composite**	
Ammonia as N (July)	mg/L	2.8		1.4	twice/week	composite**	
Ammonia as N (August)	mg/L	2.6		1.3	twice/week	composite**	
Ammonia as N (September)	mg/L	2.8		1.4	twice/week	composite**	
Ammonia as N (October)	mg/L	4.2		2.1	twice/week	composite**	
Ammonia as N (November)	mg/L	4.2		2.1	twice/week	composite**	
Ammonia as N (December)	mg/L	4.2		2.1	twice/week	composite**	
Total Kjeldahl Nitrogen	mg/L	*		*	once/week	composite**	
Nitrate + Nitrite	mg/L	*		*	once/week	composite**	
Cyanide, amenable to chlorination (Note 3, Page 11)	μg/L	9.6		3.6	once/month	grab	
Lead, Total Recoverable	μg/L	8.5		3.9	once/month	composite**	
Hardness, Total	mg/L	*		*	once/month	grab	
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE	
pH – Units***	SU	6.5		9.0	twice/week	grab	
EFFLUENT PARAMETER(S)	UNITS	DAILY MINIMUM		MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE	
Dissolved Oxygen	mg/L	7.0		7.0	once/week	grab	
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY : THE FIRST REPORT IS DUE FEBRUARY 28, 2033							

OUTFALL	
#001	

TABLE A-3 (continued). FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in **Table A-3** shall become effective on **January 1, 2033**, and remain in effect until expiration of the permit. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

eDMR Limit Set: M FINAL EFFLU			JUENT LIMITATIONS		MONITORING REQUIREMENTS		
EFFLUENT PARAMETER(S)				MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE	
Carbonaceous Biochemical Oxygen Dem (Note 2, Page 11)	%	85	once/month	calculated			
Total Suspended Solids - Percent Removal (Note 2, Page 11)				85	once/month	calculated	
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE		MONTHLY TOTAL §	MEASUREMENT FREQUENCY	SAMPLE TYPE	
Total Phosphorus	mg/L	*			once/week	composite**	
Total Phosphorus	lbs.			*	once/month	calculated	
Total Nitrogen (Note 4, Page 11)	mg/L	*			once/week	calculated	
Total Nitrogen (Note 4, Page 11)	Page 11)lbs.			*	once/month	calculated	
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE <u>FEBRUARY 28, 2033</u> .							

eDMR Limit Set: A								
EFFLUENT PARAMETER(S)	UNITS	ANNUAL AVERAGE ¥		ANNUAL TOTAL Φ	MEASUREMENT FREQUENCY	SAMPLE TYPE		
Total Phosphorus	mg/L	*			once/year	calculated		
Total Phosphorus	lbs.			18,265	once/year	calculated		
Total Nitrogen (Note 4, Page 11)	mg/L	*			once/year	calculated		
Total Nitrogen (Note 4, Page 11)	lbs.			392,689	once/year	calculated		
MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY; THE FIRST REPORT IS DUE JANUARY 28, 2034.								

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

 \S - The facility shall calculate pounds per month by using the monthly average concentration in mg/L multiplied by 8.34 and multiplied by the total monthly flow in Million Gallons.

 \mathbf{Y} - Annual Average is calculated as the average of the 12 calendar months (January 1st through December 31st) of weekly samples in mg/L.

 Φ - Annual Total is calculated as the sum of the 12 calendar months (January 1st through December 31st) of monthly samples in pounds (lbs.).

OUTFALI	
#001	

TABLE A-3 (continued). FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in **Table A-3** shall become effective on **January 1, 2033**, and remain in effect until expiration of the permit. Such discharges shall be controlled, limited, and monitored by the permittee as specified below:

		FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM		MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
eDMR Limit Set: Q						
Beryllium, Total Recoverable	μg/L	*		*	once/quarter****	composite**
Cadmium, Total Recoverable	μg/L	*		*	once/quarter****	composite**
Selenium, Total Recoverable	μg/L	*		*	once/quarter****	composite**
Oil & Grease	mg/L	*		*	once/quarter****	grab

MONITORING REPORTS SHALL BE SUBMITTED **<u>QUARTERLY</u>**; THE FIRST REPORT IS DUE <u>APRIL 28, 2033</u>.

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

**** See table below for quarterly sampling requirements.

Quarterly Minimum Sampling Requirements							
Quarter	Months Quarterly Effluent Parameters		Report is Due				
First	January, February, March	Sample at least once during any month of the quarter	April 28th				
Second	April, May, June	Sample at least once during any month of the quarter	July 28th				
Third	July, August, September	Sample at least once during any month of the quarter	October 28th				
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th				

Note 1 - Effluent limits of 126 #/100 mL daily maximum and monitoring only for monthly average for *E. coli* are applicable year round due to losing stream designation. No more than 10% of samples over the course of a calendar year shall exceed the 126 #/100 mL daily maximum.

Note 2 - Influent sampling for $BOD_5/CBOD_5$ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

Note 3 - This effluent limit is below the accepted minimum quantification level (ML). The Department has determined the current acceptable ML of Cyanide Amenable to Chlorination to be 10 μ g/L when using SM 4500-CN⁻G. <u>Cyanides Amenable to Chlorination</u> <u>after Distillation</u> in *Standard Methods for the Examination of Water and Wastewater*, 22nd Edition. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 10 μ g/L will be considered violations of the permit and values less than the minimum quantification level of 10 μ g/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of Cyanide in excess of the effluent limits stated in the permit.

Note 4 - Total Nitrogen is calculated as; TN = Total Kjeldahl Nitrogen + Nitrate+Nitrite.

TABLE B-1 FINAL IRRIGATION SYSTEM LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to conduct irrigation of wastewater as specified in the application for this permit. The final limitations in **Table B-1** shall become effective on <u>July 1, 2024</u> and remain in effect until expiration of the permit. The irrigation of wastewater shall be controlled, limited, and monitored by the permittee as specified below:

IRRIGATED WASTEWATER PARAMETER	UNITS	DAILY MAXIMUM	DAILY TOTAL	MONTHLY TOTAL	MEASUREMENT FREQUENCY	SAMPLE TYPE			
Limit Set: IP									
<i>E. coli</i> (Note 5)	#/100mL	126			twice/week	grab			
Irrigation Period (Note 5)	hours		*	*	daily	total			
Volume Irrigated (Note 5)	gallons		*	*	daily	total			
Irrigation Area (Note 5)	acres		*	*	daily	total			
Irrigation Rate (Note 5)	inches		*	*	daily	total			
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE AUGUST 28, 2024.									

* Monitoring requirement only.

Note 5 - Required only for irrigation to public use areas. Report using the No Data Indicator Code (NODI) "Cond Monitoring – Not Req This Period" if irrigation does not occur to public use areas during the report period. See Special Condition #21 for additional requirements.

PERMITTED FEATURE <u>INF</u>

TABLE C-1. INTERIM INFLUENT MONITORING REQUIREMENTS

These interim monitoring requirements in **Table C-1** become effective on <u>July 1, 2024</u> and remain in effect through <u>December 31, 2032</u>. The final monitoring limitations outlined in **Table C-2** shall become effective on <u>January 1, 2033</u>. The influent wastewater shall be monitored by the permittee as specified below:

		INTERIM MONITORING REQUIREMENTS						
PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE		
eDMR Limit Set: IM								
Biochemical Oxygen Demand ₅ (Note 2)	mg/L			*	once/month	composite**		
Total Suspended Solids (Note 2)	mg/L			*	once/week	composite**		
Ammonia as N	mg/L			*	once/month	composite**		
Total Phosphorus	mg/L			*	once/month	composite**		
Total Kjeldahl Nitrogen	mg/L			*	once/month	calculated		
Nitrate + Nitrite	mg/L			*	once/month	composite**		
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY : THE FIRST REPORT IS DUE AUGUST 28, 2024.								

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

PERMITTED FEATURE <u>INF</u>	TABLE C-2. FINAL INFLUENT MONITORING REQUIREMENTS						
The final influent monitoring requirements in Table C-2 become effective on January 1, 2033 and remain in effect until expiration of the permit. The influent wastewater shall be monitored by the permittee as specified below:							
				FINAL M	IONITORING	REQUIREMENTS	
PARAMETER(S)		UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
eDMR Limit Set:	IM						
Carbonaceous Bio Demand ₅ (Note 2)	chemical Oxygen	mg/L			*	once/month	composite**
Total Suspended S	Solids (Note 2)	mg/L			*	once/week	composite**
Ammonia as N		mg/L			*	once/month	composite**
Total Phosphorus		mg/L			*	once/month	composite**
Total Kjeldahl Nit	rogen	mg/L			*	once/month	calculated
Nitrate + Nitrite		mg/L			*	once/month	composite**
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY: THE FIRST REPORT IS DUE FEBRUARY 28, 2033							

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

Note 2 - Influent sampling for $BOD_5/CBOD_5$ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30-minute intervals by an automatic sampling device.

D. SCHEDULE OF COMPLIANCE

Ammonia (Final) and Total Suspended Solids (Interim)

The facility shall attain compliance with the final effluent limitations for Ammonia listed in Table A-2 and the interim effluent limitations for Total Suspended Solids listed in Table A-2 as soon as possible but in no case later than **July 1, 2029**.

- 1. The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limitations for Ammonia and the interim effluent limitations for Total Suspended Solids listed in Table A-2, every 12 months from the effective date of this permit.
- 2. By **July 1, 2029**, the permittee shall attain compliance with the final effluent limitations for Ammonia and the interim effluent limitations for Total Suspended Solids listed in Table A-2.

Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids (Final), Dissolved Oxygen, Total Phosphorus, and Total Nitrogen

The facility shall attain compliance with final effluent limitations for Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Dissolved Oxygen, Total Phosphorus, and Total Nitrogen listed in Table A-3, as soon as possible but in no case later than **January 1, 2033**.

- The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limits for Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Dissolved Oxygen, Total Phosphorus, and Total Nitrogen listed in Table A-3, every 12 months from the effective date of this permit.
- 2. By **January 1, 2033**, the permittee shall attain compliance with the final effluent limits for Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Dissolved Oxygen, Total Phosphorus, and Total Nitrogen listed in Table A-3.

Please submit progress reports to the Missouri Department of Natural Resources via the Electronic Discharge Monitoring Report (eDMR) Submission System.

E. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached <u>Parts I, II, & III</u> standard conditions dated <u>August 1, 2014, May 1, 2013, and August 1, 2019</u>, respectively, and hereby incorporated as though fully set forth herein. Annual reports required per Standard Conditions Part III Section K shall be submitted online to the Department via the Department's eDMR system as an attachment. This supersedes Standard Conditions Part III Section K #4. EPA reports shall continue to be submitted online via the Central Data Exchange system.

F. SPECIAL CONDITIONS

- <u>Electronic Discharge Monitoring Report (eDMR) Submission System</u>. Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent monitoring data and any report required by the permit (unless specifically directed otherwise by the permit) shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally consistent set of data about the NPDES program. All reports uploaded into the system shall be reasonably named so they are easily identifiable, such as "WET Test Chronic Outfall 002 Jan 2023," or "Outfall 004 Daily Data Mar 2025."
 - (a) eDMR Registration Requirements. The permittee must register with the Department's eDMR system through the Missouri Gateway for Environmental Management (MoGEM) before the first report is due. Registration and other information regarding MoGEM can be found at <u>https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem</u>. Information about the eDMR system can be found at <u>https://dnr.mo.gov/water/business-industry-other-entities/reporting/electronic-discharge-monitoring-reporting-system-edmr</u>. The first user shall register as an Organization Official and the association to the facility must be approved by the Department. Regarding Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit unless a waiver is granted by the Department. See paragraph (c) below.
 - (b) Electronic Submissions. To access the eDMR system, use the following link in your web browser: <u>https://apps5.mo.gov/mogems/welcome.action</u>. If you experience difficulties with using the eDMR system you may contact <u>edmr@dnr.mo.gov</u> or call 855-789-3889 or 573-526-2082 for assistance.

- (c) Waivers from Electronic Reporting. The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the Department in compliance with 40 CFR Part 127. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: <u>https://dnr.mo.gov/document-search/electronic-dischargemonitoring-report-waiver-request-form-mo-780-2692</u>. The Department will either approve or deny this electronic reporting waiver request within 120 calendar days.
- 2. The full implementation of this operating permit, which includes implementation of any applicable schedules of compliance, shall constitute compliance with all applicable federal and state statutes and regulations in accordance with §644.051.19, RSMo, and the Clean Water Act (CWA) section 402(k); however, this permit may be reopened and modified, or alternatively revoked and reissued:
 - (a) To comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) To incorporate an approved pretreatment program or modification thereto pursuant to 40 CFR 403.8(c) or 40 CFR 403.18(e), respectively.
- 3. All outfalls must be clearly marked in the field.
- 4. Report as no-discharge when a discharge does not occur during the report period.
- 5. Reporting of Non-Detects:
 - (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
 - (b) See sufficiently sensitive test method requirements in Standard Conditions Part I, Section A, No. 4 regarding proper testing and method minimum levels used for sample analysis.
 - (c) The permittee shall not report a sample result as "Non-Detect" without also reporting the method minimum level of the test. Reporting as "Non Detect" without also including the method minimum level, will be considered failure to report, which is a violation of this permit.
 - (d) The permittee shall provide the "Non-Detect" sample result using the less than symbol and the method minimum level (e.g., $<50 \ \mu g/L$, if the method minimum level for the parameter is 50 $\mu g/L$).
 - (e) Where the permit contains a Department determined Minimum Quantification Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
 - (f) For the daily maximum, the facility shall report the highest value. If the highest value was a non-detect, use the less than "<" symbol and the laboratory's highest method minimum level.
 - (g) For reporting an average based on all non-detected values, remove the "<" sign from the values, average the values, and then add the "<" symbol back to the resulting average.
 - (h) For reporting an average based on a mix of detected and non-detected values (not including *E. coli*), assign a value of "0" for all non-detects for that reporting period and report the average of all the results.
 - (i) When *E. coli* is not detected above the method minimum level, the permittee must report the data qualifier signifying less than detection limit for that parameter (e.g., <1 #/100mL, if the method minimum level is 1 #/100mL). For reporting a geometric mean based on a mix of detected and non-detected values, use one-half of the detection limit (instead of zero) for non-detects when calculating geometric means.</p>
 - (j) See the Fact Sheet Appendix Non-Detect Example Calculations for further guidance.
- 6. The permittee shall comply with any applicable requirements listed in 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. To request a modification of the operational control testing requirements listed in 10 CSR 20-9, the permittee shall submit a permit modification and fee to the Department requesting a deviation from the operational control monitoring requirements. Upon approval of the request, the Department will modify the permit.
- 7. The permittee shall continue to implement and update, if necessary, the program for maintenance and repair of its collection system. The permittee may compare collection system performance results and other data with the benchmarks used in the Departments' Capacity, Management, Operation, And Maintenance (CMOM) Model, located at https://dnr.mo.gov/document-search/capacity-management-operations-maintenance-plan-editable-template. Additional information regarding the Departments' CMOM Model is available at https://dnr.mo.gov/print/document-search/pub2574.

The permittee shall also submit a report via the Electronic Discharge Monitoring Report (eDMR) Submission System annually, by January 28th, for the previous calendar year. The report shall contain the following information:

- (a) A summary of the efforts to locate and eliminate specific sources of excessive infiltration and inflow into the collection system serving the facility for the previous year.
- (b) A summary of the general maintenance and repairs to the collection system serving the facility for the previous year.
- (c) A summary of any planned maintenance and repairs to the collection system serving the facility for the upcoming calendar year. This list shall include locations (GPS, 911 address, manhole number, etc.) and actions to be taken.
- 8. Bypasses are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2. Bypasses are to be reported to the Southwest Regional Office during normal business hours or by using the online Sanitary Sewer Overflow/Facility Bypass Application located at: https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem or the Environmental Emergency Response spill-line at 573-634-2436 outside of normal business hours. Once an electronic reporting system compliant with 40 CFR Part 127, the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, is available all bypasses must be reported electronically via the new system. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
- 9. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.
- 10. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
- 11. An all-weather access road to the treatment facility shall be maintained.
- 12. The outfall sewer shall be protected and maintained against the effects of floodwater, ice, or other hazards as to reasonably ensure its structural stability, freedom from stoppage, and that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
- 13. The media in the filter beds shall be properly maintained to prevent surface pooling, vegetative growth, and accumulation of leaf litter.
- 14. The permittee shall perform a minimum of four whole effluent toxicity tests in the four and one-half year period prior to the next permit renewal application. The four tests shall consist of three acute toxicity tests and one chronic toxicity test in accordance with Special Conditions #16 and #17.
- 15. <u>Acute Whole Effluent Toxicity (WET)</u> tests shall be conducted as follows:
 - (a) Freshwater Species and Test Methods: Species and short-term test methods for estimating the acute toxicity of NPDES effluents are found in the most recent edition of *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA/821/R-02/012; Table IA, 40 CFR Part 136). The permittee shall concurrently conduct 48-hour, static, non-renewal toxicity tests with the following species:
 - i. The fathead minnow, Pimephales promelas (Acute Toxicity EPA Test Method 2000.0).
 - ii. The daphnid, Ceriodaphnia dubia (Acute Toxicity EPA Test Method 2002.0).
 - (b) Chemical and physical analysis of the upstream control sample and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping. Where upstream receiving water is not available or known to be toxic, other approved control water may be used.
 - (c) Test conditions must meet all test acceptability criteria required by the EPA Method used in the analysis.
 - (d) The laboratory shall not chemically dechlorinate the sample.
 - (e) The Allowable Effluent Concentration (AEC) is 100%; the dilution series is: 100%, 50%, 25%, 12.5%, and 6.25%.
 - (f) All chemical and physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% effluent concentration.
 - (g) The facility must submit a full laboratory report for all toxicity testing. The report must include a quantification of acute toxic units ($TU_a = 100/LC_{50}$) reported according to the test methods manual chapter on report preparation and test review. The Lethal Concentration 50 Percent (LC_{50}) is the effluent concentration that would cause death in 50 percent of the test organisms at a specific time.

- 16. <u>Chronic Whole Effluent Toxicity (WET)</u> tests shall be conducted as follows:
 - (a) Freshwater Species and Test Methods: Species and short-term test methods for estimating the chronic toxicity of NPDES effluents are found in the most recent edition of *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms (EPA/821/R-02/013; Table IA, 40 CFR Part 136)*. The permittee shall concurrently conduct 7-day, static renewal toxicity tests with the following species:
 - i. The fathead minnow, *Pimephales promelas* (Survival and Growth Test Method 1000.0).
 - ii. The daphnid, Ceriodaphnia dubia (Survival and Reproduction Test Method 1002.0).
 - (b) Chemical and physical analysis of the upstream control sample and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping. Where upstream receiving water is not available or known to be toxic, other approved control water may be used.
 - (c) Test conditions must meet all test acceptability criteria required by the EPA Method used in the analysis.
 - (d) The laboratory shall not chemically dechlorinate the sample.
 - (e) The Allowable Effluent Concentration (AEC) is 100%, the dilution series is: 100%, 50%, 25%, 12.5%, and 6.25%.
 - (f) All chemical and physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% effluent concentration.
 - (g) The facility must submit a full laboratory report for all toxicity testing. The report must include a quantification of chronic toxic units ($TU_c = 100/IC_{25}$) reported according to the *Methods for Measuring the Chronic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* chapter on report preparation and test review. The 25 percent Inhibition Effect Concentration (IC_{25}) is the toxic or effluent concentration that would cause 25 percent reduction in mean young per female or in growth for the test populations.

17. Expanded Effluent Testing

Permittee must sample and analyze for the pollutants listed in Form B2 – Application for Operating Permit for Facilities That Receive Primarily Domestic Waste And Have A Design Flow More Than 100,000 Gallons Per Day (MO-780-1805 dated 10-20), Part D – Expanded Effluent Testing Data, #18. The permittee shall provide this data with the permit renewal application. A minimum of three samples taken within four and one-half years prior to the date of the permit application must be provided. Samples must be representative of the seasonal variation in the discharge from each outfall. Approved and sufficiently sensitive testing methods listed in 40 CFR 136.3 must be utilized. A method is "sufficiently sensitive" when; 1) The method minimum level is at or below the level of the applicable water quality criterion for the measured pollutant or pollutant parameter; or 2) the method minimum level is above the applicable water quality criterion, but the amount of the pollutant or pollutant parameter in a facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or 3) the method has the lowest minimum level of the analytical methods approved under 40 CFR part 136. These methods are also required for parameters listed as monitoring only, as the data collected may be used to determine if numeric limitations need to be established.

- 18. <u>Pretreatment:</u> The permittee shall implement and enforce its approved pretreatment program in accordance with the requirements of 10 CSR 20-6.100. The approved pretreatment program is hereby incorporated by reference.
 - (a) The permittee shall submit to the Department via the Electronic Discharge Monitoring Report (eDMR) Submission System on or before March 31st of each year a report briefly describing its pretreatment activities during the previous calendar year. At a minimum, the report shall include the following:
 - (1) An updated list of the Permittee's Industrial Users, including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The Permittee shall provide a brief explanation of each deletion. This list shall identify which Industrial Users are subject to categorical pretreatment Standards and specify which Standards are applicable to each Industrial User. The list shall indicate which Industrial Users are subject to local standards that are more stringent than the categorical Pretreatment Standards. The Permittee shall also list the Industrial Users that are subject only to local Requirements;
 - (2) A summary of the status of Industrial User compliance over the reporting period;
 - (3) A summary of compliance and enforcement activities (including inspections) conducted by the Permittee during the reporting period; and
 - (4) Any other relevant information requested by the Department.
 - (b) The permittee shall continue to develop local limits as necessary and effectively enforce such limits, per 40 CFR 403.5(c)(1). The permittee shall submit to the Department a written technical evaluation of the need to revise local limits under 40 CFR 403.5(c)(1) by January 1, 2025, pursuant to 40 CFR 122.44(j)(2)(ii). All POTWs are required to use Form 780-2954, Part I, to complete the local limits review under 40 CFR 122.44(j)(2)(ii), and Part II of the form as needed for the detailed reevaluation of local limits. See instructions for both Parts I and II, respectively, for the review and reevaluation. Please contact the Department's pretreatment coordinator for further guidance. Should revision of local limits be deemed necessary, it is recommended that revisions follow the US Environmental Protection Agency's guidance document *Local Limits Development Guidance*. EPA833-R04-002A. July 2004.

- 19. <u>Performance Optimization Plan</u>: The Permittee shall submit a Performance Optimization Plan (POP) to the Department by **July 1, 2025**. The requirements of the POP are as follows:
 - (a) A plan, which lays out the Permittee's commitments for:
 - (1) Optimizing the level of treatment of the Monett Wastewater Treatment Plant;
 - (2) Identification of non-domestic sources of Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen that have the potential to contribute to discharge levels;
 - (3) Reasonable, cost-effective activities designed to reduce or eliminate Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen loadings from identified non-domestic sources;
 - (4) Tracking of Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen non-domestic source reduction implementation and monitoring, to maximize pollutant reductions;
 - (5) Monitoring the POTW's influent and effluent, including at least monthly influent monitoring;
 - (6) Resources and staffing;
 - 1. Proper resources must be budgeted.
 - 2. Properly certified operators must be maintained.
 - (b) A plan that lays out the Permittee's commitment for Inflow and infiltration reductions; and
 - (c) Implementation of cost-effective control measures for the Monett Wastewater Treatment Plant and for non-domestic contributors; and
 - (d) The permittee shall submit a report via the Electronic Discharge Monitoring Report (eDMR) Submission System annually for the previous calendar year. The first report will be for calendar year 2028, and is due <u>January 28, 2029</u>. The report shall contain, at a minimum, the following information:
 - (1) A list of potential Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen non-domestic sources;
 - (2) A summary of actions taken to reduce or eliminate Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen at the Monett Wastewater Treatment Plant and at non-domestic sources, to enable the Monett Wastewater Treatment Plant to progress toward meeting the TMDL and water quality based effluent limitations;
 - (3) Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Ammonia, Total Phosphorus, and Total Nitrogen Chloride non-domestic source reduction implementation, non-domestic source monitoring results, and influent, and effluent results for the previous year;
 - (4) Proposed adjustments to the POP, based on the findings of Special Condition 20(d)(3).

Once approved by the department, the Performance Optimization Plan shall be located at the wastewater treatment plant and be made available upon request by the department.

20. Wastewater Irrigation System.

- (a) <u>Discharge Reporting</u>. Any unauthorized discharge from the irrigation system shall be reported to the Department as soon as possible but always within 24 hours.
- (b) <u>General Irrigation Requirements.</u> Wastewater shall be irrigated during suitable conditions so that there is no discharge from the irrigation sites. The wastewater irrigation system shall be operated so as to provide uniform distribution of irrigated wastewater over the entire irrigation site. A complete ground cover of vegetation shall be maintained on the irrigation site.
- (c) <u>Saturated/Frozen Conditions.</u> There shall be no surface irrigation during ground frost; frozen, snow-covered, or saturated soil conditions; or when precipitation is imminent or occurring.
- (d) Set Backs. There shall be no irrigation within: 50 feet of the property line or public road;
- (e) Public Access Restrictions. The public shall not be allowed into public use area irrigation sites when application is occurring.
- (f) <u>Irrigated Wastewater Disinfection</u>. Wastewater shall be disinfected prior to land application (not storage) to public use areas.
- (g) <u>Golf Course Irrigation</u>. All piping and sprinklers, installed or replaced after the effective date of this permit, associated with the distribution or transmission of wastewater at the golf course shall be color-coded and labeled or tagged to warn against the consumptive use of contents.
- (h) <u>Equipment Checks during Irrigation</u>. The irrigation system and application site shall be visually inspected at least <u>twice/day</u> during wastewater irrigation to check for equipment malfunctions and runoff from the irrigation site.
- (i) Wastewater irrigation records shall be maintained and summarized into an annual operating report for the previous calendar year. The report shall be kept onsite and made available to Department personnel upon request. The summarized annual report shall include the following:
 - Record of maintenance and repairs performed during the year, average number of times per month the irrigation equipment is checked to see if it is operating properly, and description of any unusual operating conditions encountered during the year;
 - (2) The number of days a discharge from the irrigation area has occurred during the year, the discharge flow, and the reasons discharge occurred; and
 - (3) A summary of the irrigation operations for the year including: the number of days of irrigation, the total gallons irrigated, the total acres used, and the irrigation rate in inches for the year.

21. Renewal Application Requirements.

- (a) This facility shall submit an appropriate and complete application to the department no less than 180 days prior to the expiration date listed on Page 1 of the permit.
- (b) Application materials shall include a completed Form B2.
 - (1) For Part B, Additional Application Information #14 Effluent Testing Data, the permittee shall submit at a minimum, effluent testing data based on at least three samples for each outfall through which effluent is discharged. The samples must be no more than four and one-half years apart.
 - Sufficiently sensitive analytical methods must be used. A method is "sufficiently sensitive" when; 1) the method i minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility's discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031.
 - (2) For Part D, Expanded Effluent Testing Data #18, the permittee shall submit at a minimum, effluent testing data based on at least three pollutant scans for each outfall through which effluent is discharged. The pollutant scans must be performed no more than four and one-half years prior to the date of the permit application submittal.
 - Sufficiently sensitive analytical methods must be used. See Special Condition 17(b)(i)1 above for more information.
 - (3) For Part E, Toxicity Testing Data #19, the facility shall submit at a minimum, either 4 quarterly tests for a 12-month period within the past one year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the date of the permit application submittal, for each of the facility's discharge points.
 - (4) For Part F, Industrial User Discharges and RCRA/CERCLA Wastes, if the treatment works accepts process wastewater from any significant industrial users, also known as SIUs, or receives a RCRA or CERCLA wastes, the permittee shall complete the applicable portions of #20, #21, #22, and/or #23 for each SIU and/or remedial waste accepted. i.
 - SIUs are defined as:
 - 1. All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N.
 - 2. Any other industrial user that meets one or more of the following:
 - a. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - b. Contributes a process waste stream that makes up 5% or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - c. Is designated as an SIU by the control authority.
 - d. Is otherwise required by the permitting authority to provide the information.
- (c) Application materials shall include a completed Form I.
- (d) Complete the Financial Questionnaire (https://dnr.mo.gov/document-search/financial-questionnaire-mo-780-2511) and submit it with your application.

G. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to pursue an appeal before the administrative hearing commission (AHC) pursuant to Sections 621.250 and 644.051.9 RSMo. To appeal, you must file a petition with the AHC within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

> Administrative Hearing Commission U.S. Post Office Building, Third Floor 131 West High Street, P.O. Box 1557 Jefferson City, MO 65102-1557 Phone: 573-751-2422 Fax: 573-751-5018 Website: https://ahc.mo.gov

MISSOURI DEPARTMENT OF NATURAL RESOURCES FACT SHEET FOR THE PURPOSE OF RENEWAL OF MO-0021440 MONETT WWTP

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollutant Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)(A)2.], a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

Part I – Facility Information

Application Date:	07/25/2017
Expiration Date:	12/31/2017

<u>Facility Type and Description</u>: POTW - Influent screw pump lift station / 2 mechanical bar screens / bar screen / peak flow basin / aerated grit chamber / six anaerobic basins / four anoxic basins / 2 primary clarifiers (inactive) / 3 trickling filter towers / 2 oxidation ditches / 2 final clarifiers / 2 tertiary fabric filters / ultraviolet disinfection / concrete re-aeration steps / partial direct irrigation on golf course from effluent pump station / 4 aerobic digesters / 1 gravity belt sludge thickener / 10 sludge drying beds / biosolids are land applied / facility does not have materials stored or conduct operations in a manner that would cause the discharge of pollutants via stormwater

OUTFALL(S) TABLE:

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	9.3	Tertiary	Domestic

Comments:

Changes in this permit for Outfall #001 include the addition of final effluent limits for CBOD₅, Dissolved Oxygen Total Phosphorus, Total Nitrogen, and Lead, the addition of Total Kjeldahl Nitrogen (TKN) and Nitrate + Nitrite (N+N) monitoring, the revision of final limits for TSS, E. coli, Ammonia, and Cyanide, Oil & Grease was changed from limits to monitoring only, Cadmium and Selenium changed from limits to monitoring only and sampling frequency changed to quarterly, removal of Zinc, Iron, and Aluminum monitoring, and the removal of the Acute and Chronic WET test requirement. Changes in this permit for Permitted Feature 003 include the addition of daily monitoring and monthly reporting for Irrigation Period, Volume Irrigated, Irrigation Area, and Irrigation Rate. Changes in this permit include the removal of Permitted Feature SM1. Changes in this permit for Permitted Feature INF include the addition of CBOD₅, Ammonia, Total Phosphorus, TKN, and N+N, and the monitoring frequency for influent TSS was revised to once per week to match the operational monitoring requirement in 10 CSR 20-9.010(5)(B). See Part II of the Fact Sheet for further information regarding the addition, revision, and removal of influent, instream, and effluent parameters. Special conditions were updated to include the addition of inflow and infiltration reporting requirements, reporting of Non-detects, bypass reporting requirements, pretreatment requirements, removal of instream monitoring requirements, the SWPPP requirement, the Water Quality Standards condition, the blending condition, the 2013 EPA Ammonia criteria condition, and the revision of the Electronic Discharge Monitoring Report (eDMR) Submission System condition, the CMOM condition, the bypass reporting condition, and other special conditions. Changes to the effluent limits reflect the requirements of the 1999 TMDL for Clear Creek. The facility conducted a Water Effect Ratio (WER) study due to the facility being challenged to meet the revised copper effluent limits in the previous permit. The permit also includes a requirement to develop a Performance Optimization Plan. MUDD and 100K Extent-Remaining Streams (C) (3960) is now Presumed Use Streams (C) (5079) where the WBID is based on the HUC 12 basin.

Part II – Effluent Limitations and Monitoring Requirements

OUTFALL #001 - MAIN FACILITY OUTFALL

Effluent limitations derived and established in the permit are based on current operations of the facility, outfall location, and receiving stream. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

OUTFALL #001 - RECEIVING STREAM INFORMATION

RECEIVING STREAM(S) TABLE:

WATER-BODY NAME	CLASS	WBID	DESIGNATED USES**	12-DIGIT HUC	DISTANCE TO CLASSIFIED SEGMENT (MI)
Clear Creek (Presumed Use Streams*)	С	5079	AHP (WWH), WBC-B, SCR, HHP, IRR, LWP	11070207-0704	0

* The previous permit identified MUDD WBID #3960 and 100K Extent-Remaining Stream. This change is due to a new numbering system and new naming convention of the streams, and the actual receiving stream has not changed.

**As per 10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(F)].

Uses found in the receiving streams table, above:

10 CSR 20-7.031(1)(F)1.:

AHP = Aquatic Habitat Protection - To ensure the protection and propagation of fish, shellfish, and wildlife. AHP is further subcategorized as:

WWH = Warm Water Habitat;

CLH = Cool Water Habitat;

CDH= Cold Water Habitat;

EAH = Ephemeral Aquatic Habitat;

MAH = Modified Aquatic Habitat;

LAH = Limited Aquatic Habitat.

This permit uses Aquatic Life Protection effluent limitations in 10 CSR 20-7.031 Table A for all aquatic habitat designations unless otherwise specified.

10 CSR 20-7.031(1)(F)2.: Recreation in and on the water

WBC = Whole Body Contact recreation where the entire body is capable of being submerged. WBC is further subcategorized as:

WBC-A = Whole body contact recreation that supports swimming uses and has public access;

WBC-B = Whole body contact recreation that supports swimming;

SCR = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(F)3. to 7.:

HHP = Human Health Protection as it relates to the consumption of fish;

IRR = Irrigation - Application of water to cropland or directly to cultivated plants that may be used for human or livestock consumption;

LWP = Livestock and wildlife protection - Maintenance of conditions in waters to support health in livestock and wildlife;

DWS = Drinking water supply;

IND = Industrial water supply

10 CSR 20-7.031(1)(F)8-11.: Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)

WSA = Storm- and flood-water storage and attenuation;

WHP = Habitat for resident and migratory wildlife species;

WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses;

WHC = Hydrologic cycle maintenance.

10 CSR 20-7.031(6):

 $\mathbf{GRW} = \mathbf{Groundwater}$

RECEIVING STREAM(S) LOW-FLOW VALUES:

DECENTING STREAM	LOW-FLOW VALUES (CFS)				
RECEIVING STREAM	1Q10	7Q10	30Q10		
Clear Creek (Presumed Use Streams)	0	0	0		

MIXING CONSIDERATIONS

Mixing Zone: Not Allowed [10 CSR 20-7.031(5)(A)4.B.(I)(a)]. Zone of Initial Dilution: Not Allowed [10 CSR 20-7.031(5)(A)4.B.(I)(b)].

Receiving Water Body's Water Quality

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole-body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation.

- This facility discharges to a 303(d) listed stream. Clear Creek (3239) is listed on the 2020 Missouri 303(d) List for Nutrient/Eutrophication Biological Indicators and Dissolved Oxygen. Clear Creek (3238) is listed on the 2020 Missouri 303(d) List for *E. coli*.
 - o This facility is considered to be a source of or has the potential to contribute to the above listed pollutants. The Department's Environmental Services Program conducted a low-flow critical condition wasteload allocation study in Clear Creek in the vicinity of the Monett Wastewater Treatment Facility from August 11-13, 2020. The TMDL and Modeling Unit used the study results to conduct QUAL2K modeling in 2021 to determine effluent limits for the Monett Wastewater Treatment Facility that will attain the applicable dissolved oxygen criterion of 5.0 mg/L in Clear Creek and address the nutrient/eutrophication biological indicator impairment. The effluent limits established in the permit meet the assumptions and requirements of the QUAL2K model.
- ✓ This facility discharges to a stream with an EPA approved TMDL. The TMDL for Clear Creek was approved December 1, 1999. The pollutants were listed as Biochemical Oxygen Demand, Suspended Solids, and Ammonia. The Monett WWTP was listed as the sole source of pollution in Clear Creek. The effluent limits established in the permit meet the assumptions and requirements of the TMDL.

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit/ Frequency	Sampling Frequency	Reporting Frequency	Sample Type ****
Flow	MGD	1	*		*	1/day	1/weekday	monthly	Т
CBOD ₅ (Table A-3)	mg/L	6		5.9	3.9	15/10 (BOD)	2/week	monthly	С
TSS (Interim – Table A-2)	mg/L	8		15	10	20/15	2/week	monthly	С
TSS (Final – Table A-3)	mg/L	8		13.8	9.2	15/10	2/week	monthly	С
Escherichia coli**	#/100mL	1, 3	126		*	126/126	1/week	monthly	G
Ammonia (Jan-Mar) Interim	mg/L	2, 3	11.3		2.1	11.3/2.1	2/week	monthly	С
Ammonia (Apr-Sep) Interim	mg/L	2, 3	3.8		1.4	3.8/1.4	2/week	monthly	С
Ammonia (Oct-Dec) Interim	mg/L	2, 3	11.3		2.1	11.3/2.1	2/week	monthly	С
Ammonia (Jan-Mar) (Final -Table A-2 & A-3)	mg/L	2, 3	4.2		2.1	11.3/2.1	2/week	monthly	С
Ammonia (Apr-Jul) (Final -Table A-2 & A-3)	mg/L	2, 3	2.8		1.4	3.8/1.4	2/week	monthly	С
Ammonia (Aug) (Final -Table A-2 & A-3)	mg/L	2, 3	2.6		1.3	3.8/1.4	2/week	monthly	С
Ammonia (Sep) (Final -Table A-2 & A-3)	mg/L	2, 3	2.8		1.4	3.8/1.4	2/week	monthly	С
Ammonia (Oct-Dec) (Final -Table A-2 & A-3)	mg/L	2, 3	4.2		2.1	11.3/2.1	2/week	monthly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	***	1/week	monthly	М
Nitrate + Nitrite	mg/L	1	*		*	*/* 1/month	1/week	monthly	С
Cyanide, ATC	μg/L	2, 3	9.6		3.6	8.2/4.1	1/month	monthly	G
Lead, TR	μg/L	2, 3	8.5		3.9	*/*	1/month	monthly	С
Total Hardness	mg/L	7	*		*	***	1/month	monthly	G

CHANGES TO EFFLUENT LIMITATIONS TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit/ Frequency	Sampling Frequency	Reporting Frequency	Sample Type ****
Oil & Grease	mg/L	1, 3	*		*	15/10	1/quarter	quarterly	G
Beryllium, TR	μg/L	7	*		*	***	1/quarter	quarterly	С
Cadmium, TR	μg/L	7	*		*	0.43/0.4	1/quarter	quarterly	С
Selenium, TR	μg/L	7	*		*	8.2/4.1	1/quarter	quarterly	С
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
Dissolved Oxygen (Final - Table A-3)	mg/L	8	7.0		7.0	*/*	1/week	monthly	G
CBOD ₅ Percent Removal	%	1			85	BOD - 85	1/month	monthly	М

		Basis	Mon	thly	An	nual	Previous Permit	Sampling	Reporting	Sample
PARAMETER	Unit	for Limits	Avg	Total	Avg	Total	Limit/ Frequency	Frequency	Frequency	Туре
Total Phosphorus	mg/I	6	*		*		*/* and	1/week/	monthly/	C/M
(Tables A-1 & A-2, Interim)	ing/ E	0					quarterly	1/year	annually	0/101
Total Phosphorus	lbs	6		*		*	**	1/week/	monthly/	м
(Tables A-1 & A-2, Interim)	108.	0						1/year	annually	IVI
Total Phosphorus	/T	6	*		*		*/* and	1/week/	monthly/	CM
(Table A-3, Final)	mg/L	0			-1-		quarterly	1/year	annually	C/M
Total Phosphorus	11	-				10.265	ste /ste	1/week/	monthly/	
(Table A-3, Final)	lbs.	6		*		18,265	*/*	1/year	annually	М
Total Nitrogen		-	.1.		ala.		*/* and	1/week/	monthly/	
(Table A-1 & A-2, Interim)	mg/L 6	6	*		*		quarterly	1/year	annually	М
Total Nitrogen		-		.1.				1/week/	monthly/	
(Table A-1 & A-2, Interim)	lbs.	6		*		Ŷ	**	1/year	annually	М
Total Nitrogen	/T	6	÷		*		*/* and	1/week/	monthly/	м
(Table A-3, Final)	mg/L	6	Ť		Ť		quarterly	1/year	annually	M
Total Nitrogen	11	<i>.</i>		4		202 (00		1/week/	monthly/	
(Table A-3, Final)	lbs.	6		*		392,689	*/*	1/year	annually	М
		Basis						a l'		G 1
PARAMETER	Unit	for	Daily M	inimum	Monthly	Avg. Min	Previous Permit	Sampling	Reporting	Sample
		Limits	-				Liiiit	Frequency	Frequency	Type
Dissolved Oxygen	ma/I	7	*			*	* /*	1/maal-	monthly	C
(Tables A-1 & A-2, Interim)	mg/L	/	-1-					1/week	monthly	G
Dissolved Oxygen	π	0	_	0	_	0	ste /ste	1/ 1	.1.1	C
(Table A-3, Final)	mg/L	8	7.	0	1	.0	*/*	1/week	monthly	G

* - Monitoring requirement only.

** - No more than 10% of samples over the course of the calendar year shall exceed 126 #/100 mL daily maximum.

*** - Parameter not previously established in previous state operating permit.

Basis for Limitations Codes:

- 1. State or Federal Regulation/Law
- 2. Water Quality Standard (includes RPA)
- 3. Water Quality Based Effluent Limits
- 4. Antidegradation Review
- Antidegradation Policy
 Water Quality Model

8.

7. Best Professional Judgment

TMDL or Permit in lieu of TMDL

**** - C = 24-hour composite

G = GrabT = 24-hr. total

E = 24-hr. estimate

M = Measured/calculated

9. WET Test Policy

- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

- OUTFALL #001 DERIVATION AND DISCUSSION OF LIMITS:
- <u>Flow</u>. In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.

Biochemical Oxygen Demand (BOD5) & Carbonaceous Biochemical Oxygen Demand (CBOD5)

	2022 QUAL2K		TBE (Technology Based	LS I Effluent Limits)	LSBEL (Losing Stream Based Effluent Limits)		
PARAMETER	Weekly Average	Monthly Average	Weekly Average	Monthly Average	Weekly Average	Monthly Average	
CBOD ₅	5.9	3.9	40	25	10	5	
BOD5 (Spring, Summer, Fall)	7.5	5	45	30	15	10	
BOD ₅ (Winter)	7.5	5	45	30	15	10	

Green cells are final effluent limits, yellow cells are interim effluent limits.

<u>Biochemical Oxygen Demand (BOD₅) Interim Limits</u>. Operating permit retains 15 mg/L as a Weekly Average and 10 mg/L as a Monthly Average from the previous permit. Please see the CATEGORIZATION OF WATERS OF THE STATE subsection of the <u>Effluent Limits Determination</u>.

o Carbonaceous Biological Oxygen Demand₅ Final Limits.

Carbonaceous Biochemical Oxygen Demand (CBOD₅) 2022 QUAL2K. The 2022 QUAL2K Memo for Clear Creek provides a single value Wasteload Allocation (WLA) of 3.9 mg/L. The Wasteload Allocation (WLA) is applied as the AML. As CBOD₅ has an AWL and AML, the permit writer determined that to calculate the AWL, the AML would be multiplied by 1.5 (using the Department's 2009 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5). See APPENDIX: 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2.

WLA = 3.9 mg/L WLA = AML AML = 3.9 mg/L

AWL = AML * 1.5 AWL = 3.9 * 1.5 AWL = 5.9 mg/L

• Total Suspended Solids (TSS).

PARAMETER	1999 T (Total Maximur	MDL m Daily Load)	2022 QUAL2K			PBELS (Performance Based Effluent Limits)		LSBEL (Losing Stream Based Effluent Limits)	
	Weekly	Monthly	Daily	Weekly	Weekly	Weekly	Monthly	Weekly	Monthly
	Average	Average	Maximum	Average	Average	Average	Average	Average	Average
TSS	13.8	9.2	NA	22.5	15	15	10	20	15

Green cells are final effluent limits, yellow cells are 1st interim effluent limits, and orange cells are 2nd interim limits

- <u>Total Suspended Solids (TSS) Losing Stream (Interim Limits)</u>. Operating permit retains 20 mg/L as a Weekly Average and 15 mg/L as a Monthly Average from the previous permit. Effluent limits were established in accordance with 10 CSR 20-7.015(4) for discharges to Losing Streams.
- Total Suspended Solids (TSS) (Interim). The Department has the ability to require more stringent limitations than what is established in 10 CSR 20-7.015(8). 10 CSR 20-7.015(8)(A)3.D.(I) allows the Department to set the BOD₅ and TSS limits for existing facilities, based upon an analysis of the past performance, rounded up to the next five milligrams per liter (5 mg/L) range. The permit writer conducted a review of data submitted by the facility for TSS and calculated a monthly average limit using the 95th percentile of monthly average data, and then rounded up to the next 5 mg/L.

The 95th percentile of monthly average data for TSS from October 2017 to August 2022 was 9.305 mg/L, which rounded up to the next 5 mg/L provided an Average Monthly Limit of 10 mg/L. Per the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance, for conventional pollutants, and the Department's 2009 Dissolved Oxygen Modeling and Biochemical Oxygen Demand Effluent Limit Development Administrative Guidance document, the Average Weekly Limit is calculated by multiplying the AML by 1.5. The AWL was calculated to be 14.0 mg/L, which was rounded up to the next 5 mg/L, resulting in an AWL of 15 mg/L.

AML = 9.305 mg/L rounded up to the next 5 mg/L = 10 mg/L

AWL = AML * 1.5 = 9.305 * 1.5 = 14.0 mg/LAWL = 14.0 mg/L rounded up to the next 5 mg/L = 15 mg/L • <u>Total Suspended Solids (TSS) 1999 TMDL</u>. The 1999 EPA approved TMDL for Clear Creek assigns a WLA of 462 lbs/day year-round for TSS, for the Monett WWTP. See APPENDIX: 1999 TMDL SECTION 5.

Chronic WLA: $C_e = 462 \text{ lbs/day} \div (9.3 \text{ cfs x } 5.394286) = 9.2 \text{ mg/L}$

WLA = 9.2 mg/L WLA = AML AML = 9.2 mg/L AWL = AML * 1.5 AWL = 9.2 * 1.5 AWL = 13.8 mg/L

<u>Total Suspended Solids (TSS) 2022 QUAL2K</u>. The 2022 QUAL2K Memo for Clear Creek provides a single value Wasteload Allocation (WLA) of 15 mg/L. The Wasteload Allocation (WLA) is applied as the AML. As CBOD₅ has an AWL and AML, the permit writer determined that to calculate the AWL, the AML would be multiplied by 1.5 (using the Department's 2009 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5). See APPENDIX: 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2.

WLA = 15 mg/L WLA = AML AML = 15 mg/L AWL = AML * 1.5 AWL = 15 * 1.5 AWL = 22.5 mg/L

• <u>Escherichia coli (E. coli)</u>. Discharges to losing streams shall not exceed 126 per 100 mL as a Daily Maximum at any time, as per 10 CSR 20-7.031(5)(C). Monitoring only for a monthly average. No more than 10% of samples over the course of the calendar year shall exceed 126 #/100 mL daily maximum as per 10 CSR 20-7.015(9)(B)1.G.

MONTH	1999 T (Total Maximu	ГMDL ım Daily Load)	2022 QUAL2K WLAs		WQBELS (Water Quality Based Effluent Limits)		EXISTING PERMIT LIMITS	
	Daily Maximum	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Monthly Average
January	4.2	2.1	4.2	2.1	12.1	3.1	11.3	2.1
February	4.2	2.1	4.2	2.1	10.1	2.7	11.3	2.1
March	4.4	2.2	4.2	2.1	12.1	3.1	11.3	2.1
April	4.4	2.2	2.8	1.4	12.1	2.7	3.8	1.4
May	4.4	2.2	2.8	1.4	12.1	2.2	3.8	1.4
June	3.0	1.5	2.8	1.4	12.1	1.7	3.8	1.4
July	3.0	1.5	2.8	1.4	12.1	1.5	3.8	1.4
August	3.0	1.5	2.6	1.3	10.1	1.3	3.8	1.4
September	4.4	2.2	2.8	1.4	12.1	1.8	3.8	1.4
October	4.4	2.2	4.2	2.1	12.1	2.5	11.3	2.1
November	4.4	2.2	4.2	2.1	12.1	3.1	11.3	2.1
December	4.2	2.1	4.2	2.1	12.1	3.1	11.3	2.1

• <u>Total Ammonia Nitrogen</u>.

Green cells are final effluent limits using most protective limits, yellow cells are interim effluent limits

• Total Ammonia Nitrogen 1999 TMDL.

Ammonia 1999 TMDL (Spring, Fall = Mar-May, Sep-Nov). The 1999 EPA approved TMDL for Clear Creek assigns a WLA of 110.7 lbs/day for Ammonia for the spring and fall season for the Monett WWTP. As Ammonia has an AML and MDL, the permit writer determined that to calculate the MDL, the AML would be multiplied by 2.0 (using the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5, and the Department uses a 2.0 multiplier to calculate a Daily Maximum). See APPENDIX: 1999 TMDL SECTION 5.

Chronic WLA: $C_e = 110.7 \text{ lbs/day} \div (9.3 \text{ cfs x } 5.394286) = 2.2 \text{ mg/L}$

WLA = 2.2mg/L WLA = AML **AML = 2.2 mg/L** MDL = AML * 2

MDL = AML * 2MDL = 2.2 * 2MDL = 4.4 mg/L

Ammonia 1999 TMDL (Summer = Jun - Aug). The 1999 EPA approved TMDL for Clear Creek assigns a WLA of 77.4 lbs/day for Ammonia for the summer season for the Monett WWTP. As Ammonia has an AML and MDL, the permit writer determined that to calculate the MDL, the AML would be multiplied by 2.0 (using the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5, and the Department uses a 2.0 multiplier to calculate a Daily Maximum). See APPENDIX: 1999 TMDL SECTION 5.

Chronic WLA: $C_e = 77.4 \text{ lbs/day} \div (9.3 \text{ cfs x } 5.394286) = 1.5 \text{ mg/L}$

WLA = 1.5 mg/L WLA = AML AML = 1.5 mg/L MDL = AML * 2

MDL = AML + 2MDL = 1.5 * 2MDL = 3.0 mg/L

Ammonia 1999 TMDL (Winter = Dec - Feb). The 1999 EPA approved TMDL for Clear Creek assigns a WLA of 105.3 lbs/day for Ammonia for the winter season for the Monett WWTP. As Ammonia has an AML and MDL, the permit writer determined that to calculate the MDL, the AML would be multiplied by 2.0 (using the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5, and the Department uses a 2.0 multiplier to calculate a Daily Maximum). See APPENDIX: 1999 TMDL SECTION 5.

Chronic WLA: $C_e = 105.3 \text{ lbs/day} \div (9.3 \text{ cfs x } 5.394286) = 2.1 \text{ mg/L}$

WLA = 2.1mg/L WLA = AML AML = 2.1 mg/L

MDL = AML * 2 MDL = 2.1 * 2 MDL = 4.2 mg/L

- <u>Total Ammonia Nitrogen 2022 OUAL2K.</u> The 2022 QUAL2K Memo for Clear Creek provides a single value Wasteload Allocation (WLA) for Summer Ammonia of 1.4 mg/L (1.3 for August) and for Winter Ammonia of 2.1 mg/L. As Ammonia has an AML and MDL, the permit writer determined that to calculate the MDL, the AML would be multiplied by 2.0 (using the Department's 2010 Guidance for Water Quality and Antidegradation Review Assistance calculates average weekly limits by multiplying the AML by 1.5, and the Department uses a 2.0 multiplier to calculate a Daily Maximum). See APPENDIX: 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2.
 - Total Ammonia Nitrogen (Summer = Apr Jul, Sep) QUAL2K.

Chronic WLA: $C_e = 1.4 \text{ mg/L}$ WLAc = AML AML = 1.4 mg/L MDL = AML x 2.0 MDL = 1.4 x 2.0 = 2.8 mg/L

• Total Ammonia Nitrogen (Summer = August)) QUAL2K.

$$\label{eq:chronic WLA: Ce} \begin{split} & C_e = 1.3 \ mg/L \\ & WLAc = AML \\ & AML = 1.3 \ mg/L \end{split}$$

MDL = AML x 2.0 MDL = 1.3 x 2.0 = **2.6** mg/L

• Total Ammonia Nitrogen (Winter = Oct - Mar) QUAL2K.

Chronic WLA: $C_e = 2.1 \text{ mg/L}$ WLAc = AML AML = 2.1 mg/L MDL = AML x 2.0 MDL = 2.1 x 2.0 = 4.2 mg/L

o <u>Total Ammonia Nitrogen WQBEL.</u>

Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(5)(B)7.C. & Table B3]. Background total ammonia nitrogen = 0.01 mg/L. No mixing considerations allowed; therefore, WLA = appropriate criterion.

The Department previously followed the 2007 Ammonia Guidance method for derivation of ammonia limits. However, the EPA's Technical Support Document for Water Quality-based Toxic Controls (TSD) establishes other alternatives to limit derivation. The Department has determined that the approach established in Section 5.4.2 of the TSD, which allows for direct application of both the acute and chronic wasteload allocations (WLA) as permit limits for toxic pollutants, is more appropriate limit derivation approach. Using this method for a discharge to a waterbody where mixing is not allowed, the criterion continuous concentration (CCC) and the criterion maximum concentration (CMC) will equal the chronic and acute WLA respectively. The WLAs are then applied as effluent limits, per Section 5.4.2 of the TSD, where the CMC is the Daily Maximum and the CCC is the Monthly Average. The direct application of both acute and chronic criteria as WLA is also applicable for facilities that discharge into receiving waterbodies with mixing considerations. The CCC and CMC will need to be calculated into WLA with mixing considerations using the mass-balance equation:

$$Ce = \frac{(Qe + Qs)C - (Qs \times Cs)}{(Qe)}$$

 $\begin{array}{ll} \mbox{Where} & C = \mbox{downstream concentration} \\ Cs = \mbox{upstream concentration} \\ Qs = \mbox{upstream flow} \end{array}$

Ce = effluent concentration Qe = effluent flow

In the event that mixing considerations derive an AML less stringent than the MDL, the AML and MDL will be equal and based on the MDL.

Month	Temp (°C)*	pH (SU)*	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
January	8.1	7.8	3.1	12.1
February	9.3	7.9	2.7	10.1
March	13.0	7.8	3.1	12.1
April	16.7	7.8	2.7	12.1
May	20.0	7.8	2.2	12.1
June	24.0	7.8	1.7	12.1
July	26.6	7.8	1.5	12.1
August	26.5	7.9	1.3	10.1
September	23.5	7.8	1.8	12.1
October	18.0	7.8	2.5	12.1
November	14.0	7.8	3.1	12.1
December	10.0	7.8	3.1	12.1

* Ecoregion data (Ozark Highlands)

January Chronic WLA:	Ce = ((9.3 + 0)3.1 - (0 * 0.01)) / 9.3
Acute WLA:	Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3 $Ce = 12.1$
AML = WLAc = 1 MDL = WLAa = 1	3.1 mg/L 12.1 mg/L
X	C
March Chronic WLA:	Ce = ((9.3 + 0)3.1 - (0 * 0.01)) / 9.3 Ce = 3.1
Acute WLA:	Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3 Ce = 12.1
AML = WLAc = 1 MDL = WLAa =	3.1 mg/L 12.1 mg/L
<u>May</u> Chronic WLA:	Ce = ((9.3 + 0)2.2 - (0 * 0.01)) / 9.3 Ce = 2.2
Acute WLA:	Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3 Ce = 12.1
AML = WLAc = 2 MDL = WLAa = 2	2.2 mg/L 12.1 mg/L
Julv	
Chronic WLA:	Ce = ((9.3 + 0)1.5 - (0 * 0.01)) / 9.3 Ce = 1.5
Acute WLA:	Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3 Ce = 12.1
AML = WLAc = MDL = WLAa =	1.5 mg/L 12.1 mg/L
September	
Chronic WLA:	Ce = ((9.3 + 0)1.8 - (0 * 0.01)) / 9.3 Ce = 1.8
Acute WLA:	Ce = ((9.3 + 0)12.1 – (0 * 0.01)) / 9.3 Ce = 12.1
AML = WLAc = MDL = WLAa =	1.8 mg/L 12.1 mg/L
November	
Chronic WLA:	Ce = ((9.3 + 0)3.1 – (0 * 0.01)) / 9.3 Ce = 3.1
Acute WLA:	Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3 Ce = 12.1
AML = WLAc = 3 MDL = WLAa = 3	3.1 mg/L 12.1 mg/L

February Chronic WLA: Ce = ((9.3 + 0)2.7 - (0 * 0.01)) / 9.3Ce = 2.7 Acute WLA: Ce = ((9.3 + 0)10.1 - (0 * 0.01)) / 9.3Ce = 10.1AML = WLAc = 2.7 mg/LMDL = WLAa = 10.1 mg/L<u>April</u> $Ce = \left((9.3 + 0)2.7 - (0 * 0.01) \right) / 9.3$ Chronic WLA: Ce = 2.7Acute WLA: Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3Ce = 12.1AML = WLAc = 2.7 mg/LMDL = WLAa = 12.1 mg/LJune Chronic WLA: Ce = ((9.3 + 0)1.7 - (0 * 0.01)) / 9.3Ce = 1.7Acute WLA: Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3Ce = 12.1AML = WLAc = 1.7 mg/LMDL = WLAa = 12.1 mg/LAugust Chronic WLA: Ce = ((9.3 + 0)1.3 - (0 * 0.01)) / 9.3Ce = 1.3Acute WLA: Ce = ((9.3 + 0)10.1 - (0 * 0.01)) / 9.3Ce = 10.1AML = WLAc = 1.3 mg/LMDL = WLAa = 10.1 mg/LOctober Chronic WLA: Ce = ((9.3 + 0)2.5 - (0 * 0.01)) / 9.3Ce = 2.5Acute WLA: Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3Ce = 12.1AML = WLAc = 2.5 mg/LMDL = WLAa = 12.1 mg/L**December** Chronic WLA: Ce = ((9.3 + 0)3.1 - (0 * 0.01)) / 9.3Ce = 3.1Acute WLA: Ce = ((9.3 + 0)12.1 - (0 * 0.01)) / 9.3Ce = 12.1

AML = WLAc = 3.1 mg/LMDL = WLAa = 12.1 mg/L

- <u>Oil & Grease</u>. During the drafting of this permit, the permit writer reviewed DMR data submitted by the permittee. Additionally, no evidence of an excursion of the water quality standard has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of the water quality standard. As a result, monitoring requirements have been included in this permit to determine if the discharge has the reasonable potential to cause or contribute to an excursion of the water quality standard. Be the reasonable potential to cause or contribute to an excursion of the water quality standard. Data will be reviewed at renewal to reassess this determination.
- <u>Total Kjeldahl Nitrogen & Nitrate + Nitrite</u>. Effluent monitoring for Total Kjeldahl Nitrogen and Nitrate + Nitrite are required per 10 CSR 20-7.015(9)(D)8.
- <u>pH</u>. 6.5-9.0 SU. pH limitations of 6.0-9.0 SU [10 CSR 20-7.015] are not protective of the in-stream Water Quality Standard, which states that water contaminants shall not cause pH to be outside the range of 6.5-9.0 SU.

Dissolved Oxygen

PARAMETER	2022 QUAL2K WLAs				
	Daily Minimum	Monthly Average Minimum			
Dissolved Oxygen	7.0	7.0			

Green cells are final effluent limits (Table A-3)

- **Dissolved Oxygen (Table A-1)**. Monitoring only requirements were included in Table A-1 and Table A-2 and will be in effect until the final limits in Table A-3 becomes effective.
- Dissolved Oxygen (Table A-3). The 2022 QUAL2K required that for water quality standards to be attained at specified wasteload allocations, Monett's WWTP effluent should be maintained to no less than 7.0 mg/L dissolved oxygen. See APPENDIX: 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2.
- <u>Cyanide, Amenable to Chlorination</u>. Protection of Aquatic Life CCC = $5.2 \mu g/L$, CMC = $22 \mu g/L$, Background CN = $0 \mu g/L$. The Department has determined the current acceptable ML of Cyanide Amenable to Chlorination to be $10 \mu g/L$ when using SM 4500-CN-G.

Acute AQL: 22 µg/L Chronic AQL: 5.2 µg/L

Acute WLA: Ce = ((9.283 cfs + 0 cfs) * 22 - (0 cfs * 0 background)) / 9.283 cfs = 22Chronic WLA: Ce = ((9.283 cfs + 0 cfs) * 5.2 - (0 cfs * 0 background)) / 9.283 cfs = 5.2

LTAa: WLAa * LTAa multiplier = 22 * 0.172 = 3.785 [CV: 1.213, 99th percentile] LTAc: WLAc * LTAc multiplier = 5.2 * 0.318 = 1.655 [CV: 1.213, 99th percentile]

Use most protective LTA: 1.655

Daily Maximum: MDL = LTA * MDL multiplier = $1.655 * 5.812 = 9.6 \mu g/L$ [CV: 1.213, 99th percentile] Monthly Average: AML = LTA * AML multiplier = $1.655 * 2.147 = 3.6 \mu g/L$ [CV: 1.213, 95th percentile, n=4]

- <u>Biochemical Oxygen Demand (BOD₅) Percent Removal</u>. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for BOD₅.
- <u>Total Suspended Solids (TSS) Percent Removal</u>. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for TSS.
 - <u>Total Hardness</u>. Monitoring only requirement as the metals parameters contained in the permit are hardness based. This data will be used in the next permit renewal.
- Total Nitrogen (Tables A-1 & A-2). Effluent monitoring for Total Nitrogen is required per 10 CSR 20-6.010(8)(B).

• <u>Total Phosphorus (Table A-3)</u>. The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tribal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Therefore the Department has determined that the summer effluent limit provided in the 2022 QUAL2K model will be applied as a daily maximum load (MDL). Due to the long term effects of nutrients on streams, an Annual Total Limit (ATL) with a Monthly Total monitoring only requirement has been applied. The effluent limit was obtained from the 2022 QUAL2K Model. See APPENDIX - 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2:

MDL = 1.0 mg/L x 8.34 x 6 MGD = 50.04 lbs/day ATL = MDL x 365 days ATL = 50.04 lbs/day x 365 days = **18,265 lbs.**

• <u>Total Nitrogen</u>. The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tribal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Therefore the Department has determined that the summer effluent limit provided in the 2022 QUAL2K model will be applied as a daily maximum load (MDL). Due to the long term effects of nutrients on streams, an Annual Total Limit (ATL) with a Monthly Total monitoring only requirement has been applied. The effluent limit was obtained from the 2022 OUAL2K Model. See APPENDIX - 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2:

MDL = 21.5 mg/L x 8.34 x 6 MGD = 1,075.86 lbs/day ATL = MDL x 365 days **ATL** = 1,075.86 lbs/day x 365 days = **392,689 lbs.**

Metals

Effluent limitations for total recoverable metals were developed using methods and procedures outlined in the "Technical Support Document for Water Quality-based Toxic Controls" (EPA/505/2-90-001) and "The Metals Translator: Guidance For Calculating a Total Recoverable Permit Limit from a Dissolved Criterion" (EPA 823-B-96-007). General warm-water fishery criteria apply. Downstream water hardness of 142 mg/L is used in the calculation below. This value represents the 50th percentile (median) for all sample data submitted to the Department by the facility in compliance with the In-stream monitoring requirements of the operating permit.

Due to the absence of contemporaneous effluent and instream data for total recoverable metals, dissolved metals, hardness, and total suspended solids with which to calculate metals translators, partitioning between the dissolved and absorbed phases was assumed to be minimal (Section 5.7.3, EPA/505/2-90-001). Freshwater criteria conversion factors for dissolved metals were used as the metals translator as recommended in guidance (Section 1.3, 1.5.3, and Table 1, EPA 823-B-96-007). If concurrent site-specific data for total recoverable metals, dissolved metals, hardness, and total suspended solids are provided to the Department, partitioning evaluations may be considered and site-specific translators developed.

METAL	CONVERSION FACTORS				
METAL	Acute	CHRONIC			
Lead	0.74	0.74			

Conversion factors for Pb are hardness dependent. Values calculated using equation found in Section 1.3 of EPA 823-B-96-007 and hardness = 142 mg/L.

• Lead, Total Recoverable. Protection of Aquatic Life Acute Criteria = 94.357 µg/L, Chronic Criteria = 3.679 µg/L.

Acute AQL: $e^{(1.0166 * \ln 142 - 3.062490) * (1.136672 - \ln 142 * 0.041838) = 94.357 \mu g/L}$ [at hardness 142] Chronic AQL: $e^{(0.7977 * \ln 142 - 3.909) * (1.101672 - \ln 142*0.041938) = 3.679 \mu g/L}$ [at hardness 142]

TR Conversion: AQL/Translator = 94.357 / 0.74 = 127.526 [at hardness 142] TR Conversion: AQL/Translator = 3.679 / 0.74 = 4.973 [at hardness 142]

Acute WLA: Ce = ((9.283 cfs + 0 cfs) * 127.526 - (0 cfs * 0 background)) / 9.283 cfs = 127.526Chronic WLA: Ce = ((9.283 cfs + 0 cfs) * 4.973 - (0 cfs * 0 background)) / 9.283 cfs = 4.973

LTAa: WLAa * LTAa multiplier = 127.526 * 0.278 = 35.497 [CV: 0.708, 99th percentile] LTAc: WLAc * LTAc multiplier = 4.973 * 0.477 = 2.373 [CV: 0.708, 99th percentile]

Use most protective LTA: 2.373

Daily Maximum: MDL = LTA * MDL multiplier = $2.373 * 3.593 = 8.5 \mu g/L$ [CV: 0.708, 99th percentile] Monthly Average: AML = LTA * AML multiplier = $2.373 * 1.658 = 3.9 \mu g/L$ [CV: 0.708, 95th percentile, n=4]

- <u>Cadmium, Total Recoverable</u>. Monitoring only requirements have been included in this permit. An RPA was conducted based on the current WQS and determined that there is no reasonable potential to violate the water quality standard for Cadmium, please see **Appendix RPA Results.** This determination will be reassessed at the time of renewal.
- <u>Selenium, Total Recoverable</u>. Monitoring only requirements have been included in this permit. An RPA was conducted based on the current WQS and determined that there is no reasonable potential to violate the water quality standard for Selenium, please see **Appendix RPA Results.** This determination will be reassessed at the time of renewal.
- <u>Beryllium, Total Recoverable</u>. Monitoring only requirements have been included in this permit. Monitoring only requirements have been included in this permit as the facility's expanded effluent test results for Beryllium contained one result that was a detection above the minimum detection limit for the test, but the result was less than the Water Quality Standard. The lone data point is such that the permit writer is concerned that a reasonable potential to violate Water Quality Standards for Beryllium may exist. The data collected during this permit cycle will allow the permit writer to calculate/determine whether a reasonable potential to violate Water Quality Standards exists. This determination will be reassessed at the time of renewal.

Sampling Frequency Justification: The Department has determined that previously established sampling and reporting frequency is sufficient to characterize the facility's effluent and be protective of water quality, except for flow, which was increased to daily, and Total Phosphorus, Total Nitrogen, Total Kjeldahl Nitrogen, and Nitrate + Nitrite which were increased to weekly. The increases in sampling were due to the requirements for Total Phosphorus and Total Nitrogen. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)7.A.

Sampling Type Justification: As per 10 CSR 20-7.015, samples collected for mechanical plants shall be a 24 hour composite sample. Grab samples, however, must be collected for pH, *E. coli*, Oil & Grease, Dissolved Oxygen, and Cyanide, in accordance with recommended analytical methods. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

PERMITTED FEATURE INF – INFLUENT MONITORING

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

CHANGES TO INFLUENT MONITORING:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
BOD ₅ (Interim)	mg/L	1			*	*	1/month	monthly	С
CBOD ₅ (Final)	mg/L	1			*	***	1/month	monthly	С
TSS	mg/L	1			*	*	1/week	monthly	С
Ammonia as N	mg/L	1	*		*	***	1/month	monthly	С
Total Phosphorus	mg/L	1	*		*	***	1/month	monthly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	***	1/month	monthly	С
Nitrate + Nitrite	mg/L	1	*		*	***	1/month	monthly	С
* - Monitoring requirement only.									

* - Monitoring requirement only.

*** - Parameter not previously established in previous state operating permit.

Basis for Limitations Codes:

- 1. State or Federal Regulation/Law
- Water Quality Standard (includes RPA) 2.
- 3. Water Quality Based Effluent Limits
- 4 Antidegradation Review
- 5. Antidegradation Policy
- 6. Water Quality Model
- Best Professional Judgment
 TMDL or Permit in lieu of TMDL

Influent Parameters

- Biochemical Oxygen Demand (BOD₅), Carbonaceous Biochemical Oxygen Demand (CBOD₅), and Total Suspended Solids (TSS). An influent sample is required to determine the removal efficiency. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅, CBOD₅, and TSS for Publicly Owned Treatment Works (POTWs)/municipals.
- Total Phosphorus, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Ammonia. Influent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Ammonia required per 10 CSR 20-7.015(9)(D)8.

Sampling Frequency Justification: The sampling and reporting frequencies for Total Phosphorus and Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Ammonia parameters were established to provide adequate data for the Department to review. The sampling and reporting frequencies for influent BOD₅ and CBOD₅ were established to provide adequate data for the determination of percent removal requirements. The sampling and reporting frequency for influent TSS were established match the influent sampling requirements found in 10 CSR 20-9.010(5)(B)2.

Sampling Type Justification: Sample types for influent parameters were established to match the required sampling type of these parameters in the effluent. Samples should be analyzed as soon as possible after collection and/or properly preserved according to method requirements.

PERMITTED FEATURE 003 – IRRIGATION

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

- E. coli. 126#/100mL Daily Maximum in accordance with 10 CSR 20-8.200(6)(F).
- Irrigation Period. Monitoring requirement only. Monitoring for the Irrigation Period is included to determine if proper irrigation is occurring on the irrigation fields.
- Volume Irrigated. Monitoring requirement only. Monitoring for the Volume Irrigated is included to determine if proper irrigation is occurring on the irrigation fields.
- Irrigation Area. Monitoring requirement only. Monitoring for the Irrigation Area is included to determine if proper irrigation is occurring on the irrigation fields.

-	C =	Compos
	G =	Grab

- M = Measured/calculated
- 9 WET Test Policy
- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

• <u>Irrigation Rate</u>. Monitoring requirement only. Monitoring for the Irrigation Rate is included to determine if proper irrigation is occurring on the irrigation fields.

Sampling Frequency Justification:

Sampling frequency has been determined by the permit writer to be appropriate for irrigation systems, and the frequency for *E. coli* was retained from the previous state operating permit.

Sampling Type Justification:

Due to the discharge being from irrigation, a grab sample is a representative and appropriate sample type.

OUTFALL #001 – GENERAL CRITERIA CONSIDERATIONS:

In accordance with 40 CFR 122.44(d)(1), effluent limitations shall be placed into the permit for those pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The rule further states that pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above a narrative criterion within an applicable State water quality standard, the permit shall contain a numeric effluent limitation to protect that narrative criterion. In order to comply with this regulation, the permit writer will complete reasonable potential determinations on whether the discharge will violate any of the general criteria listed in 10 CSR 20-7.031(4). These specific requirements are listed below followed by derivation and discussion (the lettering matches that of the rule itself, under 10 CSR 20-7.031(4)). It should also be noted that Section 644.076.1, RSMo as well as Section D – Administrative Requirements of Standard Conditions Part I of this permit states that it shall be unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri that is in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law or any standard, rule or regulation promulgated by the commission.

- (A) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses. The discharge from this facility is made up of treated domestic wastewater. Based upon review of the Report of Compliance Inspection for the inspection conducted on August 7 and 8, 2019, no evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, this facility utilizes tertiary treatment technology and is currently in compliance with effluent limits that are more stringent than the secondary treatment technology based effluent limits established in 40 CFR 133 and there has been no indication to the Department that the stream has had issues maintaining beneficial uses as a result of this discharge. Based on the information reviewed during the drafting of this permit, these final effluent limitations appear to have protected against the excursion of this criterion.
- (B) <u>Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses</u>. Please see (A) above as justification is the same.
- (C) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (D) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life. This permit contains final effluent limitations which are protective of both acute and chronic toxicity for various pollutants that are either expected to be discharged by domestic wastewater facilities or that were disclosed by this facility on the application for permit coverage. Based on the information reviewed during the drafting of this permit, it has been determined if the facility meets final effluent limitations established in this permit, there is no reasonable potential for the discharge to cause an excursion of this criterion.
- (E) <u>Waters shall provide for the attainment and maintenance of water quality standards downstream including waters of another state</u>. Please see (D) above as justification is the same.
- (F) <u>There shall be no significant human health hazard from incidental contact with the water</u>. Please see (D) above as justification is the same.
- (G) There shall be no acute toxicity to livestock or wildlife watering. Please see (D) above as justification is the same.
- (H) <u>Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community</u>. Please see (A) above as justification is the same.
- (I) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247. The discharge from this facility is made up of treated domestic wastewater. No evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, any solid wastes received or produced at this facility are wholly contained in appropriate storage facilities, are not discharged, and are disposed of offsite. This discharge is subject to Standard Conditions Part III, which contains requirements for the management and disposal of sludge to prevent its discharge. Therefore, this discharge does not have reasonable potential to cause or contribute to an excursion of this criterion.

Part III – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream, and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

✓ The facility discharges to a Losing Stream as defined by [10 CSR 20-2.010(40)] & [10 CSR 20-7.031(1)(O)], and is an existing facility. The facility underwent an alternative evaluation during the approval of construction which determined alternative options to be unacceptable for environmental and/or economic reasons.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(o); 40 CFR Part 122.44(1)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- Limitations in this operating permit for the reissuance of this permit conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 CFR Part 122.44.
 - Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.
 - Oil and Grease. The permit writer conducted a reasonable potential determination using new DMR data. The previous permit had final effluent limits of 15 mg/L as a daily maximum and 10 mg/L as a monthly average. During the drafting of this permit, the permit writer reviewed DMR data submitted by the permittee. Additionally, no evidence of an excursion of the water quality standard has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of the water quality standard. Therefore, the permit writer has made a determination that the discharge does not have the reasonable potential to cause or contribute to an excursion of this permit and added monitoring only requirements. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (new DMR data). This new information justifies the application of a less stringent effluent limitation at the time of permit issuance. Also, the removal of the effluent limit and addition of a monitoring only requirement also meets the requirements of the safety clause, as the revision will not result in a violation of a water quality standard.
 - <u>Total Recoverable Aluminum, Copper, Iron, and Zinc</u>. A reasonable potential analysis for Aluminum, Copper, Iron, and Zinc was calculated using new DMR data and new instream hardness data. As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standards for Aluminum, Copper, Iron, and Zinc in the receiving stream, and these parameters were removed from the permit. Please see **Appendix RPA Results** for more information. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (new DMR data and new instream hardness data). This new information justifies the removal of the monitoring requirements at the time of permit issuance. Also, the removal of the monitoring requirements of the safety clause, as the removal of the monitoring requirements will not result in a violation of a water quality standard.
 - Total Recoverable Cadmium and Selenium. A reasonable potential analysis was calculated for Cadmium and Selenium using new DMR data and instream hardness data. As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standard for Cadmium and Selenium in the receiving stream. Therefore final effluent limits for Cadmium and Selenium have been removed and monitoring only is required to collect data over the permit cycle so this determination can be reassessed during the next renewal. Please see Appendix RPA Results for more information. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (new DMR data and new instream hardness data). This new information justifies the application of a less stringent effluent limitation at the time of permit issuance. Also, the revision of the effluent limit also meets the requirements of the safety clause, as the revision of the effluent limit will not result in a violation of a water quality standard.

- <u>Cyanide</u>. Effluent limitations were re-calculated for Cyanide using new DMR data. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (new DMR data). This new information justifies the application of a less stringent effluent limitation at the time of permit issuance. Also, the revision of the effluent limit also meets the requirements of the safety clause, as the revision of the effluent limit will not result in a violation of a water quality standard. Cyanide concentration and load have increased as a result of how water quality standards are calculated. The receiving stream, Clear Creek, is not impaired for metal contributions and has sufficient assimilative capacity to handle the increase concentration and load into the stream. See APPENDIX: ASSIMILATIVE CAPACITY CALCULATIONS.
- <u>Cadmium and Selenium Sampling and Reporting Frequency</u>. Sampling and reporting frequencies for Cadmium and Selenium were reduced from monthly to quarterly. Discharge monitoring data submitted by the permittee shows that operations at the facility have been consistent and have low variability. Therefore, the Department has found the permittee eligible for reduced monitoring frequencies. The reduction of the sampling and reporting frequencies of the parameter meets the requirements of the safety clause, as the removal will not result in a violation of a water quality standard.
- <u>Acute Whole Effluent Toxicity (WET) test</u>. The previous permit included requirements to conduct an Acute WET test once per year. The permit writer conducted a reasonable potential determination for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists. Also, the facility has passed previous Acute WET tests. The permit writer determined the facility does not have reasonable potential to exceed narrative water quality standards for acute toxicity at this time and the Acute WET testing requirements have been removed from this permit. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (previous passing WET tests). This new information justifies the removal of the test at the time of permit issuance. Also, the removal of the test also meets the requirements of the safety clause, as the removal will not result in a violation of a water quality standard.
- <u>Chronic Whole Effluent Toxicity (WET) test</u>. The previous permit included requirements to conduct a Chronic WET test once during the permit cycle. The permit writer conducted a reasonable potential determination for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists. Also, the facility has passed a previous Chronic WET test. The permit writer determined the facility does not have reasonable potential to exceed narrative water quality standards for chronic toxicity at this time and the Chronic WET testing requirements have been removed from this permit. This backsliding is justified as there is information available which was not available at the time of the previous permit issuance (previous passing WET tests). This new information justifies the removal of the test at the time of permit issuance. Also, the removal of the test also meets the requirements of the safety clause, as the removal will not result in a violation of a water quality standard.
- <u>Instream Total Phosphorus and Total Nitrogen Monitoring</u>. The previous permit contained upstream instream monitoring requirements for Total Phosphorus and Total Nitrogen. The Department has made a determination that monitoring of background nutrients is not needed. This permit is still protective of water quality and this determination will be reassessed at the time of renewal.
- The Department determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
 - <u>General Criteria</u>. The previous permit contained a special condition which described a specific set of prohibitions related to general criteria found in 10 CSR 20-7.031(4). In order to comply with 40 CFR 122.44(d)(1), the permit writer has conducted reasonable potential determinations for each general criterion and established numeric effluent limitations where reasonable potential exists. While the removal of the previous permit special condition creates the appearance of backsliding, since this permit establishes numeric limitations where reasonable potential to cause or contribute to an excursion of the general criteria exists the permit maintains sufficient effluent limitations and monitoring requirements in order to protect water quality, this permit is equally protective as compared to the previous permit. Therefore, given this new information, and the fact that the previous permit special condition of the previous permit. Please see Part II Effluent Limitations and Monitoring Requirements for more information regarding the reasonable potential determinations for each general criteria exists.
 - The previous permit indicated "There Shall Be No Discharge of Floating Solids or Visible Foam in Other Than Trace Amounts" under each table. The statement was not evaluated against actual site conditions therefore, this general criteria was re-assessed. It was determined that this facility does not discharge solids or foam in amounts which would indicate reasonable potential, therefore the statement was removed. Each general criteria was assessed for this facility.

ANTIDEGRADATION:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See https://dnr.mo.gov/document-search/antidegradation-implementation-procedure.

✓ No degradation was proposed in this permit action and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

For stormwater discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

✓ The facility stormwater outfalls onsite have no industrial exposure.

AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(2)(C)], an applicant may utilize a lower preference continuing authority when a higher level authority is available by submitting information as part of the application to the Department for review and approval, provided it does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

Permittee is authorized to land apply biosolids in accordance with Standard Conditions III. If other methods to remove and dispose (landfill, haul to another permitted treatment facility, etc.) of sludge/biosolids are needed and that method is not listed in the current permit, the permittee must modify the operating permit to add any biosolids/sludge disposal method to the facility description of the operating permit. For time sensitive situations, the permittee may contact the Department to see about approval for a one-time removal and disposal of sludge/biosolids that are not identified in the facility description of the operating permit.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

Facility Performance History:

✓ The facility is not currently under Water Protection Program enforcement action. This facility was last inspected on August 7 and 7, 2019. The inspection showed the following unsatisfactory features: failure to meet effluent limits for Ammonia, failure to submit annual I&I and sludge reports by the due dates, nor were they submitted using the eDMR system, and failure to operate and maintain the facility (failed intermediate pump and out of service mixer of the anaerobic/anoxic basins. In an October 11, 2019 letter to the City of Monett, the Department returned the facility to compliance.
CONTINUING AUTHORITY:

Each application for an operating permit shall identify the person, as that term is defined in section 644.016(15), RSMo, that is the owner of, operator of, or area-wide management authority for a water contaminant source, point source, wastewater treatment facility, or sewer collection system. This person shall be designated as the continuing authority and shall sign the application. By doing so, the person designated as the continuing authority for compliance with all permit conditions.

10 CSR 20-6.010(2) establishes preferential levels for continuing authorities: Levels 1 through 5 (with Level 1 as the highest level), and generally requires permits to be issued to a higher preference continuing authority if available. A Level 3, 4, or 5 applicant may constitute a continuing authority by showing that Level 1 and Level 2 authorities are not available; do not have jurisdiction; are forbidden by state statute or local ordinance from providing service to the person; or that the Level 3, 4, or 5 applicant has met one of the requirements listed in paragraphs (2)(C)1.–7. of 10 CSR 20-6.010(2). The seven options in paragraphs (2)(C)1.–7. for a lower-level authority to demonstrate that it is the valid continuing authority are:

- 1. A waiver from the existing higher authority declining the offer to accept management of the additional wastewater or stormwater;
- 2. A written statement or a demonstration of non-response from the higher authority;
- 3. A to-scale map showing all parts of the legal boundary of the facility's property are beyond 2000 feet from the collection (sewer) system operated by the higher preference authority;
- 4. A proposed connection or adoption charge by the higher authority that would equal or exceed what is economically feasible for the applicant, which may be in the range of one hundred twenty percent (120%) of the applicant's cost for constructing or operating a wastewater treatment system;
- 5. A proposed service fee on the users of the system by the higher authority that is above what is affordable for existing homeowners in that area;
- 6. Terms for connection or adoption by the higher authority that would require more than two (2) years to achieve full sewer service; or
- 7. A demonstration that the terms for connection or adoption by the higher authority are not viable or feasible to homeowners in the area.

Permit applicants that are Levels 3, 4, and 5 must, as part of their application, identify their method of compliance with this regulation. The following are the methods to comply.

- No higher level authorities are available to the facility;
- No higher level authorities have jurisdiction;
- Higher level authorities are forbidden by state statute or local ordinance from providing service to the person;
- The existing higher level authority is available to the facility, however the facility has proposed the use of a lower preference continuing authority and has submitted one of the following as part of their application provided it does not conflict with any area-wide management plan approved under section 208 of the Clean Water Act or by the Missouri Clean Water Commission. (See Fact Sheet Appendix Continuing Authority for more information on these options):
 - A waiver from the existing higher authority;
 - A written statement or a demonstration of non-response from the higher authority;
 - A to-scale map showing all parts of the legal boundary of the facility's property are beyond 2000 feet from the collection (sewer) system operated by the higher preference authority;
 - Documentation that the proposed connection or adoption charge by the higher authority would equal or exceed what is economically feasible for the applicant, which may be in the range of one hundred twenty percent (120%) of the applicant's cost for constructing or operating a wastewater treatment system;
 - Documentation that the proposed service fee on the users of the system by the higher authority is above what is affordable for existing homeowners in that area;
 - Documentation that the terms for connection or adoption by the higher authority would require more than two (2) years to achieve full sewer service;
 - A demonstration that the terms for connection or adoption by the higher authority are not viable or feasible to homeowners in the area;
- ✓ The continuing authority listed on the application is a municipality, and therefore a Level 3 Authority. There is no approved Clean Water Act Section 208 plan in Barry County. The applicant has shown that:
 - A higher level authority is not available to the facility.

ELECTRONIC DISCHARGE MONITORING REPORT (EDMR) SUBMISSION SYSTEM:

The U.S. Environmental Protection Agency (EPA) promulgated a final rule on October 22, 2015, to modernize Clean Water Act reporting for municipalities, industries, and other facilities by converting to an electronic data reporting system. This final rule requires regulated entities and state and federal regulators to use information technology to electronically report data required by the National Pollutant Discharge Elimination System (NPDES) permit program instead of filing paper reports. To comply with the federal rule, the Department is requiring all permittees to begin submitting discharge monitoring data and reports online. In an effort to aid facilities in the reporting of applicable information electronically, the Department has created several new forms including operational control monitoring forms and an I&I location and reduction form. These forms are optional and can be provided upon request to the Department.

Per 40 CFR 127.15 and 127.24, permitted facilities may request a temporary waiver for up to 5 years or a permanent waiver from electronic reporting from the Department. To obtain an electronic reporting waiver, a permittee must first submit an eDMR Waiver Request Form: <u>https://dnr.mo.gov/document-search/electronic-discharge-monitoring-report-waiver-request-form-mo-780-2692</u>. Each facility must make a request. If a single entity owns or operates more than one facility, then the entity must submit a separate request for each facility based on its specific circumstances. An approved waiver is non-transferable.

The Department must review and notify the facility within 120 calendar days of receipt if the waiver request has been approved or rejected [40 CFR 124.27(a)]. During the Department review period as well as after a waiver is granted, the facility must continue submitting a hard-copy of any reports required by their permit. The Department will enter data submitted in hard-copy from those facilities allowed to do so and electronically submit the data to the EPA on behalf of the facility.

✓ The permittee/facility is currently using the eDMR data reporting system.

FEES:

It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).

NUMERIC LAKE NUTRIENT CRITERIA:

✓ This facility does not discharge into a lake watershed where numeric lake nutrient criteria are applicable.

OPERATOR CERTIFICATION REQUIREMENTS:

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], the permittee shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.020(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems with population equivalents greater than 200 and are owned or operated by or for municipalities, public sewer districts, counties, public water supply districts, private sewer companies regulated by the Public Service Commission and state or federal agencies.

✓ This facility is required to have a certified operator as it has a population equivalent greater than 200 and is owned or operated by or for a municipality, public sewer district, county, public water supply district, private sewer company regulated by the PSC, state or federal agency.

This facility currently requires a chief operator with an (\underline{A}) Certification Level. Please see **Appendix - Classification Worksheet**. Modifications made to the wastewater treatment facility may cause the classification to be modified.

Operator's Name:	Owen W. Baker
Certification Number:	10690
Certification Level:	WW-A

The listing of the operator above only signifies that staff drafting this operating permit have reviewed appropriate Department records and determined that the name listed on the operating permit application has the correct and applicable Certification Level.

OPERATIONAL CONTROL TESTING:

Missouri Clean Water Commission regulation 10 CSR 20-9.010 requires certain publicly owned treatment works and privately owned facilities regulated by the Public Service Commission to conduct internal operational control monitoring to further ensure proper operation of the facility and to be a safeguard or early warning for potential plant upsets that could affect effluent quality. This requirement is only applicable if the publicly owned treatment works and privately owned facilities regulated by the Public Service Commission has a calculated Population Equivalent greater than two hundred (200).

10 CSR 20-9.010(3) allows the Department to modify the monitoring frequency required in the rule based upon the Department's judgement of monitoring needs for process control at the specified facility.

- ✓ As per [10 CSR 20-9.010(4))], the facility is required to conduct operational monitoring. These operational monitoring reports are to be submitted to the Department along with the MSOP discharge monitoring reports.
 - The facility is a mechanical plant and is required to conduct operational control monitoring as follows:

Operational Monitoring Parameter	Frequency
Precipitation	Daily (M-F)
Flow – Influent or Effluent	Daily (M-F)
pH – Influent	Daily (M-F)
Temperature (Aeration basin)	Daily (M-F)
TSS – Influent	Weekly
TSS – Mixed Liquor	Weekly
Settleability – Mixed Liquor	Daily (M-F)
Dissolved Oxygen – Mixed Liquor	Daily (M-F)
Temperature – Mixed Liquor (sample contact and reaeration basins for contact stabilization)	Daily (M-F)
Dissolved Oxygen – Aerobic Digester	Daily (M-F)

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users,
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation
- ✓ This permittee has an approved pretreatment program in accordance with the requirements of [40 CFR Part 403] and [10 CSR 20-6.100] and is expected to implement and enforce its approved program.

REASONABLE POTENTIAL (RP):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] and State Regulation [10 CSR 20-7.015(9)(A)2] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

A reasonable potential analysis (RPA) is a numeric RP decision calculated using effluent data provided by the facility for parameters that have a numeric Water Quality Standard (WQS).

Reasonable potential determinations (RPD) are based on physical conditions of the site as provided in Sections 3.1.2, 3.1.3, and 3.2 of the TSD using best professional judgement. An RPD consists of evaluating visual observations for compliance with narrative criteria, non-numeric information, or small amounts of numerical data (such as 3 data points supplied in the application). Narrative criteria with RP typically translate to a numeric WQS, so a parameter's establishment being based on narrative criteria does not necessarily make the decision an RPD vs RP—how the data is collected does, however. When insufficient data is received to make a determination on RP based on numeric effluent data, the RPD decisions are based on best professional judgment considering the sources of influent wastewater, type of treatment, and historical overall management of the site.

- ✓ An RPA was conducted on appropriate parameters. Please see APPENDIX RPA RESULTS.
- ✓ A RPD was made for Oil & Grease, that a potential to violate water quality standards does not exist. Please see Derivation and Discussion of Limits.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

✓ Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(12)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur. The permit also contains requirements for permittees to develop and implement a program for maintenance and repair of the collection system. The permit requires that the permittee submit an annual report to the Department for the previous calendar year that contains a summary of efforts taken by the permittee to locate and eliminate sources of excess I & I, a summary of general maintenance and repairs to the collection system, and a summary of any planned maintenance and repairs to the collection system.

✓ At this time, the Department recommends the US EPA's Guide for Evaluating Capacity, Management, Operation and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems (Document # EPA 305-B-05-002) or the Departments' CMOM Model located at <u>https://dnr.mo.gov/document-search/capacity-management-operations-maintenance-plan-editabletemplate</u>. For additional information regarding the Departments' CMOM Model, see the CMOM Plan Model Guidance document at <u>https://dnr.mo.gov/print/document-search/pub2574</u>. The CMOM identifies some of the criteria used to evaluate a collection system's management, operation, and maintenance and was intended for use by the EPA, state, regulated community, and/or third party entities. The CMOM is applicable to small, medium, and large systems; both public and privately owned; and both regional and satellite collection systems. The CMOM does not substitute for the Clean Water Act, the Missouri Clean Water Law, and both federal and state regulations, as it is not a regulation.

SCHEDULE OF COMPLIANCE (SOC):

Per 644.051.7 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

A SOC is not allowed:

• For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 CFR § 125.3.

- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study that may result in site-specific criteria or alternative effluent limits. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOCs, and attain a greater level of consistency, on April 9, 2015 the Department issued an updated policy on development of SOCs. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as a Cost Analysis for Compliance.

✓ The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(11)]. The facility has been given a schedule of compliance to meet final effluent limits for Ammonia, Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Dissolved Oxygen, Total Phosphorus, and Total Nitrogen. The approximately 9-year schedule of compliance allowed for this facility should provide adequate time to evaluate operations, obtain an engineering report, hold a bond election, obtain a construction permit and implement upgrades required to meet effluent limits. Due to the high economic burden on this community of the cost of compliance and associated difficulty in raising the necessary funding, the schedule has been established at approximately 9 years in accordance with the Department's "Schedule of Compliance, Policy for Staff Drafting Operating Permits". Please see the Cost Analysis for Compliance attached as an appendix to the permit for further detail on how the socio-economic status of the community has impacted this SOC.

The following suggested milestones can be used by the permittee as a timeline toward compliance with new permit requirements. Once the permit holder's engineer has completed facility design with actual costs associated with permit compliance, it may be necessary for the permit holder to request additional time within the schedule of compliance. The Department is committed to review all requests for additional time in the schedule of compliance where adequate justification is provided.

Year	Milestone(s)
2025	Submission of Facility Plan for Phase I, and pay on current debt
2026	Pay on current debt
2027	Construction Permit application and construction of Phase I, and pay on current debt
2028	Construction of Phase I, and pay on current debt
2029	Meet final limits for Ammonia and interim limits for TSS, and pay on current debt
2030	Submission of Facility Plan for Phase II and pay on current debt
2031	Construction Permit application and construction of Phase II, and pay on current debt
2032	Complete construction activities for Phase II, and pay on current debt
2033	Meet final limits and pay on current debt

Suggested Milestones during the approximate 9 Year Schedule of Compliance

SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM:

In accordance with [10 CSR 20-6.010(6)(A)], the Department may grant approval of a permittee's Sewer Extension Authority Supervised Program. These approved permittees regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility. The permittee shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. See <u>https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/wastewater/construction-engineering</u>.

✓ The permittee does not have a Department approved Sewer Extension Authority Supervised Program.

STORMWATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities: (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's <u>Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators</u>, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in June 2015], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 CFR 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and reevaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. For further guidance, consult the antidegradation implementation procedure (https://dnr.mo.gov/document-search/antidegradation-implementation-procedure).

The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why "no discharge" or "no exposure" is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure* (AIP), Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the Department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs. The request shall be submitted in the form of an operating permit modification; the application is found at: https://dnr.mo.gov/forms-applications.

The City of Monett submitted to the Department a No Exposure Certification for Exclusion from NPDES Stormwater Permitting on June 27, 2019. As a result of the submittal of the certification, the permittee is not required to develop and implement a SWPPP at this time. This exclusion will be reevaluated at the time of renewal or during a Department inspection.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

 \checkmark This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(86)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

✓ Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$Ce = \frac{(Qe + Qs)C - (Qs \times Cs)}{(Qe)}$$
 (EPA/505/2-90-001, Section 4.5.5)

Where C = downstream concentration Cs = upstream concentration Qs = upstream flow Ce = effluent concentration Qe = effluent flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

Number of Samples "n":

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of "n" for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for "n" must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is "n = 4" at a minimum. For Total Ammonia as Nitrogen, "n = 30" is used.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

✓ WLA modeling was conducted by the Department. Department staff developed a QUAL2K model for the receiving stream.

WHOLE EFFLUENT TOXICITY (WET) TEST:

✓ At this time, the permittee is not required to conduct WET test for this facility. The previous permit included requirements to conduct an Acute WET test once per year and a Chronic WET test once per permit cycle. The facility passed the previous Acute and Chronic WET tests. The permit writer also conducted a reasonable potential determination for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists.

40 CFR 122.41(M) - BYPASSES:

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from "bypassing" untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 CFR 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 CFR 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 CFR 122.41(l)(6) and per Missouri's Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

 \checkmark This facility does not anticipate bypassing.

Part IV - Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

✓ The Department is required to determine "findings of affordability" because the permit applies to a combined or separate sanitary sewer system for a publicly-owned treatment works.

Cost Analysis for Compliance - The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

The following table summarizes the results of the cost analysis. See **Appendix – Cost Analysis for Compliance** for detailed information.

Dummary Tuble Col	st marysis for compr	lance Dammary for th	it only of monete			
Annual Median Household Income (MHI)	Estimated Monthly User Rate	Residential Indicator (User Rate as a Percent of MHI)	Financial Capability Indicator	Financial Burden	Schedule of Compliance Length	
\$42,628	\$124.35	3.5%	1.67	High Burden	~9 years	
Pollution Control Option Selected for Analysis: Modifications to the existing treatment plant, including denitrification after the oxidation ditch, upgrading the filters, adding two Total Phosphorus removal locations, and adding intermediate pumping						
Estimated Present Worth: \$56,651,550						

Summary Table. Cost Analysis for Compliance Summary for the City of Monett

Part V – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

WATER QUALITY STANDARD REVISION:

In accordance with section 644.058, RSMo, the Department is required to utilize an evaluation of the environmental and economic impacts of modifications to water quality standards of twenty-five percent or more when making individual site-specific permit decisions.

✓ This operating permit contains a permit requirement for Lead which water quality criteria has been modified by twenty-five percent or more since the issuance of the previous permit. The approval of these changes by the EPA is environmentally necessary to ensure the criteria are reflective of the most current science available while protecting the water quality standards of the receiving stream without placing needless and overly burdensome requirements on regulated entities. The "Evaluation of Environmental and Economic Impacts of Revised Water Quality Standards and Criteria on a Subbasin Basis" report is available upon request to the Department.

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

✓ The Public Notice period for this operating permit was from March 15, 2024 to April 15, 2024. No responses received.

DATE OF FACT SHEET: APRIL 29, 2024

COMPLETED BY:

BRANT FARRIS, ENVIRONMENTAL PROGRAM SPECIALIST MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT (660) 385-8019 brant.farris@dnr.mo.gov

Appendices

APPENDIX - CLASSIFICATION WORKSHEET:

Item	Points Possible	Points Assigned
Maximum Population Equivalent (P.E.) served , peak day	1 pt./10,000 PE or major fraction	7
Design Flow (avg. day) or peak month's flow (avg. day) whichever is larger	1 pt. / MGD or major fraction thereof. (Max 10 pts.)	6
Effluent Discharge	· · · · · · ·	
Missouri or Mississippi River	0	
All other stream discharges except to losing streams and stream	1	
Discharge to lake or reservoir outside of designated whole body contact recreational area	2	
Discharge to losing stream, lake or reservoir area supporting whole body contact recreation	3	3
Direct reuse or recycle of effluent	6	
Land Application/Irriga	tion	
Drip Irrigation	3	
Land application/irrigation	5	5
Overland flow	4	
Variation in Raw Wastes (higher	st level only)	
Variations do not exceed those normally or typically expected	0	
Reoccurring deviations or excessive variations of 100 to 200 percent in strength and/or flow	2	
Reoccurring deviations or excessive variations of more than 200 percent in strength and/or flow	4	
Department-approved pretreatment program	6	6
Preliminary Treatment	nt	
STEP systems (operated by the permittee)	3	
Screening and/or comminution	3	3
Grit removal	3	3
Plant pumping of main flow	3	3
Flow equalization	5	5
Primary Treatment		
Primary clarifiers	5	5
Chemical addition (except chlorine, enzymes)	4	
Secondary Treatmen	t	
Trickling filter and other fixed film media with or without secondary	10	10
Activated sludge (including aeration, oxidation ditches, sequencing batch reactors, membrane bioreactors, and contact stabilization)	15	15
Stabilization ponds without aeration	5	
Aerated lagoon	8	
Advanced Lagoon Treatment – Aerobic cells, anaerobic cells, covers, or fixed film	10	
Biological, physical, or chemical	12	12
Carbon regeneration	4	
Total from page ONE (1)		83

APPENDIX - CLASSIFICATION WORKSHEET ((CONTINUED):
---------------------------------------	--------------

Ітем	POINTS POSSIBLE	POINTS ASSIGNED
Solids Handling		
Sludge Holding	5	
Anaerobic digestion	10	
Aerobic digestion	6	6
Evaporative sludge drying	2	2
Mechanical dewatering	8	8
Solids reduction (incineration, wet oxidation)	12	
Land application	6	6
Disinfection		
Chlorination or comparable	5	
On-site generation of disinfectant (except UV light)	5	
Dechlorination	2	
UV light	4	4
Required Laboratory Control Performed by Plant	Personnel (highest level only)	
Lab work done outside the plant	0	
Push – button or visual methods for simple test such as pH, settleable solids	3	
Additional procedures such as DO, COD, BOD, titrations, solids, volatile content	5	
More advanced determinations, such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc.	7	7
Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph	10	
Total from page TWO (2)		33
Total from page ONE (1)		83
Grand Total		116

A: 71 points and greater
B: 51 points – 70 points
C: 26 points – 50 points
D: 0 points – 25 points

APPENDIX – RPA RESULTS:

Parameter	CMC*	RWC Acute*	CCC*	RWC Chronic*	n**	Range max/min	CV***	MF	RP Yes/No
Ammonia as N – Summer (mg/L)	12.1	50.49	1.5	50.49	29	10.8/0.05	1.82	4.67	YES
Ammonia as N – Winter (mg/L)	12.1	29.68	2.9	29.68	30	7.2/0.1	1.60	4.12	YES
Aluminum, TR (µg/L)	750.00	388.78	n/a	388.78	19	176/0.1	0.55	2.21	No
Cadmium, TR (µg/L)	7.21	0.24	1.05	0.24	59	0.5/0.15	0.45	0.49	No
Copper, TR (µg/L)	155.79	18.97	100.71	18.97	59	11/0.1	0.85	1.72	No
Cyanide (µg/L)	22.00	52.90	5.20	52.90	59	47/0.25	1.21	1.13	Yes
Iron, TR (µg/L)	n/a	121.63	1000	121.63	19	67.3/16.6	0.40	1.81	No
Lead, TR (µg/L)	127.53	10.69	4.97	10.69	19	5/0.55	0.71	2.14	Yes
Selenium, TR (µg/L)	n/a	4.67	5.00	4.67	59	6/1.1	0.28	0.78	No
Zinc, TR (µg/L)	161.60	126.83	160.29	126.83	19	65.9/2.9	0.45	1.92	No

N/A - Not Applicable

* - Units are $(\mu g/L)$ unless otherwise noted.

** - If the number of samples is 10 or greater, then the CV value must be used in the WQBEL for the applicable constituent. If the number of samples is < 10, then the default CV value must be used in the WQBEL for the applicable constituent.

*** - Coefficient of Variation (CV) is calculated by dividing the Standard Deviation of the sample set by the Mean of the same sample set.

RWC – Receiving Water Concentration. It is the concentration of a toxicant or the parameter toxicity in the receiving water after mixing (if applicable).

n - Is the number of samples.

MF - Multiplying Factor. 99% Confidence Level and 99% Probability Basis.

RP – Reasonable Potential. It is where an effluent is projected or calculated to cause an excursion above a water quality standard based on a number of factors including, as a minimum, the four factors listed in 40 CFR 122.44(d)(1)(ii).

Reasonable Potential Analysis is conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request.

APPENDIX – Non-Detect Example Calculations:

Example: Permittee has four samples for Pollutant X which has a method minimum level of 5 mg/L and is to report a Daily Maximum and Monthly Average.

Week 1 = 11.4 mg/L Week 2 = Non-Detect or <5.0 mg/L Week 3 = 7.1 mg/L Week 4 = Non-Detect or <5.0 mg/L

For this example, use subpart (h) - For reporting an average based on a mix of detected and non-detected values (not including *E. coli*), assign a value of "0" for all non-detects for that reporting period and report the average of all the results.

```
11.4 + 0 + 7.1 + 0 = 18.5 \div 4 (number of samples) = 4.63 mg/L.
```

The Permittee reports a Monthly Average of 4.63 mg/L and a Daily maximum of 11.4 mg/L (Note the < symbol was dropped in the answers).

Example: Permittee has five samples for Pollutant Y that has a method minimum level of $9 \mu g/L$ and is to report a Daily Maximum and Monthly Average.

Day 1 = Non-Detect or $<9.0 \ \mu g/L$ Day 2 = Non-Detect or $<9.0 \ \mu g/L$ Day 3 = Non-Detect or $<9.0 \ \mu g/L$ Day 4 = Non-Detect or $<9.0 \ \mu g/L$ Day 5 = Non-Detect or $<9.0 \ \mu g/L$

For this example, use subpart (g) - For reporting an average based on all non-detected values, remove the "<" sign from the values, average the values, and then add the "<" symbol back to the resulting average.

 $(9 + 9 + 9 + 9 + 9) \div 5$ (number of samples) = $<9 \mu g/L$.

The Permittee reports a Monthly Average of <9.0 µg/L (retain the 'less than' symbol) and a Daily Maximum of <9.0 µg/L.

Example: Permittee has four samples for Pollutant Z where the first two tests were conducted using a method with a method minimum level of 4 μ g/L and the remaining two tests were conducted using a different method that has a method minimum level of <6 μ g/L and is to report a Monthly Average and a Weekly Average.

Week 1 = Non-Detect or $<4.0 \ \mu g/L$ Week 2 = Non-Detect or $<4.0 \ \mu g/L$ Week 3 = Non-Detect or $<6.0 \ \mu g/L$ Week 4 = Non-Detect or $<6.0 \ \mu g/L$

For this example, use subpart (g) - For reporting an average based on all non-detected values, remove the "<" sign from the values, average the values, and then add the "<" symbol back to the resulting average.

 $(4 + 4 + 6 + 6) \div 4$ (number of samples) = $<5 \mu g/L$. (Monthly)

The facility reports a Monthly Average of $<5.0 \ \mu g/L$ and a Weekly Average of $<6.0 \ \mu g/L$.

APPENDIX – Non-Detect Example Calculations (Continued):

Example: Permittee has five samples for Pollutant Z where the first two tests were conducted using a method with a method minimum level of 4 μ g/L and the remaining three tests were conducted using a different method that has a method minimum level of <6 μ g/L and is to report a Monthly Average and a Weekly Average.

Week 1 = Non-Detect or $<4.0 \ \mu g/L$ Week 2 = Non-Detect or $<4.0 \ \mu g/L$ Week 2 = Non-Detect or $<6.0 \ \mu g/L$ Week 3 = Non-Detect or $<6.0 \ \mu g/L$ Week 4 = Non-Detect or $<6.0 \ \mu g/L$

For this example, use subpart (g) - For reporting an average based on all non-detected values, remove the "<" sign from the values, average the values, and then add the "<" symbol back to the resulting average.

 $(4 + 4 + 6 + 6 + 6) \div 5$ (number of samples) = $<5.2 \ \mu$ g/L. (Monthly) $(4 + 6) \div 2$ (number of samples) = $<5 \ \mu$ g/L. (Week 2)

The facility reports a Monthly Average of <5.2 µg/L and a Weekly Average of <6.0 µg/L (report highest Weekly Average value)

Example: Permittee has four samples for Pollutant Z where the tests were conducted using a method with a method minimum level of 10 μ g/L and is to report a Monthly Average and Daily Maximum. The permit lists that Pollutant Z has a Department determined Minimum Quantification Level (ML) of 130 μ g/L.

Week 1 = 12 μ g/L Week 2 = 52 μ g/L Week 3 = Non-Detect or <10 μ g/L Week 4 = 133 μ g/L

For this example, use subpart (h) - For reporting an average based on a mix of detected and non-detected values (not including *E. coli*), assign a value of "0" for all non-detects for that reporting period and report the average of all the results.

For this example, $(12 + 52 + 0 + 133) \div 4$ (number of samples) = $197 \div 4 = 49.3 \mu g/L$.

The facility reports a Monthly Average of 49.3 µg/L and a Daily Maximum of 133 µg/L.

Example: Permittee has five samples for *E. coli* which has a method minimum level of 1 #/100mL and is to report a Weekly Average (seven (7) day geometric mean) and a Monthly Average (thirty (30) day geometric mean).

Week 1 = 102 #/100mL Week 2 (Monday) = 400 #/100mL Week 2 (Friday) = Non-Detect or <1 #/100mL Week 3 = 15 #/100mL Week 4 = Non-Detect or <1 #/100mL

For this example, use subpart (i) - When E. coli is not detected above the method minimum level, the permittee must report the data qualifier signifying less than detection limit for that parameter (e.g., <1 #/100mL, if the method minimum level is 1 #/100mL). For reporting a geometric mean based on a mix of detected and non-detected values, use one-half of the detection limit (instead of zero) for non-detects when calculating geometric means. The Geometric Mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected.

The Monthly Average (30 day Geometric Mean) = 5th root of (102)(400)(0.5)(15)(0.5) = 5th root of 153,000 = 10.9 #/100mL. The 7 day Geometric Mean = 2nd root of (400)(0.5) = 2nd root of 200 = 14.1 #/100mL. (Week 2)

The Permittee reports a Monthly Average (30 day Geometric Mean) of 10.9 #/100mL and a Weekly Average (7 day geometric mean) of 102 #/100mL (report highest Weekly Average value)

APPENDIX - PROCESS FLOW DIAGRAM:

.

.



FORM B-2 ITEM 7.1 PROCESS FLOW DIAGRAM W/ PLANT LOADINGS

\\Arnce-fs\projects\Monett MO\City of Monett\Wastewater\\WWTP Operating Permit\JobFile\2017\Monett WWTF Process Flaw Diag..docx

APPENDIX - PLANT LAYOUT AND FLOW DIAGRAM:



APPENDIX – 1999 TMDL SECTION 5

5. Wasteload Allocation (WLA)

The wasteload allocation of the single point source is the loading capacity minus the load allocation minus the margin of safety minus the load allocation reserved for future growth. The allocation reserved for future growth is zero. The wasteload allocations for the Monett WWTP are:

(loading capacity) - (margin of safety) - (load allocation) - (held in reserve) = wasteload allocation

Suspended Solids (discharge from the pipe): (924 lb/da) - (462 lb/da) - (0) - (0) = 462 pounds per day suspended solids year round

CBOD (discharge from the pipe):

Spring Summer Fall:

(154 lb/da) - (15.4 lb/da) - (0) - (0) = 138.6 pounds per day CBOD Winter:

(308 lb/da) - (30.8 lb/da) - (0) - (0) = 277.2 pounds per day CBOD

Ammonia as N (discharge from the pipe):

Spring Fall:

(123 lb/da) - (12.3 lb/da) - (0) - (0) = 110.7 pounds per day NH₃ as N Summer: (86 lb/da) - (8.6 lb/da) - (0) - (0) = 77.4 pounds per day NH₃ as N Winter: (117 lb/da) - 11.7 lb/da) - (0) - (0) = 105.3 pounds per day NH₃ as N

Summarizing, 462 pounds per day of suspended solids is allocated to the Monett WWTP discharge before the mixing zone. The CBOD allocations to the discharge before the mixing zone are 138.6 pounds per day for spring, summer, and fall, and 277.2 pounds per day for winter. The ammonia N allocations to the discharge before the mixing zone are 110.7 pounds per day for spring and fall, 77.4 pounds per day for summer, and 105.3 pounds per day for winter.

If monitoring data indicates that applicable water quality standards are not being met, these TMDLs will be reopened and these allocations will be re-evaluated.

APPENDIX – 2022 QUAL2K PERMIT IMPLEMENTATION GUIDANCE TABLE 2:

		Final Effluent Limitations			
Effluent Parameter	Units	Daily Max	Weekly Avg	Monthly Avg	
BOD5	mg/L		7.5	5.0	
CBOD5	mg/L		5.9	3.9	
TSS	mg/L		22.5	15	
Ammonia as N					
January	mg/L	4.2		2.1	
February	mg/L	4.2		2.1	
March	mg/L	4.2		2.1	
April	mg/L	2.8		1.4	
May	mg/L	2.8		1.4	
June	mg/L	2.8		1.4	
July	mg/L	2.8		1.4	
August	mg/L	2.6		1.3	
September	mg/L	2.8		1.4	
October	mg/L	4.2		2.1	
November	mg/L	4.2		2.1	
December	mg/L	4.2		2.1	
Total Phosphorus	mg/L	*		1.0	
Total Nitrogen					
Summer	mg/L	*		21.5	
Winter	mg/L	*		22.2	
Effluent Parameter	Units	Daily Minimum		Daily Average Maximum	
Dissolved Oxygen	mg/L	7.0		7.0	

Table 2. 2022 Effluent Limits for the Monett Wastewater Treatment Facility

APPENDIX: ASSIMILATIVE CAPACITY CALCULATIONS.

Facility Assimilative Capacity (FAC) = $(C_c * (Q_s + Q_d) - (EWQ * Q_s)) * CF$

 C_c = Chronic Criterion (mg/L) Q_s = stream flow (7Q10 or other representative flow) in cubic feet per second (cfs) Q_d = average daily design flow of discharge in cfs EWQ = Existing Water Quality (mg/L) CF = conversion factor to convert a pollutant mass loading into the desired units.

Discharge Load = $Q_d x C_d x CF$ C_d = Effluent Concentration (mg/L)

Cyanide

Facility Assimilative Capacity (FAC) = $(C_c * (Q_s + Q_d) - (EWQ * Q_s)) * CF$ $C_c = 5.2 \ \mu g/L = 0.0052 \ mg/L$ $Q_d = 9.3 \ cfs$ $EWQ = 0 \ mg/L$ CF = 5.4FAC = $(0.0052 * (0 + 9.3) - (0 * 0)) * 5.4 = 0.26114 \ lbs/day$

Discharge Load = $Q_d \ge C_d \ge C_F$ $Q_d = 9.3 \text{ cfs}$ $C_d = 0.0036 \text{ mg/L}$ CF = 5.4Discharge load = (9.3 $\ge 0.0036 \ge 5.4$) = 0.181 lbs/day

Percent of FAC = (Discharge Load / FAC) x 100 Percent of FAC = $(0.181 / 0.26114) \times 100 = 69.3\%$ FAC remaining: 0.08014 lbs/day or 30.7%

APPENDIX – COST ANALYSIS FOR COMPLIANCE:

Missouri Department of Natural Resources Water Protection Program Cost Analysis for Compliance (In accordance with RSMo 644.145)

Monett WWTP, Permit Renewal City of Monett Missouri State Operating Permit #MO-0021440

Section 644.145 RSMo requires the Department of Natural Resources (Department) to make a "finding of affordability" when "issuing permits under" or "enforcing provisions of" state or federal clean water laws "pertaining to any portion of a combined or separate sanitary sewer system for publicly-owned treatment works." This cost analysis does not dictate that the permittee will upgrade their facility, or how the permittee will comply with new permit requirements. The results of this analysis are used to determine an adequate compliance schedule for the permit that may mitigate the financial burden of new permit requirements.

New Permit Requirements

The permit requires compliance with new effluent limitations for Ammonia, Carbonaceous Biochemical Oxygen Demand₅, Total Suspended Solids, Dissolved Oxygen, Total Phosphorus, and Total Nitrogen, which may require the design, construction, and operation of a different treatment technology. The cost assumptions in this analysis anticipate modifications to the existing treatment facility. For this analysis, the Department has selected the mechanical treatment technology that could be the most practical solution to meet the new requirements for the community.

The permit also requires compliance with new monitoring requirements for Outfall #001, which includes Total Kjeldahl Nitrogen (quarterly to weekly as part of the Total Nitrogen calculation), Nitrate + Nitrite (monthly to weekly as part of the Total Nitrogen calculation), Total Phosphorus (quarterly to weekly), and Beryllium (quarterly). The permit also requires compliance with new monitoring requirements for Permitted Feature INF, which includes monthly Ammonia, Total Phosphorus, Total Kjeldahl Nitrogen, and Nitrate + Nitrite.

Flow and Connections

The size of the facility evaluated for upgrades was chosen based on the permitted design flow. If significant population growth is expected in the community, or if a significant portion of the flow is due to inflow and infiltration, then the flows and resulting estimated costs used in a facility plan prepared by a consulting engineer may differ. The number of connections was reported by the permittee on the Financial Questionnaire.

Flow Evaluated: 6.0 million gallons per day					
Connection Type Number					
Residential	3.350				
Commercial	458				
Industrial	46				
Total 3,854					

Data Collection for this Analysis

This cost analysis is based on data available to the Department as provided by the permittee and data obtained from readily available sources. For the most accurate analysis, it is essential that the permittee provides the Department with current information about the City's financial and socioeconomic situation. The financial questionnaire available to permittees on the Department's website (<u>https://dnr.mo.gov/document-search/financial-questionnaire-mo-780-2511</u>) is a required attachment to the permit renewal application. If the financial questionnaire is not submitted with the renewal application, the Department sends a request to complete the form with the welcome correspondence. The City of Monett provided the department with an updated Financial Questionnaire on December 20, 2023. The Department has relied heavily on readily available data to complete this analysis. If certain data was not provided by the permittee to the Department and the data is not obtainable through readily available sources, this analysis will state that the information is "unknown".

The Department estimates the cost for reconstruction of a treatment plant using a software program from Hydromantis¹ titled CapdetWorks. CapdetWorks is a preliminary design and costing software program for wastewater treatment plants utilizing national indices, such as the Marshall and Swift Index and Engineering News Records Cost Index, to price the development of capital, operating, maintenance, material, and energy costs for various treatment technologies. The program works from national indices; therefore, estimated costs will vary from actual costs, as each community is unique in its budget commitments and treatment design.

Because the methods used to derive the analysis estimate costs that tend to be greater than actual costs associated with an upgrade, it reflects a conservative estimate anticipated for a community. The overestimation of costs is due to the fact that it is unknown by the Department what existing equipment and structures will be reused in the upgraded facility before an engineer completes a facility design. For questions associated with CapdetWorks, please contact the Department's Engineering Section at (573) 751-6621.

Eight Criteria of 644.145 RSMo

The Department must consider the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with new permit requirements.

(1) A community's financial capability and ability to raise or secure necessary funding;

Criterion 1 Table. Current Financial Information for the City of Monett					
Current Monthly User Rates per 5,000 gallons*	\$27.95				
Municipal Bond Rating (if applicable)	A+				
Bonding Capacity**	\$4,598,936				
Median Household Income (MHI) ²	\$42,628				
Current Annual Operating Costs (excludes depreciation)	\$3,275,000				
Current Outstanding Debt for the Facility	\$2,382,500				
Amount within the Current User Rate Used toward Payments on Outstanding Debt Related to the Current Wastewater Infrastructure	\$7.00				

* User Rates were reported by the permittee on the Financial Questionnaire.

** General Obligation Bond capacity allowed by constitution: Cities = up to 20% of taxable tangible property; Sewer districts or villages = up to 5% of taxable tangible property

(2) Affordability of pollution control options for the individuals or households at or below the median household income level of the community;

- Total Present Worth includes a five percent interest rate to construct and perform annual operation and maintenance of the new treatment plant over the term of the loan, which is 20 years for the mechanical plant option.
- Capital Cost includes design, construction, inspection, and contingency costs from CapdetWorks.
- Operation and maintenance (O&M) includes operations, maintenance, materials, chemical, and electrical costs for the facility on an annual basis. It includes items that are expected to be replaced during operations, such as pumps and is estimated between 15% and 45% of the user rate.
- Estimated user costs per 5,000 gallons per month are calculated using equations that account for debt retirement and annualized operation and maintenance costs over the life of the treatment facility. Estimated user costs are not added to the community's current user rate because they estimate total replacement of the facility.

The following table outlines the estimated costs of the new permit requirements:

Criterion 2A Table. Estimated Cost Breakdown of New Permit Requirements						
New Requirement	Frequency	Estimated Cost	Estimated Annual Cost			
Total Phosphorus – Influent	Monthly	\$26 x 12	\$312			
Total Kjeldahl Nitrogen - Influent	Monthly	\$35 x 12	\$420			
Nitrate + Nitrite - Influent	Monthly	\$44 x 12	\$528			
Ammonia - Influent	Monthly	\$22 x 12	\$264			
Total Phosphorus – Effluent	Weekly £	\$26 x 48	\$1,248			
Total Kjeldahl Nitrogen - Effluent	Weekly £	\$35 x 48	\$1,680			
Nitrate + Nitrite - Effluent	Weekly β	\$44 x 40	\$1,760			
Total Recoverable Beryllium	Quarterly	\$22 x 4	\$88			
Total Estimated Annual Cost of New Sampling and Permit Requirements\$6,300						

 $\ensuremath{\mathfrak{L}}$ - previous permit required quarterly frequency

 β – previous permit required monthly frequency

Mechanical Plant Pollution Control Option Cost Estimates:

For the mechanical plant option, the Department has estimated costs for modifications to the existing treatment plant, including denitrification after the oxidation ditch, upgrading the filters, adding two Total Phosphorus removal locations, and adding intermediate pumping. Treatment technologies were selected that meet the following monthly average effluent limits:

- Total Phosphorus of less than 1 mg/L
- Total Nitrogen of less than 20 mg/L
- Carbonaceous Biochemical Oxygen Demand (CBOD₅) of less than 2 mg/L
- Total Suspended Solids (TSS) of less than 8 mg/L
- Post aeration DO equal to 7 mg/L

New sampling costs are also included in the following cost estimations.

Criterion 2B Table. Estimated Costs for Mechanical Plant Pollution Control Option				
(1)	Estimated Total Present Worth	\$56,651,550		
	Estimated Capital Cost	\$14,750,000		
	Estimated Annual Cost of Operation and Maintenance	\$3,112,500		
	Estimated Monthly Cost Per User	\$96.26		
	Estimated Monthly Cost of New Sampling and Permit Requirements Per User	\$0.14		
(2)	Current Monthly User Rate	\$27.95		
(3)	Total Monthly User Cost*	\$124.35		
	Total Monthly User Cost as a Percent of MHI ³	3.5%		

* Current User Rate + Estimated Monthly Costs + Estimated Monthly Costs of New Sampling and Permit Requirements

(3) An evaluation of the overall costs and environmental benefits of the control technologies;

An investment in wastewater treatment will provide several social, environmental, and economic benefits. Improved wastewater provides benefits such as avoided health costs due to water-related illness, enhanced environmental ecosystem quality, and improved natural resources. The preservation of natural resources has been proven to increase the economic value and sustainability of the surrounding communities. Maintaining Missouri's water quality standards fulfills the goal of restoring and maintaining the chemical, physical, and biological integrity of the receiving stream; and, where attainable, it achieves a level of water quality that provides for the protection and propagation of fish, shellfish, wildlife, and recreation in and on the water.

Nutrient Limits

Nutrients are mineral compounds that are required for organisms to grow and thrive. Of the six (6) elemental macronutrients, nitrogen and phosphorus are generally not readily available and limit growth of organisms. Excess nitrogen and phosphorus will cause a shift in the ecosystem's food web. Once excess nitrogen and phosphorus are introduced into a waterbody, some species' populations will dramatically increase, while other populations will not be able to sustain life. Competition and productivity are two factors in which nutrients can alter aquatic ecosystems and the designated uses of a waterbody. For example, designated uses, such as drinking water sources and recreational uses, become impaired when algal blooms take over a waterbody. These blooms can cause foul tastes and odors in the drinking water, unsightly appearance, and fish mortality in the waterbody. Some algae also produce toxins that may cause serious adverse health conditions such as liver damage, tumor promotion, paralysis, and kidney damage. The effluent limits for nitrogen and phosphorus have been added to the permit to protect the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

Metals Monitoring

Metals dissolve in water and are easily absorbed by fish and other aquatic organisms. Small concentrations can be toxic because metals undergo bioconcentration, which means that their concentration in an organism is higher than in water. Metal toxicity produces adverse biological effects on an organism's survival, activity, growth, metabolism, or reproduction. Metals can be lethal or harm the organism without killing it directly. Adverse effects on an organism's activity, growth, metabolism, and reproduction are examples of sub-lethal effects.

In order for a metal to be toxic, it needs to enter the body of the exposed organism and interact with the surface or interior of cells. The pathways by which this happens includes diffusion into the bloodstream via the gills and skin, as fish become exposed by drinking water or eating sediments contaminated with the metal, or eating other animals or plants that became exposed to the metal. Humans become exposed to metals via analogous pathways: diffusion into the bloodstream via the lungs and skin, drinking contaminated water, and eating contaminated food.

The monitoring requirements for metals have been added to the permit to provide data regarding the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

Metals Limits

Metals dissolve in water and are easily absorbed by fish and other aquatic organisms. Small concentrations can be toxic because metals undergo bioconcentration, which means that their concentration in an organism is higher than in water. Metal toxicity produces adverse biological effects on an organism's survival, activity, growth, metabolism, or reproduction. Metals can be lethal or harm the organism without killing it directly. Adverse effects on an organism's activity, growth, metabolism, and reproduction are examples of sub-lethal effects.

In order for a metal to be toxic, it needs to enter the body of the exposed organism and interact with the surface or interior of cells. The pathways by which this happens includes diffusion into the bloodstream via the gills and skin, as fish become exposed by drinking water or eating sediments contaminated with the metal, or eating other animals or plants that became exposed to the metal. Humans become exposed to metals via analogous pathways: diffusion into the bloodstream via the lungs and skin, drinking contaminated water, and eating contaminated food.

The effluent limits for metals have been added to the permit to protect the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

TMDL Limits

Effluent limits have been added or revised in the permit to protect the health of the receiving stream. These limits have been established based on the approved total maximum daily load (TMDL) for the receiving stream. The TMDL is the calculation of the maximum amount of a specific pollutant that a water body can absorb and still meet water quality standards. Missouri's water quality standards establish pollutant limits to protect drinking water supply, fishing, swimming, aquatic life and other designated uses. When waterbodies fail to meet the water quality standards, they are considered impaired waters. The federal Clean Water Act requires states to develop TMDLs for all waters on the 303(d) List of Impaired Waters. The calculated TMDL is allocated among the various pollutant sources in the watershed and becomes the goal to restore water quality. Each TMDL document includes allocations of the acceptable load for all pollutant sources. The portion of the load distributed to point sources (e.g., sewage treatment plants) is the wasteload allocation (WLA). Point source discharges are controlled by including water quality-based effluent limits (WQBEL) in permits issued to point source entities. WQBELs are calculated based on the WLAs in the TMDLs.

(4) Inclusion of ongoing costs of operating and maintaining the existing wastewater collection and treatment system, including payments on outstanding debts for wastewater collection and treatment systems when calculating projected rates:

The community reported that their outstanding debt for their current wastewater collection and treatment systems is \$2,385,500. The community reported that each user pays \$27.95 monthly, of which, \$7.00 is used toward payments on the current outstanding debt.

As shown in Criterion 2, the projected user rate plus the amount of the current user rate plus the cost for new sampling is \$124.35 for the mechanical treatment option.

(5) An inclusion of ways to reduce economic impacts on distressed populations in the community, including but not limited to low and fixed income populations. This requirement includes but is not limited to:

- (a) Allowing adequate time in implementation schedules to mitigate potential adverse impacts on distressed populations resulting from the costs of the improvements and taking into consideration local community economic considerations.
 - A schedule of compliance will be provided based on the results of this cost analysis. The schedule of compliance is provided to ensure that the entity has time to reasonably plan for compliance with the new permit requirements. The time provided ensures the entity has time to hire an engineer, develop facility plans, hold community meetings, seek an appropriate funding source, and construct the facility. If it is determined by the permittee that a longer schedule of compliance is necessary due to financial reasons, please contact the Department and request modification of the compliance schedule.
 - An integrated plan may be an appropriate option if the community needs to meet other environmental obligations as well as the new requirements within this permit. The integrated plan needs to be well thought out with specific timeframes built into the management plan in which the municipality can reasonably commit. The plan should be designed to allow the municipality to meet Clean Water Act obligations by maximizing infrastructure improvement dollars through the appropriate sequencing of work. For further information on how to develop an integrated plan, please see the Department publication, "Missouri Integrated Planning Framework," at https://dnr.mo.gov/document-search/missouri-integrated-planning-framework-pub2684.

- If the permittee can demonstrate that the proposed pollution controls result in substantial and widespread economic and social impact, they may use Factor 6 of the Use Attainability Analysis (UAA) 40 CFR 131.10(g)(6) in the form of a variance. This process is completed by determining the treatment type with the highest attainable effluent quality that would not result in a socio-economic hardship. For more information on variance requests, please visit the Department's water quality standards webpage at https://dnr.mo.gov/water/what-were-doing/water-planning/quality-standards-impaired-waters-total-maximum-daily-loads/standards/variances.
- (b) Allowing for reasonable accommodations for regulated entities when inflexible standards and fines would impose a disproportionate financial hardship in light of the environmental benefits to be gained.
 - An opportunity may exist for the relocation of the point of discharge to a different receiving stream.
 - The permittee may apply for State Revolving Fund (SRF) financial support in order to help fund a capital improvements plan. Other loans and grants also exist for which the facility may be eligible. More information can be found on the Department's FAC website at https://dnr.mo.gov/water/business-industry-other-entities/financial-opportunities/financial-assistance-center/wastewater.

The following table characterizes the current overall socioeconomic condition of the community as compared to the overall socioeconomic condition of Missouri. The following information was compiled using the latest U.S. Census data.

Criterion 5 Table. Socioeconomic Data ^{2, 4-8} for the City of Monett

No.	Administrative Unit	Monett City	Missouri State
1	Population (2021)	9,512	6,141,534
2	Percent Change in Population (2000-2021)	28.6%	9.8%
3	2021 Median Household Income (in 2022 Dollars)	\$42,628	\$65,928
4	Percent Change in Median Household Income (2000-2021)	-21.1%	-1.1%
5	Median Age (2021)	33.6	38.8
6	Change in Median Age in Years (2000-2021)	-1.8	2.7
7	Unemployment Rate (2021)	4.0%	4.5%
8	Percent of Population Below Poverty Level (2021)	15.9%	12.8%
9	Percent of Household Received Food Stamps (2021)	15.5%	10.1%
10	(Primary) County Where the Community Is Located	Barry County	

(6) An assessment of other community investments and operating costs relating to environmental improvements and public health protection;

The community did not report any other investments relating to environmental improvements.

(7) An assessment of factors set forth in the United States Environmental Protection Agency's guidance, including but not limited to the "Combined Sewer Overflow Guidance for Financial Capability Assessment and Schedule Development" that may ease the cost burdens of implementing wet weather control plans, including but not limited to small system considerations, the attainability of water quality standards, and the development of wet weather standards;

The table on the following page (Criterion 7A Table) characterizes the community's overall financial capability to raise the necessary funds to meet the new permit requirements.

Criterion 7A Table. Financial Capability Indicator

Indicators	Strong (3 points)	Mid-Range (2 points)	Weak (1 point)	Score
Bond Rating Indicator	Above BBB or Baa	BBB or Baa	Below BBB or Baa	3
Overall Net Debt as a % of Full Market Property Value	Below 2%	2% - 5%	Above 5%	1
Unemployment Rate (2021)	Beyond 1% below Missouri average of 4.5%	± 1% of Missouri average of 4.5%	Beyond 1% above Missouri average of 4.5%	2
2021 Median Household Income (in 2021 Dollars)	Beyond 25% above Missouri MHI (\$65,928)	± 25% of Missouri MHI (\$65,928)	Beyond 25% below Missouri MHI (\$65,928)	1
Percent of Population Below Poverty Level (2021)	Beyond 10% below Missouri average of 12.8%	± 10% of Missouri average of 12.8%	Beyond 10% above Missouri average of 12.8%	2
Percent of Household Received Food Stamps (2021)	Beyond 5% below Missouri average of 10.1%	± 5% of Missouri average of 10.1%	Beyond 5% above Missouri average of 10.1%	1
Property Tax Revenues as a % of Full Market Property Value	Below 2%	2% - 4%	Above 4%	NA £
Property Tax Collection Rate	Above 98%	94% - 98%	Below 94%	NA £
Total Average Score (Financial Capability Indicator)				1.67

£ - The City does not collect property taxes.

The **Financial Capability Indicator** and the **Residential Indicator** are considered jointly in the Financial Capability Matrix to determine the financial burden that could occur from compliance with the new requirements of the permit.

1 67

3.5

- Financial Capability Indicator (from Criterion 7):
 - Mechanical Plant Residential Indicator (from Criterion 2):

Criterion 7B Table. Financial Capability Matrix

Financial Canability	Residentia	% of MHI)	
Indicator	Low	Mid-Range	High
	(Below 1%)	(1.0% to 2.0%)	(Above 2.0%)
Weak (Below 1.5)	Medium Burden	High Burden	High Burden
Mid-Range (1.5 – 2.5)	Low Burden	Medium Burden	High Burden
Strong (Above 2.5)	Low Burden	Medium Burden	High Burden

Resulting Financial Burden for Mechanical Plant: High Burden

(8) An assessment of any other relevant local community economic conditions.

The City reported that \$1.39 million of the existing wastewater debt will be retired by February 2025.

The Department contracted with Wichita State University to complete an assessment tool that would allow for predictions on rural Missouri community populations and future sustainability. The purpose of the study is to use a statistical modeling analysis in order to determine factors associated with each rural Missouri community that would predict the future population changes that could occur in each community. A stepwise regression model was applied to 19 factors which were determined as predictors of rural population change in Missouri. The model established a hierarchy of the predicting factors which allowed the model to place a weighted value on each of the factors. A total of 745 rural towns and villages in Missouri received a weighted value for each of the predicting factors. The weighted values for each town / village were then added together to determine an overall decision score. The overall decision score. The categorical groups were developed from the range of overall scores across all rural towns and villages within Missouri.

Based on the assessment tool, the City of Monett has been determined to be a category 5 community. This means that the City of Monett is predicted to be stable over time.

Conclusion and Finding

As a result of new regulations, the Department is proposing modifications to the current operating permit that may require the permittee to upgrade the facility and construct new control technologies and to increase monitoring. The Department has considered the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with the new permit requirements.

The Department finds that a modification to the existing mechanical treatment facility is the most practical and affordable option for the City of Monett. The construction and operation of the modified mechanical treatment facility will ensure that the individuals within the community will not be required to make unreasonable sacrifices in their essential lifestyle or spending patterns or undergo hardships in order to make the projected monthly payments for sewer connections.

In accordance with 40 CFR 122.47(a)(1) and 10 CSR 20-7.031(11), compliance must occur as soon as possible; therefore, based on this analysis, the permit holder has received an approximate 9-year schedule of compliance for the design and construction of modifications to the existing treatment plant, including denitrification after the oxidation ditch, upgrading the filters, adding two Total Phosphorus removal locations, and adding intermediate pumping. The following suggested milestones can be used by the permittee as a timeline toward compliance with new permit requirements. Once the permit holder's engineer has completed facility design with actual costs associated with permit compliance, it may be necessary for the permit holder to request additional time within the schedule of compliance. The Department is committed to review all requests for additional time in the schedule of compliance where adequate justification is provided.

Suggested Milestones during the ~9 Year Schedule of Compliance

Year	Milestone(s)
2025	Submission of Facility Plan for Phase I, and pay on current debt
2026	Pay on current debt
2027	Construction Permit application and construction of Phase I, and pay on current debt
2028	Construction of Phase I, and pay on current debt
2029	Meet final limits for Ammonia and interim limits for TSS, and pay on current debt
2030	Submission of Facility Plan for Phase II and pay on current debt
2031	Construction Permit application and construction of Phase II, and pay on current debt
2032	Complete construction activities for Phase II, and pay on current debt
2033	Meet final limits and pay on current debt

The Department is committed to reassessing the cost analysis for compliance at renewal to determine if the initial schedule of compliance will accommodate the socioeconomic data and financial capability of the community at that time. Because each community is unique, the Department wants to make sure that each community has the opportunity to consider all options and tailor solutions to best meet their needs. The Department understands the economic challenges associated with achieving compliance, and is committed to using all available tools to make an accurate and practical finding of affordability for Missouri communities. If the community is interested in the funding options available to them, please contact the Financial Assistance Center for more information. https://dnr.mo.gov/water/business-industry-other-entities/financial-opportunities/financial-assistance-center/wastewater.

This determination is based on readily available data and may overestimate the financial impact on the community. The community's facility plan that is submitted as a part of the construction permit process includes a discussion of community details, what the community can afford, existing obligations, future growth potential, an evaluation of options available to the community with cost information, and a discussion on no-discharge alternatives. The cost information provided through the facility plan process, which is developed by the community and their engineer, is more comprehensive of the community's individual factors in relation to selected treatment technology and costing information.

References

- http://www.hydromantis.com/ 1.
- (A) 2021 MHI in 2021 Dollar: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B19013: 2. Median Household Income in the Past 12 Months (in 2021 Inflation-Adjusted Dollars). https://data.census.gov/cedsci/table?q=B19013&tid=ACSDT5Y2021.B19013. (B) 2000 MHI in 1999 Dollar: (1)For United States, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-1 Part 1. United States Summary, Table 5. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-27, Missouri, Table 10. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf. (C) 2022 CPI, 2021 CPI and 1999 CPI: U.S. Department of Labor Bureau of Labor Statistics (2022) Consumer Price Index - All Urban Consumers, U.S. City Average. All Items. 1982-84=100 (unadjusted) - CUUR0000SAO. https://data.bls.gov/cgi-bin/surveymost?bls. (D) 2021 MHI in 2022 Dollar = 2021 MHI in 2021 Dollar x 2022 CPI /2021 CPI; 2000 MHI in 2021 Dollar = 2000 MHI in 1999 Dollar x 2022 CPI /1999 CPI. (E) Percent Change in Median Household Income (2000-2021) = (2021 MHI in 2022 Dollar - 2000 MHI in 2022 Dollar) / (2000 MHI in 2022 Dollar).
- 3. (\$124.35/(\$42,628/12))100% = 3.5% (mechanical + existing rate + sampling)
- (A) Total Population in 2021: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B01003: Total 4 Population - Universe: Total Population. https://data.census.gov/cedsci/table?q=B01003&tid=ACSDT5Y2021.B01003. (B) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC. https://www2.census.gov/library/publications/2003/dec/phc-2-1-pt2.pdf. (C) Percent Change in Population (2000-2021) = (Total Population in 2021 - Total Population in 2000) / (Total Population in 2000). Median Age in 2021: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B01002: Median Age by 5. Sex - Universe: Total population. https://data.census.gov/cedsci/table?q=B01002&tid=ACSDT5Y2021.B01002. (B) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing
- Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC., Page 2. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC., Pages 64-92. https://www2.census.gov/library/publications/2003/dec/phc-2-1-pt2.pdf. (C) Change in Median Age in Years (2000-2021) = (Median Age in 2021 - Median Age in 2000).
- United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, S2301: Employment Status for the Population 16 6. Years and Over - Universe: Population 16 years and Over. https://data.census.gov/cedsci/table?q=unemployment&tid=ACSST5Y2021.S2301.
- 7. United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table S1701: Poverty Status in the Past 12 Months. https://data.census.gov/cedsci/table?g=S1701&tid=ACSST5Y2021.S1701.
- United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table S2201: Food Stamps/Supplemental Nutrition 8. Assistance Program (SNAP) - Universe: Households. https://data.census.gov/cedsci/table?q=S2201&tid=ACSST5Y2021.S2201.

APPENDIX – CapdetWorks Cost Estimate:

Modification to existing treatment plant- denitrification after O. ditch, upgrade filters, add 2-TP removal locations, intermediate pumping.

NOTE
Assumptions
Basic Data
Key Results

	Calculation Steps	Data and Result
Interest Rate	(1) or "i"	5%
Project Life (Years)	(2) or "n"	20
Capital Costs	(3)	\$14,750,000
Total Present Worth of Capital Costs	(4) = (3)	\$14,750,000
Annualization Factor	(5) = (i*(1+i)^n)/(1+i)^n-1)	0.0802
Annualized Capital Cost (Annual Debt Requirement for Capital Cost)	(6) = (3) × (5)	\$1,183,578
Annual Operating & Maintenance Costs	(7)	\$3,112,500
Total Present Worth of Operating & Maintenance Costs	(8) = (7) / (5)	\$38,788,630
Total Present Worth of Replacement Costs	(9)	\$3,112,920
Annual Replacement Costs	(10) = (9) / (2)	\$155,646
		•
Total Present Worth of All Costs	(11) = (4) + (8) + (14)	\$56,651,550
Total Annual Cost	(12) = (6) + (7) + (10)	\$4,451,724
Number of Users	(13)	3,854
Monthly User Cost	(14) = (12) / 12 / (13)	\$96.26



These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions

Section A - Sampling, Monitoring, and Recording

1. Sampling Requirements.

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.

2. Monitoring Requirements.

a.

- Records of monitoring information shall include:
- i. The date, exact place, and time of sampling or measurements;
- ii. The individual(s) who performed the sampling or measurements;
- iii. The date(s) analyses were performed;
- iv. The individual(s) who performed the analyses;
- v. The analytical techniques or methods used; and
- vi. The results of such analyses.
- b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
- 3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
- Test Procedures. The analytical and sampling methods used shall conform 4. to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is "sufficiently sensitive" when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility's discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
- 5. Record Retention. Except for records of monitoring information required by the permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

6. Illegal Activities.

- a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than (4) years, or both.
- b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B - Reporting Requirements

1. Planned Changes.

- The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
 - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
 - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.

2. Non-compliance Reporting.

a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
- c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
- 3. Anticipated Noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
- 4. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
- 5. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
- 6. **Other Information**. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

7. Discharge Monitoring Reports.

- a. Monitoring results shall be reported at the intervals specified in the permit.
- b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
- c. Monitoring results shall be reported to the Department no later than the 28^{th} day of the month following the end of the reporting period.

Section C - Bypass/Upset Requirements

1. Definitions.

- a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
- b. Severe Property Damage: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- c. *Upset:* an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

2. Bypass Requirements.

a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

- b. Notice.
 - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
 - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
- c. Prohibition of bypass.
 - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 - 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - 3. The permittee submitted notices as required under paragraph 2. b. of this section.
 - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.

3. Upset Requirements.

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B

 Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 iv. The permittee complied with any remedial measures required under
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

Section D - Administrative Requirements

- 1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- It is unlawful for any person to cause or permit any discharge of water d. contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

2. Duty to Reapply.

- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission

for applications to be submitted later than the expiration date of the existing permit.)

- c. A permittees with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- 3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- 4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
- 5. Proper Operation and Maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

6. Permit Actions.

- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
 - i. Violations of any terms or conditions of this permit or the law;ii. Having obtained this permit by misrepresentation or failure to
 - disclose fully any relevant facts;A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized
 - discharge; or
 - iv. Any reason set forth in the Law or Regulations.
- b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

7. Permit Transfer.

- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
- 8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- 9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.



- 10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
- 11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
 - Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.

12. Closure of Treatment Facilities.

- a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
- b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.

13. Signatory Requirement.

- a. All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
- b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
- c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
- 14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.



PART II - SPECIAL CONDITIONS – PUBLICLY OWNED TREATMENT WORKS SECTION A – INDUSTRIAL USERS

1. Definitions

Definitions as set forth in the Missouri Clean Water Laws and approved by the Missouri Clean Water Commission shall apply to terms used herein.

Significant Industrial User (SIU). Except as provided in the *General Pretreatment Regulation* 10 CSR 20-6.100, the term Significant Industrial User means:

- 1. All Industrial Users subject to Categorical Pretreatment Standards; and
- 2. Any other Industrial User that: discharges an average of 25,000 gallons per day or more of process wastewater to the Publicly-Owned Treatment Works (POTW) (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's or for violating any Pretreatment Standard or requirement.

Clean Water Act (CWA) is the the federal Clean Water Act of 1972, 33 U.S.C. § 1251 et seq. (2002).

2. Identification of Industrial Discharges

Pursuant to 40 CFR 122.44(j)(1), all POTWs shall identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR 403.

3. Application Information

Applications for renewal or modification of this permit must contain the information about industrial discharges to the POTW pursuant to 40 CFR 122.21(j)(6)

4. Notice to the Department

Pursuant to 40 CFR 122.42(b), all POTWs must provide adequate notice of the following:

- Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging these pollutants; and
- 2. Any substantial change into the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- 3. For purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

For POTWs without an approved pretreatment program, the notice of industrial discharges which was not included in the permit application shall be made as soon as practicable. For POTWs with an approved pretreatment program, notice is to be included in the annual pretreatment report required in the special conditions of this permit. Notice may be sent to:

> Missouri Department of Natural Resources Water Protection Program Attn: Pretreatment Coordinator P.O. Box 176 Jefferson City, MO 65102

PART III - BIOSOLIDS AND SLUDGE FROM DOMESTIC TREATMENT FACILITIES

SECTION A - GENERAL REQUIREMENTS

- PART III Standard Conditions pertain to biosolids and sludge requirements under the Missouri Clean Water Law and regulations for domestic and municipal wastewater and also incorporates federal sludge disposal requirements under 40 CFR Part 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR Part 503 for domestic biosolids and sludge.
- 2. PART III Standard Conditions apply only to biosolids and sludge generated at domestic wastewater treatment facilities, including public owned treatment works (POTW) and privately owned facilities.
- 3. Biosolids and Sludge Use and Disposal Practices:
 - a. The permittee is authorized to operate the biosolids and sludge generating, treatment, storage, use, and disposal facilities listed in the facility description of this permit.
 - b. The permittee shall not exceed the design sludge/biosolids volume listed in the facility description and shall not use biosolids or sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
 - c. For facilities operating under general operating permits that incorporate Standard Conditions PART III, the facility is authorized to operate the biosolids and sludge generating, treatment, storage, use and disposal facilities identified in the original operating permit application, subsequent renewal applications or subsequent written approval by the department.
- 4. Biosolids or Sludge Received from other Facilities:
 - a. Permittees may accept domestic wastewater biosolids or sludge from other facilities as long as the permittee's design sludge capacity is not exceeded and the treatment facility performance is not impaired.
 - b. The permittee shall obtain a signed statement from the biosolids or sludge generator or hauler that certifies the type and source of the sludge
- 5. Nothing in this permit precludes the initiation of legal action under local laws, except to the extent local laws are preempted by state law.
- 6. This permit does not preclude the enforcement of other applicable environmental regulations such as odor emissions under the Missouri Air Pollution Control Lawand regulations.
- This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable biosolids or sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
- 8. In addition to Standard Conditions PARTIII, the Department may include biosolids and sludge limitations in the special conditions portion or other sections of a site specific permit.
- 9. Exceptions to Standard Conditions PARTIII may be authorized on a case-by-case basis by the Department, as follows:
 - a. The Department may modify a site-specific permit following permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR § 124.10, and 40 CFR § 501.15(a)(2)(ix)(E).
 - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR Part 503.

SECTION B - DEFINITIONS

- 1. Best Management Practices are practices to prevent or reduce the pollution of waters of the state and include agronomic loading rates (nitrogen based), soil conservation practices, spill prevention and maintenance procedures and other site restrictions.
- 2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
- 3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food, feed or fiber. The facility includes any structures necessary to store the biosolids untilsoil, weather, and crop conditions are favorable for land application.
- 4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR Part 503.
- 5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with 40 CFR Part 503.
- 6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
- 7. Feed crops are crops produced primarily for consumption by animals.
- 8. Fiber crops are crops such as flax and cotton.
- 9. Food crops are crops consumed by humans which include, but is not limted to, fruits, vegetables and tobacco.
- 10. Industrial wastewater means any wastewater, also known as process wastewater, not defined as domestic wastewater. Per 40 CFR Part 122.2, process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product. Land application of industrial wastewater, residuals or sludge is not authorized by Standard Conditions PART III.
- 11. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological contact systems, and other similar facilities. It does not include wastewater treatment lagoons or constructed wetlands for wastewater treatment.
- 12. Plant Available Nitrogen (PAN) is nitrogen that will be available to plants during the growing seasons after biosolids application.
- 13. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
- 14. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs), sewage sludge incinerator ash, or grit/screenings generated during preliminary treatment of domestic sewage.
- 15. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen or concrete lined basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
- 16. Septage is the sludge pumped from residential septic tanks, cesspools, portable toilets, Type III marine sanitation devices, or similar treatment works such as sludge holding structures from residential wastewater treatment facilities with design populations of less than 150 people. Septage does not include grease removed from grease traps at a restaurant or material removed from septic tanks and other similar treatment works that have received industrial wastewater. The standard for biosolids from septage is different from other sludges. See Section H for more information.

SECTION C-MECHANICAL WASTEWATER TREATMENT FACILITIES

- 1. Biosolids or sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and the requirements of Standard Conditions PART III or in accordance with Section A.3.c., above.
- The permittee shall operate storage and treatment facilities, as defined by Section 644.016(23), RSMo, so that there is no biosolids or sludge discharged to waters of the state. Agricultural storm water discharges are exempt under the provisions of Section 644.059, RSMo.
- 3. Mechanical treatment plants shall have separate biosolids or sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove biosolids or sludge from these storage compartments on the required design schedule is a violation of this permit.

SECTION D - BIOSOLIDS OR SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR BY CONTRACT HAULER

- 1. Permittees that use contract haulers, under the authority of their operating permit, to dispose of biosolids or sludge, are responsible for compliance with all the terms of this permit. Contract haulers that assume the responsibility of the final disposal of biosolids or sludge, including biosolids land application, must obtain a Missouri State Operating Permit unless the hauler transports the biosolids or sludge to another permitted treatment facility.
- 2. Testing of biosolids or sludge, other than total solids content, is not required if biosolids or sludge are hauled to a permitted wastewater treatment facility, unless it is required by the accepting facility.

SECTION E- INCINERATION OF SLUDGE

- Please be aware that sludge incineration facilities may be subject to the requirements of 40 CFR Part 503 Subpart E, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or, if the ash is determined to be hazardous, with 10 CSR 25.
- 3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, mass of sludge incinerated and mass of ash generated. Permittee shall also provide the name of the ash disposal facility and permit number if applicable.

$Section\,F-Surface\,Disposal\,Sites\,and\,Biosolids\,and\,Sludge\,Lagoons$

- Please be aware that surface disposal sites of biosolids or sludge from wastewater treatment facilities may be subject to other laws including the requirements in 40 CFR Part 503 Subpart C, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Biosolids or sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain biosolids or sludge storage lagoons as storage facilities, accumulated biosolids or sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of biosolids or sludge removed will be dependent on biosolids or sludge generation and accumulation in the facility. Enough biosolids or sludge must be removed to maintain adequate storage capacity in the facility.
 - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of biosolids or sludge on the bottom of the lagoon, upon prior approval of the Department; or
 - b. Permittee shall close the lagoon in accordance with Section I.

SECTION G - LAND APPLICATION OF BIOSOLIDS

- 1. The permittee shall not land apply biosolids unless land application is authorized in the facility description, the special conditions of the issued NPDES permit, or in accordance with Section A.3.c., above.
- 2. This permit only authorizes "Class A" or "Class B" biosolids derived from domestic wastewater to be land applied onto grass land, crop land, timber, or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
- 3. Class A Biosolids Requirements: Biosolids shall meet Class A requirements for application to public contact sites, residential lawns, home gardens or sold and/or given away in a bag or other container.
- 4. Class B biosolids that are land applied to agricultural and public contact sites shall comply with the following restrictions:
 - a. Food crops that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
 - b. Food crops below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for four months or longer prior to incorporation into the soil.
 - c. Food crops below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than four months prior to incorporation into the soil.
 - d. Animal grazing shall not be allowed for 30 days after application of biosolids.
 - e. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
 - f. Turf shall not be harvested for one year after application of biosolids if used for lawns or high public contact sites in close proximity to populated areas such as city parks or golf courses.
 - g. After Class B biosolids have been land applied to public contact sites with high potential for public exposure, as defined in 40 CFR § 503.31, such as city parks or golf courses, access must be restricted for 12 months.
 - h. After Class B biosolids have been land applied public contact sites with low potential for public exposure as defined in 40 CFR § 503.31, such as a rural land application or reclamation sites, access must be restricted for 30 days.
- 5. Pollutant limits
 - a. Biosolids shall be monitored to determine the quality for regulated pollutants listed in Table 1, below. Limits for any pollutants not listed below may be established in the permit.
 - b. The number of samples taken is directly related to the amount of biosolids or sludge produced by the facility (See Section J, below). Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to achieve pollutant concentration below those identified in Table 1, below.
 - c. Table 1 gives the ceiling concentration for biosolids. Biosolids which exceed the concentrations in Table 1 may not be land applied.
TABLE 1

Biosolids ceiling concentration					
Pollutant	Milligrams per kilogram dry weight				
Arsenic	75				
Cadmium	85				
Copper	4,300				
Lead	840				
Mercury	57				
Molybdenum	75				
Nickel	420				
Selenium	100				
Zinc	7,500				

d. Table 2 below gives the low metal concentration for biosolids. Because of its higher quality, biosolids with pollutant concentrations below those listed in Table 2 can safely be applied to agricultural land, forest, public contact sites, lawns, home gardens or be given away without further analysis. Biosolids containing metals in concentrations above the low metals concentrations but below the ceiling concentration limits may be land applied but shall not exceed the annual loading rates in Table 3 and the cumulative loading rates in Table 4. The permittee is required to track polluntant loading onto application sites for parameters that have exceeded the low metal concentration limits.

TABLE 2					
Biosolids Low Metal Concentration					
Pollutant	Milligrams per kilogram dry weight				
Arsenic	41				
Cadmium	39				
Copper	1,500				
Lead	300				
Mercury	17				
Nickel	420				
Selenium	100				
Zinc	2,800				

e. Annual pollutant loading rate.

Ta	bl	e	3	

Biosolids Annual Loading Rate					
Pollutant	Kg/ha (lbs./ac) per year				
Arsenic	2.0 (1.79)				
Cadmium	1.9 (1.70)				
Copper	75 (66.94)				
Lead	15 (13.39)				
Mercury	0.85 (0.76)				
Nickel	21 (18.74)				
Selenium	5.0 (4.46)				
Zinc	140 (124.96)				

f. Cumulative pollutant loading rates.

с.

Ta	ble	4	

Biosolids Cumulative Pollutant Loading Rate					
Pollutant	Kg/ha (lbs./ac)				
Arsenic	41 (37)				
Cadmium	39 (35)				
Copper	1500 (1339)				
Lead	300 (268)				
Mercury	17 (15)				
Nickel	420 (375)				
Selenium	100 (89)				
Zinc	2800 (2499)				

- 6. Best Management Practices. The permittee shall use the following best management practices during land application activities to prevent the discharge of biosolids to waters of the state.
 - a. Biosolids shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under § 4 of the Endangered Species Act or its designated critical habitat.
 - b. Apply biosolids only at the agronomic rate of nitrogen needed (see 5.c. of this section).
 - The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop

nitrogen removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.

i. PAN can be determined as follows:

(Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹). ¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis.

- ii. Crop nutrient production/removal to be based on crop specific nitrogen needs and realistic yield goals. NO TE: There are a number of reference documents on the Missouri Department of Natural Resources website that are informative to implement best management practices in the proper management of biosolids, including crop specific nitrogen needs, realistic yields on a county by county basis and other supporting references.
- iii. Biosolids that are applied at agronomic rates shall not cause the annual pollutant loading rates identified in Table 3 to be exceeded.
- d. Buffer zones are as follows:
 - i. 300 feet of a water supply well, sinkhole, water supply reservoir or water supply intake in a stream;
 - ii. 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstandingstate resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
 - iii. 150 feet of dwellings or public use areas;
 - iv. 100 feet (35 feet if biosolids application is down-gradient or the buffer zone is entirely vegetated) of lake, pond, wetlands or gaining streams (perennial or intermittent);
 - v. 50 feet of a property line. Buffer distances from property lines may be waived with written permission from neighboring property owner.
 - vi. For the application of dry, cake or liquid biosolids that are subsurface injected, buffer zones identified in 5.d.i. through 5.d.iii above, may be reduced to 100 feet. The buffer zone may be reduced to 35 feet if the buffer zone is permanently vegetated. Subsurface injection does not include methods or technology reflective of combination surface/shallow soil incorporation.
- e. Slope limitation for application sites are as follows:
 - i. For slopes less than or equal to 6 percent, no rate limitation;
 - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels;
 - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
 - iv. Dry, cake or liquid biosolids that are subsurface injected, may be applied on slopes not to exceed 20
 percent. Subsurface injection does not include the use of methods or technology reflective of combination
 surface/shallow soil incorporation.
- f. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- g. Biosolids may be land applied to sites with soil that are snow covered, frozen, or saturated with liquid when site restrictions or other controls are provided to prevent pollutants from being discharged to waters of the state during snowmelt or stormwater runoff. During inclement weather or unfavorable soil conditions use the following management practices:
 - i. A maximum field slope of 6% and a minimum 300 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be utilized for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of mthods or technology refletive of combination surface/shallow soil incorporation;
 - ii. A maximum field slope of 2% and 100 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be used for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not included the use of methods or technology refletive of combination surface/shallow soil incorporation;
 - iii. Other best management practices approved by the Department.

SECTION H – SEPTAGE

- 1. Haulers that land apply septage must obtain a state permit. An operating permit is not required for septage haulers who transport septage to another permitted treatment facility for disposal.
- 2. Do not apply more than 30,000 gallons of septage per acre per year or the volume otherwise stipulated in the operating permit.
- 3. Septic tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to mechanical treatment facilities.
- 4. Septage must comply with Class B biosolids regarding pathogen and vector attraction reduction requirements before it may be applied to crops, pastures or timberland. To meet required pathogen and vector reduction requirements, mix 50 pounds of hydrated lime for every 1,000 gallons of septage and maintain a septage pH of at least 12 pH standard units for 30 minutes or more prior to application.
- 5. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.
- 6. As residential septage contains relatively low levels of metals, the testing of metals in septage is not required.

SECTION I- CLOSURE REQUIREMENTS

- 1. This section applies to all wastewater facilities (mechanical and lagoons) and sludge or biosolids storage and treatment facilities. It does not apply to land application sites.
- 2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all sludges and/or biosolids. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20-6.010 and 10 CSR 20-6.015.
- 3. Biosolids or sludge that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
 - a. Biosolids and sludge shall meet the monitoring and land application limits for agricultural rates as referenced in Section G, above.
 - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
 - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre. Alternative, site-specific application rates may be included in the closure plan for department consideration.
 - i. PAN can be determined as follows:
 - (Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹).
 - ¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis
- 4. Domestic wastewater treatment lagoons with a design treatment capacity less than or equal to 150 persons, are "similar treatment works" under the definition of septage. Therefore the sludge within the lagoons may be treated as septage during closure activities. See Section B, above. Under the septage category, residuals may be left in place as follows:
 - a. Testing for metals or fecal coliform is not required.
 - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
 - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
- 5. Biosolids or sludge left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, and unless otherwise approved, the lagoon berm shall be demolished, and the site shall be graded and contain ≥70% vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion. Alternative biosolids or sludge and soil mixing ratios may be included in the closure plan for department consideration.
- 6. Lagoon and earthen structure closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200.
- 7. When closing a mechanical wastewater plant, all biosolids or sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
 - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to storm water per 10 CSR 20-6.200. The site shall be graded and contain \geq 70% vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate

surface water drainage without creating erosion.

- b. Hazardous Waste shall not be land applied or disposed during mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations pursuant to 10 CSR 25.
- c. After demolition of the mechanical plant, the site must only contain clean fill defined in Section 260.200.1(6) RSMo as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill, reclamation, or other beneficial use. Other solid wastes must be removed.
- 8. If biosolids or sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or I, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for on-site sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR Part 503, Subpart C.

SECTION J - MONITORING FREQUENCY

1. At a minimum, biosolids or sludge shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

TABLE 5						
Biosolids or Sludge	Monitoring Frequency (See Notes 1, and 2)					
produced and disposed (Dry Tons per Year)	Metals, Pathogens and Vectors, Total Phosphorus, Total Potassium	Nitrogen TKN, Nitrogen PAN ¹	Priority Pollutants ²			
319 or less	1/year	1 per month	1/year			
320 to 1650	4/year	1 per month	1/year			
1651 to 16,500	6/year	1 per month	1/year			
16,501+	12/year	1 per month	1/year			

¹Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

² Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) are required only for permit holders that must have a pre-treatment program. Monitoring requirements may be modified and incorporated into the operating permit by the Department on a case-by-case basis.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

- 2. Permittees that operate wastewater treatment lagoons, peak flow equalization basins, combined sewer overflow basins or biosolids or sludge lagoons that are cleaned out once a year or less, may choose to sample only when the biosolids or sludge is removed or the lagoon is closed. Test one composite sample for each 319 dry tons of biosolids or sludge removed from the lagoon during the reporting year or during lagoon closure. Composite sample must represent various areas at one-foot depth.
- 3. Additional testing may be required in the special conditions or other sections of the permit.
- 4. Biosolids and sludge monitoring shall be conducted in accordance with federal regulation 40 CFR § 503.8, Sampling and analysis.

SECTION K – RECORD KEEPING AND REPORTING REQUIREMENTS

- 1. The permittee shall maintain records on file at the facility for at least five years for the items listed in Standard Conditions PART III and any additional items in the Special Conditions section of this permit. This shall include dates when the biosolids or sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
- 2. Reporting period
 - a. By February 19th of each year, applicable facilities shall submit an annual report for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and biosolids or sludge disposal facilities.
 - b. Permittees with wastewater treatment lagoons shall submit the above annual report only when biosolids or sludge are removed from the lagoon during the report period or when the lagoon is closed.
- 3. Report Form. The annual report shall be prepared on report forms provided by the Department or equivalent forms approved by the Department.
- 4. Reports shall be submitted as follows:

Major facilities, which are those serving 10,000 persons or more or with a design flow equal to or greater than 1 million gallons per day or that are required to have an approved pretreatment program, shall report to both the Department and EPA if the facility land applied, disposed of biosolids by surface disposal, or operated a sewage sludge incinerator. All other facilities shall maintain their biosolids or sludge records and keep them available to Department personnel upon request. State reports shall be submitted to the address listed as follows:

DNR regional or other applicable office listed in the permit (see cover letter of permit) ATTN: Sludge Coordinator Reports to EPA must be electronically submitted online via the Central Data Exchange at: https://cdx.epa.gov/. Additional information is available at: https://www.epa.gov/biosolids/compliance-and-annual-biosolids-reporting.

- 5. Annual report contents. The annual report shall include the following:
 - a. Biosolids and sludge testing performed. If testing was conducted at a greater frequency than what is required by the permit, all test results must be included in the report.
 - b. Biosolids or sludge quantity shall be reported as dry tons for the quantity produced and/or disposed.
 - c. Gallons and % solids data used to calculate the dry ton amounts.
 - d. Description of any unusual operating conditions.
 - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
 - i. This must include the name and address for the hauler and sludge facility. If hauled to a municipal wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that facility.
 - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.
 - f. Contract Hauler Activities:

If using a contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate biosolids or sludge use permit.

- g. Land Application Sites:
 - i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as alegal description for nearest ¹/₄, ¹/₄, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
 - ii. If the "Low Metals" criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
 - iii. Report the method used for compliance with pathogen and vector attraction requirements.
 - iv. Report soil test results for pH and phosphorus. If no soil was tested during the year, report the last date when tested and the results.

€ €

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM FORM B2 – APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY

JUL 2 5 2017

APPLICATION OVERVIEW

Water Protection Program

Form B2 has been developed in a modular format and consists of Parts A, B and C and a Supplemental Application Information (Parts D, E, F and G) packet. All applicants must complete Parts A, B and C. Some applicants must also complete parts of the Supplemental Application Information packet. The following items explain which parts of Form B2 you must complete. Submittal of an incomplete application may result in the application being returned.

BASIC APPLICATION INFORMATION

- A. Basic application information for all applicants. All applicants must complete Part A.
- B. Additional application information for all applicants. All applicants must complete Part B.
- C. Certification. All applicants must complete Part C.

SUPPLEMENTAL APPLICATION INFORMATION

- D. Expanded Effluent Testing Data. A treatment works that discharges effluent to surface water of the United States and meets one or more of the following criteria must complete *Part D Expanded Effluent Testing Data*:
 - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
 - 2. Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- E. Toxicity Testing Data. A treatment works that meets one or more of the following criteria must complete Part E -Toxicity Testing Data:
 - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
 - 2. Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- F. Industrial User Discharges and Resource Conservation and Recovery Act / Comprehensive Environmental Response, Compensation and Liability Act Wastes. A treatment works that accepts process wastewater from any significant industrial users, also known as SIUs, or receives a Resource Conservation and Recovery Act or CERCLA wastes must complete *Part F Industrial User Discharges and Resource Conservation and Recovery Act /CERCLA Wastes*.

SIUs are defined as:

- 1. All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N.
- 2. Any other industrial user that meets one or more of the following:
 - i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - ii. Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - iii. Is designated as an SIU by the control authority.
 - iv. Is otherwise required by the permitting authority to provide the information.
- G. Combined Sewer Systems. A treatment works that has a combined sewer system must complete Part G Combined Sewer Systems.

ALL APPLICANTS MUST COMPLETE PARTS A, B and C

	e43					
MISSOURI DEPARTMENT OF NATURAL RE WATER PROTECTION PROGRAM FORM B2 – APPLICATION FOR AN FACILITIES THAT RECEIVE PRIMA	ESOURCES	S FING PERMIT FO MESTIC WASTE	DR AND	CHEC	R AGENO	FEE SUBMIDIED
HAVE A DESIGN FLOW MORE THA	AN 100,00	0 GALLONS PE	R DAY	7-7	25-1	1 04
PART A – BASIC APPLICATION INFORMATION						
1. THIS APPLICATION IS FOR:	oility (Construction D	ormit #			
 An operating permit for a new of unpermitted factorial (Include completed Antidegradation Review or response) An operating permit renewal: Permit #MO- 0021 	equest to cor 1440	nduct an Antidegrada Expiration Date	ation Revie	ew, see in)17	struction	s)
An operating permit modification: Permit #MO		Reason:				
1.1 Is the appropriate fee included with the application	n (see instru	ctions for appropriate	e fee)?		☐ YES	NO NO
2. FACILITY						
NAME Monett Municipal WWTF				TELEPHON 417-235	IE NUMBER -7455	WITH AREA CODE
ADDRESS (PHYSICAL) South Eisenhower	Monett			MO		ZIP CODE 65708
2.1 LEGAL DESCRIPTION (Facility Site): nw 1/4, se	e 1/4, se 1/4	, Sec. 36 , T 26r	, R 28W		Barry	
2.2 UTM Coordinates Easting (X): <u>416243</u> Nor For Universal Transverse Mercator (UTM), Zone	rthing (Y):	4086034 eferenced to North Ar	merican D	atum 198.	3 (NAD8	3)
2.3 Name of receiving stream: Clear Creek						
2.4 Number of Outfalls: 1 wastewater outfall	s,0 st	ormwater outfalls, 1	instre	am monit	oring site	es
3. OWNER						
NAME City of Monett	e d	EMAIL ADDRESS	om	TELEPHON 417-235	E NUMBER	WITH AREA CODE
ADDRESS 217 5th Street	Monett			STATE MO		ZIP CODE 65708
3.1 Request review of draft permit prior to Public Not	ice?	YES	□ NO			
3.2 Are you a Publically Owned Treatment Works (PC If yes, is the Financial Questionnaire attached?	OTW)?	YES				
3.3 Are you a Privately Owned Treatment Facility?		C YES	NO NO			
3.4 Are you a Privately Owned Treatment Facility reg	ulated by the	e Public Service Con	nmission (PSC)?	☐ YES	NO NO
 CONTINUING AUTHORITY: Permanent organiza maintenance and modernization of the facility. 	ation which	will serve as the co	ontinuing	authority	for the	operation,
NAME City of Monett	e dj	MAIL ADDRESS pyle@cityofmonett.co	om	TELEPHON 417-235-	E NUMBER 4611	WITH AREA CODE
ADDRESS 217 5th Street	Monett			STATE MO		ZIP CODE 65708
If the Continuing Authority is different than the Owner, includes description of the responsibilities of both parties within the	ude a copy o agreement.	of the contract agree	nent betw	een the tw	vo partie	s and a
5. OPERATOR						
NAME Dave Sims	E TITLE CERTIFICATE NUMBER (IF APPLICABLE)					
EMAIL ADDRESS	TELEPHON	E NUMBER WITH AREA COD	E			
	417-235	-7455				
Dave Sims		WWTP Superinte	endent			
EMAIL ADDRESS lave@cityofmonett.com	1	TELEPHONE NUMBER 417-235-7455	WITH AREA C	ODE		
ADDRESS 17 5th Street	Monett			STATE MO		ZIP CODE 65708
			in the second			Dans 0

FACILITY NAME	PERMIT NO.	OUTFALL NO.	
Monett Municipal WWTF	MO- 0021440	001	
PART A - BASIC APPLICATION INFOR	MATION		

7. FACILITY INFORMATION

7.1 Process Flow Diagram or Schematic. Provide a diagram showing the processes of the treatment plant. Show all of the treatment units, including disinfection (e.g. – Chlorination and Dechlorination), influents, and outfalls. Specify where samples are taken. Indicate any treatment process changes in the routing of wastewater during dry weather and peak wet weather. Include a brief narrative description of the diagram. Attach sheets as necessary.

Pumping facilities, screening, grit removal, two oxidation ditches, four anaerobic basins, six anoxic basins, three trickling filter towers, two secondary clarifiers, tertiary filtration, ultraviolet disinfection, partial golf course irrigation, land application of aerobically digested sludge. Influent, effluent, and downstream sampling.



4

FORM B-2 ITEM 7.1 PROCESS FLOW DIAGRAM W/ PLANT LOADINGS

FACILI	TY NAME att Municipal WWTF	PERMIT NO. MO-0021440		0	OUTFALL NO.	
PAR	T A - BASIC APPLICATION IN	FORMATION				
7.	FACILITY INFORMATION (co	ntinued)				
7.2	 Topographic Map. Attach to property boundaries. This mata. The area surrounding the b. The location of the downs c. The major pipes or other sthrough which treated was applicable. d. The actual point of dischate. Wells, springs, other surfatthe treatment works, and f. Any areas where the sewateg. If the treatment works reconstruction of the treatment works reconstruction. The actual point of several structure to the sewate of the treatment works and f. Any areas where the sewateg. If the treatment works reconstructure to the several structure of the several structure to the several structure of the treatment works reconstructure to the several structure of the several s	this application a topographic map of p must show the outline of the facilit treatment plant, including all unit pr tream landowner(s). (See Item 10.) structures through which wastewate stewater is discharged from the trea rge. Ince water bodies and drinking water 2) listed in public record or otherwise age sludge produced by the treatme eives waste that is classified as haz pecial pipe, show on the map where bosed.	of the a y and to occessed r enter tment p wells t e know nt wor ardous e that h	the following es. s the treatme blant. Includ hat are: 1) w n to the appl ks is stored, under the R azardous wa	ng at least one mile information. ent works and the pi e outfalls from bypa ithin ¼ mile of the p icant. treated, or disposed esource Conservati iste enters the treat	beyond facility pes or other structures ss piping, if property boundaries of t. on and Recovery Act ment works and where
7.3	Facility SIC Code: NA	Discha 4952	arge S	C Code:		
7.4	Number of people presently co	nnected or population equivalent (P	.E.):	2,000	Design P.E. 78	3,830
7.5	Connections to the facility:	ntire City of Monett - Residential - 3,	350			
	Number of units presently co	nnected:				
	Homes Trailers	Apartments Oth	er (inc	uding indust	rial) 46	П
	Number of Commercial Esta	blishments: 458				
.6	Design Flow 6.0 MGD	Actual 2.7 MG	Actual Flow 2.7 MGD Avg.; 3.2 MGD Weekday			
7.7	Will discharge be continuous th Discharge will occur during the	rough the year? Yes Z following months: How many day	rs of th	No 🗌 e week will d	lischarge occur?	
.8	Is industrial wastewater dischar If yes, describe the number and See Attached	rged to the facility? I types of industries that discharge t	Yes o your	facility. Attac	No 🗌 Sh sheets as necess	sary
9	Refer to the APPLICATION OV	ERVIEW to determine whether add	tional		No V	
.10	Is wastewater land applied?			Yes 🔽	No 🗖	
	If yes, is Form I attached?			Yes 🔽	No 🗖	
.11	Does the facility discharge to a	losing stream or sinkhole?		Yes 🖌	No 🗌	
12	Has a wasteload allocation stud	ly been completed for this facility?		Yes 🗌	No 🗹	
5	LABORATORY CONTROL INF	ORMATION				
	LABORATORY WORK CONDL	ICTED BY PLANT PERSONNEL				
	Lab work conducted outside of	plant.			Yes 🛄	No 🗖
	Push-button or visual methods	for simple test such as pH, settleab	le solid	S.	Yes 🗸	No 🗌
	Additional procedures such as I Oxygen Demand, titrations, soli	Dissolved Oxygen, Chemical Oxyge ds, volatile content.	n Dem	and, Biologic	al Yes ₽	No 🗌
	More advanced determinations nutrients, total oils, phenols, etc.	such as BOD seeding procedures, t	ecal co	oliform,	Yes 🗹	No 🗔
		Man and the start of the star	1			

1



FORM B-2 **ITEM 7.2**

FACILIT	TY NAME It Municipal WWTF	PERMIT NO. MO- 0021440		OUTFALL NO.			
PART	TA - BASIC APPLICATION INFORM	ATION					
9.	SLUDGE HANDLING, USE AND DIS	SPOSAL					
9.1	Is the sludge a hazardous waste as defined by 10 CSR 25? Yes 🗌 No 🗹						
9.2	Sludge production (Including sludge r	received from others): Design Dry T	ons/Yea	r 1,400 Actual Dry	Tons/Year 318		
9.3	3 Sludge storage provided: <u>164k</u> Cubic feet; <u>158</u> Days of storage; <u>2.7</u> Average percent solids of sludge;						
	No sludge storage is provided.	Sludge is stored in lagoon.					
9.4	Type of storage:	Holding Tank 🔲 Bui Basin 🗍 Lag Concrete Pad 🗍 Oth	lding Joon er (Desc	ribe)			
9.5	Sludge Treatment:						
0.6	Anaerobic Digester Aerobic Digester Aerobic Digester Air or He	e Tank Lime Stabilize eat Drying Composting	ation	☐ Lagoon ☐ Other (Attac	h Description)		
9.7	 Land Application Contract Surface Disposal (Sludge Disposa Other (Attach Explanation Sheet) Person responsible for hauling sludge By Applicant By Others 	t Hauler Hauled to Another T Il Lagoon, Sludge Held For More Tha to disposal facility: (complete below)	reatment an Two Y	Facility Solic Years) Incin	d Waste Landfill leration		
NAME			EMA	AIL ADDRESS			
City of	Monett		da	ve@cityofmonett.con	n		
ADDRES	S	CITY		STATE	ZIP CODE		
217 5th	n Street	Monett	Monett		65708		
CONTAC	TPERSON	TELEPHONE NUMBER WIT	H AREA CO	DE PERMIT N	10.		
Dave S	Sims	417-235-7455	417-235-7455		021440		
9.8	Sludge use or disposal facility:	(Complete below)					
NAME			EMA	IL ADDRESS			
City of	Monett		dav	e@cityofmonett.com			
ADDRES	S	CITY	CITY		ZIP CODE		
217 50	1 Street	Monett		МО	65708		
CONTAC	T PERSON	TELEPHONE NUMBER WIT	H AREA COL	DE PERMIT N	0.		
Dave 5	417-235-7455 MO-0021440						
9.9	Does the sludge or biosolids disposal	I comply with Federal Sludge Regula	ation 40 (CFR 503?			
		END OF PART A					
780-1805	5 (09-16)				Page 5		

FACILITY NAME		
	PERMIT NO. MO-0021440	OUTFALL NO. 001
PART B - ADDITIONAL APPLICAT		
10. COLLECTION SYSTEM		-
10.1 Length of sanitary sewer colle 76	ection system in miles	
10.2 Does significant infiltration or If yes, briefly explain any step	ccur in the collection system?	s 🔲 No flow and infiltration:
Ongoing program of manhole rehabili	itation and sewer lining/grouting of dete	eriorated sewers.
11. BYPASSING		· · · · · · · · · · · · · · · · · · ·
Does any bypassing occur anywhere If yes, explain:	in the collection system or at the treat	ment facility? Yes 🗹 No 🗌
Bypassing does not normally occur, b result in bypassing at several sewer s basin during extremely wet periods. It	ut is possible during periods of signific system manholes. It is rare, but bypass normally takes 5 or 6-inches of rainfal	ant rainfall when contributions of infiltration and inflow can ing has also occurred at the WWTP flow equalization I over a 2-3 day period to result in bypassing.
Are any operational or maintenance a responsibility of the contractor? Yes No Z	aspects (related to wastewater treatme	nt and effluent quality) of the treatment works the
(Attach additional pages if necessary	r.)	
MAILING ADDRESS		
MAILING ADDRESS	EMAIL ADI	DRESS
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR	EMAIL ADI	DRESS
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13 SCHEDUL ED IMPROVEMENT		DRESS
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMENT Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planning	EMAIL AD TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und , or design capacity of the treatment w ing several improvements, submit sepa	ITATION Completed plans for improvements that will affect the forks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planni lo pending Improvements	EMAIL AD TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und /, or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the porks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planni lo pending Improvements	EMAIL ADI TS AND SCHEDULES OF IMPLEMEN Ipleted implementation schedule or und , or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the vorks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planni lo pending Improvements	EMAIL ADI TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und /, or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the orks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planni lo pending Improvements	TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und , or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the rorks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is planni lo pending Improvements	EMAIL AD TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und , or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the orks. If the treatment works has several different arate responses for each.
MAILING ADDRESS TELEPHONE NUMBER WITH AREA CODE RESPONSIBILITIES OF CONTRACTOR 13. SCHEDULED IMPROVEMEN Provide information about any uncom wastewater treatment, effluent quality implementation schedules or is plann Io pending Improvements	EMAIL AD TS AND SCHEDULES OF IMPLEMEN pleted implementation schedule or und , or design capacity of the treatment w ing several improvements, submit sepa	ITATION completed plans for improvements that will affect the rorks. If the treatment works has several different arate responses for each.

FACILITY NAME			PERMIT NO. OUTFALL NO.									
Monett Municipal W	NTF		MO-00214	40		001						
PART B - ADDITIC	NAL APP	LICATION IN	FORMATIO	N								
14. EFFLUENT	TESTING I	DATA										
Applicants must pro through which effl reported must be ba comply with QA/QC not addressed by 40 more than four and	vide efflue uent is dis ased on da requireme) CFR Part one-half ye	nt testing dat scharged. D ta collected tl nts of 40 CFI 136. At a m ears apart.	a for the follo o not include hrough analy R Part 136 ar inimum, efflu	wing param information sis conducte nd other app ent testing o	eters. Provid of combined ed using 40 C propriate QA/ lata must be	le the indicated e sewer overflows FR Part 136 met QC requirements based on at leas	in this section in this section hods. In add for standard t three samp	or each on. All in dition, thi method oles and	outfall formation s data must s for analytes must be no			
Outfall Number												
DAD	METER		MAXI	MUM DAILY	/ VALUE	A	VERAGE DA	AILY VAL	UE			
FAIV			Va	alue	Units	Value	Units	Numb	er of Samples			
pH (Minimum)	(Minimum)			7.1	S.U.		S.U.		12			
pH (Maximum)			1	7.7	S.U.		S.U.		12			
Flow Rate	low Rate			7.4 MGD			MGD	12				
*For pH report a mir	nimum and	a maximum	daily value									
		MAXIMU DISCH	MAXIMUM DAILY DISCHARGE		AGE DAILY D	DISCHARGE	ANALYT	ICAL				
POLLUTAN	POLLUTANT		Units	Units Conc. Unit		Number of Samples	METHOD		MENVIDE			
Conventional and N	onconventi	onal Compou	unds									
BIOCHEMICAL OXYGEN	BOD ₅	7.9	mg/L	2.5	mg/L	12	5210	В	15			
DEMAND (Report One)	CBOD ₅		mg/L		mg/L							
E. COLI		547	#/100 mL	15.7	#/100 mL	12	9223	В	126			
TOTAL SUSPENDE SOLIDS (TSS)	D	21.2	mg/L	4.3	mg/L	12	2540	В	20			
AMMONIA (as N)		1.4	mg/L	0.27	mg/L	12	EPA 35	0.2	3.8 - 11.3			
CHLORINE* (TOTAL RESIDUAL,	TRC)		mg/L		mg/L							
DISSOLVED OXYG	EN	9.2	mg/L	6.8	mg/L	12	4500-	0				
OIL and GREASE		2.6	mg/L	2.6	mg/L	4	EPA 166	64 A	15			
OTHER			mg/L		mg/L							
*Report only if facility	chlorinate	s										
				END OF P	ART B							

780-1805 (09-16)

Page 7

	MO- 0021440	001	
FACILITY NAME	PERMIT NO.	OUTFALL NO.	

15. ELECTRONIC DISCHARGE MONITORING REPORT (eDMR) SUBMISSION SYSTEM

Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent limits and monitoring shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally-consistent set of data. **One of the following must be checked in order for this application to be considered complete**. Please visit http://dnr.mo.gov/env/wpp/edmr.htm to access the Facility Participation Package.

- You have completed and submitted with this permit application the required documentation to participate in the eDMR system.

∠ - You have previously submitted the required documentation to participate in the eDMR system and/or you are currently using the eDMR system.

- You have submitted a written request for a waiver from electronic reporting. See instructions for further information regarding waivers.

16. CERTIFICATION

All applicants must complete the Certification Section. This certification must be signed by an officer of the company or city official. All applicants must complete all applicable sections as explained in the Application Overview. By signing this certification statement, applicants confirm that they have reviewed the entire form and have completed all sections that apply to the facility for which this application is submitted.

ALL APPLICANTS MUST COMPLETE THE FOLLOWING CERTIFICATION.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

ALL TITLE AN OFFICED OF THE CONDANN OD OFFICE

PRINTED NAME	FICIAL TITLE (MUST BE AN OFFICER OF THE COMPANY OR CITY OFFICIAL)
Dennis L. Pyle	City Administrator
SIGNATURE	
TELEPHONE NUMBER WITH AREA CODE	
417. 235. 3355	
DATE SIGNED July 20, 2017	
Upon request of the permitting authority, you must submit any other info at the treatment works or identify appropriate permitting requirements.	ormation necessary to assess wastewater treatment practices
Send Completed Form to:	
Department of Natura	al Resources
Water Protection	Program
ATTN: NPDES Permits and	Engineering Section
P.O. Box 1	76
Jefferson City, MO	65102-0176
END OF PAP	RT C
REFER TO THE APPLICATION OVERVIEW TO DETERMINE V	WHICH PARTS OF FORM B2 YOU MUST COMPLETE.
Do not complete the remainder of this application, unless at least one of	f the following statements applies to your facility:
1. Your facility design flow is equal to or greater than 1,0)00,000 gallons per day.
Your facility is a pretreatment treatment works.	
Your facility is a combined sewer system.	
Submittal of an incomplete application may result in the application bein forfeited. Permit fees for applications being processed by the department	ig returned. Permit fees for returned applications shall be int that are withdrawn by the applicant shall be forfeited.

MAKE ADDITIONAL	COPIES	S OF THIS I	FORM FO	OR EACH	I OUTF	ALL					
FACILITY NAME Monett Municipal WWT	F		PERM MO-	IT NO. 002144	0			001	ALL NO.		
PART D - EXPANDE	DEFFL	UENT TES	TING DA	TA							
17. EXPANDED EF	FLUEN	IT TESTING	G DATA								
Refer to the APPLICA	TION O	VERVIEW	to determ	ine whet	her Part	D applies	to the trea	atment we	orks.		
If the treatment works pretreatment program, following pollutants. P include information of analysis conducted us identifying, and measu Part 136 and other ap the blank rows provide data must be based or	has a d or is of combine ing 40 (uring the propriate d below n at lease	esign flow g therwise rec the indicated ed sewer ov CFR Part 13 e concentrat e QA/QC re v any data y st three po l	preater that puired by the d effluent verflows in 66 method ions of po quiremen you may h lutant sc	an or equ the perm testing in this sec ds. The f ollutants. ts for sta ave on p ans and	ual to 1 n itting aut formatio ction. All facility sh In additi andard m pollutants must be	nillion gall thority to p on for eac informati- iall use su on, this da ethods fo not spec no more	ons per da provide the th outfall to on reporte officiently s ata must c r analytes ifically liste than four a	ay or it has data, the through d must be ensitive a omply with not addre ed in this and one-h	is (or is requ en provide e which efflue e based on o analytical me th QA/QC re essed by 40 form. At a n aalf years ap	ired to have) a ffluent testing da ant is discharge lata collected th othods for detect quirements of 4 CFR Part 136. ninimum, effluer art.	ata for the ed. Do not rough ting, 0 CFR Indicate in tt testing
Outfall Number (Comp	lete On	ce for Each	Outfall D	ischargir	ng Efflue	nt to Wate	ers of the S	State.) 0	01 (See Atta	ched Reports)	
	MAX	XIMUM DAI	LY DISCI	HARGE		AVERAG	E DAILY	DISCHAR	RGE		
POLLUTANT	Con	nc. Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	ML/MDL
METALS (TOTAL RECO	VERAB	LE), CYANID	E, PHENC	LS AND	HARDNE	SS					
ALUMINUM	79	ug/L			53	ug/L			4	EPA 200.7	N/A
ANTIMONY											
ARSENIC											
BERYLLIUM											
CADMIUM	15	ug/L			3.5	ug/L			12	EPA 200.7	N/A
CHROMIUM III											
CHROMIUM VI											
COPPER	15	ug/L			5.2	ug/L			12	EPA 200.7	N/A
IRON	51	ug/L			32	ug/L			4	EPA 200.7	N/A
LEAD	25	ug/L			9.3	ug/L			4	EPA 200.7	N/A
MERCURY											
NICKEL											
SELENIUM	25	ug/L			7.8	ug/L			12	EPA 200.7	N/A
SILVER						_					
THALLIUM											
ZINC	87	ug/L			49	ug/L			4	EPA 200.7	N/A
CYANIDE	14	ug/L			7.4	ug/L			12	9010 C	N/A
TOTAL PHENOLIC COMPOUNDS											
HARDNESS (as CaCO ₃)											
VOLATILE ORGANIC CO	MPOUN	IDS									
ACROLEIN											
ACRYLONITRILE											
BENZENE											
BROMOFORM											
CARBON TETRACHLORIDE 780-1805 (09-16)										Pa	ae 9

FACILITY NAME Monett Mun	NAME PERMIT NO. Monett Municipal WWTF MO- 00.							OUTF	ALL NO. 001		
PART D - EXPANDED	EFFLUE	NT TES	TING DA	ТА							
17. EXPANDED EFF	LUENT	TESTING	DATA								
Complete Once for Eac	h Outfall	Discharg	ing Efflue	ent to Wa	Naters of the State						
	MAXIM	IUM DAIL	Y DISCH	/ DISCHARGE		AVERAGE DAILY DIS			RGE	ANALYTICAL	
POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	ML/MDL
CHLOROBENZENE											
CHLORODIBROMO- METHANE											
CHLOROETHANE											
2-CHLORO-ETHYLVINYL ETHER											
CHLOROFORM											
DICHLOROBROMO- METHANE							(
1,1-DICHLORO-ETHANE	_										
1,2-DICHLORO-ETHANE											
TRANS-1,2- DICHLOROETHYLENE											
1,1-DICHLORO- ETHYLENE											
1,2-DICHLORO-PROPANE											
1,3-DICHLORO- PROPYLENE											
ETHYLBENZENE											
METHYL BROMIDE											
METHYL CHLORIDE											
METHYLENE CHLORIDE											
1,1,2,2-TETRA- CHLOROETHANE											
TETRACHLORO-ETHANE											
TOLUENE											
1,1,1-TRICHLORO- ETHANE											
1,1,2-TRICHLORO- ETHANE											
TRICHLORETHYLENE											
VINYL CHLORIDE											
ACID-EXTRACTABLE CO	MPOUND	S									
P-CHLORO-M-CRESOL											
2-CHLOROPHENOL											
2,4-DICHLOROPHENOL											
2,4-DIMETHYLPHENOL											
4,6-DINITRO-O-CRESOL											
2,4-DINITROPHENOL											
2-NITROPHENOL											
4-NITROPHENOL											
700 4005 (00 48)										P	00 10

FACILITY NAME Monett Mur	nicipal W\	I WWTF PERMIT NO. MO- 0021440					0 OUTFALL NO. 001				
PART D – EXPANDED	EFFLUE	INT TES	TING DA	ТА							
17. EXPANDED EFF	LUENT	TESTING	J DATA								
Complete Once for Eac	h Outfall	Discharg	ing Efflue	ent to Wa	ters of the	e State.					
	MAXIN	IUM DAIL	Y DISCH	ARGE	P	VERAG	E DAILY	DISCHA	RGE		
POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	ML/MDL
PENTACHLOROPHENOL										_	
PHENOL											
2,4,6-TRICHLOROPHENOL											
BASE-NEUTRAL COMPO	UNDS										
ACENAPHTHENE											
ACENAPHTHYLENE											
ANTHRACENE											
BENZIDINE											
BENZO(A)ANTHRACENE											
BENZO(A)PYRENE											
3,4-BENZO- FLUORANTHENE											
BENZO(GH) PHERYLENE											
BENZO(K) FLUORANTHENE											
BIS (2-CHLOROTHOXY) METHANE											
BIS (2-CHLOROETHYL) – ETHER											
BIS (2-CHLOROISO- PROPYL) ETHER											
BIS (2-ETHYLHEXYL) PHTHALATE											
4-BROMOPHENYL PHENYL ETHER											
BUTYL BENZYL PHTHALATE											
2-CHLORONAPH- THALENE											
4-CHLORPHENYL PHENYL ETHER		_									
CHRYSENE											
DI-N-BUTYL PHTHALATE											
DI-N-OCTYL PHTHALATE											
DIBENZO (A,H) ANTHRACENE											
1,2-DICHLORO-BENZENE											
1,3-DICHLORO-BENZENE											
1,4-DICHLORO-BENZENE											
3,3-DICHLORO- BENZIDINE											
DIETHYL PHTHALATE											
DIMETHYL PHTHALATE											
700 1005 (00 10)											

FACILITY NAME Monett Munic	ipal WW	ΓF	PERMIT NO. 0021440 OUTFALL NO. 001								
PART D - EXPANDED E	FFLUEN	T TESTI	NG DATA	1							
17. EXPANDED EFFL	UENITE	ESTINGL		1-10/-1-	C 11 (24-4-					
Complete Once for Each	Outfall Di	ischarging			rs of the a				POE		
POLLUTANT	Conc	UM DAIL	Mass	IARGE	Conc	Units	Mass	Units	No of	ANALYTICAL	ML/MDL
	0010.	Onits	IVId35	Onita	00110.		IVI255		Samples	METHOD	
2,4-DINITRO-TOLUENE											
2,6-DINITRO-TOLUENE											
1,2-DIPHENYL-HYDRAZINE											
FLUORANTHENE											
FLUORENE											
HEXACHLOROBENZENE											
HEXACHLOROBUTADIENE											
HEXACHLOROCYCLO- PENTADIENE											
HEXACHLOROETHANE											
INDENO (1,2,3-CD) PYRENE											
ISOPHORONE											
NAPHTHALENE											
NITROBENZENE											
N-NITROSODI- PROPYLAMINE											
N-NITROSODI- METHYLAMINE											
N-NITROSODI- PHENYLAMINE											
PHENANTHRENE											
PYRENE											
1,2,4-TRICHLOROBENZENE											
Use this space (or a sepa	rate shee	t) to provi	ide inform	nation on	other po	llutants no	ot specific	ally listed	d in this form		
Phosphorus	14:1	mg/L			12.6	mg/L			4	EPA 365.3	N/A
Total Nitrogen	24.9	mg/L			15.8	mg/L			4	Calc	N/A
			_								
	-										

MAKE ADDITIONAL CODIES OF THIS FOR			
FACILITY NAME		OUTFALL NO	
Monett Municipal WWTF	MO- 0021440	(001
PART E – TOXICITY TESTING DATA			
18. TOXICITY TESTING DATA			
Refer to the APPLICATION OVERVIEW to de	termine whether Part E applies	s to the treatment works.	
Publicly owned treatment works, or POTWs, m	neeting one or more of the follo	owing criteria must provide the	results of whole effluent toxicity
tests for acute or chronic toxicity for each of th	e facility's discharge points.		
A. POTWs with a design flow rate grea	ater than or equal to 1 million g	allons per day	(00)
B. POTWs with a pretreatment progra	m (or those that are required to	o have one under 40 CFR Par	[403)
C. POTVs required by the permitting a	at include questorly testing for	se parameters	act one year using multiple
 species (minimum of two species prior to the application, provided on the range of receiving water information reported must be baaddition, this data must comply standard methods for analytes r If EPA methods were not used, all of the information requested complete Part E. Refer to the applicate the number of whole offluent toxicity to the applicate the number of whole offluent toxicity to the term of term of the term of the term of the term of term of term of the term of term of the term of ter	is), or the results from four tes if the results show no apprecia dilution. Do not include inform used on data collected through with QA/QC requirements of 4 not addressed by 40 CFR Part report the reason for using alter below, they may be submitted pplication overview for direction parts conducted in the past form	ts performed at least annually ble toxicity, and testing for acu- lation about combined sewer of analysis conducted using 40 (0 CFR Part 136 and other app 136. emative methods. If test summ in place of Part E. If no biomore ns on which other sections of	In the four and one-half years te or chronic toxicity, depending overflows in this section. All CFR Part 136 methods. In ropriate QA/QC requirements for naries are available that contain onitoring data is required, do not the form to complete.
Indicate the number of whole endent toxicity to		Allense shares of the second	
Complete the following chart for the last three three tests are being reported.	whole effluent toxicity tests	s. Allow one column per test.	Copy this page if more than
	Most Recent	2 ND Most Recent	3 RD Most Recent
A. Test Information			
Test Method Number	See Attached	See Attached	See Attached
Final Report Number	EAS Log# 2013617	EAS Log# 1815620	EAS Log# 1714322
Outfall Number	001	001	001
Dates Sample Collected	11/14/16 - 11/15/16	06/15/15 - 06/16/15	08/25/14 - 08/26/14
Date Test Started	11/16/2016	06/17/2015	08/27/2014
Duration	48 hrs.	48 hrs.	48 hrs.
B. Toxicity Test Methods Followed			
Manual Title	US EPA 600/4-90/027	US EPA 600/4-90/027	US EPA 600/4-90/027
Edition Number and Year of Publication	5th / Oct. 2002	5th / Oct. 2002	5th / Oct. 2002
Page Number(s)			
C. Sample collection method(s) used. For mul	tiple grab samples, indicate th	e number of grab samples use	ed
24-Hour Composite	Sampler	Sampler	Sampler
Grab			
D. Indicate where the sample was taken in rela	tion to disinfection (Check all	that apply for each)	
Before Disinfection			
After Disinfection			V
After Dechlorination			
E Describe the point in the treatment process	at which the sample was colle	cted	

After Dechlorination				
E. Describe the point in the treatment	process at which the sample was c	ollected		
Sample Was Collected:	Outfall 001	Outfall 001	Outfall 001	
F. Indicate whether the test was intend	ded to assess chronic toxicity, acute	e toxicity, or both		
Chronic Toxicity				
Acute Toxicity				
G. Provide the type of test performed				
Static				
Static-renewal				
Flow-through				
H. Source of dilution water. If laborato	ry water, specify type; if receiving v	vater, specify source		
Laboratory Water	Mod. Hard	Mod. Hard	Mod. Hard	
Receiving Water				
780-1805 (09-16)			Page 13	

FACILITY NAME Monett Municipal WWTF	PERMIT NO. MO- 0021440	OUTFALL NO.	1
PART E - TOXICITY TESTING DATA			
18. TOXICITY TESTING DATA (continued	d) (k		
	Most Recent	Second Most Recent	Third Most Recent
I. Type of dilution water. If salt water, specify	y "natural" or type of artificia	al sea salts or brine used.	
Fresh Water	Mod. Hard	Mod. Hard	Mod. Hard
Salt Water			
J. Percentage of effluent used for all concent	rations in the test series		
	100	100	100
K. Parameters measured during the test (Stat	e whether parameter meets	s test method specifications)	1
рН	8.13 - 8.21	7.12 - 7.57	7.62 - 8.27
Salinity			
Temperature	24.8 - 25.0 °C	23.4 - 25.0 °C	23.6 - 25.0 °C
Ammonia	<0.05 pm	<0.05 pm	<0.05 pm
Dissolved Oxygen	8.0 - 9.0 ppm	7.7 - 8.6 ppm	8.1 - 8.8 ppm
L. Test Results			
Acute:			
Percent Survival in 100% Effluent	100	100	100
LC ₅₀	>100	>100	>100
95% C.I.			
Control Percent Survival	100	100	100
Other (Describe)			
Chronic:			
NOEC			
IC25			
Control Percent Survival			
Other (Describe)			
M. Quality Control/ Quality Assurance			
Is reference toxicant data available?	Yes	Yes	Yes
Was reference toxicant test within acceptable bounds?	Yes	Yes	Yes
What date was reference toxicant test run (MM/DD/YYYY)?	11/09/2016	06/03/2015	08/06/2014
Other (Describe)			
Is the treatment works involved in a toxicity red If ves, describe:	duction evaluation?	Yes 🔽 No	

If you have submitted biomonitoring test information, or information regarding the cause of toxicity, within the past four and one-half years, provide the dates the information was submitted to the permitting authority and a summary of the results. No Date Submitted (MM/DD/YYYY)

Summary of Results (See Instructions) All results reflect 100% survival in 100% effluent.

END OF PART E

REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE. Page 14

780-1805 (09-16)

CITY OF MONETT

Re: CaSi File/Case/Log: 0036/171378-1379/3976 Samples Received: 05-10-17, 11:27

PRIORITY POLLUTANTS; METALS, CYANIDE, PHENOLICS

CONTROL NUMBER 171378 171379 EFFLUENT EFFLUENT FLAG UNITS ANALYSIS ANALYSIS SAMPLE DESCRIPTION COMPOSITE GRAB TIME DATE 05-10-17 05-10-17 PARAMETER METHOD 08:00 07:45 05-18-17 10:56 Aluminum, total EPA 200.7 96.5 ug/l 05-18-17 09:07 Antimony, total EPA 200.7 <6.5 ug/l EPA 200.7 05-18-17 09:07 <10 ug/l Arsenic, total EPA 200.7 <1.1 ug/l 05-18-17 09:07 Beryllium, total EPA 200.7 05-18-17 09:07 Cadmium, total <1.0 ug/l Calculation < 0.9 ug/l 05-18-17 09:07 CHROMIUM III, total 05-10-17 16:50 <5 CHROMIUM VI, total SM 3500-Cr B ug/l Copper, total EPA 200.7 <0.6 ug/l 05-18-17 09:07 EPA 200.7 09:07 <5.0 05-18-17 Lead, total ug/l < 0.0005 05-26-17 11:47 EPA 245.1 ug/l Mercury, total 05-18-17 Nickel, total EPA 200.7 <3.1 ug/l 09:07 05-18-17 09:07 Selenium, total EPA 200.7 <12 ug/l 05-18-17 09:07 EPA 200.7 <1.0 Silver, total ug/l 09:07 Thallium, total EPA 200.7 <11 ug/l 05-18-17 EPA 200.7 <2.8 05-18-17 09:07 ug/l Zinc, total EPA 9010 C 10:50 22 05-16-17 Cyanide, total ug/l EPA 9014 EPA 9010 C <10 05-16-17 10:50 Cyanide, amenable ug/l EPA 9014 Phenolics, total SM 5530D-2005 <0.006 mg/l 05-11-17 16:07 SM 2340 B/ 12:12 147 05-18-17 Hardness mg/l EPA 200.7

June 5, 2017 Page 1

CITY OF MONETT

Re: CaSi File/Case/Log: 0036/171378-1379/3976 Samples Received: 05-10-17, 11:27 June 5, 2017 Page 2

PRIORITY POLLUTANTS, VOLATILE FRACTION

CONTROL NUMBER		171379				
SAMPLE DESCRIPTION		EFFLUENT	AG	UNITS	ANALYSIS	ANALYSIS
PARAMETER	METHOD	05-10-17 07:45	Ц		DATE	TIME
1,1,1-Trichloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
1,1,2,2-Tetrachloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
1,1,2-Trichloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
1,1-Dichloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
1,1-Dichloroethylene	SW 624	<1.0		ug/l	05-17-17	03:34
1,2-Dichloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
1,2-Dichloropropane	SW 624	<1.0		ug/l	05-17-17	03:34
2-Chloroethylvinyl Ether	SW 624	<5.0	EZ	ug/l	05-17-17	03:34
Acrolein	SW 624	<25	EV	ug/l	05-17-17	03:34
Acrylonitrile	SW 624	<1.0		ug/l	05-17-17	03:34
Benzene	SW 624	<1.0		ug/l	05-17-17	03:34
Bromodichloromethane (Dichlorobromomethane)	SW 624	<1.0		ug/l	05-17-17	03:34
Bromoform	SW 624	<1.0		ug/l	05-17-17	03:34
Bromomethane (Methyl Bromide)	SW 624	<1.0		ug/l	05-17-17	03:34
Carbon Tetrachloride	SW 624	<1.0		ug/l	05-17-17	03:34
Chlorobenzene	SW 624	<1.0		ug/l	05-17-17	03:34
Chloroethane	SW 624	<1.0		ug/l	05-17-17	03:34
Chloroform	SW 624	<1.0		ug/l	05-17-17	03:34
Chloromethane (Methyl Chloride)	SW 624	<1.0		ug/l	05-17-17	03:34
Dibromochloromethane (Chlorodibromomethane)	SW 624	<1.0		ug/l	05-17-17	03:34
Ethylbenzene	SW 624	<1.0		ug/l	05-17-17	03:34
Methylene Chloride	SW 624	<1.0		ug/l	05-17-17	03:34
Tetrachloroethylene (Tetrachloroethene)	SW 624	<1.0		ug/l	05-17-17	03:34
Toluene	SW 624	<1.0		ug/l	05-17-17	03:34
Trichloroethylene	SW 624	<1.0		ug/l	05-17-17	03:34
Vinyl Chloride	SW 624	<1.0		ug/l	05-17-17	03:34
1,2-Dichloroethylene (cis)	SW 624	<1.0		ug/l	05-17-17	03:34
1,2-Dichloroethylene, (trans)	SW 624	<1.0		ug/l	05-17-17	03:34
cis-1,3-Dichloropropene (1,3-Dichloropropylene)	SW 624	<1.0		ug/l	05-17-17	03:34
trans-1,3-Dichloropropene (1,3-Dichloropropylene)	SW 624	<1.0		ug/l	05-17-17	03:34
1,2-Dichlorobenzene	SW 624	<1.0		ug/l	05-17-17	03:34
1,3-Dichlorobenzene	SW 624	<1.0		ug/l	05-17-17	03:34
1,4-Dichlorobenzene	SW 624	<1.0		ug/l	05-17-17	03:34

EZ: Acid preservation is not appropriate of the analysis of 2-Chloroethylvinyl ether. The stated reporting limit or concentration is an estimated value. EV: Using the recommended analytical procedure, this analyte routinely yields low and/or variable recoveries. The stated reporting limit or concentration is an estimated value.

CITY OF MONETT

Re: CaSi File/Case/Log: 0036/171378-1379/3976 Samples Received: 05-10-17, 11:27 June 5, 2017 Page 3

PRIORITY POLLUTANTS, BASE/NEUTRAL EXTRACTABLE FRACTION

CONTROL NUMBER	171379						
SAMPLE DESCRIPTION	EFFLUENT	AG	UNITS	ANALYSIS	ANALYSIS		
PARAMETER	METHOD	05-10-17 07:45	Ē		DATE		
1,2,4-Trichlorobenzene	SW 625	<5.0	-	ug/l	05-28-17	13:09	
1,2-Diphenylhydrazine	SW 625	<5.0		ug/l	05-28-17	13:09	
2,4,6-Trichlorophenol	SW 625	<5.0		ug/l	05-28-17	13:09	
2,4-Dichlorophenol	SW 625	<5.0		ug/l	05-28-17	13:09	
2,4- and 2,5-Dimethylphenol	SW 625	<10		ug/l	05-28-17	13:09	
2,4-Dinitrophenol	SW 625	<25		ug/l	05-28-17	13:09	
2,4-Dinitrotoluene	SW 625	<5		ug/l	05-28-17	13:09	
2,6-Dinitrotoluene	SW 625	<5.0		ug/l	05-28-17	13:09	
2-Chloronaphthalene	SW 625	<5.0		ug/l	05-28-17	13:09	
2-Chlorophenol	SW 625	<5.0		ug/l	05-28-17	13:09	
2-Nitrophenol	SW 625	<5.0		ug/l	05-28-17	13:09	
Dichlorobenzidine 3, 3'	SW 625	<5.0	EV	ug/l	05-28-17	13:09	
4,6-Dinitro-o-Cresol	SW 625	<15		ug/l	05-28-17	13:09	
4-Bromophenyl Phenyl Ether	SW 625	<5.0		ug/l	05-28-17	13:09	
4-Chlorophenyl Phenyl Ether	SW 625	<5.0		ug/l	05-28-17	13:09	
4-Nitrophenol	SW 625	<20		ug/l	05-28-17	13:09	
Acenaphthene	SW 625	<5.0		ug/l	05-28-17	13:09	
Acenaphthylene	SW 625	<5.0		ug/l	05-28-17	13:09	
Anthracene	SW 625	<5.0		ug/l	05-28-17	13:09	
Benzidine	SW 625	<5.0	EV	ug/l	05-28-17	13:09	
Benzo (a) Anthracene	SW 625	<5.0		ug/l	05-28-17	13:09	
Benzo (a) Pyrene	SW 625	<5.0		ug/l	05-28-17	13:09	
Benzo (b) + (j) Fluoranthene (3,4-Benzo Fluoranthene)	SW 625	<5		ug/l	05-28-17	13:09	
Benzo (g,h,i) Perylene (Benzo (GH) Perylene)	SW 625	<5.0		ug/l	05-28-17	13:09	
Benzo (k) Fluoranthene	SW 625	<5		úg/l	05-28-17	13:09	
bis (2-Chloroethoxy) Methane	SW 625	<5.0		ug/l	05-28-17	13:09	
bis (2-Chloroethyl) Ether	SW 625	<5.0		ug/l	05-28-17	13:09	
bis (2-Chloroisopropyl) Ether	SW 625	<5.0		ug/l	05-28-17	13:09	
bis (2-Ethylhexyl) Phthalate	SW 625	<5.0		ug/l	05-28-17	13:09	
Butyl Benzyl Phthalate	SW 625	<5.0		ug/l	05-28-17	13:09	
Chrysene	SW 625	<5.0		ug/l	05-28-17	13:09	

EV: Using the recommended analytical procedure, this analyte routinely yields low and/or variable recoveries. The stated reporting limit or concentration is an estimated value.

CITY OF MONETT

Re: CaSi File/Case/Log: 0036/171378-1379/3976 Samples Received: 05-10-17, 11:27 June 5, 2017 Page 4

PRIORITY POLLUTANTS, BASE/NEUTRAL EXTRACTABLE FRACTION, CONTINUED

CONTROL NUMBER		171379				
SAMPLE DESCRIPTION		EFFLUENT	AG	UNITS	ANALYSIS	
PARAMETER	METHOD	05-10-17 07:45			DATE	
Di-n-butylphthalate	SW 625	<5.0		ug/l	05-28-17	13:09
Di-n-octylphthalate	SW 625	<10		ug/l	05-28-17	13:09
Dibenzo (a,h) Anthracene	SW 625	<5		ug/l	05-28-17	13:09
Diethylphthalate	SW 625	<5.0		ug/l	05-28-17	13:09
Dimethylphthalate	SW 625	<5.0		ug/l	05-28-17	13:09
Fluoranthene	SW 625	<5.0		ug/l	05-28-17	13:09
Fluorene	SW 625	<5.0		ug/l	05-28-17	13:09
Hexachlorobenzene	SW 625	<5		ug/l	05-28-17	13:09
Hexachlorobutadiene	SW 625	<5		ug/l	05-28-17	13:09
Hexachlorocyclopentadiene	SW 625	<10		ug/l	05-28-17	13:09
Hexachloroethane	SW 625	<5.0		ug/l	05-28-17	13:09
Indeno (1,2,3-cd) Pyrene	SW 625	<5.0		ug/l	05-28-17	13:09
Isophorone	SW 625	<5.0		ug/l	05-28-17	13:09
N-Nitrosodi-n-Propylamine	SW 625	<5.0		ug/l	05-28-17	13:09
N-Nitrosodimethylamine	SW 625	<10		ug/l	05-28-17	13:09
N-Nitrosodiphenylamine	SW 625	<5.0		ug/l	05-28-17	13:09
Naphthalene	SW 625	<5.0		ug/l	05-28-17	13:09
Nitrobenzene	SW 625	<5.0		ug/l	05-28-17	13:09
p-Chloro-m-Cresol	SW 625	<5.0		ug/l	05-28-17	13:09
Pentachlorophenol	SW 625	<5		ug/l	05-28-17	13:09
Phenanthrene	SW 625	<5		ug/l	05-28-17	13:09
Phenol	SW 625	<5		ug/l	05-28-17	13:09
Pyrene	SW 625	<5.0		ug/l	05-28-17	13:09

Laboratory analyses were performed on samples utilizing procedures published in Title 40 of the Code of Federal Regulations, Parts 136 or 141, or in EPA Publication SW-846, 3rd edition, September 1986, and the latest promulgated update. Data qualifiers may be appended to this report. All results are reported on a wet weight basis, unless otherwise noted.

Samples are maintained in the laboratory for fourteen (14) days following issuance of the final report, unless an alternate arrangement is agreed to in writing. All samples determined to be hazardous, or which may not be disposed to the publicly owned treatment works (POTW) or to the sanitary landfill, will be returned to you for proper disposal.



December 05, 2016

Dave Sims Monett, City of 217 5th St. Monett, MO 65807

Dear Dave Sims:

Please find enclosed the analytical results for the sample(s) the laboratory received on **11/15/16 10:45** am and logged in under work order **6112245**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Chad Cooper Laboratory Supervisor (417) 864-8924 ccooper@pdclab.com





PDC Laboratories, Inc.

1805 West Sunset Street Springfield, MO 65807 (417) 864-8924

ANALYTICAL RESULTS

Sample: Name: Matrix:	6112245-02 Effluent Waste Water - Compo	site				Sampled: Received:	11/15/16 (11/15/16 1	08:00 10:45
Parameter		Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u> Aiscellaneous - S</u>	SPMO							
VET Testing Multiple ubcontracted	e Dilution -	Subcontracted		Pass	11/16/16 10:15	11/16/16 10:15	KBW	Subcontracted*
	·							
				-				



PDC Laboratories, Inc.

1805 West Sunset Street Springfield, MO 65807 (417) 864-8924

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553 Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870 Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870) Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338) Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050 Drinking Water Certifications: Missouri (1050) Missouri Department of Natural Resources

* Not a TNI accredited analyte

Qualifiers

Pass Pass



Certified by:

: Chad Cooper, Laboratory Supervisor



4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#2013617 November 16, 2016 through November 18, 2016

Tests performed by:

John P. Clippard / Chemical Analyst at Environmental Analysis South (EAS) Kelly J. Ray / Biologist at Environmental Analysis South (EAS) Sara C. Shields / Lab Supervisor - Chemist at Environmental Analysis South (EAS) David F. Warren / Lab Director - Chemist at Environmental Analysis South (EAS)

- 1. Report Summation
 - 1.1. Data Summation
 - 1.2. Conclusion
- 2. Method Summation
 - 2.1. Test Conditions and Methods
 - 2.2. Potassium chloride Reference Salt Test
 - 2.2.1. Pimephales promelas data
 - 2.2.2. Ceriodaphnia dubia data
 - 2.3. Literature Cited
- 3. Raw Data Bench Sheets
 - 3.1. Initial observations (page 1)
 - 3.2. Zero hour Observations (page 1)
 - 3.3. Twenty-four (24) hour Observations (page 1)
 - 3.4. Forty-eight (48) hour Observations (page 1)
 - 3.5. Survival Data Table (page 2)
 - 3.6. Test Comments (page 3)
- 4. Chain of Custody
- 5. MO DNR "Whole Effluent Toxicity (WET) Test Report (Form 780-1899)

Page 1 of 4

Analytical Chemistry · Research · Field Studies

Page 4 of 13



4000 East Jackson Blvd. · Jackson, MO 63755 · 573-204-8817 · Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#2013617 November 16, 2016 through November 18, 2016

1. REPORT SUMMATION:

1.1. Multiple Dilution Data Summation

Test Solution	Pimephales promelas Acute Toxicity Test 48 Hour Survival	Ceriodaphnia dubia Acute Toxicity Test 48 Hour Survival
Reconstituted Control (RC)	100%	100%
Upstream Control (UC)	N/A	N/A
6.25% Effluent	100%	100%
12.5% Effluent	100%	100%
25% Effluent	100%	100%
50% Effluent	100%	95%
100% Effluent	100%	100%
Estimated 48 Hour LC50 Value	>100% Effluent	>100% Effluent
Acute Toxic Unit (TUa)	<1.0	<1.0
Result of Toxicity Test	Monitor Only	Monitor Only

* Indicates a significant difference at alpha = 0.5 between effluent and control survival data. Conclusion:

Pimephales promelas 48 hour WET results:

Ceriodaphnia dubia 48 hour WET results:

LC 50 > 100% using the Graphical Method NOAEC = 100% by Steel's Many-One Rank Test LC 50 >100% using Trimmed Spearmen-Karber NOAEC = 100% by Steel's Many-One Rank Test

Approved by

Sara C. Shields, Chemist

Page 2 of 4



4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#2013617 November 16, 2016 through November 18, 2016

2. TEST METHOD SUMMARY

2.1. TEST CONDITIONS AND METHODS:

	Ceriodaphnia dubia:	Pimephales promelas:
Test duration:	48 hours	48 hours
Temperature:	24 - 26 degree Celsius	24 - 26 degree Celsius
Light quality:	Ambient laboratory illumination	Ambient laboratory illumination
Photoperiod:	16 hour light, 8 hours dark	16 hour light, 8 hours dark
Control Water:	Moderately Hard Reconstituted Water	Moderately Hard Reconstituted Water
Dilution Water:	Upstream Water - If unavailable or toxic, then control water will be used.	Upstream Water - If unavailable or toxic, then control water will be used.
Size of test vessel:	30 milliliters	250 milliliters
Volume of test solution:	15 milliliters	200 milliliters
Age of test organisms:	<24 hours	1 -14 days (all same age)
Number of organisms/test vessel:	5	10
Number of replicates/concentration:	4	2
Number of organisms/concentration:	20	40 for a single dilution test and 20 for a multiple dilution test
Feeding regime:	None (fed prior to test)	None (fed prior to test)
Aeration:	None	None
Test acceptability criterion:	90% or greater survival in controls	90% or greater survival in controls

The methodology used for the chemistry data was taken from the *Standard Methods for the Examination* of *Water and Wastewater*, 18th edition (1992). The exception was hardness, which was determined using a Hach EDTA titration test kit. The toxicity tests follow guidelines laid out in the permittee's NPDES permit and were conducted according to EPA approved methods (USEPA 2002).

All test organisms were cultured according to EPA approved methods (USEPA 2002). The Ceriodaphnia dubia and the Pimephales promelas were obtained from C-K Associates Inc. located in Baton Rouge, Louisiana and shipped overnight for use in the whole effluent toxicity test.

Page 3 of 4



4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#2013617 November 16, 2016 through November 18, 2016

2.2. REFERENCE TOXICITY TEST:

Environmental Analysis South performs monthly reference toxicity tests. The most recent reference test was initiated on November 9, 2016 using KCL Lot #41713. Following are the results:

2.2.1. P. promelas - 48 hr. Acute Test - LC50 = 0.973 g/l 95%CI (0.795 g/l -1.421 g/l) EAS %CV = 14.1%

National Warning Limits (75th percentile) = 19%CV

National Control Limits (90th percentile) = 33%CV

2.2.2. C. dubia - 48 hr. Acute Test - LC50 = 0.446 g/l 95%Cl (0.330 g/l - 0.698g/l) EAS %CV = 17.9%

National Warning Limits (75th percentile) = 29%CV National Control Limits (90th percentile) = 34%CV

2.3. LITERATURE CITED:

- 1. APHA. 1992. Standard methods for the examination of water and wastewater, 18th Ed. American Public Health Association, Washington, D.C.
- 2. USEPA. 2002. Methods for measuring the acute toxicity of effluents and receiving waters to freshwater and marine organisms, 5th Ed. EPA-821-R-02-012
- 3. USEPA 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications under the National Pollutant Discharge Elimination System, (Table B-2). June 2000. EPA 833-R-00-003.

Page 4 of 4

Page 1 of 3

WHOLE EFFLUENT TEST conducted in accordance with US EPA 600/4-90/027 Fifth Edition October 2002

· · · · · · · · · · · · · · · · · · ·					T HET GATE		-	Line of the second		10.000				
CLIENT	T NAME:	Monett Wast	ewater Tre	atment Plan	t, Outfall 002, 24 hr compo	site								
NPDES N	UMBER:	MO-0021440)											
TYPE OF M	ETHOD:	nultiple dilution, 48 hrs, PP & CD, AEC=100%, Tua report												`
DATE & TIME OF COLLI	ECTION:	11/15/16 0800 hrs by Monett Upstream: Clear Creek												
DATE & TIME OF SUBM	ISSION:	11/16/16 100	00 hrs by U	IPS			Not availab	ole						
INITIAL OBSERV	ATIONS	DATE	TIME	ANALYST	QC LOT	NTUC	INT RC							
LOG NUMBER / ID N	UMBER	(Constant		Sale Sale State		Netise Splatter of	2013617		RC4169					
	pH - SU	11/16/16	1015 hrs	SCS	SB114 (8.8-9.2)	8.99	7.38		7.61					
TEMPERATURE ^O C RE	ECEIVED	11/16/16	1015 hrs	SCS	EAS 106		4		21					
SPECIFIC CONDUCTANCE	Eumhos	11/16/16	1015 hrs	SCS	ERA243-506 (308-346)	324	1718		253					
HARDNES	SS - ppm	11/17/16	1100 hrs	SCS	DMRQA36 (251-399)	285	191		73.6					
CHLORIN	NE - ppm	11/16/16	1015 hrs	SCS	tap water	+	<0.04		<0.04					
DISSOLVED OXYGE	EN - pom	11/16/16	1015 hrs	SCS	cal@840		10.6		9					
TOTAL ALKALINI	TY - ppm	11/17/16	1130 hrs	SCS	P243-506 (48.8-58.3)	57.0	177		56.2					
INITIAL AMMON	IA - pom	11/22/16	1200 hrs	JPC	EAS2641 (8-12)	10.7	<0.05	ter and the second diversity of	<0.05					
TOTAL DISSOLVED SOL	DS -pom										17431			- Street
0 HOUR OBSER	VATIONS	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
	pH - SU	11/16/16	1100 hrs	SCS	SB114 (8.8-9.2)	8.99	8.17		7.76	7.88	8.01	8.11	8.20	
TEMPERA	TURE °C	11/16/16	1100 hrs	SCS	EAS 106		24.8	- Autor	24.6	24.2	23.9	24.2	24.6	
SPECIFIC CONDUCTANC	E umhos	11/16/16	1100 hrs	SCS	ERA243-506 (308-346)	324	234		1653	1019	613	427	336	
DISSOLVED OXYG	EN - ppm	11/16/16	1100 hrs	SCS	cal@840		9.0		10.2	9.7	9.4	9.2	9.2	
					1									.
24 HOUR OBSERVATI	IONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
**************************************	pH - SU	11/17/16	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.13		8.18	8.08	8.07	8.12	8.19	
TEMPERA	ATURE °C	11/17/16	1100 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
SPECIFIC CONDUCTANC	E umhos	11/17/16	1100 hrs	SCS	ERA229-506 (308-346)	321	258		1532	1022	632	446	352	
DISSOLVED OXYG	EN - ppm	11/17/16	1100 hrs	SCS	cal@840		8.2		7.9	. 8	7.9	8	8	1
48 HOUR OBSERVATI	IONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AE
	pH - SU	11/18/16	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.04		8,10	8.05	8.10	8.14	8.27	
TEMPER	ATURE °C	11/18/16	1100 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	1
SPECIFIC CONDUCTANC	CE umhos	11/18/16	1100 hrs	SCS	ERA243-506 (308-346)	324	269		1739	1030	636	451	379	
DISSOLVED OXYG	EN - ppm	11/18/16	1100 hrs	SCS	cal@840		8.0		8.1	8.0	8.1	8.2	8.5	
FINAL AMMO	NIA - ppm			1	DMRQA33 (10.0-16.8)									
			L				-				-			
24 HOUR OBSERVAT	IONS - CD	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AE
	pH - SU	11/17/16	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.21		8.15	8.18	8.23	8.33	8.49	
TEMPER	ATURE °C	11/17/10	5 1100 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
SPECIFIC CONDUCTANC	CE umhos	11/17/16	6 1100 hrs	SCS	ERA243-506 (308-346)	321	254		1601	986	617	431	321	
DISSOLVED OXYO	GEN - ppm	11/17/16	3 1100 hrs	SCS	cal@840		8.9		9.1	8.9	8.8	9.1	9.2	
48 HOUR OBSERVAT	IONS - CE	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AE
J	pH - SL	J 11/18/10	3 1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.62		8.18	8.24	8.32	8.43	8.58	
C TEMPER	ATURE °C	11/18/10	6 1100 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
COPECIFIC CONDUCTAN	CE umho	s 11/18/1	6 1100 hrs	SCS	ERA243-506 (308-346)	324	308		1651	998	631	440	392	
O DISSOLVED OXYO	GEN - ppn	n 11/18/1	6 1100 hrs	SCS	cal@840		9.1		9.1	9.1	9.2	9.1	9.0	
FINAL AMMO	DNIA - ppn	n	T		DMRQA33 (10.0-16.8)		_	t						
		1	- 1					Second to be the second						

Approved by: Mult

Date: 11/23/16

WHOLE EFFLUENT TEST conducted in accordance with US EPA 600/4-90/027 Fifth Edition October 2002

Monett Wastewater Treatment Plant, Outfall 002, 24 hr composite EAS LOG# 2013617 November 16, 2016 Time Test Began: 1100 hrs Date Test Began: Analyst 1: DFW Analyst 2: KJR November 18, 2016 Time Test Finished: 1100 hrs Date Test Finished: Analyst 3: SCS HATCH NUMBER: 4 c-k P. promelas (PP) 5 days AGE: RC UC 100% 50% 25% 12.5% 6.25% X% AEC PERIOD ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE 0 HR-PP 10,10 10,10 10,10 10,10 10,10 10,10 24 HR-PP 10,10 10,10 10,10 10,10 10,10 10,10 48 HR-PP 10,10 10,10 10,10 10,10 10,10 10,10 AGE: <24 HATCH NUMBER: 3401 c-k Ceriodaphnia dubia (CD) hours RC UC 100% 50% 25% 12.5% 6.25% X% AEC PERIOD ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE 0 HR-CD 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 24 HR-CD 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5

5,5,4,5

5,5,5,5

Page 9 of 13

Approved by Sult

48 HR-CD

5,5,5,5

Date: 11/23/16

5,5,5,5

5,5,5,5

5,5,5,5

Page 2 of 3

WHOLE EFFLUENT TEST conducted in accordance with US EPA 600/4-90/027 Fifth Edition October 2002

				Notes &	Comme	ents					
1								1	1		
	I		I	l	l				ł		
	Patration and the second s							and the second		Automote = 1	A.B
Anna		 								- Minne Krane .x. Minsel	
		 						·····			
		 									_
								and streets by			
	ANATOLISIA.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1	 			ur an ann an	*	de airt mideren die teste fon teste daen pe		fer felten er en		
	·····	 									
		 							and the second se		
		 teres and the second									
		 and the state of the								<u> </u>	
and the second s	the second se										

Page 3 of 3

Page 10 of 13

Prepared by

Date: 11/23/14

	the of	138869									
4	y' O' Cex	PDC Laboratories, Inc. 6112245									
	SENDING LABORATORY PDC Laboratories, Inc. 1805 W Sunset St Springfield, MO 65807 (417) 864-8924		RECEIVING LABORATO Environmental Analysis So 4000 East Jackson Blvd Jackson, MO 63755 (573) 204-8817	Suth							
	Sample: 6112245-01 Name: Effluent	Month	Sample Matrix:	t: 11/15/16 08:00 Water							
	Analysis	Due	Expires	nents Jung. d=							
	01-WET Multiple SPMO	11/29/16 16:00	11/17/16 08:00	(OC							
	2013617			Î							
" απη στρική κατάνι της ποι ότι και θε π. Το τημαν τη παριοτική στην ποριά στην την στινική την π. τ. το την ο ποιτο γ 											
		Please email results to Cl	had Cooper at ccooper@pdclab.c	:om							
T	Date Shipped: 11/1510	Total # of Containers:	Sample Origin (State): Date Results Neede	<u>(W</u> PO #:							
R	elinquished By Date/	Time Received By	Sample Ter Sample (s) Date/Time Bottles Fille Samples Rille Samples Rille Date/Time Date/Time	nperature Upon Receipt*C Received on Ice Y or N les Received in Good Condition Y or N id with Adequate Volume Y or N seelved Within Hold Time Y or N Faken From Sample Bottle Y or N							
				Page 11 of 13							

···.
Facility Name	Monett	Vastewate	r Treatment	Plant	Rec	eiving Water	Cloor	reek not a	vailable	
Permit Number	MO-00	21440	a rreatment	Fidili	Labo	oratory Name	Environn	nental Analys	is South, Ir	nc.
Outfail	002				Labor	atory Report #		MO 2	012617	
	1002			SAMPI	E INFORMATI	ON		10_2	013017	
Sample Numbe	r	Sa	mple Collection		Sample T	Sample Temperature (°C)		Hand delivered? (If yes, ≤ 4 hrs?	Hold Time ≤ 36 hours?	Sample
	Effluent or Upstream	Sample Typ	e Beginning Date	End Date	At Collection	At Lab	At Lab			
1	2013617	Effluent	11/14/16	11/15/16		4	7.38	DYEN	BYDN	BYD
2								DYDN	DYDN	DYD
3				-				DYDN	DYDN	OYO
4						·		DYDN	DYDN	DYD
escribe any unu	sual conditions d	uring sampling t	hat might influence to	est results					l	1
	TEST	INFORMATI	ON - ACUTE				QA/QC CONDI	FIONS - ACUTE		
Test Method:	C. dubia	2002.0	P. promelas	2000.0					YES	NO
Date Test	11/16/201	6			Did test condi	tions meet all test ad	ceptability criter	ion required by		
AEC/IWC Info:		AEC	100%		Temperatures		1			
	1008/	100% 50% 25% 13 S% Temperatures maintained during test (25 ± 1°C)							V	
Dilution Series	100%	30%	23%	12.3%	Dissolved oxy	gen > 4.0 mg/L thro	ughout test?		V	
	6.25%	DIV (1.11	7	TO INTO ON	Bon _ no mg b the	0.0 Sti theory	hout to at	V	
Dilution Water	C., auoia	KW L	LWB		Effluent pri m	aintained within 0.0	- 9,0 SO (moug	nout test?		
Situation Trater,	P. promelas	RW 🗆	LW 🛢		Concurrent or	monthly reference t	ests within accept	table limits?	\checkmark	
	RW = Receiving	Stream Control	LW = Lab	Water Control	Were effluent filtration, act chlorination or	samples modifie ration, chemical pH adjustment)	ting? (ex. ding de-		\checkmark	
omments:					Comments:					
	-		WATER CHEMI	STRY (All values re	ported in mg/L, ex	ccept for pH and con	nductivity)	· · · · · · · · · · · · · · · · · · ·		
Sample	Sample	Conductivity	Unionized	Hardness	Alkalinity	pH (SU)	Total Residual	Other	Other	Other
Type	Number	(µmhos)	Ammonia			After Warming	Chlorine			
Opstream	not available									
Effluent	2013617	1718	<0.010	191	177	7.76	<0.05	DO=10.6		
Lab Water	RC4169	253	<0.010	73.6	56.2	8.17	<0.05	DO=9.0		
nments:		-			1					
a limit = Monito	ring only.		Pimephales prom	elas Acute Results	LCso=	>100%	Confidence	N/A	TUa=	<1.0
			Ceriodaphnia du	bia Acute Results	LC50=	>10070	Confidence	NIA	TUa=	<1.0
						>100%	Interval % =	IN/A		<1.0
						0				
	Receiving Wa	ater Controls			Lab Water	Controls				
Fathead Mi	nnow	Ceriodap	phnia dubia	Fathcad N	linnow	Ceriodaphr	nia dubia			
rvival≥90%	OY ON S	urvival $\ge 90\%$	DYDN	Survival≥90%	BYON	Survival ≥ 90%	BY DN			
ceiving v	vater not	availabl	e		· · · · · · · · · · · · · · · · · · ·					
NATURE AND	TITLE OF AUT	HORIZED IND	VIDUAL, IN ACCO	RDANCE WITH I	0 CSR 20-6.010	DATE		PH	ONE NUMBER	

Page 12 of 13

PDC LABORATORIES, INC. **1805 WEST SUNSET** SPRINGFIELD, MO 65807

PHONE # 417-864-8924 FAX # 417-864-7081

State where samples collected

		ALL HIGHL	IGHTED AREA	S MUST BE CO	MPLETED BY	CLIENT (PLEA	SE PRIN	T) - (SAMPLE ACCEPTANCE	E POLICY ON REVERSE)
	Ocity of Monett	PROJECT NU	MBER	P.O. NUMBER	MEANS	SHIPPED	3 A	NALYSIS RÉQUESTED	(FOR LAB USE ONLY)
Constant State	SON, Elsenhower	PHONE NUM	1BER	FAX NUMBER	DATES	HIPPED			LOGIN #
and the second second	orry State Ziri Mos 65708		n 1 01	50M	MATRIX T WW-WASTE DW-DRINKII GW-GROUN	YPES: WATER NG WATER ID WATER	7		TEMPLATE:
Serve Variation	DOUC SIMS	SAMPLERS SIGNATURE	els.		WWSL-SLUI NAS-SOLID LCHT-LEAC	DGE	ME.		PHOJ. MGH.:
	2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT	DATE COLLECTED	TIME COLLECTED	SAMPLE TYP GRAB COM	E MATRIX	BOTTLE COUNT	4-		REMARKS
	Plant Eff.	11-14,15	0800	· · ·	ww		×		FWETCube
-									
					-				
	· · · · · · · · · · · · · · · · · · ·								
	5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) M 5 (RUSH TAT IS SUBJECT TO POC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX FAX # PHONE # EMAIL ADDRE	PHONE	SH DATE	RESULTS NEED	6	The sample this area yo the sample this area yo sample ten	e temperate ou request temperatu ou allow the operature	If will be measured upon receiption the lab notify you, before p that the lab notify you, before p re is outside of the range of 0. a lab to proceed with analytical	hipt at the lab. By Initialing proceeding with analysis, if 1-6.0°C. By not initialing testing regardless of the
	Paul Olson	TE S-16 ECEIV	PED BY: (SIGNAT	TURE)			DATE TIME		S: (FOR LAB USE ONLY)
Pane	RELINQUISHED BY: (SIGNATURE)	ATE RECEIV		(SIGNATURE)	ŀ		PATE TIME DATE	16 SAMPLE TEMPERATUR CHILL PROCESS STAR SAMPLE(S) RECEIVED PROPERBOTTLES RECE BOTTLES FILLED WITH BOTTLES FILLED WITH	IE UPON RECEIPT
13 of	U TI	IME					TIME	SAMPLES RECEIVED V (EXCLUDES TYPICAL F DATE AND TIME TAKEN	VITHIN HOLD TIME(S) & OR N FIELD PARAMETERS) I FROM SAMPLE BOTTLE
13	Copies: white should accompany samples	to PDC Labs	. Yello	w copy to t	e retained	by the cli	ent.		PAGEOF

CHAIN OF CUSTODY RECORD



July 06, 2015

Dave Sims Monett, City of 217 5th St. Monett, MO 65807

Dear Dave Sims:

Please find enclosed the analytical results for the sample(s) the laboratory received on 6/16/15 9:12 am and logged in under work order 5062462. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Chad Cooper Laboratory Supervisor (417) 864-8924 ccooper@pdclab.com







PDC Laboratories, Inc.

1805 West Sunset Street Springfield, MO 65807 (417) 864-8924

ANALYTICAL RESULTS

Sample: Name: Matrix:	5062462-01 WET TEST EFFLUENT Water - Composite	COMPOSITE				Sampled: Received:	06/16/15 (06/16/15 (08:00 09:12
Parameter		Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Miscellaneous - S	SPMO							
WET Testing Multiple Dilution - Subcontracted subcontracted		Subcontracted		Pass	06/17/15 10:45	06/17/15 10:45	KBB	Subcontracted*



PDC Laboratories, Inc.

1805 West Sunset Street Springfield, MO 65807 (417) 864-8924

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553 Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870 Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870) Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338) Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050 Drinking Water Certifications: Missouri (1050) Missouri Department of Natural Resources

* Not a TNI accredited analyte

Qualifiers

Pass Pass



Certified by: Chad Cooper, Laboratory Supervisor



4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#1815620 June 17, 2015 through June 19, 2015

Tests performed by:

John P. Clippard / Chemical Analyst at Environmental Analysis South (EAS) Kelly J. Ray / Biologist at Environmental Analysis South (EAS) Sara C. Shields / Lab Supervisor - Chemist at Environmental Analysis South (EAS) David F. Warren / Lab Director - Chemist at Environmental Analysis South (EAS)

- 1. Report Summation
 - 1.1. Data Summation

1.2. Conclusion

2. Method Summation

2.1. Test Conditions and Methods

- 2.2. Potassium chloride Reference Salt Test
 - 2.2.1. Pimephales promelas data:
 - 2.2.2. Ceriodaphnia dubia data
- 2.3. Literature Cited
- 3. Raw Data Bench Sheets
 - 3.1. Initial observations (page 1)
 - 3.2. Zero hour Observations (page 1)
 - 3.3. Twenty-four (24) hour Observations (page 1)
 - 3.4. Forty-eight (48) hour Observations (page 1)
 - 3.5. Survival Data Table (page 2)
 - 3.6. Test Comments (page 3)
- 4. Chain of Custody

5. MO DNR "Whole Effluent Toxicity (WET) Test Report (Form 780-1899)

Page 4 of 13

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#1815620 June 17, 2015 through June 19, 2015

1. REPORT SUMMATION:

1.1. Multiple Dilution Data Summation

Test Solution	Pimephales promelas Acute Toxicity Test 48 Hour Survival	Ceriodaphnia dubla Acute Toxicity Test 48 Hour Survival
Reconstituted Control (RC)	100%	100%
Upstream Control (UC)	N/A	N/A
6.25% Effluent	100%	100%
12.5% Effluent	100%	100%
25% Effluent	100%	100%
50% Effluent	100%	100%
100% Effluent	100%	100%
Estimated 48 Hour LC ₅₀ Value	>100% Effluent	>100% Effluent
Acute Toxic Unit (TUa)	<1.0	<1.0
Result of Toxicity Test	Monitor Only	Monitor Only

* Indicates a significant difference at alpha = 0.5 between effluent and control survival data. Conclusion:

Pimephales promelas 48 hour WET results:

Ceriodaphnia dubia 48 hour WET results:

LC 50 > 100% using the Graphical Method NOAEC = 100% by Steel's Many-One Rank Test LC 50 >100% using the Graphical Method NOAEC = 100% by Steel's Many-One Rank Test

Approved by

Shields, Chemist

Page 2 of 4

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#1815620 June 17, 2015 through June 19, 2015

2. TEST METHOD SUMMARY 21. TEST CONDITIONS AND METHODS:

	Ceriodaphnia dubia:	Pimephales promelas:
Test duration:	48 hours	48 hours
Temperature:	24 - 26 degree Celsius	24 - 26 degree Celsius
Light quality:	Ambient laboratory illumination	Ambient laboratory illumination
Photoperiod:	16 hour light, 8 hours dark	16 hour light, 8 hours dark
Control Water:	Moderately Hard Reconstituted Water	Moderately Hard Reconstituted Water
Dilution Water:	Upstream Water - If unavailable or toxic, then control water will be used.	Upstream Water - If unavailable or toxic, then control water will be used.
Size of test vessel:	30 milliliters	250 milliliters
Volume of test solution:	15 milliliters	200 milliliters
Age of test organisms:	<24 hours	1 -14 days (all same age)
Number of organisms/test vessel:	5	10
Number of replicates/concentration:	4	2
Number of organisms/concentration:	20	40 for a single dilution test and 20 for a multiple dilution test
Feeding regime:	None (fed prior to test)	None (fed prior to test)
Aeration:	None	None
Test acceptability criterion:	90% or greater survival in controls	90% or greater survival in controls

The methodology used for the chemistry data was taken from the *Standard Methods for the Examination* of Water and Wastewater, 18th edition (1992). The exception was hardness, which was determined using a Hach EDTA titration test kit. The toxicity tests follow guidelines laid out in the permittee's NPDES permit and were conducted according to EPA approved methods (USEPA 2002).

All test organisms were cultured according to EPA approved methods (USEPA 2002). The Ceriodaphnia dubia and the Pimephales promelas were obtained from C-K Associates Inc. located in Baton Rouge, Louisiana and shipped overnight for use in the whole effluent toxicity test.

Page 3 of 4

Page 6 of 13

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING Monett Wastewater Treatment Plant Outfall 002 (24 hr composite) AEC = 100% MO-0021440 EAS LOG#1815620 June 17, 2015 through June 19, 2015

2.2. REFERENCE TOXICITY TEST:

Environmental Analysis South performs monthly reference toxicity tests. The most recent reference test was initiated on June 3, 2015 using KCL Lot #41713. Following are the results: 2.2.1. *P. promelas* - 48 hr. Acute Test - $LC_{50} = 0.916$ g/l 95%Cl (0.662 g/l -1.417 g/l) EAS %CV = 18.2% National Warning Limits (75th percentile) = 19%CV National Control Limits (90th percentile) = 33%CV 2.2.2. *C. dubia* - 48 hr. Acute Test - $LC_{50} = 0.474$ g/l 95%Cl (0.293 g/l - 0.655g/l) EAS %CV = 19.1% National Warning Limits (75th percentile) = 29%CV

National Warning Limits (75" percentile) = 29%CV National Control Limits (90th percentile) = 34%CV

2.3. LITERATURE CITED:

- 1. APHA. 1992. Standard methods for the examination of water and wastewater, 18th Ed. American Public Health Association, Washington, D.C.
- USEPA. 2002. Methods for measuring the acute toxicity of effluents and receiving waters to freshwater and marine organisms, 5th Ed. EPA-821-R-02-012
- USEPA 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications under the National Pollutant Discharge Elimination System, (Table B-2). June 2000. EPA 833-R-00-003.

Page 4 of 4

Page 7 of 13

	CLIENT NAME:	Monett Was	tewater Tre	atment Plan	t, Outfall 002, 24 hr compo	site								
	NPDES NUMBER:	MO-0021440	0				······							
	TYPE OF METHOD:	multiple dilut	tion, 48 hrs	, PP & CD, A	AEC=100%				1					
	DATE & TIME OF COLLECTION:	06/16/15 08	00 hrs by N	Ionett WWT	P			100 A	Upstream	Clear Cre	ek			
_	DATE & TIME OF SUBMISSION:	06/17/15 10	25 hrs by U	IPS					Not availa	ble				
	INITIAL OBSERVATIONS	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	INT EFFLI	NT UC	INT RC					
	LOG NUMBER / ID NUMBER				· · · · · · · · · · · · · · · · · · ·		1815620		RC4130					
	pH - SU	06/17/15	1045 hrs	SCS	SB114 (8.8-9.2)	8.96	7.47		7.19					
	TEMPERATURE °C RECEIVED	06/17/15	1045 hrs	SCS	EAS 106		4		22					
S	PECIFIC CONDUCTANCE umhos	06/17/15	1045 hrs	SCS	ERA229-506 (490-549)	539	1418		244					
	HARDNESS - ppm	06/17/15	1045 hrs	SCS	DMRQA34 (184-250)	240	220		80					
	CHLORINE - ppm	06/17/15	1045 hrs	SCS	tap water	+	<0.04		<0.04					•
	DISSOLVED OXYGEN - ppm	06/17/15	1045 hrs	SCS	cal@840		8.2		8.6					,
	TOTAL ALKALINITY - ppm	06/17/15	1330 hrs	SCS	DMRQA34 (61.9-83.7)	79.4	176		96.4					
	INITIAL AMMONIA - ppm	06/22/15	1100 hrs	JPC	DMRQA34 (5.78-8.90)	7.28	<0.05		< 0.05		_			
1	TOTAL DISSOLVED SOLIDS -ppm													
	0 HOUR OBSERVATIONS	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
	pH - SU	06/17/15	1200 hrs	SCS	SB114 (8.8-9.2)	8.96	7.23		7.15	7.17	7.16	7.14	7.18	
	TEMPERATURE °C	06/17/15	1200 hrs	SCS	EAS 106		23.4		23.6	24.4	24.4	24.2	24.3	
	PECIFIC CONDUCTANCE umhos	06/17/15	1200 hrs	SCS	ERA229-506 (490-549)	539	247		1503	847	540	381	306	
	DISSOLVED OXYGEN - ppm	06/17/15	1200 hrs	SCS	cal@840		8.6		8.7	8.7	8.7	8.6	8.6	
	24 HOUR OBSERVATIONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
	pH - SU	06/18/15	1200 hrs	SCS	SB114 (8.8-9.2)	8.83	7.32		7.39	7.23	7.06	6.96	7.05	
	TEMPERATURE °C	06/18/15	1200 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
:	SPECIFIC CONDUCTANCE umhos	06/18/15	1200 hrs	SCS	ERA229-506 (490-549)	540	258		1546	895	547	388	314	
	DISSOLVED OXYGEN - ppm	- 06/18/15	1200 hrs	SCS	cal@840		. 8		8	8	7.9	7.8	7.8	
_	48 HOUR OBSERVATIONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
	pH - SU	06/19/15	1200 hrs	SCS	SB114 (8.8-9.2)	8.89	7.27		7.45	7.35	7.25	7.19	7.20	
	TEMPERATURE °C	06/19/15	1200 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
1	SPECIFIC CONDUCTANCE umhos	06/19/15	1200 hrs	SCS	ERA229-506 (490-549)	543	27.8		1640	941	562	398	323	
	DISSOLVED OXYGEN - ppm	06/19/15	1200 hrs	SCS	çal@840	1	7.7		8.1	8.1	8.0	8.0	7.9	1
	FINAL AMMONIA - ppm				DMRQA33 (10.0-16.8)		1		1	1			-	
	· · · ·						.							
-	24 HOUR OBSERVATIONS - CD	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
	pH - SU	06/18/15	1200 hrs	SCS	SB114 (8.8-9.2)	8.83	7.12		7.61	7.38	7.26	7.19	7.14	
	TEMPERATURE °C	06/18/15	1200 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	
	SPECIFIC CONDUCTANCE umhos	06/18/15	1200 hrs	SCS	ERA229-506 (490-549)	540	252		1504	848	538	388	312	
-	DISSOLVED OXYGEN - ppm	06/18/15	1200 hrs	SCS	cal@840		8.1		8.6	8.4	8.9	8.8	8.4	
	48 HOUR OBSERVATIONS - CD	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
P	.pH - SU	06/19/15	1200 hrs	SCS	\$B114 (8.8-9.2)	8.89	7.57		7.53	7.42	7.36	7.37	7.43	
ge	TEMPERATURE °C	06/19/15	1200 hrs	SCS	EAS 106		25.0		25.0	25.0	25.0	25.0	25.0	-
00	SPECIFIC CONDUCTANCE umhos	s 06/19/15	5 1200 hrs	SCS	ERA229-506 (490-549)	543	296		1502	848	556	402	323	
of	DISSOLVED OXYGEN - ppm	06/19/1	5 1200 hrs	SCS	cal@840		8.3	-	8.5	8.4	8.4	8.3	8.3	-
13	FINAL AMMONIA - ppm	n		1	DMRQA33 (10.0-16.8)	1	1		1	1	L	1	1	
		Al	4 1				-1"							
-	Assessed by		1 .1.			Data MALS	3/15	÷						

Approved by: Mules

Date: 06/93/11-

Monett Wastewater Treatment Plant, Outfall 002, 24 hr composite EAS LOG# 1815620 June 17, 2015 Time Test Began: 1200 hrs Analyst 1: DFW Date Test Began: Analyst 2: KJR June 19, 2015 Time Test Finished: 1200 hrs Date Test Finished: Analyst 3: SCS 5 days HATCH NUMBER: 9485 c-k P. promelas (PP) AGE: UC 100% 12.5% 6.25% X% AEC RC 50% 25% PERIOD ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE ALIVE 0 HR-PP 10,10 10,10 10,10 10,10 10,10 10,10 24 HR-PP 10,10 10,10 10,10 10,10 10,10 10,10 48 HR-PP. 10,10. 10,10 10,10 10,10 10,10 10,10 AGE: <24 HATCH NUMBER: 3050 c-k Ceriodaphnia dubia (CD) hours UC 100% 50% 25% 12.5% 6.25% X% AEC RC ALIVE ALIVE ALIVE PERIOD ALIVE ALIVE ALIVE ALIVE ALIVE 5,5,5,5 0 HR-CD 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 24 HR-CD 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 5,5,5,5 48 HR-CD 5,5,5,5

Page 9 of 13

Approved by Achileb

Date: Ocelas/15

8

Page 2 of 3

					Notes	s & Com	ments				 	
				1	1							
	d											
191910 1911 19 - South						C1447.5.5.5						
	and the second second second second											
			a second de second	erent annen				·····			 	
			Party and Arrest Street			the second						
									ttt_		 	
				- 1								
								2 1000 1 km h			 	
		1971										
		a transmission and the	aller and the state of the state									
						. Conservation of the					 	
								· · · · · · · · · · · · · · · · · · ·			 	
				the second second				and the second		يمدح وسترجع فيتحدث	 	
			and the second state of the								10	
									1		 	
	-											
-	1.00				-			-				

Page 10 of 13

Page 3 of 3

1005		SUBCONT PDC Labo 50	RACT ORDER pratories, Inc. 52462		31627
SENDING LABORATOR		C Laboratories, Inc, 22 C Laboratories, Inc, 18 C Laboratories, Inc, 32	31 W Altorfer Peoria, IL 61615 05 W Sunset, Springfield, MO 6 78 N Highway 67, Florissant, MC	5807 5 63033	
Project Manager: Cha	d Cooper	ccooper@pd	clab.com Phone: 417-864-8	924	15
RECEIVING LABORATO Environmental Analysis 4000 East Jackson Blv Jackson, MO 63755 Phone :(573) 204-8817	<u>DRY:</u> s South d		Date Sh Sample PO# Total # of	ipped <u>Util</u> Origin (State) M	
Analysi s	Due	Expires	Comm	ients	
Sample ID: 5062462-01	Water San	npled:06/16/15:08:00	181562 0	tempid	*
01-WET Multiple SPMO	06/26/15 16:00	06/18/15 08:00		496	
	· · ·				
					· · ·
rn-Around Time Requ	ested (circle one)		Date Results Needed:		
In affer	(4:14:15 - 1505 Date/Time	Received Bu	Sample T Sample(s	emperature Upon F) Received on Ice ottles Received in G	leceipt Y or N lood Condition Y or N
		y idra I	Lindia 1/25 Bottles Fi	lied with Adequate	Volume Y or N

	TMENT OF NATURAL	RESOURCES	S FERSON CITY MO, 65102					
	JENT TOXICITY (M	VET) TEST	REPORT N TO THE REGULATORY AUTHOR	ITY)				
PART A - TO BE COMPLETED	IN FULL BY PERMIT	TEE						
FACILITY NAME Monett Wastewater Treatme	ent Plant		DATE & TIME COLLECTED EFFLUENT 06/16/15 0800	UPSTR	EAM not available			
PERMIT NUMBER MO-0021440			PERMIT OUTFALL NUMBER Outfall # 002					
COLLECTOR'S NAME								
Monett WWTP		5						
Clear Creeknot available	DESCRIPTION							
PERMIT ALLOWABLE EFFLUENT CONCENTR	ATION (AEC)	k	EFFLUENT SAMPLE TYPE (CHECK ONE)	вПо	THER			
SAMPLE NUMBER			UPSTREAM SAMPLE TYPE (CHECK ONE)					
EFFLUENT 1815620	UPSTREAM not av	ailable	24HR COMPOSITE GRA	BXO	THER not available			
PERMITTED EFFLUENT DAILY MAXIMUM LIM	ITATION FOR	mg/L		TION FOR	mg/L			
PART B - TO BE COMPLETED	IN FULL BY PERFOR	MING LABOR	RATORY	an den de				
Environmental Analysis Sout	h, Inc.		Acute Static Non renew	al Test	Multiple Dilution			
FINAL REPORT NUMBER MO_1815620			TEST DURATION 48 hour					
DATE OF LAST REFERENCE TOXICANT TEST June 3, 2015	ING		TEST METHOD Methods for Measuring the Acute Toxicity of Efflue Marine Organisms	nts and Recei	ving Waters to Freshwater and			
DATE AND TIME SAMPLES RECEIVED AT LAB 06/17/15 1025 hrs by UPS	ORATORY	-	TEST START DATE AND TIME 06/17/15 1200 hrs	TEST END 1 06/19/	DATE AND TIME 15 1200 hrs			
SAMPLE DECHLORINATED PRIOR TO ANALYS			TEST ORGANISM #1 AND AGE Pimephales promelas 5 days	TEST ORGA	nnism #2 and age phnia dubia < 24 hours			
SAMPLE FILTERED PRIOR TO ANALYSIS?			90% OR GREATER SURVIVAL IN SYNTHETIC DILUTION WATER USED TO ACHIE CONTROL? YES NO Reconstituted Control					
FILTER MESH SIEVE SIZE ²			EFFLUENT ORGANISM #1 % MORTALITY AT AEC EFFLUENT ORGANISM #2 % MORTALIT LC50>100%/TUa<1.0 (monitor only) LC50>100%/TUa<1.0 (monito					
	YES X NO		UPSTREAM ORGANISM #1 % MORTALITY RC=0%	ORGANISM #2 % MORTALITY				
PH ADJUSTED? YES NO	UPSTREAM		TEST RESULT AT AEC FOR ORGANISM #1		LT AT AEC FOR ORGANISM #2			
MINIMUM REQUIRED ANALYTI	CAL RESULTS FOR T	HE 100% EFF	LUENT SAMPLE					
PARAMETER	RESULT		METHOD	_	WHEN ANALYZED			
Temperature °C	4	SM18 2550	B stored at 4 degree C until tes	t setup	06/17/15 1045 hrs			
pH Standard Units	7.47	SM18 4500-	-Н В		06/17/15 1045 hrs			
Conductance µMohs	1418	SM18 2510	В		06/17/15 1045 hrs			
Dissolved Oxygen mg/L	8.2	SM18 4500-	-0 G		06/17/15 1045 hrs			
Total Residual Chlorine mg/L	<0.04	SM18 4500-	-CI G		06/17/15 1045 hrs			
Unionized Ammonia mg/L	<0.05x0.02<0.010	SM18 4500-	NH3 F @ 25 degree C		06/22/15 1100 hrs			
*Total Alkalinity mg/L	176	SM18 2320	8	06/17/15 1330 hrs				
*Total Hardness mg/L	220	SM18 2340	C	06/17/15 1045 hrs				
*Recommended by USEPA guida	nce, not a required ana	ilysis.	· ·					

¹ Samples shall only be filtered if indigenous organisms are present that may be confused with, or attack, the test organisms.

² Filters shall have a sieve size of 60 microns or greater.

PAGE 1 OF 2

WHOLE EFFLUENT TOXICITY (WET) TEST REPORT

(TO BE ATTACHED TO WET TESTS FOR SUBMISSION TO THE REGULATORY AUTHORITY)

RESULT	METHOD	WHEN ANALYZED
5	SM18 2550B stored at 4 degree C until test setup	06/17/15 1045 hrs
7.11	SM18 4500-H B	06/17/15 1045 hrs
404	SM18 2510B	06/17/15 1045 hrs
7.8	SM18 4500-O G	06/17/15 1045 hrs
<0.04	SM18 4500-CI G	06/17/15 1045 hrs
<0.05x0.007<0.01	SM18 4500-NH3 F @ 25 degree C	06/22/15 1100 hrs
144	SM18 2320B	06/17/15 1330 hrs
140	SM18 2340 C	06/17/15 1045 hrs
	RESULT 5 7.11 404 7.8 <0.04	RESULT METHOD 5 SM18 2550B stored at 4 degree C until test setup 7.11 SM18 4500-H B 404 SM18 2510B 7.8 SM18 4500-O G <0.04

PRELIMINARY TEST ACCEPTABILITY MATRIX (FOR USE BY PERMITTEE IN DETERMINING TEST VALIDITY)

PERMIT ALLOWABLE EFFLUENT CONCENTRATION (AEC): As indicated on permit. Test is invalid otherwise.

EFFLUENT SAMPLE TYPE: As indicated on permit. Test is invalid otherwise.

TEST TYPE: Acute Static Non-Renewal Test or other as indicated on permit. Test is invalid otherwise.

TEST DURATION: Forty-eight (48) hours or as indicated on permit. Test is invalid otherwise.

TEST ORGANISMS: As indicated on permit. Test is invalid otherwise.

DILUTION WATER USED TO ACHIEVE AEC: Upstream receiving water required if available.

TEST METHOD: The only acceptable method is the *most current edition* of <u>Methods for Measuring the Acute Toxicity of Effluents and</u> <u>Receiving Waters to Freshwater and Marine Organisms</u>, or other as specifically assigned by EPA for determining NPDES compliance. Test is invalid otherwise.

TEST START DATE & TIME: Unless otherwise specified in writing by EPA, if >36 hours lapse between collection and initiation, test is invalid.

FILTER MESH SIEVE SIZE: Unless otherwise specified in writing by EPA, if sieve size is smaller than 60 microns, test is invalid.

90% OR GREATER SURVIVAL IN LABORATORY CONTROL(S) (Y/N): If NO, test is invalid.

			STATE AND A STATE OF STATE
PARAMETER	RESULT	NOTES	WHEN ANALYZED
Temperature °C	0 - 6	Unless received by the laboratory on the same day as collected, values outside this range invalidate the test.	Upon receipt

PAGE 2 OF 2

Page 13 of 13

³ Where no upstream control is available, enter results from laboratory or synthetic control.

MO 78-01899 (12-04)



PDC Laboratories, Inc. 1805 W Sunset St • Springfield, MO 65807 (417) 864-8924 • FAX (417) 864-7081

Monett, City of 217 5th St. Monett, MO 65807 Attn: Dave Sims Date Received: 08/26/14 10:34 Report Date: 09/09/14 Customer #: 277575

Laboratory Results

Sample No: 4084309-01

Collect Date: 08/26/14 08:00 Matrix: Water Composite

Sample Description: WET Single

Parameters	Result	Qual	Prep Date	Analysis Date	Analyst	Method
Miscellaneous - SPM						
WET Testing Single Dilution - subcontracted	Subcontracted	Pass	08/27/14 09:50	08/27/14 09:50	KBW	Subcontracted



PDC Laboratories, Inc. 1805 W Sunset St • Springfield, MO 65807 (417) 864-8924 • FAX (417) 864-7081

Monett, City of 217 5th St. Monett, MO 65807 Attn: Dave Sims Date Received: 08/26/14 10:34 Report Date: 09/09/14 Customer #: 277575

Laboratory Results

Notes

This report shall not be reproduced, except in full, without the written approval of the laboratory.

PDC Laboratories participates in the following accreditation/certification and proficiency programs at the following locations. Endorsement by Federal or State Governments or their agencies is not implied.

PIA PDC Laboratories - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553 Drinking Water Certifications: Kansas (E-10338); Missouri (870); Wisconsin (998284430); Iowa (240) Wastewater Certifications: Arkansas (88-0677); Wisconsin (998284430); Iowa (240); Kansas (E-10335) Hazardous/Solid Waste Certifications; Arkansas (88-0677); Wisconsin (998284430); Iowa (240); Kansas (E-10335) UST Certification; Iowa (240) SPM PDC Laboratories - Springfield, MO EPA DMR-QA Program

STL PDC Laboratories - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS EPA Lab No. E-10389

Pass Pass

Certified by: Chad Cooper, Laboratory Supervisor

4084309

eas

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Municipal WWTF OUTFALL 001 (24 hr composite) AEC = 100% MO-0021440 EAS LOG# 1714322 August 27, 2014 through August 29, 2014

Tests performed by:

John P. Clippard / Chemical Analyst at Environmental Analysis South (EAS) Kelly J. Ray / Biologist at Environmental Analysis South (EAS) Sara C. Shields / Lab Supervisor - Chemist at Environmental Analysis South (EAS) David F. Warren / Lab Director - Chemist at Environmental Analysis South (EAS)

1. Report Summation

- 1.1. Data Summation
- 1.2. Conclusion
- 2. Method Summation
 - 2.1. Test Conditions and Methods
 - 2.2. Potassium chloride Reference Salt Test
 - 2.2.1. Pimephales promelas data
 - 2.2.2. Ceriodaphnia dubia data
 - 2.3. Literature Cited

3. Raw Data Berich Sheets

- 3.1. Initial observations (page 1)
- 3.2. Zero hour Observations (page 1)
- 3.3. Twenty-four (24) hour Observations (page 1)
- 3.4. Forty-eight (48) hour Observations (page 1)
- 3.5. Survival Data Table (page 2)
- 3.6. Test Comments (page 3)
- 4. Chain of Custody
- 5. MO DNR "Whole Effluent Toxicity (WET) Test Report (Form 780-1899)

eas

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Municipal WWTF OUTFALL 001 (24 hr composite) AEC = 100% MO-0021440 EAS LOG# 1714322 August 27, 2014 through August 29, 2014

1. REPORT SUMMATION:

1.1. Single Dilution Data Summation

	<i>Pimephales promelas</i> Acute Toxicity Test	<i>Ceriodaphnia dubia</i> Acute Toxicity Test
Survival in the Effluent at 48 Hours	100%	100%
Survival in the Reconstituted Control (RC) at 48 Hours	100%	100%
Survival in the Upstream Control (UC) at 48 Hours	N/A	N/A
Statistical Results Comparing the Survival Data of the Effluent with the Control (arc sine square root transformation)	No Significant Difference at alpha = 0.05 PASS	No Significant Difference at alpha = 0.05

* Indicates a significant difference at a pha = 0.5 between effluent and control survival data.

Conclusion: The mortality observed with both species was determined not to be significantly different than that observed in the control sample. Based on these results the outfall **passed** the whole effluent toxicity test with both indicator species.

Approved by Sara C. Shields, Chemist

eas

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Municipal WWTF OUTFALL 001 (24 hr composite) AEC = 100% MO-0021440 EAS LOG# 1714322 August 27, 2014 through August 29, 2014

2. TEST METHOD SUMMARY 2.1. TEST CONDITIONS AND METHODS:

	Ceriodaphnia dubia:	Pimephales promelas:
Test duration:	48 hours	48 hours
Temperature:	24 - 26 degree Celsius	24 - 26 degree Celsius
Light quality:	Ambient laboratory illumination	Ambient laboratory illumination
Photoperiod:	16 hour light, 8 hours dark	16 hour light, 8 hours dark
Control Water:	Moderately Hard Reconstituted Water	Moderately Hard Reconstituted Water
Dilution Water:	Upstream Water - If unavailable or toxic, then control water will be used.	Upstream Water - If unavailable or toxic, then control water will be used.
Size of test vessel:	30 milliliters	250 milliliters
Volume of test solution:	15 milliliters	200 milliliters
Age of test organisms:	<24 hours	1 -14 days (all same age)
Number of organisms/test vessel:	5	10
Number of replicates/concentration:	4	4
Number of organisms/concentration:	20	40 for a single dilution test and 20 for a multiple dilution test
Feeding regime:	None (fed prior to test)	None (fed prior to test)
Aeration:	None	None
Test acceptability criterion:	90% or greater survival in controls	90% or greater survival in controls

The methodology used for the chemistry data was taken from the *Standard Methods for the Examination of Water and Wastewater*, 18th edition (1992). The exception was hardness, which was determined using a Hach EDTA titration test kit. The toxicity tests follow guidelines laid out in the permittee's NPDES permit and were conducted according to EPA approved methods (USEPA 2002).

All test organisms were cultured according to EPA approved methods (USEPA 2002). The *Ceriodaphnia dubia* and the *Pimephales promelas* were obtained from C-K Associates Inc. located in Baton Rouge, Louisiana and shipped overnight for use in the whole effluent toxicity test.



4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818

REPORT OF ACUTE TOXICITY TESTING Monett Municipal WWTF OUTFALL 001 (24 hr composite) AEC = 100% MO-0021440 EAS LOG# 1714322 August 27, 2014 through August 29, 2014

2.2. REFERENCE TOXICITY TEST:

Environmental Analysis South performs monthly reference toxicity tests. The most recent reference test was initiated on August 6, 2014 using KCL Lot #41713. Following are the results:

2.2.1. *P. promelas* - 48 hr. Acute Test – LC₅₀ = 0.796 g/l 95%Cl (0.640-1.173 g/l) EAS %CV = 14.7%

National Warning Limits (75th percentile) = 19%CV National Control Limits (90th percentile) = 33%CV

2.2.2. **C. dubia** - 48 hr. Acute Test – LC₅₀ = 0.451 g/l 95%Cl (0.326-0.575g/l) EAS %CV = 13.8% National Warning Limits (75th percentile) = 29%CV National Control Limits (90th percentile) = 34%CV

2.3. LITERATURE CITED:

- 1. APHA. 1992. Standard methods for the examination of water and wastewater, 18th Ed. American Public Health Association, Washington, D.C
- USEPA. 2002. Methods for measuring the acute toxicity of effluents and receiving waters to freshwater and marine organisms, 5th Ed. EPA-821-R-02-012
- 3. USEPA 2000. Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications under the National Pollutant Discharge Elimination System, (Table B-2). June 2000. EPA 833-R-00-003.

-

VVHOLE EFFLUENT TEST conducted in accordance with US EPA 600/4-90/027 Fifth Edition October 2002

CLIENT NAME:	Monett Municipal WWTF, Outfall 001, 24 hr composite												
NPDES NUMBER:	MO-0021440												
TYPE OF METHOD:	single dilutio	n, 48 hrs, 1	non-renewal,	PP & CD, AEC=100%				7					
DATE & TIME OF COLLECTION:	08/26/14 09	00 hrs by C	ity of Monne	tt				Upstream:	Unnamed	Tributary	to Clear C	reek	
DATE & TIME OF SUBMISSION:	08/27/14 09	30 hrs by L	IPS					Not available					
INITIAL OBSERVATIONS	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	INT EFFL	INT UC	INT RC					
LOG NUMBER / ID NUMBER	1 - A				and the state of the state	1714322		RC4109					
pH - SU	08/27/14	0950 hrs	SCS	SB114 (8.8-9.2)	8.91	7.66		7.56					
TEMPERATURE °C RECEIVED	08/27/14	0950 hrs	SCS	EAS 106		2		21					
SPECIFIC CONDUCTANCE umhos	08/27/14	0950 hrs	SCS	ERA225-506 (379-425)	422	1861		256					
HARDNESS - ppm	08/27/14	0950 hrs	SCS	DMRQA34 (184-250)	120	200	-	80					
CHLORINE - ppm	08/27/14	0950 hrs	SCS	tap water	+	< 0.04		< 0.04					
DISSOLVED OXYGEN - ppm	08/27/14	0950 hrs	SCS	cal@840		11.2		8.7					
TOTAL ALKALINITY - ppm	08/27/14	1300 hrs	SCS	ERA P225-506(66.3-79.2)	76.6	163		67.0					
INITIAL AMMONIA - ppm	09/02/14	1100 hrs	JPC	DMRQA33 (10.0-16.8)	15.2	<0.05		< 0.05					
TOTAL DISSOLVED SOLIDS -ppm								-					
0 HOUR OBSERVATIONS	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
pH - SU	08/27/14	1100 hrs	SCS	SB114 (8.8-9.2)	8.91	7.68		7.64					
TEMPERATURE °C	08/27/14	1100 hrs	SCS	EAS 106		23.6		23.9					
SPECIFIC CONDUCTANCE umhos	08/27/14	1100 hrs	SCS	ERA225-506 (379-425)	422	265		1797					
DISSOLVED OXYGEN - ppm 08/27/14 1100 hrs IS		SCS	cal@840		8.8		10.1						
24 HOUR OBSERVATIONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
pH - SU	08/28/14	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	7.62		8.22					
TEMPERATURE °C	08/28/14	1100 hrs	SCS	EAS 106		25.0		25.0					
SPECIFIC CONDUCTANCE umhos	08/28/14	1100 hrs	SCS	ERA225-506 (379-425)	425	271		1901					
DISSOLVED OXYGEN - ppm	08/28/14	1100 hrs	SCS	cal@840	-	8.1		8.1					
48 HOUR OBSERVATIONS - PP	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
pH - SU	08/29/14	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	7.90		8.24					
TEMPERATURE °C	08/29/14	1100 hrs	SCS	EAS 106		25.0		25.0					
SPECIFIC CONDUCTANCE umhos	08/29/14	1100 hrs	SCS	ERA225-506 (379-425)	418	280		1945					
DISSOLVED OXYGEN - ppm	08/29/14	1100 hrs	SCS	cal@840		8.1		7.8					
FINAL AMMONIA - ppm				DMRQA33 (10.0-16.8)									
24 HOUR OBSERVATIONS - CE	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UC	100%	50%	25%	12.5%	6.25%	X %AEC
pH - SU	08/28/14	1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.17	1	8.10					
TEMPERATURE °C	08/28/14	1 1100 hrs	SCS	EAS 106		25.0		25.0					
SPECIFIC CONDUCTANCE umhos	s 08/28/14	4 1100 hrs	SCS	ERA225-506 (379-425)	425	263		1752					
DISSOLVED OXYGEN - ppn	08/28/14	4 1100 hrs	SCS	cal@840		8.5		8.8					
48 HOUR OBSERVATIONS - CI	DATE	TIME	ANALYST	QC LOT	QC EXP VALUE	RC	UÇ	100%	50%	25%	12.5%	6.25%	X %AEC
pH - SI	J 08/29/1	4 1100 hrs	SCS	SB114 (8.8-9.2)	8.94	8.27		8.22					
TEMPERATURE °C	08/29/1	4 1100 hrs	SCS	EAS 106		25.0		25.0					
SPECIFIC CONDUCTANCE umho	s 08/29/1	4 1100 hrs	SCS	ERA225-506 (379-425)	418	289		1812					
DISSOLVED OXYGEN - ppr	n 08/29/1	4 1100 hrs	SCS	cal@840		8.8	1	8.4					
FINAL AMMONIA - ppr	n			DMRQA33 (10.0-16.8)									

Approved by: Adulta

Date: 19/03/14

onett Municipal WWT	F, Outfall 001, 24	hr composite	EAS LOG# 1	1714322				
Date Test Began:	Augu	ıst 27, 2014	Tim	e Test Began:	1100 hrs			Analyst 1: DF
Date Test Finished:	Augu	ıst 29, 2014	Time	Test Finished:	1100 hrs			Analyst 2: KJ Analyst 3: SC
promelas (PP)		AGE:	7	days	HA	TCH NUMBER:	9188 c-k]
	RC	UC	100%	50%	25%	12.5%	6.25%	80
PERIOD	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE
0 HR-PP	10,10,10,10		10,10,10,10					
24 HR-PP	10,10,10,10		10,10,10,10					
48 HR-PP	10,10,10,10		10,10,10,10					
eriodaphnia dubia (Cl	0)	AGE:	<24	hours	НА	TCH NUMBER:	2908 c-k]
	RC	UC	100%	50%	25%	12.5%	6.25%	X% AEC
PERIOD	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE	ALIVE
0 HR-CD	5,5,5,5		5,5,5,5					
24 HR-CD	5,4,5,5		5,5,5,5					
48 HR-CD	5,4,5,5		5,5,5,5					

Approved by: Milde

Date: 09/03/14

Monett Municipal WV	VIF, Outfall 001, 24 h	ir composite	EAS#: 1714322		 		
			Notes & Co	mments			
						T	
······································						78.7 A X 190	
	······································				 · · ·		
	·····				 		
					 		·····
	and the second sec				 4.8.0.40 ft		
	· · · · · · · · · · · · · · · · · · ·				 		
					 	and the second	
	· · · · · · · · · · · · · · · · · · ·						
	The second s						
		A. 160 P. 1. 0					A set of the set of th
		· · · · · · · · · · · · · · · · · · ·					
		1.000 - 5.00				,	
	the second s						· · · · · · · · · · · · · · · · · · ·
· · · · · · · · · · · · · · · · · · ·					 	1.0.1.1.1.00	
					 · · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·
	and the second						
					 11 an a 11 an		
and we have a set of the set of t							
						1	

Prepared by:

Date: 09/03/14

-

Nor.		SUBCONTRACT OR PDC Laboratories, 4084309	NDER Inc.	-
SENDING LABORATORY	<u>Y:</u>	PDC Laboratories, Inc, 2231 W Altorf	er Peoria, IL 61615	
	/	<u>N PDC Laboratories</u> , Inc, 1805 W Suns DDC Laboratories, Inc. 2278 N Highur	et, Springfield, MO 65807	
Charles Managary Charl	-	PDC Laboratories, Inc, 3276 N Highw	Bhame: 417 864 8024	
roject Manager. Chao	Cooper	ccooper@pociab.com	Prione: 417-004-0924	
RECEIVING LABORATO	RY:		Date Shipped <u>8 AUT</u>	
Environmental Analysis	South		Sample Origin (State) <u>1710</u>	
000 East Jackson Blvd	1.		PO#	
Phone :(573) 204-8817			Total # of Containers	
nalysis	Due	Expires	Comments	
ample ID: 4084309-01	Water	Sampled:08/26/14 09:00	. and the	and the second second
1-WET Single SPMO	09/08/14	16:00 08/28/14 09:00	2655)	
	÷.			
n-Around Time Reque	ested (circle	e one): NORMAL RUSH Date F	Results Needed:	
m-Around Time Reque	ested (circle	e one): NORMAL RUSH Date F	Results Needed: Sample Temperature Upon Receipt	
m-Around Time Reque	ested (circle	e one): NORMAL RUSH Date F	Results Needed:	Y or N

				Samples Received Within Hold Time
ished By	Date/Time	Received By	Date/Time	
				Date/Time Taken From Sample Bottle

Y or N

MISSOURI DEPAR	TMENT OF NATURAL ION PROGRAM - P.O.	RESOURCES BOX 176, JEF	S FFERSON CITY MO. 65102					
	JENT TOXICITY (W	VET) TEST	REPORT					
(TO BE ATTACHED	TO WET TESTS FOR	SUBMISSIO	N TO THE REGULATORY AUTHOR	ITY)				
PART A - TO BE COMPLETED	IN FULL BY PERMIT	TEE	DATE & TIME COLLECTED		19 x			
Monett Municipal WWTF			EFFLUENT 08/26/14 0900	UPSTR	EAM			
PERMIT NUMBER MO-0021440			PERMIT OUTFALL NUMBER Outfall # 001					
COLLECTOR'S NAME		energies en energies			· ·			
CITY OF MONET	DESCRIPTION							
Unnamed tributary to Clear C	Creeknot available							
PERMIT ALLOWABLE EFFLUENT CONCENTR	ATION (AEC)		EFFLUENT SAMPLE TYPE (CHECK ONE)	вПо	THER			
SAMPLE NUMBER EFFLUENT 1714322	UPSTREAM not av	ailable	UPSTREAM SAMPLE TYPE (CHECK ONE)	в До	THER not available			
PERMITTED EFFLUENT DAILY MAXIMUM LIMI	TATION FOR	"	PERMITTED EFFLUENT DAILY MAXIMUM LIMITA	TION FOR				
					mg/L			
PERFORMING LABORATORY	IN FOLL BY PERFOR		TEST TYPE					
Environmental Analysis South	n, Inc.		Acute Static Non renew	al Test	Single Dilution			
FINAL REPORT NUMBER		TEST DURATION 48 hour						
DATE OF LAST REFERENCE TOXICANT TESTI August 6, 2014		TEST METHOD Methods for Measuring the Acute Toxicity of Efflue Marine Organisms	nts and Recei	ving Waters to Freshwater and				
DATE AND TIME SAMPLES RECEIVED AT LABO 08/27/14 0930 hrs by UPS	ORATORY		TEST START DATE AND TIME 08/27/14 1100 hrs	TEST END 0 08/29/1	DATE AND TIME 14 1100 hrs			
SAMPLE DECHLORINATED PRIOR TO ANALYS			TEST ORGANISM #1 AND AGE TEST ORGANISM #2 AND AGE Pimephales promelas 7 days Ceriodaphnia dubia < 24 hours					
SAMPLE FILTERED ¹ PRIOR TO ANALYSIS?	YES NO		90% OR GREATER SURVIVAL IN SYNTHETIC DILUTION WATER USED TO ACHIEVE AEC					
FILTER MESH SIEVE SIZE ²			FEFLUENT ORGANISM #1 % MORTALITY AT AEC EFFLUENT ORGANISM #2 % MORTALITY AT A					
None			0%					
SAMPLE AERATED DURING TESTING?	ES XI NO		UPSTREAM ORGANISM #1 % MORTALITY RC=0%	REAM ORGANISM #1 % MORTALITY UPSTREAM ORGANISM #2 % MORTALITY =0%				
PH ADJUSTED? YES X NO	UPSTREAM		TEST RESULT AT AEC FOR ORGANISM #1		LT AT AEC FOR ORGANISM #2			
MINIMUM REQUIRED ANALYTIC	CAL RESULTS FOR T	HE 100% EFF	LUENT SAMPLE					
PARAMETER	RESULT		METHOD		WHEN ANALYZED			
Temperature °C	2	SM18 2550	B stored at 4 degree C until test	setup	08/27/14 0950 hrs			
pH Standard Units	7.66	SM18 4500	-Н В		08/27/14 0950 hrs			
Conductance µMohs	1861	SM18 2510	В		08/27/14 0950 hrs			
Dissolved Oxygen mg/L	11.2	03/12/14 09	45 hrsSM18 4500-O G		08/27/14 0950 hrs			
Total Residual Chlorine mg/L	<0.04	SM18 4500-	-CI G		08/27/14 0950 hrs			
Unionized Ammonia mg/L	<0.05x0.03<0.010	SM18 4500-	NH3 F @ 25 degree C 09/02/14 1100 hrs					
*Total Alkalinity mg/L	163	SM18 2320	8		08/27/14 1300 hrs			
*Total Hardness mg/L	200	SM18 2340	С		08/27/14 0950 hrs			
	· · · · · · · · · · · · · · · · · ·							

*Recommended by USEPA guidance, not a required analysis.

Samples shall only be filtered if indigenous organisms are present that may be confused with, or attack, the test organisms.
 Filters shall have a sieve size of 60 microns or greater.

WHOLE EFFLUENT TOXICITY (WET) TEST REPORT

(TO BE ATTACHED TO WET TESTS FOR SUBMISSION TO THE REGULATORY AUTHORITY)

and the second se		the second s
MININALINA DEOLUDED ANALVTIOAL	DECULTE FOD THE 4000	LIDOTDEAM CAMPIES
	RESULTS FOR THE 100%	

PARAMETER	RESULT	METHOD	WHEN ANALYZED
Temperature °C	21	SM18 2550B stored at 4 degree C until test setup	08/27/14 0950 hrs
pH Standard Units	7.56	SM18 4500-H B	08/27/14 0950 hrs
Conductance µMohs	256	SM18 2510B	08/27/14 0950 hrs
Dissolved Oxygen mg/L	8.7	SM18 4500-O G	08/27/14 0950 hrs
Total Residual Chlorine mg/L	<0.04	SM18 4500-CI G	08/27/14 0950 hrs
Unionized Ammonia mg/L	<0.05x0.02<0.010	SM18 4500-NH3 F @ 25 degree C	09/02/14 1100 hrs
*Total Alkalinity mg/L	67.0	SM18 2320B	08/27/14 1300 hrs
*Total Hardness mg/L	80	SM18 2340 C	08/27/14 0950 hrs
*Deserved at the UICEDA solid			

*Recommended by USEPA guidance, not a required analysis.

PRELIMINARY TEST ACCEPTABILITY MATRIX (FOR USE BY PERMITTEE IN DETERMINING TEST VALIDITY)

PERMIT ALLOWABLE EFFLUENT CONCENTRATION (AEC): As indicated on permit. Test is invalid otherwise.

EFFLUENT SAMPLE TYPE: As indicated on permit. Test is invalid otherwise.

TEST TYPE: Acute Static Non-Renewal Test or other as indicated on permit. Test is invalid otherwise.

TEST DURATION: Forty-eight (48) hours or as indicated on permit. Test is invalid otherwise.

TEST ORGANISMS: As indicated on permit. Test is invalid otherwise.

DILUTION WATER USED TO ACHIEVE AEC: Upstream receiving water required if available.

TEST METHOD: The only acceptable method is the *most current edition* of <u>Methods for Measuring the Acute Toxicity of Effluents and</u> <u>Receiving Waters to Freshwater and Marine Organisms</u>, or other as specifically assigned by EPA for determining NPDES compliance. Test is invalid otherwise.

TEST START DATE & TIME: Unless otherwise specified in writing by EPA, if >36 hours lapse between collection and initiation, test is invalid.

FILTER MESH SIEVE SIZE: Unless otherwise specified in writing by EPA, if sieve size is smaller than 60 microns, test is invalid.

90% OR GREATER SURVIVAL IN LABORATORY CONTROL(S) (Y/N): If NO, test is invalid.

PARAMETER	RESULT	NOTES	WHEN ANALYZED
Temperature °C	0 - 6	Unless received by the laboratory on the same day as collected, values outside this range invalidate the test.	Upon receipt

³ Where no upstream control is available, enter results from laboratory or synthetic control.

CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC. 1805 W. SUNSET SPRINGFIELD, MO 65807

PHONE # 417-864-8924 FAX# 417-864-7081

State where samples collected _____MO__

	ALL HIGHLIG	HTED AREAS	MUST BE CO	MPLE	TED BY CLI	ENT (PLEAS	EPRIN	T)			
(1) MONETT, CITY OF	PROJECT NU	MBER . I	P.O. NUMBER	2	MEANS	SHIPPED	3	ANAL	YSIS REQUESTE	D	(FOR LAB USE ONLY)
ADDRESS 217 5 TH STREET	PHONE NUN 417-235-74	IBER I 155	FAX NUMBER	\$	DATES	HIPPED		T			LOGIN # 4084309
MONETT, MO 65708	SAMPLER	T.)			MATRIX TY	PES: NATER IG WATER	e Dil.				LAB PROJ. # TEMPLATE:
	SAMPLER'S SIGNATURE	1 			WWSL-SLUD NAS-SOLID LCHT-LEACH	IGE	Singl			-	PROJ. MGR.: CHAD COOPER
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT	DATE		SAMPLE T	COMP	MATRIX		WET				REMARKS
EFFLUENT	8-26-14	0500		x	ww	1	X				called client for
	9-9+4 KAW										time i date of
								_			collection
					····· /····						8-212-14 KBW
											Ballon BH15307
							<u> </u>		·		
· · · · · · · · · · · · · · · · · · ·											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL 6 (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE RUSH RESULTS VIA (PLEASE CIRCLE) FAX # IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:	RUSH	DATE F	RESULTS NEE	EDED	6	The sample this area yo the sample this area yo sample ten	e temper ou reque témpera ou allow aperatur	ature wi ist that to the lab t e.	Il be measured up he lab notify you, butside of the ran to proceed with a	before pro ge of 0.1-6 nalytical te	at the lab. By initialing ceeding with analysis, if .0°C. By not initialing sting regardless of the
RELINQUISHED BY: (SIGNATURE) DATE PRIMA (MADEMA) TIME	14 RECEIV	ED BY: (SIGNAT	URE)			DATE 8- TIME	26 -	14	8 <u>-</u>	DMMENTS:	(FOR LAB USE ONLY)
RELINCUSHED BY: (SIGNATURE) DATE -26	-14 RECEIV	ED BY: (SIGNAT	NA AL	a k		TIME	267L	/	SAMPLE TEMP	ERATURE	UPON RECEIPT 7.7 °C
RELINQUISHED BY: (SIGNATURE) DATE	RECEIV	ED BY: (SIGNAT	TURE)	4		DATE	004		SAMPLE(S) RE PROPER BOTT BOTTLES FILL	CEIVED OI LES RECE	VICE
. TIME						TIME			(EXCLUDES TY DATE AND TIM	PICAL FIE	LD PARAMETERS)

X:\COC Templates\Monett_WW.doc

Page of

MAK	E ADDITIONAL COPIES OF THIS FORM FO	R EACH OUTFA	LL			
FACILI	Monett Municipal WWTF MO-	0021440		OUTFALL NO. 001		
PAR	T F – INDUSTRIAL USER DISCHARGES AN	D RCRA/CERCL	A WASTES			
Refe	r to the APPLICATION OVERVIEW to determi	ne whether Part F	applies to the treatme	ent works.		
19.	GENERAL INFORMATION					
19.1	Does the treatment works have, or is it subje ✓ Yes □ No	ect to, an approve	d pretreatment program	n?		
19.2	Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs). Provide the number of each of the following types of industrial users that discharge to the treatment works: Number of non-categorical SIUs 3 Number of CIUs 3					ch of the
20.	INDUSTRIES CONTRIBUTING MORE THAI SIGNIFICANT INDUSTRIAL USERS INFOR	N 5 PERCENT OF	THE ACTUAL FLOW	TO THE FACILITY	Y OR OT	HER
Supp	ly the following information for each SIU. If me ested for each. Submit additional pages as ne	ore than one SIU o cessary.	discharges to the treat	ment works, provide	e the info	mation
See	Attached Listing					
MAILING	3 ADDRESS		CITY		STATE	ZIP CODE
20.1 See A	Describe all of the industrial processes that a ttached Listing	affect or contribute	to the SIU's discharge	9		
20.3	Principal Product(s): See Attached Listing Raw Material(s): 20.3 Flow Rate See Attached Listing a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent.					
	b. NON-PROCESS WASTEWATER FLOW F the collection system in gallons per day, gpd Continuous	ATE. Indicate the or gpd, and wheth	e average daily volume er the discharge is con ermittent	e of non-process wa ntinuous or intermitt	stewater ent.	discharged into
20.4	Pretreatment Standards. Indicate whether the	e SIU is subject to	the following:			
	a. Local Limits	Yes	No			
	b. Categorical Pretreatment Standards	✓ Yes	No			
	If subject to categorical pretreatment standard	ds, which category	and subcategory?			
20.5 Most re	Problems at the treatment works attributed to (e.g., upsets, interference) at the treatment we Ves If Yes, describe each episode ecent issue was in May, 2014 when Tyson's di	waste discharged orks in the past th ischarged a waste	I by the SIU. Has the s ree years? that had been transpo	SIU caused or contr	ibuted to	any problems
nill. El	evated ammonia levels in the Monett effluent i	resulted in a well o	documented fish-kill.			

5 - F

ATTACHMENT TO FORM B-2 PART F - ITEMS NO. 19.2 THRU 20.3

LIST OF SIGNIFICANT INDUSTRIAL DISCHARGES INTO THE MONETT MUNICIPAL WWTF

NAME OF FACILITY	ADDRESS	FLOW ()MGD)	TYPE OF INDUSTRY	PRODUCTS	RAW MATERIALS	MANUFACTURING PROCESSES
Tyson Foods, Inc.	Kyler & County Road P. O. Box 191 Monett, MO 65708	0.95 Process 0.25 Non-Process 3 Shifts; 5 Days/Wk	Poultry Processing Plant (Non-Categorical)	Chicken	Live poultry	Poultry slaughter and cut-up
Schrieber	10 Dairy Street P. O. Box 669 Monett, MO 65708	0.051 Process 0.021 Non-Process 3 Shifts; 7 Days/Wk	Processing and Packaging Cheese into Cheese Products (Non-Cat.)	Cheese	Cheese	Process cheese
IDF	700 South Chapel Dr. P. O. Box 186 Monett, MO 65808	0.31 Process 0.02 Non-Process 2 Shifts; 7 Days/Wk	Dehydration of of Various Types of Food (Non-Cat.)	Spray dried broth and chicken powders, liquid flavors	Chicken frames	Chicken frames and the meat from those frames are processed into dried or liquid products
SAPA Extrusions	808 County Road P. O. Box 699 Monett, MO 65808	Nil Process Nil Non-Process 2 Shifts; 7 Days/Wk	Extruded Aluminum Products (Categorical-464,467)	Aluminum extrusion billet	Aluminum, chrome, magnesium, manganese, TiBor, copper, silicon	Secondary aluminum re-melting
EFCO	1000 County Road P. O. Box 609 Monett, MO 65708	0.11 Process 0.06 Non-Process 2 Shifts; 7 Days/Wk	Aluminum Window Manufacturer (Categorical-467)	Fenestration, windows, curtain walls, doors, extrusions	Aluminum	Extrusion presses, paint line, anodizing, glass washers
Miracle Recreation Equip (Playpower)	Hiway 60 & Bridal Ln P.O.Box 420 Monett, MO 65708	0.009 Process 0.012 Non-Process 3 Shifts; 5 Days/Wk	Playground Equipment Manufacturer (Categorical-433)	Playground equipment	Steel, aluminum, and stainless steel tubing and sheet	Metal fabrication, welding, powder coating, PVC coating, assembly, warehousing, and shipping

The cumulative wastewater flow from other establishments connected to the Monett Sewer System that are billed as" industrial" equals approximately 0.12 MGD.

MAKE ADDITIONA	L COPIES OF THIS FOR	RM FOR EACH OUTFALL			
FACILITY NAME Monett Municipal W	WTF	PERMIT NO. MO- 0021440	OUTFALL NO.		
PART F - INDUST	RIAL USER DISCHARGE	ES AND RCRA/CERCLA WASTE	S		
21. RCRA HAZA	RDOUS WASTE RECEIV	VED BY TRUCK, RAIL, OR DED	ICATED PIPELINE		
21.1 Does the trea pipe?	1 Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe? ☐ Yes ☑ No				
21.2 Method by wh	21.2 Method by which RCRA waste is received. (Check all that apply)				
21.3 Waste Descri	ption				
EPA Hazardo	us Waste Number	Amount (volume or ma	ss)	Units	
22. CERCLA (SU REMEDIAL A	PERFUND) WASTEWAT	TER, RCRA REMEDIATION/COF	RECTIVE ACTION WASTEWAT	ER, AND OTHER	
22.1 Does the treat	tment works currently (or	has it been notified that it will) red	ceive waste from remedial activitie	s?	
Provide a list	of sites and the requeste	d information for each current and	future site.		
22.2 Waste Origin. expected to o	Describe the site and ty riginate in the next five ye	pe of facility at which the CERCL ears).	A/RCRA/or other remedial waste of	originates (or is	
22.3 List the hazard known. (Attac	dous constituents that are ch additional sheets if neo	e received (or are expected to be cessary)	received). Included data on volum	e and concentration, if	
22.4 Waste Treatm a. Is this wast	nent e treated (or will it be trea	ited) prior to entering the treatmen	nt works?		
lf Yes, de	Yes scribe the treatment (pro	☐ No vide information about the remova	al efficiency):		
b. Is the disch	arge (or will the discharge ☐ Continuous	e be) continuous or intermittent?			
If intermit	ent, describe the dischar	ge schedule:			
REFER TO THE APP 780-1805 (09-16)	PLICATION OVERVIEW	TO DETERMINE WHICH OTHER	R PARTS OF FORM B2 YOU MUS	ST COMPLETE.	

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL						
FACILITY NAME PERMIT NO. OUTFALL NO. Monett Municipal W/W/TE No. 001						
MO- 0021440 001						
PART G - COMBINED SEWER SYSTEMS						
Rele			to the treatment works.			
23.	GENERAL INFORMATION					
23.1	System Map. Provide a map indicating	the following: (May be included	d with basic application information.)			
	B. Sensitive Use Areas Potent	ially Affected by CSOs. (e.g., be	aches, drinking water supplies, shellfish beds, sensitive			
	aquatic ecosystems and Ou	tstanding Natural Resource Wa	ters.)			
	C. Waters that Support Threate	ened and Endangered Species	Potentially Affected by CSOs.			
23.2	System Diagram. Provide a diagram, e	either in the map provided above	e or on a separate drawing, of the Combined Sewer			
	Collection System that includes the follo	owing information:	Que en te Que item			
	A. Locations of Major Sewer II B. Locations of Points where S	enarate Sanitary Sewers Feed	Separate Sanitary.			
	C. Locations of In-Line or Off-L	ine Storage Structures.				
	D. Locations of Flow-Regulatin	g Devices.				
	E. Locations of Pump Stations.					
23.3	Percent of collection system that is com	bined sewer				
23.4	Population served by combined sewer of	collection system				
23.5	Name of any satellite community with co	ombined sewer collection syster	n			
24.	CSO OUTFALLS. COMPLETE THE FO	OLLOWING ONCE FOR EACH	CSO DISCHARGE POINT			
24.1	Description of Outfall					
	a. Outfall Number					
	b. Location					
	a Distance from Share (if applicable)	#				
	c. Distance from Shore (if applicable) II					
	a. Depth Below Surface (if applicable) II					
		CSO Pollutant Concentrations				
	CSO Flow Volume	Receiving Water Quality				
	f. How many storm events were monito	red last year?				
24.2	CSO Events					
	a. Give the Number of CSO Events in th	e Last Year Events	Actual Approximate			
	b.		Give the Average Duration Per CSO Event			
	Hours		Actual Approximate			
	C.		Give the Average Volume Per CSO Event			
	Million Gallons					
04.0	d. Give the minimum rainfall that caused	a CSO event in the last year				
24.3	Description of Receiving Waters					
	a. Name of Wetershed/River/Stream Sv	tom				
	b. Name of Watershed/River/Stream Sys	stern sit Matarahad Cada (If Known)				
	c. U.S. Soil Conservation Service 14-Digit watershed Code (If Known)					
	a. U.S. Coological Suprov 8. Digit Hydro	SIII Jogia Cataloging Unit Code /If K	nown)			
24.4	e. U.S. Geological Survey 8- Digit Hydro	logic Cataloging Unit Code (II K	nown)			
Descri	be any known water quality impacts on the	he receiving water caused by th	is CSO (e.g., permanent or intermittent beach closings.			
perma	nent or intermittent shellfish bed closings	s, fish kills, fish advisories, other	recreational loss, or violation of any applicable state			
water quality standard.)						
END OF PART G REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM R2 YOU MUST COMPLETE						
700.40		S BETERMINE WHICH OTHER				

INSTRUCTIONS FOR COMPLETING FORM B2 APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY, Form 780-1805

(Facilities less than or equal to 100,000 gallons per day of domestic waste must use Form B, 780-1512.)

PART A - BASIC APPLICATION INFORMATION

\$150.....<5,000 gpd

Check the appropriate box. Do not check more than one item. Operating permits refer to permits issued by the Department 1. of Natural Resources, Water Protection Program. If an Antidegradation Review has not been conducted, submit the application located at the following link, to the Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, MO 65102: dnr.mo.gov/forms/780-1893-f.pdf.

Fees Information: 1.1

DOMESTIC OPERATING PERMIT FEES - PRIVATE

Annual operating permit fees are based on flow. Annual fee/Design flow

Annual fee/Design flow \$1,000.....15,000-24,999 gpd \$300......5,000-9,999 gpd \$1,500.....25,000-29,999 gpd \$600.....10,000-14,999 gpd \$3,000......30,000-99,999 gpd Annual fee/Design flow \$4,000......100,000-249,999 gpd \$5,000.....≥250,000 gpd

New domestic wastewater treatment facilities must submit the annual fee with the original application. If the application is for a site-specific permit re-issuance, send no fees. You will be invoiced separately by the department on the anniversary date of the original permit. Permit fees must be current for the department to reissue the operating permit. Late fees of two percent per month are charged and added to outstanding annual fees.

PUBLIC SEWER SYSTEM OPERATING PERMIT FEES (City, public sewer district, public water district, or other publicly owned treatment works) Annual fee is based on number of service connections. Fees listings are found in 10 CSR 20-6.011 which is available at http://s1.sos.mo.gov/cmsimages/adrules/csr/current/10csr/10c20-6.pdf. New public sewer system facilities should not submit any fee as the department will invoice the permittee.

OPERATING PERMIT MODIFICATIONS, including transfers, are subject to the following fees:

- a. Publicly Owned Treatment Works (POTWs) \$200 each.
- Non-POTWs -- \$100 each for a minor modification (name changes, address changes, other non-substantive b changes) or a fee equal to 25 percent of the facility's annual operating fee for a major modification.
- Name of Facility Include the name by which this facility is locally known. Example: Southwest Sewage Treatment Plant, 2. Country Club Mobile Home Park, etc. Provide the street address or location of the facility. If the facility lacks a street name or route number, provide the names of the closest intersection, highway, country road, etc.
- 2.1 Self-explanatory.
- Global Positioning System, or GPS, is a satellite-based navigation system. The department prefers that a GPS receiver is 2.2 used and the displayed coordinates submitted. If access to a GPS receiver is not available, use a mapping system to approximate the coordinates; the department's mapping system is available at www.gnr.mo.gov/internetmapviewer/.
- 2.3-2.4 Self-explanatory.
- Owner Provide the legal name, mailing address, phone number, and email address of the owner. 3.
- Prior to submitting a permit to public notice, the Department of Natural Resources shall provide the permit applicant 15 days to 3.1 review the draft permit for nonsubstantive drafting errors. In the interest of expediting permit issuance, permit applicants may waive the opportunity to review draft permits prior to public notice.
- 3.2-3.4 Self-explanatory.
- 4. Continuing Authority - Provide information for the permanent organization which will serve as the continuing authority for the operation, maintenance, and modernization of the facility. The regulatory requirement regarding continuing authority is available at http://s1.sos.mo.gov/cmsimages/adrules/csr/current/10csr/10c20-6.odf or contact the Department of Natural Resources Water Protection Program (see contact information 'below).
- Operator Provide the name, certificate number, title, mailing address, phone number, and email address of the operator of 5. the facility.
- Provide the name, title, mailing address, work phone number, and email address of a person who is thoroughly familiar with 6. the operation of the facility and with the facts reported in this application and who can be contacted by the department.

7.1 Process Flow Diagram Examples

WASTEWATER TREATMENT LAGOON

WASTEWATER TREATMENT FACILITY



- 7.2 A topographic map is available on the web at <u>www.dnr.mo.gov/internetmapviewer/</u> or from the Department of Natural Resources' Geological Survey in Rolla at 573-368-2125.
- 7.3 For Standard Industrial Codes visit <u>www.osrha.gov/pis/imis/sicsea.rch.html</u> and for the North American Industry Classification System, visit <u>www.cen.sus.gov/naics</u> or contact the Department of Natural Resources' Water Protection Program.
- 7.4-7.8 Self explanatory.
- 7.9 If wastewater is land-applied submit form I: www.dnr.mo.gov/forms/780-1686-f.pdf.
- 7.10-8. Self-explanatory
- 9.1 A copy of 10 CSR 25 is available at www.sos.mo.gov/adrules/csr/current/10csn/f0csn/asp#10-25.
- 9.2-9.9 Self explanatory.

INSTRUCTIONS FOR COMPLETING FORM B2

APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY

(continued)

PART B – ADDITIONAL APPLICATION INFORMATION 10.-14. Self-explanatory

PART C – CERTIFICATION

15. Electronic Discharge Monitoring Report (eDMR) Submission System – Visit the eDMR site at <u>http://dnr.mo.gov/env/wpp/edmr.htm</u> and click on the "Facility Participation Package" link. The eDMR Permit Holder and Certifier Registration Form and information about the eDMR system can be found in the Facility Participation Package.

Waivers to electronic reporting may be granted by the Department per 40 CFR 127.15 under certain, special circumstances. A written request must be submitted to the Department for approval. Waivers may be granted to facilities owned or operated by:

- a. members of religious communities that choose not to use certain technologies or
- b. permittees located in areas with limited broadband access. The National Telecommunications and Information Administration (NTIA) in collaboration with the Federal Communications Commission (FCC) have created a broadband internet availability map: <u>http://www.broadbandmap.gov/</u>. Please contact the Department if you need assistance.
- 16. Signature All applications must be signed as follows and the signatures must be original:
 - a. For a corporation, by an officer having responsibility for the overall operation of the regulated facility or activity or for environmental matters.
 - b. For a partnership or sole proprietorship, by a general partner or the proprietor.
 - c. For a municipal, state, federal or other public facility, by either a principal executive officer or by an individual having overall responsibility for environmental matters at the facility.

PART D - EXPANDED EFFLUENT TESTING DATA

17. Self-explanatory. ML/MDL means minimum limit or minimum detection limit.

PART E - TOXICITY TESTING DATA

- 18. Self- explanatory.
- PART F INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES
- 19. Federal regulations are available through the U.S. Government Printing Office at
- https://www.gpo.gov/fdsys/browse/collectionCfr.action?collectionCode=CFR.

19.1 Self – explanatory 19.2 A noncategorical si

- A noncategorical significant industrial user is an industrial user that is not a CIU and meets one or more of the following:
 - i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - ii. Contributes a process waste stream that makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - iii. Is designated as an SIU by the control authority.

20.-22.4 Self-explanatory.

PART G – COMBINED SEWER SYSTEMS 23.-24.4 Self-explanatory.

Submittal of an incomplete application may result in the application being returned.

This completed form and any attachments along with the applicable permit fees, should be submitted to:

Department of Natural Resources Water Protection Program ATTN: NPDES Permits and Engineering Section P.O. Box 176 Jefferson City, MO 65102-0176

Map of regional offices with addresses and phone numbers are available on the web at <u>http://dnr.mo.gov/regions/</u>. If there are any questions concerning this form, contact the appropriate regional office or the Department of Natural Resources, Water Protection Program, Operating Permits Section at 800-361-4827 or 573-751-6825.

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM FORM I – PERMIT APPLICATION FOR **OPERATION OF WASTEWATER IRRIGATION SYSTEMS**

G==== &)	MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM FORM I – PERMIT APPLICATION FOR OPERATION OF WASTEWATER IRRIGATION SYSTEMS	FOR AGENCY USE ONLY PERMIT NUMBER MO - DATE RECEIVED
INSTRUCTI	ONS: The following forms must be submitted with Form I: FORM B or B2 fo FORM A for indus	r domestic wastewater. strial wastewater.

1. FACILITY INFORMATION	BECEIVED						
1.1 Facility Name	1.2 Permit Number						
Monett Municipal WWTF	MO- 0021440 JUL 2 5 2017						
1.3 Type of wastewater to be irrigated:	Municipal State/National Park Waldressam						
Municipal with Pretreatment Program or Significant Indust	trial Users 🗹 Other (explain) Effluent from Outfall No. 1						
SIC Codes (list all that apply, in order of importance)	SIC Codes (list all that apply, in order of importance)						
1.4 Months when the business or enterprise will operate or gener ☑ 12 months per year □ Part of year (list Months):	Months when the business or enterprise will operate or generate wastewater: ✓ 12 months per year □ Part of year (list Months):						
 1.5 This system is designed for: □ No-discharge Partial irrigation when feasible and c □ Irrigation during recreation season (April – October) and d □ Other (explain) 	 This system is designed for: □ No-discharge Partial irrigation when feasible and discharge rest of time. □ Irrigation during recreation season (April – October) and discharge during November – March. □ Other (explain)						
1.6 List the Facility outfalls which will be applicable to the irrigatic Outfall Numbers: 003	List the Facility outfalls which will be applicable to the irrigation system. Outfall Numbers: 003						
2. STORAGE BASINS							
2.1 Number of storage basins: 0 Type of basin: Steel Concrete Earthen with membrane liner	Fiberglass Earthen						
3. LAND APPLICATION SYSTEM							
3.1 Number of irrigation sites 1 Total Acres Location: 1/4, E1/2, NW 1/4, Sec 6 T 25n R 2 Location: 1/4, NE 1/4, SE 1/4, Sec 6 T 25n R 2 Attach pages as needed. S 1/2, NE 1/4, T 1/4, T 25n R 2	75 (470 sprinkler heads) 27w Barry County Acres 27w Barry County Acres y						
Attach a site map showing topography, storage basins, irrigation sites, property boundary, streams, wells, roads, dwellings, and other pertinent features.Aerial photo attached with S.O.P							
3.3 Type of vegetation: Grass hay Pasture	Timber Row crops I Other (describe) Golf Course						
3.4 Wastewater flow (dry weather) gallons/day:	Wastewater flow (dry weather) gallons/day:						
Average annual: 2.7 MGD Seasonal 2.7 MGD	Average annual: 2.7 MGD Seasonal 2.7 MGD Off-season 2.7 MGD						
Months of seasonal flow: 9							
780-1686 (08-14)							
3. LAND APPLICATION SYSTEM (continued)							
--	--	--	--	--	--	--	--
.5 Land Application rate per acre (design flow including 1 in 10 year stormwater flows):							
Design: <u>17</u> inches/year <u>0.12</u> inches/hour <u>0.12</u> inches/day <u>0.83</u> inches/week							
Actual: 10 inches/year 0.08 inches/hour 0.08 inches/day 0.54 inches/week							
Total Irrigation per year (gallons): 40 MG Design 20 MG Actual 650 gpm typical; 1,000 gpm Actual months used for Irrigation (check all that apply): Actual months used for Irrigation (check all that apply): Actual months used for Irrigation (check all that apply): Actual months used for Irrigation (check all that apply):							
☐ Jan ☐ Feb ☑ Mar ☑ Apr ☑ May ☑ Jun ☑ Jul ☑ Aug ☑ Sep ☑ Oct ☑ Nov ☐ Dec							
Land Application Rate is based on: □ Nutrient Management Plan (N&P) □ Hydraulic Loading ✓ Other (describe) Application rate required to keep grass green.							
3.7 Equipment type: 🗹 Sprinklers 🗌 Gated pipe 🗌 Center pivot 🔲 Traveling gun 🗌 Other (describe)							
Equipment Flow Capacity: 39,000 Gallons per hour 520 Total hours of operation per year (4 hrs/d; 130 d/y)							
 Public Use Areas. Public access shall not be allowed to public use area irrigation sites when application is occurring. Method of Public Access Restriction: Site is Fenced Usatewater disinfection prior to irrigation Site is not for public use Other (describe): WWTF Effluent disinfected prior to irrigation. 							
3.9 Separation distance (in feet) from the outside edge of the wetted irrigation area to nearby down gradient features: NA Permanent flowing stream 60 Losing Stream 60 Intermittent (wet weather) stream 350 Lake or pond 40 Property boundary 80 Dwellings 3,000 Water supply well Other (describe)							
3.10 The facility must develop and retain an Operation and Maintenance (O&M) Plan for the irrigation system.							
Date of O&M Plan: August, 2014							
4. CERTIFICATION							
I certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attachments and that based on my inquiry of those individuals immediately responsible for obtaining this information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine or imprisonment.							
OWNER OR AUTHORIZED REPRESENTATIVE Dennis L. Pyle City Administrator							
address Telephone Kumber with area code 417. 235. 3355							
SIGNATURE DATE SIGNED 1/20/2017 780-1686 (08-14)							

<u>Standard Operating Procedures</u> <u>Municipal Golf Course Irrigation System</u> <u>City of Monett, Missouri</u>

INTRODUCTION

The City of Monett, Missouri operates an 18-hole municipal golf course that is irrigated with the treated and disinfected water that is discharged from the City's wastewater treatment plant. The wastewater treatment plant operates in accordance with requirements set forth in Missouri State Operating Permit MO-0021440. Because plant effluent is pumped to the golf course directly from the WWTP, this flow is identified in the permit as Permitted Feature No. 003, and separate monitoring requirements and limitations are established for the irrigated effluent.

The purpose for the development of standard operating procedures for the irrigation of the municipal golf course with wastewater treatment plant effluent is to insure that the irrigation is undertaken in a manner that protects both human health and the environment. To this end it is important that land application rates be limited to prevent runoff from the golf course, and the timing of the irrigation be controlled to prevent public access to areas during irrigation.

IRRIGATION EQUIPMENT

The golf course irrigation system includes a booster pump station located at the City's WWTP, that draws treated and disinfected effluent at a location immediately upstream from the point of discharge from the facility into Clear Creek. The booster station is designed to maintain a relatively constant pressure over a wide range of irrigation flows.

The booster pumps deliver flow directly to individually controlled sprinkler heads located throughout the 18-hole golf course. The pattern of irrigation is controlled from a Central Irrigation Controller that allows personnel to individually adjust the application of water to all greens, fairways, tee boxes, etc.

Booster Pump Station

The booster pump station was installed as a package-type system manufactured by Flowtronex PSI, and includes pumps, electrical controls, pressure sensors, flowmeters, valves, etc. required to insure a constant pressure to the irrigation system over a flow range up to about 1000 gallons per minute. The controls automatically shut down the pumps if the system pressure drops to a preset level that would indicate a possible leak from the system.

Operation of the booster pump station is independent of the control of the sprinkler heads. As irrigation demands increase, the pump control system senses a pressure drop, and increases the flow rate and system pressure to insure an adequate supply of water to the sprinkler heads. At times of no demand, the system pressure in maintained by a small jockey pump that operates just enough to hold the system pressure constant.

Irrigation Facilities

The irrigation system is provided water through a network of buried piping that consists of ductile iron and PVC piping varying in size from 2-inch diameter to 10-inch diameter. Sprinkler heads are of a rotary impact-driven type with electric actuation of an internal control valve. The valves are mounted flush with the ground surface, and pop up upon actuation from the irrigation controller. Sprinkler heads and controller are manufactured by Toro. The pipe network is equipped with manually actuated isolation valves, to allow sections to be individually maintained.

Fairway sprinklers deliver approximately 46 gallons per minute of flow over an 85 foot radius. The sprinkler heads are arranged to insure a uniform application of water over the fairways. Tee boxes and greens are equipped with somewhat smaller capacity sprinkler heads due to the lesser surface area that must be irrigated.

Approximately 75 acres of the golf course can be irrigated, utilizing about 300 sprinkler heads on the fairways, and 170 smaller sprinklers on greens and tee boxes. Over the course of a normal 4-hour irrigation cycle, at a typical flow rate of 650 gpm, an average of 0.08-inches of water is applied to the entire golf course. By increasing the number of sprinkler heads in operation at any given time, and/or increasing the duration of the irrigation cycles, the application rate over the entire course can be increased to a maximum of near 0.25-inches per day.

The Central Irrigation Controller allows for the individual operation of each sprinkler head on the golf course via two-way radio communication to pedestal mounted satellites. The controller allows for the division of the irrigation system into separate groups. The controller also has the ability to calculate actual station time based on user input of total time required, operational evapo-transpiration, manual adjustment factors, number of starts, and number of repeat cycles. The controller also logs system operation to allow the user to verify that equipment is operating as planned. The Superintendent can communicate with the irrigation system controller via cellular phone. Low pressure conditions and power outages automatically result in the issuance of emails or text message to the Superintendent.

The irrigation rate is limited to the flow rate through the City's wastewater treatment plant. Nighttime weekend flows through the WWTP can be low enough to require a reduction in the number of sprinkler heads in operation at any given time, thereby reducing the irrigation flow rate. Golf course personnel need to coordinate irrigation patterns and rates with availability of effluent at the WWTP.

Standards – General Irrigation

Water is the most essential part of the golf course operation. Since the game of golf is played on a living plant, either rain or irrigation is necessary for proper course conditioning.

Water is a limited resource, therefore the treated, filtered, and disinfected effluent from the City's wastewater treatment plant is delivered to the golf course for irrigation of the fairways, tee boxes, and greens. The majority of the irrigation shall be conducted in the evening, when the course is empty. The golf course shall be watered to meet the needs of the turf grass and to enhance its playability by maintaining its surfaces as firm as possible.

- Daily water usage records will be maintained by the Superintendent.
- The irrigation system and pump station will be inspected daily by golf course personnel.
- All irrigation will be scheduled under the direction of the Superintendent. Hand watering that is needed during the day in certain areas of the course will be under the direction of the Superintendent.
- Periodic maintenance will be done to the irrigation system in coordination with golf course personnel.
- Annually inspect and replace sprinkler heads that are worn, partially clogged, or do not rotate freely.
- All irrigation piping, sprinklers, and valves shall be inaccessible to patrons of the golf course to insure that the irrigation water is not used for consumptive

purposes. Any accessible system components shall be color-coded and/or tagged to identify the water as non-potable.

- Irrigation of portions of the golf course during periods of play shall be undertaken in a manner that prohibits public access to areas being actively irrigated.
- Irrigation shall provide adequate water for proper plant growth, but shall not result in surface runoff from the course.
- Irrigation shall not be undertaken during or immediately after periods of rainfall when the chance of runoff is increased.
- Refer to the attached Central Irrigation Controller Operations Manual for information on system operation and capabilities.

Standards - After-Hours Irrigation

The City's golf course irrigation system includes a computerized irrigation management system equipped with flow management to increase irrigation efficiency. The system allows preprogrammed control and remote monitoring of all sprinkler heads to insure the uniform application of water to the entire course. In the automatic mode, startup and shutdown are initiated based on a time setting. If needed, manual operation of the irrigation system can also be accomplished.

- Periodically inspect the irrigation system while in operation to insure adequate flows and spray patterns.
- In order to insure that irrigation operations do not result in runoff from the course, golf course personnel shall visually inspect all irrigated areas prior to the start of play each day. Any evidence of too little or too much irrigation shall be reported to the Superintendent.
- On a monthly basis golf course personnel shall verify proper operation of the booster pump pressure monitoring system by creating a low pressure condition that simulates a system leak. Personnel shall confirm that the booster pumps shut down as programmed.
- A discharge from the irrigation equipment is currently considered by regulatory authorities to be an unpermitted outfall that would not be in compliance with the City's wastewater treatment plant operative permit. Any discharge should be immediately reported to the WWTP operators who, in turn, are to notify MDNR within 24-hours per Standard Conditions Part 1 of the plant operating permit.





T

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM FINANCIAL QUESTIONNAIRE

RECEIVED

JUL 2 5 2017

NOTE FINANCIAL INFORMATION THAT IS NOT PROVIDED THROUGH THIS FORM WILL BE OBTAINED BY SECTION DEPARTMENT FROM READILY AVAILABLE SOURCES.						
1.	GENERAL INFORMATION					
FACI Mon	ility NAME nett Municipal WWTF	PERMIT NUMBER #MO- 0021440				
CITY Mon	nett	соимту Вагту				
•	PERMIT RENEWAL/MODIFICATION STATE REVOLVING FUND APPLICATION	SRF PROJECT NUMBER (IF C295	APPLICABLE)			
2.	GENERAL FINANCIAL INFORMATION (ALL FACILITIES)					
2.1	Number of connections to the facility: Residential 3,350	Commercial 458	Industrial 46			
2.2	Current sewer user rate: Based on a 5,000 gallon per month usage \$27.95		The sewer user rate is (check one):			
2.3	Current operating costs for the facility (excludes depreciation):		\$3,291,135			
2.4	Bond Rating (if applicable):		Standard and Poor A+			
2.5	Bonding Capacity: General obligation bond capacity allowed by constitution: cities=up to a property; sewer districts=up to 5% of taxable tangible property	\$25,909,549				
2.6	Current outstanding debt relating to wastewater collection and Debt information is typically available from your community's annual fin	\$6,720,000				
2.7	Amount of current user rate per household per month used tow wastewater debt:	7.40				
2.8	Net direct debt: Net direct debt is the total amount of outstanding general obligation de short-term financing.	\$220,000				
2.9	Overlapping debt: Overlapping debt is the financial obligations of one political jurisdiction a nearby jurisdiction.	\$6,735,006				
2.10	Overall net debt: Overall net debt is defined as debt repaid by property taxes within a util service area. It excludes debt that is repaid by special user fees (e.g. of Overall net debt = Net direct debt + Overlapping debt. Debt information from your community's annual financial statements	\$6,955,006				
2.11	Attach any relevant financial statements.					
3.	FINANCIAL INFORMATION SPECIFIC TO MUNICIPALITIES					
3.1	Municipality's Full Market Property Value (FMPV):		\$525 018 153			
	FMPV data is typically available through your community or state asses	ssor's office	\$525,010,105			
3.2	Municipality's property tax revenues: Property tax revenues are typically available from your community's an statements	nual financial	0			
3.3	Municipality's property tax collection rate: To determine the collection rate, you will need to divide property tax rev taxes levied. To calculate property taxes levied, multiply the assessed within your community/service area by the property tax rate. This inform available through your community or state assessor's office. Property ta typically available in your community's annual financial statements.	renues by the property ralue of real property nation is typically ax revenues are	N/A			

4.	FINANCIAL INFORMATION SPECIFIC TO SEWER	DISTRICTS				
4.1	Total connections to the sewer district: Residential		Commercial	Industrial		
4.2	2 When facilities require upgrades, how are the costs divided? Will the homes connected to the upgraded facility bear the cost Will the costs be divided across the sewer district?					
5.	OTHER CONSIDERATIONS (ALL FACILITIES)					
5.1	Provide a list of major infrastructure or other investments in environmental projects. Include project timing and costs and indicate any possible overlap or complications (attach sheets as necessary):					
5.2	Provide a list of any other relevant local community e requirements or the proposed SRF project. (See Con	conomic conc nmunity Supp	litions that may impa lemental Survey on	ct the ability to afford new permit the following page):		
6.	CERTIFICATION					
FINAN	Dannis I Pila		OFFICIAL TITLE	ministrator		
EMAIL	IMAIL ADDRESS TELEPHONE NUMBER WITH AREA CODE 117 235 3355					
cert attac the ir	ify under penalty of law that I have personally examine hments and that based on my inquiry of those individu of formation is true, accurate and complete. I am aware ding the possibility of fine or imprisonment.	ed and am fan als immediate that there are	hiliar with the informa ly responsible for ob significant penalties	tion submitted in this application and all taining this information, I believe that for submitting false information		
OWNER			OFFICIAL TITLE	Iniziationation		
SIGNAT	DENNIS L. IVIE Dennis I. Le		City rid	DATE SIGNED 7/20/2017		
For a	dditional guidance, see http://usmayors.org/urbanwate	r/media/2013	/0529-report-WaterA	ffordability.pdf.		
or m	nore information regarding your Missouri State Operati /51-1300, to speak with a permit writer in the domestic	ng Permit, con wastewater u	ntact the department init.	's Water Protection Program at		
or m	nore information regarding your State Revolving Fund 51-1300, to speak with a project coordinator in the Fin	Application, co ancial Assista	ontact the departmer ance Center.	nt's Water Protection Program at		
his d	completed form and any attachments should be submi	ted to one of	the following:			
or S	r Submittal of Permit Renewal/Modification: For Submittal of SRF Applications:					
Vate Vate TTN .O. effe	artment of Natural ResourcesDepartment of Natural Resourceser Protection ProgramWater Protection Program'N: NPDES Operating Permits SectionATTN: Financial Assistance Center. Box 176P.O. Box 176erson City, MO 65102Jefferson City, MO 65102					

G	***
6	

780-2511 (09/15)

5 . . i A

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM **Community Supplemental Survey**

PLEASE ANSWER THE FOLLOWING APPLICABLE QUESTIONS. (ATTACH ADDITIONAL SHEETS AS NECESSARY) 1. Are there any significant transportation conforms within 20 miles of your community? If yes, please explain. (Example: major interstate, railroad center) Yes, I-44 is 15 miles from Monett. BNSF railroad bisects MonetI - 35 trains/day 2. Are there any significant manufacturing or employment centers within 20 miles of your community? If yes, please explain. (Example: commercial farming, manufacturing, government operation, big box store) Yes, Large industrial and commercial base (EFCO, Tyson, IDF, Schreiber Foods, Walmart, Lowe's) 3. Where do the majority of children in your community receive their education? (Please cleck appropriate box for each education level) Elementary Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles Farther than 20 miles High School Within your community Within 20 miles 4. Considering your community is tabes, debt level, ability to bond capital improvement projects, or repay toans, how likely is it that your community could wilkely Very Likely 4. An upgrade or replacements to your wastewater system costing \$250,000 Improvement projects, or repay toans, how likely attements as it relates to the population change you predicted in questions 5. 6. Otherk the appropriate boxes in the following statements as it									
1. Are there any significant transportation coridors within 20 miles of your community? If yes, Jease explain, Cample: major interstate, rainoad center) 2. Are there any significant manufacturing or employment centers within 20 miles of your community? If yes, please explain, Cample: community indicaturing, government operation, big box store) 3. Where do the majority of children in your community receive their education? (Please check appropriate box for each education level) Elementary Within your community Within your community Within 20 miles Farther than 20 miles Farther than 20 miles Middle School Within your community Within 20 miles Farther than 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 4. Considering your community Within 20 miles Farther than 20 miles 5. Other the following: <	PLE	PLEASE ANSWER THE FOLLOWING APPLICABLE QUESTIONS. (ATTACH ADDITIONAL SHEETS AS NECESSARY)							
Yes, I-44 is 15 miles from Monett. BNSF railroad bisects Monett - 35 trains/day 2. Are there any significant manufacturing or employment centers within 20 miles of your community? If yes, please explain. (Example: commercial farming, manufacturing, government operation, big box store) Yes, Large industrial and commercial base (EFCO, Tyson, IDF, Schreiber Foods, Walmart, Lowe's) 3. Where do the majority of children in your community receive their education? (Please check appropriate box for each education level) Elementary Within your community Within your community Within 20 miles Farther than 20 miles Farther than 20 miles 4. Considering your community to back capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very unlikely Unlikely Likely Ukely 4. An upgrade or replacements to your wastewater system costing \$250,000 Image: Community Very unlikely Unlikely Likely 5. Which of the following best describes anticipated population change for your community over the next ten years? Significant Decrease Remain the Same Increase Significant Increase 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. Increase Significantly Increase 7. The majority of young people leave the community in search of employment or education elsewha	1.	 Are there any significant transportation corridors within 20 miles of your community? If yes, please explain. (Example: major interstate, railroad center) 							
 Are there any significant manufacturing or employment centers within 20 miles of your community? If yes, Jarge industrial and commercial base (EFCO, Tyson, IDF, Schreiber Foods, Walmart, Lowe's) Where do the majority of children in your community mecalve their education? (Please check appropriate box for each education level) Elementary [2] Within your community [2] Within 20 miles [2] Farther than 20 miles Middle School [2] Within your community [2] Within 20 miles [2] Farther than 20 miles High School [2] Within your community [2] Within 20 miles [2] Farther than 20 miles Farther than 20 miles [2] Farther than 20 miles Considering your community [2] Within your community [2] Within 20 miles [2] Farther than 20 miles Considering your community fast base, debt level, ability to bond capital innovoement projects, or repay loans, how likely is it that your community could innove the following: A. 1 An upgrade or replacements to your wastewater system costing \$50,000 [2] (2] (2] (2] (2] (2] (2] (2] (2] (2] (Yes,	I-44 is 15 miles from Mo	nett. BNSF railroad bise	cts Monett - 35 trains/day					
Yes, Large industrial and commercial base (EFCO, Tyson, IDF, Schreiber Foods, Walmart, Lowe's) 3. Where do the majority of children in your community receive their education? (Please check appropriate box for each education level) Elementary Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community is tabase, debt level, ability to bond capital improvement projects, or repay teams, how likely is it that your community could afford to pay for the following: Very unlikely Unlikely Likely Very Unlikely Unlikely Likely Very Likely 4. An upgrade or replacements to your wastewater system costing \$50,000 Improvement projects, or repay teams, how likely is it that your community over the next ten years? 5. Which of the following best describes anticipated population change for your community over the next ten years? 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6. Check the appropriate boxes in the following statements as it relates to the population elsewhere. 6. Check the appropriate boxes in the following statements as it relates to the population elsewhere. 6. Check the appropriate boxes in the following statements as it relates to the populatio	2.	 Are there any significant manufacturing or employment centers within 20 miles of your community? If yes, please explain, (Example: commercial farming, manufacturing, government operation, big box store) 							
3. Where do the majority of children in your community receive their education? (Please check appropriate box for each education level) Elementary Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community stax base, debt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very Unlikely Unlikely Likely Very Unlikely 4.1 An upgrade or replacements to your wastewater system costing \$50,000 V Variant Very 4.3 An upgrade or replacements to your wastewater system costing \$250,000 Very Vulkely Likely Very 5. Which of the following best describes anticipated population change for your community over the next ten years? Significant Decrease Remained the Same Increase Significant Uncrease 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. Over the past 20 years the population has: Significantly Decreased Decreased Increased Significantly Increase 6. Definitely False Probably False Probably True True Unknown <td>Yes,</td> <td>Large industrial and con</td> <td>nmercial base (EFCO, T)</td> <td>vson, IDF, Schreiber Foods</td> <td>. Walm</td> <td>art, Lowe's</td> <td></td> <td></td> <td></td>	Yes,	Large industrial and con	nmercial base (EFCO, T)	vson, IDF, Schreiber Foods	. Walm	art, Lowe's			
3. Where do the majority of children in your community receive their education? (Please check appropriate box for each education level) Elementary Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community is tax base, delt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very Unlikely Unlikely Likely Very Unlikely 4. An upgrade or replacements to your wastewater system costing \$50,000									
Elementary Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community to base, debt level, ability to bond capital improvement projects, or repay to the stase, debt level, ability to bond capital universe of the following: Very Unlikely Unlikely Likely Very Unlikely Likely Very Unlikely Likely Likely <td>3.</td> <td colspan="7">Where do the majority of children in your community receive their education? (Please check appropriate box for each education level)</td> <td></td>	3.	Where do the majority of children in your community receive their education? (Please check appropriate box for each education level)							
Middle School Within your community Within 20 miles Farther than 20 miles High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community is tax base, debt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very Unlikely Unlikely Likely Ver		Elementary	Within your communit	ty 🔲 Within 20 miles		Farther that	an 20 miles		
High School Within your community Within 20 miles Farther than 20 miles 4. Considering your community tax base, debt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very Unlikely Unlikely Likely Very Unlikely Likely Very Likely 4.1 An upgrade or replacements to your wastewater system costing \$250,000 4.2 An upgrade or replacements to your wastewater system costing \$250,000 4.3 An upgrade or replacements to your wastewater system costing \$1 million 5. Which of the following best describes anticipated population change for your community over the next ten years? Significant Decrease Decrease Remain the Same Increase Significant Increase 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6.1 Over the past 20 years the population has:		Middle School	Within your communit	ty 🔲 Within 20 miles		Farther that	n 20 miles		
4. Considering your community's tax base, debt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following: Very Unlikely Unlikely Likely Likely Very Likely 4.1 An upgrade or replacements to your wastewater system costing \$250,000 Image: Consider the system costing \$1 million Image: Consider the system costing \$250,000 Image: Consideres: Conset: Consider the system costing \$250,000		High School	Within your communit	ty 🔲 Within 20 miles		Farther that	n 20 miles		
4.1 An upgrade or replacements to your wastewater system costing \$250,000 4.2 An upgrade or replacements to your wastewater system costing \$250,000 4.3 An upgrade or replacements to your wastewater system costing \$1 million 5. Which of the following best describes anticipated population change for your community over the next ten years? Significant Decrease Decrease Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6.1 Over the past 20 years the population has: Significantly Decreased Significantly Decreased Decrease Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6.1 Over the past 20 years the population has: Significantly Decreased Significantly Decreased Decrease Definitely False Probably False Probably False Probably True Definitely False Probably False Probably False Probably True Definitely False Probably False Significantly Decrease Decrease Remain the Same Increase Significantly Decrease Decrease Remain the Same Increase Significantly Decrease	4.	Considering your community's tax base, debt level, ability to bond capital improvement projects, or repay loans, how likely is it that your community could afford to pay for the following:			Very Unlikely	Unlikely	Likely	Very Likely	
4.2 An upgrade or replacements to your wastewater system costing \$250,000 An upgrade or replacements to your wastewater system costing \$1 million Significant Decrease Decrease Remain the Same Increase Significant Decrease Decrease Remain the Same Increase Significant Decrease Significantly Decrease Remain the Same Increase Significantly Decreased Decrease Remained the Same Increase Significantly Increased Significantly Decreased Decrease Remained the Same Increase Significantly Increased Significantly Increased Significantly Decreased Probably Faise Probably True True Unknown An the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase An the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Increase Significantly Increase Significantly Increase		4.1 An upgrade or re	placements to your wast	tewater system costing \$50	,000			2 2 3	~
4.3 An upgrade or replacements to your wastewater system costing \$1 million 5. Which of the following best describes anticipated population change for your community over the next ten years? Significant Decrease Decrease Remain the Same Increase Significant Increase 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6.1 Over the past 20 years the population has: Significantly Decreased Decreased Remained the Same Increased Significantly Increased 6.2 The majority of the population in the community is retired or is near retirement. Definitely False Probably False Probably True True Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Increase Significantly Increase 6.5 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: </td <td></td> <td>4.2 An upgrade or re</td> <td>placements to your wast</td> <td>tewater system costing \$25</td> <td>0,000</td> <td></td> <td></td> <td></td> <td>~</td>		4.2 An upgrade or re	placements to your wast	tewater system costing \$25	0,000				~
 An opticate of replacements to your wastewater system costing \$1 minute processing \$1 minute process \$1 minute processing \$1 minute processing \$1 minute process \$1 min		4.2 An ungrado or ro	placements to your wast	towator system costing \$1	million	 			
3. Wind of the following best describes anticipated population change for your community over the fiext left years? [Significant Decrease] Decrease Remain the Same Increase Significant Increase 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6. Over the past 20 years the population has: Significantly Decreased Decreased Remained the Same Increase Significantly Increased 6.2 The majority of the population in the community is retired or is near retirement. Definitely False Probably False Probably True True Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Increase Significantly Increase 6.5. In the foreseeable future the tax base of the community will: Significantly Decrease Remain the Same Increase Significantly Increase 6.5. In the foreseeable future the tax base of the community will: Significantly Decrease Significantly will: Significantly Increase Significantly Increase	5	Which of the following h	placements to your wast	d population change for you	Innon		the post to	L	
6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6. Check the appropriate boxes in the following statements as it relates to the population change you predicted in questions 5. 6. Over the past 20 years the population has: Significantly Decreased Decreased Remained the Same Increased Significantly Increased 6.2 The majority of the population in the community is retired or is near retirement. Definitely False Probably False Probably False Probably True True Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably False Probably True Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Estimate Remain the Same Increase Significantly Increase 6.5 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Bernain the Same Pincrease Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Pincrease Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Remain the Same Pincrease Significant employment 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. 8. Should an existing or proposed regional wastewater district be willing to connect, Wery Unlikely Unlikely Unlikely Likely Very Unlikely	0.							i years?	orogoo
 6. Critect the appropriate bodes in the following statements as it relates to the population change you predicted in questions 5. 6.1 Over the past 20 years the population has: Significantly Decreased Decreased Remained the Same Increased Significantly Increased 6.2 The majority of the population in the community is retired or is near retirement. Definitely False Probably False Probably True True Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is	6	Chack the appropriate k	Decrease			tion change		ignificant in	tions F
6.1 Over the past 20 years the population has: Significantly Decreased Decreased Remained the Same Increased Significantly Increased 6.2 The majority of the population in the community is retired or is near retirement. Increased Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Increase Significantly Increase 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Increase Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: Significantly Increase Significantly Increase 6.5 In the foreseeable future the tax base of the community will: Significantly Increase Significantly Increase Significantly Increase 6.6.7 It is	0.	Check the appropriate t	Joxes in the following sta	atements as it relates to the	popula	ation change	e you predic	ted in ques	uons 5.
 Significantly Decreased Decreased Remained the Same Increased Significantly Increased Significantly Increased Significantly Increased Significantly Increased Significantly Decreased Probably False Probably True True Unknown The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True True Unknown In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase In the foreseeable future the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy No Debt What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, sign	6.1	Over the past 20 years	the population has:						
 6.2 The majority of the population in the community is retired or is near retirement. Definitely False Probably False Probably True Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, wind your Current facility, how likely would you be to consider this as an ontion? 		Significantly Decreas	sed 🔲 Decreased	Remained the Same	🗖 In	creased	🗹 Si	gnificantly I	ncreased
☑ Definitely False □ Probably False □ Probably True □ True □ Unknown 6.3 The majority of young people leave the community in search of employment or education elsewhere. □ Definitely False □ Probably False □ Probably True □ True □ Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.6.5 In the foreseeable future the tax base of the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.6.6 In the foreseeable future the tax base of the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.7 It is	6.2	The majority of the popu	ulation in the community	is retired or is near retireme	ent.				
 6.3 The majority of young people leave the community in search of employment or education elsewhere. Definitely False Probably False Probably True True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Difficult Somewhat Difficult Somewhat Difficult Somewhat Same searcessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, work, or operate your current facility, how likely would you be to consider this as an octoact. Very Unlikely Unlikely Unlikely Likely Likely Likely Unlikely		Definitely False	Probably False	Probably True	TI TI	rue	🗖 Ui	nknown	
 Definitely False Probably False Probably False Probably True True Unknown 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, or operate your current facility, h	6.3	The majority of young p	eople leave the commun	nity in search of employment	t or ed	ucation else	where.		
 6.4 In the foreseeable future, the employment opportunity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, Unlikely Unlikely Likely Likely Likely Likely		Definitely False	Probably False	Probably True	C Ti	rue	🗖 Ui	nknown	
□ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.5 In the foreseeable future the economic activity in or around the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.6 In the foreseeable future the tax base of the community will: □ Significantly Decrease □ Decrease □ Remain the Same □ Increase □ Significantly Increase 6.6.7 It is for the community to meet its debt obligations. □ Difficult □ Somewhat Difficult ☑ Somewhat Easy □ Easy □ No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an option? Very Unlikely Likely Very Likely	6.4	In the foreseeable future, the employment opportunity in or around the community will:							
 6.5 In the foreseeable future the economic activity in or around the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an ontion? 		Significantly Decreas	Significantly Decrease 🔲 Decrease 🔲 Remain the Same 🖉 Incr			crease	se 🔲 Significantly Increase		
 Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Decrease Remain the Same Increase Significantly Increase Somewhat Difficult Somewhat Easy Easy No Debt What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an option? 	6.5	In the foreseeable future the economic activity in or around the community will:							
 6.6 In the foreseeable future the tax base of the community will: Significantly Decrease Decrease Remain the Same Increase Significantly Increase 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an option? 		Significantly Decreas	e 🗖 Decrease	Remain the Same	🗹 In	crease	🗖 Si	gnificantly I	ncrease
 Significantly Decrease Decrease Remain the Same Increase Significantly Increase Significantly Decrease Remain the Same Increase Significantly Increase It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an ontion? 	6.6	In the foreseeable future	the tax base of the com	nmunity will:					
 6.7 It is for the community to meet its debt obligations. Difficult Somewhat Difficult Somewhat Easy Easy No Debt 7. What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) 8. Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an option? 		Significantly Decreas	e 🗖 Decrease	Remain the Same	🗹 In	crease	Si	gnificantly l	ncrease
 Difficult Somewhat Difficult Somewhat Easy Easy No Debt What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as a option? 	6.7	It is for	the community to meet i	its debt obligations.					
 What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.) Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as a option? 		Difficult	Somewhat Difficul	lt 🔄 Somewhat Easy	🗖 Ea	asy	🗖 No	Debt	
B. Should an existing or proposed regional wastewater district be willing to connect, own, or operate your current facility, how likely would you be to consider this as an option? Very Unlikely Unlikely	7.	What other issues or information should be considered when determining population stability or the financial ability for your community to pay for significant capital investments? Attach sheets as necessary. (Example: Seasonal population changes, natural resources (lakes, rivers), age of infrastructure, significant employment changes, etc.)							
	8.	Should an existing or pro own, or operate your cur an option?	posed regional wastewa rent facility, how likely w	ater district be willing to con rould you be to consider this	inect, s as	Very Unlikely	Unlikely	Likely	Very Likely



- (16) TRICKLING FILTER NO. 3 (1) INFLUENT DIVERSION MANHOLE 2 LAGOON DIVERSION STRUCTURE (17) 1ST STAGE AEROBIC DIGESTER (18) 1ST STAGE AEROBIC DIGESTER 3 LAGOON (19) SLUDGE / SCUM RECIRCULATION MANHOLE NO. 6 (4) SCREW LIFT PUMP STATION (20) SLUDGE OPERATIONS BUILDING (5) HEADWORKS BUILDING (21) WASTE SLUDGE PUMPING BOX (6) AERATED GRIT TANK (37) (7) REWORKED PRIMARY CLARIFIER INLET BOX (22) 2ND STAGE AEROBIC DIGESTER (23) 2ND STAGE AEROBIC DIGESTER PRIMARY CLARIFIER SCUM BOX & MANHOLE (8) (24) SLUDGE TRUCK LOADING PORT (9) PRIMARY CLARIFIER NO. 1 (25) REAERATION STEPS & SAMPLER (10) PRIMARY CLARIFIER NO. 2 (26) PLANT EFFLUENT (11) PRIMARY CLARIFIER EFFLUENT BOX (27) INTERMEDIATE / RAS PUMPING STRUCTURE (12) TRICKLING FILTER FLOW CONTROL STRUCTURE (28) ADMINISTRATIVE BUILDING (13) TRICKLING FILTER PUMP BUILDING (29) DIGESTER COMPLEX BUILDING (14) TRICKLING FILTER NO. 1 (30) PRIMARY DIGESTER (15) TRICKLING FILTER NO. 2
- (31) SECONDARY DIGESTER
 - (32) SLUDGE THICKENER
 - (33) SLUDGE HOLDING TANK
 - (34) SLUDGE TRUCK LOADING PORT
 - (35) MAINTENANCE BUILDING
 - (36) SLUDGE DRYING BEDS
 - EFFLUENT FLOW CONTROL STRUCTURE
 - (38) TERTIARY FILTRATION SCREW LIFT PUMP STRUCTURE
 - (39) TERTIARY FILTERS FLOW CONTROL STRUCTURE
 - (40) TERTIARY FILTER BUILDING
 - (41) TERTIARY FILTER BACKWASH MANHOLE
 - (42) DIVERSION MANHOLE
 - (43) GRIT TANK EFFLUENT SPLITTER BOX
 - (44) PAD MOUNT TRANSFORMER
 - (45) GOLF COURSE IRRIGATION BOOSTER PUMP STATION

- (46) UV BASIN
- (47) STORAGE BUILDING
- (48) SNAIL REMOVAL STRUCTURE
- (49) STORAGE BUILDING
- (50) FINAL CLARIFIER No. 2
- (51) FINAL CLARIFIER No. 1
- (52) ELECTRICAL CONTROL BUILDING
- (53) GENERATOR
- (54) PAD MOUNT TRANSFORMER
- 55 OXIDATION DITCH No. 1 56 OXIDATION DITCH No. 2
- (57) FINAL CLARIFIERS FLOW SPLITTER BOX
 (58) TRICKLING FILTER EFFLUENT INTERCEPT MANHOLE
 (59) JUNCTION BOX No. 1

- (60) JUNCTION BOX No. 2

\\Amce-fs\projects\Monett MO\City of Monett\Wastewater\\WWTP Operating Permit\JobFile\2017\Monett Plant Flow Diag..docx



10 0 Ø 43 $\lambda(2)$ (5) 4 6. n α (31) 24 29 (134) 3 (32) 30 33 6) SIX ANAEROBIC BASINS 62 FOUR ANOXIC BASINS 63 SLUDGE PUMPING 64) GRAVITY BELT THICKENER

FORM B-2 ITEM 7.1 PLANT FLOW DIAGRAM AND PLANT LAYOUT