

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law (Chapter 644 RSMo, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0024911

Owner: City of Kansas City
Address: 4800 East 63rd Street, Kansas City, MO 64130

Continuing Authority: Same as above
Address: Same as above

Facility Name: KC Blue River WWTP
Facility Address: 7300 Hawthorne Road, Kansas City, MO 64120

Legal Description: See Page 2
UTM Coordinates: See Page 2

Receiving Stream: See Page 2
First Classified Stream and ID: See Page 2
USGS Basin & Sub-watershed No.: See Page 2

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

See Page 2

This permit authorizes only wastewater and stormwater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas.

April 1, 2021
Effective Date

September 1, 2022
Modification Date

March 31, 2026
Expiration Date

Chris Wieberg, Director, Water Protection Program

FACILITY DESCRIPTION (continued):

Outfall #001 – POTW

The use or operation of this facility shall be by or under the supervision of a Certified “A” Operator.

Rock box filter unit / 6 automatic bar screens / 6 aerated grit chambers / 4 hydro cyclone-type grit removal units / 4 primary clarifiers / 4 plastic media covered trickling filters with air handling systems / 4 final clarifiers / effluent pump station / chlorination / dechlorination / 2 sludge holding tanks / 2 anaerobic sludge digesters / 3 dissolved air flotation units / 2 belt presses / 1 sludge incinerator / ash storage lagoon / sludge/biosolids are incinerated, stabilized, landfilled, or land applied

Design population equivalent is 850,000.

Design flow is 105 million gallons per day.

Actual flow is 73.4 million gallons per day.

Design sludge production is 23,800 dry tons/year.

| | |
|---------------------------------|--------------------------------------|
| Legal Description: | Sec. 15, T50N, R32W, Jackson County |
| UTM Coordinates: | X=371700, Y=4333636 |
| Receiving Stream: | Missouri River (P) |
| First Classified Stream and ID: | Missouri River (P) (356) 303(d) List |
| USGS Basin & Sub-watershed No.: | (10300101-0301) |

Outfalls #002, #003, and #004 – previous stormwater outfalls. All stormwater outfalls are now covered by Section **D. Special Condition #20**.

Outfall #005 – Discharges from this outfall is no longer authorized, and shall be subject to 40 CFR 122.41(m) and reported according to 40 CFR 122.41(m)(3)(i) & (ii).

Permitted Feature INF – Influent Monitoring Location – Headworks – Samples are to be collected from the sampling locations for the two influent lines into the plant. Samples are collected from each influent location and are averaged together. See influent averaging requirements on Page 5 (**Note 3**).

NEID influent sampling location:

| | |
|--------------------|-------------------------------------|
| Legal Description: | Sec. 31, T50N, R32W, Jackson County |
| UTM Coordinates: | X=370759, Y=4330975 |

Blue River influent sampling location:

| | |
|--------------------|-------------------------------------|
| Legal Description: | Sec. 36, T50N, R33W, Jackson County |
| UTM Coordinates: | X=370481, Y=4330819 |

CSO Locations 006-100: See Section **F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS** on pages 12-16 of the permit for the list of the CSO locations, UTM coordinates, legal descriptions, and stream information.

| OUTFALL #001 | TABLE A-1. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS | | | | | |
|---|--|----------------------------|-------------------|-------------------------------|--------------------------|----------------|
| The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in Table A-1 shall become effective on April 1, 2021 and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: | | | | | | |
| EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Limit Set: M | | | | | | |
| Flow | MGD | * | | * | once/day | 24 hr. total |
| Biochemical Oxygen Demand ₅ | mg/L | | 60 | 40 | once/weekday*** | composite** |
| Total Suspended Solids | mg/L | | 60 | 40 | once/weekday*** | composite** |
| <i>E. coli</i> (Note 1, Page 5) | #/100mL | | 1,030 | 206 | once/week | grab |
| Ammonia as N (Jan – May) | mg/L | * | | * | once/weekday*** | composite** |
| Ammonia as N (June) | mg/L | 58.1 | | 36.4 | once/weekday*** | composite** |
| Ammonia as N (July) | mg/L | 66.7 | | 32.1 | once/weekday*** | composite** |
| Ammonia as N (August) | mg/L | 71.6 | | 37.5 | once/weekday*** | composite** |
| Ammonia as N (Sep – Dec) | mg/L | * | | * | once/weekday*** | composite** |
| Total Residual Chlorine (Note 2, Page 5) | µg/L | < 130 | | < 130 | once/week | grab |
| Total Phosphorus | mg/L | * | | * | once/month | composite** |
| Total Kjeldahl Nitrogen | mg/L | * | | * | once/month | composite** |
| Nitrite + Nitrate | mg/L | * | | * | once/month | composite** |
| EFFLUENT PARAMETER(S) | UNITS | MINIMUM | | MAXIMUM | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| pH – Units**** | SU | 6.0 | | 9.0 | once/weekday*** | grab |
| EFFLUENT PARAMETER(S) | | | UNITS | MONTHLY AVERAGE MINIMUM | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Biochemical Oxygen Demand ₅ – Percent Removal (Note 3, Page 5) | | | % | 65 | once/month | calculated |
| Total Suspended Solids – Percent Removal (Note 3, Page 5) | | | % | 65 | once/month | calculated |
| MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE MAY 28, 2021 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS. | | | | | | |

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

*** Once each weekday means: Monday, Tuesday, Wednesday, Thursday & Friday, except for Federal holidays.

**** pH is measured in pH units and is not to be averaged.

| OUTFALL #001 | TABLE A-2. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS | | | | | |
|---|--|----------------------------|-------------------|--------------------|--------------------------|----------------|
| The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in Table A-2 shall become effective on <u>April 1, 2021</u> and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: | | | | | | |
| EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Limit Set: Q | | | | | | |
| Cadmium, Total Recoverable | µg/L | * | | * | once/quarter ***** | composite** |
| Copper, Total Recoverable | µg/L | * | | * | once/quarter ***** | composite** |
| Cyanide, amenable to chlorination | µg/L | * | | * | once/quarter ***** | grab |
| Oil & Grease | mg/L | * | | * | once/quarter ***** | grab |
| Phenol | µg/L | * | | * | once/quarter ***** | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>JULY 28, 2021</u> . | | | | | | |

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

***** See table below for quarterly sampling requirements.

| Quarterly Minimum Sampling Requirements | | | |
|---|-----------------------------|--|--------------------------|
| Quarter | Months | Quarterly Effluent Parameters | Report is Due |
| First | January, February, March | Sample at least once during any month of the quarter | April 28 th |
| Second | April, May, June | Sample at least once during any month of the quarter | July 28 th |
| Third | July, August, September | Sample at least once during any month of the quarter | October 28 th |
| Fourth | October, November, December | Sample at least once during any month of the quarter | January 28 th |

Note 1 – Effluent limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean. The Weekly Average for *E. coli* will be expressed as a geometric mean if more than one (1) sample is collected during a calendar week (Sunday through Saturday).

Note 2 – This permit contains a Total Residual Chlorine (TRC) limit.

- The Water Quality Based Effluent Limit for Total Residual Chlorine was calculated to be **53 µg/L** (daily maximum limit) and **36 µg/L** (monthly average limit). These limits are below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The Department has determined the current acceptable ML for total residual chlorine to be 130 µg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit. Measured values greater than or equal to the minimum quantification level of 130 µg/L will be considered violations of the permit and values less than the minimum quantification level of 130 µg/L will be considered to be in compliance with the permit limitation.
- Disinfection is required during the recreational season from April 1 through October 31. Do not chlorinate during the non-recreational months and an actual analysis for TRC is not necessary.
- Do not chemically de-chlorinate **if it is not needed to meet the limits in your permit.**
- If no chlorine was used in a given sampling period, an actual analysis for TRC is not necessary. Simply report as “AG – Conditional Monitoring Not Required This Period” for TRC in the eDMR system.

| PERMITTED FEATURE <u>INF</u> | TABLE B-1. INFLUENT MONITORING REQUIREMENTS | | | | | |
|--|--|-------------------------|-------------------|--------------------|--------------------------|-------------|
| The monitoring requirements in Table B-1 shall become effective on <u>April 1, 2021</u> and remain in effect until expiration of the permit. The influent wastewater shall be monitored by the permittee as specified below: | | | | | | |
| PARAMETER(S) | UNITS | MONITORING REQUIREMENTS | | | | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Limit Set: IM | | | | | | |
| Biochemical Oxygen Demand ₅ (Note 3) | mg/L | | | * | once/weekday*** | composite** |
| Total Suspended Solids (Note 3) | mg/L | | | * | once/weekday*** | composite** |
| Ammonia as N | mg/L | * | | * | once/month | composite** |
| Total Phosphorus | mg/L | * | | * | once/month | composite** |
| Total Kjeldahl Nitrogen | mg/L | * | | * | once/month | composite** |
| Nitrite + Nitrate | mg/L | * | | * | once/month | composite** |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>MAY 28, 2021</u> . | | | | | | |

* Monitoring requirement only.

** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

*** Once each weekday means: Monday, Tuesday, Wednesday, Thursday & Friday, except for Federal holidays.

Note 3 – Influent sampling for BOD₅ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Influent concentrations (C) will be calculated as a flow (Q) weighted average between the NEID and Blue River (BR) influent sampling locations using the following formula: $[(Q_{NEID} \times C_{NEID}) + (Q_{BR} \times C_{BR})] / (Q_{NEID} + Q_{BR})$. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Calculate Percent Removal by using the following formula: $[(\text{Average Influent} - \text{Average Effluent}) / \text{Average Influent}] \times 100\% = \text{Percent Removal}$. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device. Percent removal requirements apply only during dry weather. When calculating percent removal efficiencies, the City may exclude influent and effluent data from the percent removal calculations on corresponding days when rainfall exceeds 0.1 inches or snow melt is occurring in the KC Blue River WWTP's sewer collection system service area.

C. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached **Parts I, II, & III** standard conditions dated **August 1, 2014, May 1, 2013, and August 1, 2019**, and hereby incorporated as though fully set forth herein. The permittee is required to conduct biosolids testing frequency in accordance with the monitoring frequency of Table C-1 below. Table C-1 supersedes the requirements in Standard Conditions Part III, Section J – Monitoring Frequency Table 5.

| Table C-1: Monitoring Frequency (See † and Ω) | |
|--|---|
| Metals, Pathogens and Vectors, Phosphorus, Total Potassium | Nitrogen TKN, Nitrogen PAN ¹ |
| 6/year | 1/month |

1. Calculate plant available nitrogen (PAN) when either of the following occurs:

- when biosolids are greater than 50,000 mg/kg TN; or
- when biosolids are land applied at an application rate greater than two dry tons per acre per year.

† - Total Solids: A grab sample of biosolids shall be tested once per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of biosolids applied per acre.

Ω - This table is not applicable for incineration and permit holders that landfill their sludge/biosolids.

D. SPECIAL CONDITIONS

1. **Electronic Discharge Monitoring Report (eDMR) Submission System.** Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent monitoring data and any report required by the permit (unless specifically directed otherwise by the permit) shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally consistent set of data about the NPDES program.
 - (a) eDMR Registration Requirements. The permittee must register with the Department's eDMR system through the Missouri Gateway for Environmental Management (MoGEM) before the first report is due. Registration and other information regarding MoGEM can be found at <https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem>. Information about the eDMR system can be found at <https://dnr.mo.gov/water/business-industry-other-entities/reporting/electronic-discharge-monitoring-reporting-system-edmr>. The first user shall register as an Organization Official and the association to the facility must be approved by the Department. Regarding Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit unless a waiver is granted by the Department. See paragraph (c) below.
 - (b) Electronic Submissions. To access the eDMR system, use the following link in your web browser: <https://apps5.mo.gov/mogems/welcome.action>. If you experience difficulties with using the eDMR system you may contact edmr@dnr.mo.gov or call 855-789-3889 or 573-526-2082 for assistance.
 - (c) Waivers from Electronic Reporting. The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the Department in compliance with 40 CFR Part 127. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: <https://dnr.mo.gov/document-search/electronic-discharge-monitoring-report-waiver-request-form-mo-780-2692>. The Department will either approve or deny this electronic reporting waiver request within 120 calendar days.
2. The full implementation of this operating permit, which includes implementation of any applicable schedules of compliance, shall constitute compliance with all applicable federal and state statutes and regulations in accordance with §644.051.16, RSMo, and the Clean Water Act (CWA) section 402(k); however, this permit may be reopened and modified, or alternatively revoked and reissued:
 - (a) To comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) To incorporate an approved pretreatment program or modification thereto pursuant to 40 CFR 403.8(c) or 40 CFR 403.18(e), respectively.
3. The permittee shall comply with any applicable requirements listed in 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. To request a modification of the operational control testing requirements listed in 10 CSR 20-9, the permittee shall submit a permit modification application and fee to the Department requesting a deviation from the operational control monitoring requirements. Upon approval of the request, the Department will modify the permit.
 - (a) The facility is approved for the following modified monitoring frequency:
 - (1) Total Residual Chlorine analyses of the effluent shall be performed weekly during the recreational season per note 2 on Page 4, in accordance with the measurement frequency outlined in Table A-1 on Page 3.
4. Reporting of Non-Detects:
 - (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
 - (b) The permittee shall not report a sample result as "Non-Detect" without also reporting the detection limit of the test. Reporting as "Non Detect" without also including the detection limit will be considered failure to report, which is a violation of this permit.
 - (c) The permittee shall provide the "Non-Detect" sample result using the less than sign and the minimum detection limit (e.g. <10).
 - (d) Where the permit contains a Minimum Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
 - (e) See Standard Conditions Part I, Section A, #4 regarding proper detection limits used for sample analysis.
 - (f) When a parameter is not detected above ML, the permittee must report the data qualifier signifying less than ML for that parameter (e.g., < 50 µg/L, if the ML for the parameter is 50 µg/L). For reporting an average based on a mix of values detected and not detected, assign a value of "0" for all non-detects for that reporting period and report the average of all the results.

D. SPECIAL CONDITIONS (continued)

5. All outfalls must be clearly marked in the field.
6. Report as no-discharge when a discharge does not occur during the report period.
7. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).
8. The permittee has developed a comprehensive program for maintenance and repair of the collection system. The permittee's program is consistent with the US EPA's Guide for Evaluating Capacity, Management, Operation, And Maintenance Plan Performance Criteria (CMOM) Programs at Sanitary Sewer Collection Systems (Document number EPA 305-B-05-002). The permittee shall continue to implement the CMOM Program in accordance with the federal consent decree entered in the matter of the *United States v. The City of Kansas City, Missouri, 4:10-cv-0497*, including any amendment thereto. The permittee shall continue to submit an Annual Report to the Department on the same date it submits the report to the EPA.
9. Bypasses are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2. Bypasses are to be reported to the Kansas City Regional Office during normal business hours or by using the online Sanitary Sewer Overflow/Facility Bypass Application located at: <https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem> or the Environmental Emergency Response spill-line at 573-634-2436 outside of normal business hours. Once an electronic reporting system compliant with 40 CFR Part 127, the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, is available all bypasses must be reported electronically via the new system. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
10. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.
11. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
12. An all-weather access road to the treatment facility shall be maintained.
13. The outfall sewer shall be protected and maintained against the effects of floodwater, ice, or other hazards as to reasonably insure its structural stability, freedom from stoppage, and that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
14. The ash storage lagoon shall be operated and maintained to ensure its structural integrity, which includes maintaining adequate freeboard and keeping the berms free of deep-rooted vegetation, animal dens, or other potential sources of damage.
15. The facility shall ensure that adequate provisions are provided to prevent or minimize surface water intrusion into the ash storage lagoon and to divert stormwater runoff around the ash storage lagoon and protect embankments from erosion.
16. The permittee shall perform a minimum of four whole effluent toxicity tests in the four and one-half year period prior to the next permit renewal application. The four tests shall consist of two chronic toxicity tests and two acute toxicity tests in accordance with Special Conditions #17 and #18.
17. Acute Whole Effluent Toxicity (WET) tests shall be conducted as follows:
 - (a) Freshwater Species and Test Methods: Species and short-term test methods for estimating the acute toxicity of NPDES effluents are found in the most recent edition of *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA/821/R-02/012; Table IA, 40 CFR Part 136). The permittee shall concurrently conduct 48-hour, static, non-renewal toxicity tests with the following species:
 - i. The fathead minnow, *Pimephales promelas* (Acute Toxicity EPA Test Method 2000.0).
 - ii. The daphnid, *Ceriodaphnia dubia* (Acute Toxicity EPA Test Method 2002.0).
 - (b) Chemical and physical analysis of the upstream control sample and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping. Where upstream receiving water is not available or known to be toxic, other approved control water may be used.
 - (c) Test conditions must meet all test acceptability criteria required by the EPA Method used in the analysis.
 - (d) The laboratory shall not chemically dechlorinate the sample.
 - (e) The Allowable Effluent Concentration (AEC) is 36%; the dilution series is: 60%, 48%, 36%, 24%, and 12%.

D. SPECIAL CONDITIONS (continued)

- (f) All chemical and physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% effluent concentration.
 - (g) The facility must submit a full laboratory report for all toxicity testing. The report must include a quantification of acute toxic units ($TU_a = 100/LC_{50}$) reported according to the test methods manual chapter on report preparation and test review. The Lethal Concentration 50 Percent (LC_{50}) is the effluent concentration that would cause death in 50 percent of the test organisms at a specific time.
18. Chronic Whole Effluent Toxicity (WET) tests shall be conducted as follows:
- (a) Freshwater Species and Test Methods: Species and short-term test methods for estimating the chronic toxicity of NPDES effluents are found in the most recent edition of *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA/821/R-02/013; Table IA, 40 CFR Part 136). The permittee shall concurrently conduct 7-day, static renewal toxicity tests with the following species:
 - The fathead minnow, *Pimephales promelas* (Survival and Growth Test Method 1000.0).
 - The daphnid, *Ceriodaphnia dubia* (Survival and Reproduction Test Method 1002.0).
 - (b) Chemical and physical analysis of the upstream control sample and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping. Where upstream receiving water is not available or known to be toxic, other approved control water may be used.
 - (c) Test conditions must meet all test acceptability criteria required by the EPA Method used in the analysis.
 - (d) The laboratory shall not chemically dechlorinate the sample.
 - (e) The Allowable Effluent Concentration (AEC) is 3%, the dilution series is: 12%, 6%, 3%, 1.5%, and 0.75%.
 - (f) All chemical and physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% effluent concentration.
 - (g) The facility must submit a full laboratory report for all toxicity testing. The report must include a quantification of chronic toxic units ($TU_c = 100/IC_{25}$) reported according to the *Methods for Measuring the Chronic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* chapter on report preparation and test review. The 25 percent Inhibition Effect Concentration (IC_{25}) is the toxic or effluent concentration that would cause 25 percent reduction in mean young per female or in growth for the test populations.
19. Expanded Effluent Testing
Permittee must sample and analyze for the pollutants listed in Form B2 – Application for Operating Permit for Facilities That Receive Primarily Domestic Waste And Have A Design Flow More Than 100,000 Gallons Per Day (MO-780-1805 dated 02-19), Part D – Expanded Effluent Testing Data, #18 and additionally, Total Recoverable Barium, Total Recoverable Boron, Chloride, Total Recoverable Cobalt, and Sulfate. The permittee shall provide this data with the permit renewal application. A minimum of three samples taken within four and one-half years prior to the date of the permit application must be provided. Samples must be representative of the seasonal variation in the discharge from each outfall. Approved and sufficiently sensitive testing methods listed in 40 CFR 136.3 must be utilized. A method is “sufficiently sensitive” when; 1) The method minimum level is at or below the level of the applicable water quality criterion for the measured pollutant or pollutant parameter; or 2) the method minimum level is above the applicable water quality criterion, but the amount of the pollutant or pollutant parameter in a facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or 3) the method has the lowest minimum level of the analytical methods approved under 40 CFR part 136. These methods are also required for parameters listed as monitoring only, as the data collected may be used to determine if numeric limitations need to be established.
20. Stormwater Pollution Prevention Plan (SWPPP): A SWPPP must be implemented upon permit issuance. Through implementation of the SWPPP, the permittee shall minimize the release of pollutants in stormwater from the facility to the waters of the state. The SWPPP shall be developed in consultation with the concepts and methods described in the following document: Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators, (Document number EPA 833-B-09-002) published by the United States Environmental Protection Agency (USEPA) in June 2015.
- (a) The SWPPP must identify any stormwater outfall from the facility and Best Management Practices (BMPs) used to prevent or reduce the discharge of contaminants in stormwater. The stormwater outfalls shall either be marked in the field or clearly marked on a map and maintained with the SWPPP.
 - (b) The SWPPP must include a schedule and procedures for a once per month routine site inspection.
 - (1) The monthly routine inspection shall be documented in a brief written report, which shall include:
 - i. The person(s) conducting the inspection.
 - ii. The inspection date and time.
 - iii. Weather information for the day of the inspection.
 - iv. Precipitation information for the entire period since the last inspection.

D. SPECIAL CONDITIONS (continued)

- v. Description of the discharges observed, including visual quality of the discharges (sheen, turbid, etc.).
 - vi. Condition of BMPs
 - vii. If BMPs were replaced or repaired.
 - viii. Observations and evaluations of BMP effectiveness.
 - (2) Any deficiency observed during the routine inspection must be corrected within seven (7) days and the actions taken to correct the deficiencies shall be included with the written report.
 - (3) The routine inspection reports must be kept onsite with the SWPPP and maintained for a period of five (5) years.
 - (4) The routine inspection reports shall be made available to Department personnel upon request.
 - (c) The SWPPP must include a schedule and procedures for a once per year comprehensive site inspection.
 - (1) The annual comprehensive inspection shall be documented in a written report, which shall include:
 - i. The person(s) conducting the inspection.
 - ii. The inspection date and time.
 - iii. Findings from the areas of your facility that were examined;
 - iv. All observations relating to the implementation of your control measures including:
 - 1. Previously unidentified discharges from the site,
 - 2. Previously unidentified pollutants in existing discharges,
 - 3. Evidence of, or the potential for, pollutants entering the drainage system;
 - 4. Evidence of pollutants discharging to receiving waters at all facility outfall(s), and the condition of and around the outfall, and
 - 5. Additional control measures needed to address any conditions requiring corrective action identified during the inspection.
 - v. Any required revisions to the SWPPP resulting from the inspection;
 - vi. Any incidence of noncompliance observed or a certification stating that the facility is in compliance with Special Condition D. 21.
 - (2) Any deficiency observed during the comprehensive inspection must be corrected within seven (7) days and the actions taken to correct the deficiencies shall be included with the written report.
 - (3) The comprehensive inspection reports must be kept onsite with the SWPPP and maintained for a period of five (5) years.
 - (4) The comprehensive inspection reports shall be made available to Department personnel upon request.
 - (d) The SWPPP must be kept on-site and should not be sent to the Department unless specifically requested.
 - (e) The SWPPP must be reviewed and updated at a minimum once per permit cycle, as site conditions or control measures change.
21. The permittee shall select, install, use, operate, and maintain the Best Management Practices prescribed in the SWPPP.
- (a) Permittee shall adhere to the following minimum Best Management Practices (BMPs):
 - (1) Minimize the exposure of industrial material storage areas, loading and unloading areas, dumpsters and other disposal areas, maintenance activities, and fueling operations to rain, snow, snowmelt, and runoff, by locating industrial materials and activities inside or protecting them with storm resistant coverings, if warranted and practicable.
 - (2) Provide good housekeeping practices on the site to prevent potential pollution sources from coming into contact with stormwater and provide collection facilities and arrange for proper disposal of waste products, including sludge.
 - (3) Implement a maintenance program to ensure that the structural control measures and industrial equipment is kept in good operating condition and to prevent or minimize leaks and other releases of pollutants.
 - (4) Prevent or minimize the spillage or leaks of fluids, oil, grease, fuel, etc. from equipment and vehicle maintenance, equipment and vehicle cleaning, or activities.
 - (5) Provide sediment and erosion control sufficient to prevent or control sediment loss off of the property. This could include the use of straw bales, silt fences, or sediment basins, if needed.
 - (6) Provide stormwater runoff controls to divert, infiltrate, reuse, contain, or otherwise minimize pollutants in the stormwater discharge.
 - (7) Enclose or cover storage piles of salt or piles containing salt, used for deicing or other commercial or industrial purposes.
 - (8) Provide training to all employees who; work in areas where industrial materials or activities are exposed to stormwater, are responsible for stormwater inspections, are members of the Pollution Prevention Team. Training must cover the specific control measures and monitoring, inspection, planning, reporting and documentation requirements of this permit. Training is recommended annually for any applicable staff and whenever a new employee is hired who meets the description above.
 - (9) Eliminate and prevent unauthorized non-stormwater discharges at the facility.
 - (10) Minimize generation of dust and off-site tracking of raw, final, or waste materials by implementing appropriate control measures.

D. SPECIAL CONDITIONS (continued)

22. **Pretreatment:** The permittee shall implement and enforce its approved pretreatment program in accordance with the requirements of 10 CSR 20-6.100. The approved pretreatment program is hereby incorporated by reference.
- (a) The permittee shall submit to the Department via the Electronic Discharge Monitoring Report (eDMR) Submission System on or before March 31st of each year a report briefly describing its pretreatment activities during the previous calendar year. At a minimum, the report shall include the following:
- (1) An updated list of the Permittee's Industrial Users, including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The Permittee shall provide a brief explanation of each deletion. This list shall identify which Industrial Users are subject to categorical pretreatment Standards and specify which Standards are applicable to each Industrial User. The list shall indicate which Industrial Users are subject to local standards that are more stringent than the categorical Pretreatment Standards. The Permittee shall also list the Industrial Users that are subject only to local Requirements;
 - (2) A summary of the status of Industrial User compliance over the reporting period;
 - (3) A summary of compliance and enforcement activities (including inspections) conducted by the Permittee during the reporting period; and
 - (4) Any other relevant information requested by the Department.
- (b) The permittee is currently working to complete a technical local limit evaluation.
- (1) Submit a status report on the progress of the sampling, the IWS, and the technical analysis with the assistance of a consultant on or before **December 1, 2021**;
 - (2) Provide by email all draft local limit analyses using the EPA Region 7 Local Limit Analysis Spreadsheet on or before **June 1, 2022** (a stagger submittal of each WWTF's analysis is preferred);
 - (3) Submit a draft final formal report of the detailed technical development of local limits and program modification with ordinance revision (with city council endorsement of draft final submission) as needed for potential public notice (see formal submission process below) on or before **December 1, 2022**;
 - (4) Submit the City Council's formal adoption of the revision to the Code of Ordinances on or before **June 1, 2023**.
- (c) Please contact the Department's pretreatment coordinator for further guidance. Should revision of local limits be deemed necessary, it is recommended that revisions follow the US Environmental Protection Agency's guidance document *Local Limits Development Guidance*. EPA833-R04-002A. July 2004.
23. The permittee shall update their pretreatment program to incorporate the requirements of 10 CSR 20-6.100, effective October 30, 2012, which adopted the 2005 "Streamlining" revisions to the federal pretreatment rule, 40 CFR 403. This update to city code will include at the minimum the "required streamlining" 40 CFR 403 rule updates.

The permittee shall submit the draft final revision to the pretreatment program along with the draft final revisions to the city code to the Department by **October 1, 2021**, for review and approval. After draft review, the formal submission of the program modification will follow the requirements of 40 CFR 403.18. The permittee shall immediately implement the finalized updates to the pretreatment program and adopt the revised city code no later than **6 months** after Department approval of the changes. The permittee shall submit notification of city code adoption to the Department no later than **7 months** after Department approval.

24. **Sewer Extension Authority Supervised Program**

The Department approved the Sewer Extension Authority Supervised Program for the City of Kansas City to regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility on December 19, 2019. The City of Kansas City shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. This approval may be modified or revoked by the Department if the wastewater collection, transportation, or treatment facilities reach their design capacity, if the treatment facility falls into chronic noncompliance with the permit, or if the permittee fails to follow the terms and conditions of the submitted and approved program.

This permit may be reopened and modified or alternatively revoked and reissued to incorporate new or modified conditions to the Sewer Extension Authority Supervised Program, if information indicates changes are necessary to assure compliance with Missouri's Clean Water Law and associated regulations. When any of the above mentioned conditions occur, the permittee will be notified prior to any modifications of this permit condition. Plans and specifications for all projects which include a proposed sanitary sewer overflow must be submitted to the Department to provide record information for location and size of the sanitary sewer overflow.

D. SPECIAL CONDITIONS (continued)

An annual report on the Sewer Extension Authority Supervised Program must be submitted by **April 30th** of each year to the Missouri Department of Natural Resources' Water Protection Program's Engineering Section. Please see **Appendix – Sewer Extension Authority Supervised Program Reauthorization Letter** for applicable conditions.

The Department's Water Protection Program's Engineering Section will reevaluate the City's Sewer Extension Authority Supervised Program for reauthorization when they file an application for permit renewal to determine if it is current, complete, and meets the requirements of 10 CSR 20-8 Minimum Design Standards. Once the Sewer Extension Authority Supervised Program is reauthorized or denied, this condition will be updated accordingly.

25. Biosolids Land Application Management Plan: The City shall develop a Biosolids Land Application Management Plan (Plan) and submit the Plan to the Department for review by **(October 1, 2021)**. Upon approval by the Department, the City shall implement the Plan.

It is recommended that the City use Chapter 8.9 Biosolids Disposal on Land, of the Wastewater Guidelines and Standards Document dated February 2019 (<https://dnr.mo.gov/document-search/wastewater-guidelines-standards-document-pub2754>), as guidance to complete the Plan. The Plan shall also address temporary biosolids storage/stockpiling and necessary Best Management Practices needed to ensure proper short term storage/stockpiling of biosolids and the prevention of contaminated runoff from the storage areas. The Plan shall be updated each time a new field is added for application. The City shall review the Biosolids Land Application Management Plan annually to determine if updates are necessary.

E. COMBINED SEWER SYSTEM OVERFLOW

1. Combined Sewer System

- (a) *Combined Sewer Overflow Authorized.* The permittee is authorized to discharge from the Combined Sewer Overflow (CSO) locations listed on Page 12 of this permit and additional CSO overflow locations within the boundaries of the permittee's jurisdiction identified after the effective date of this permit.
- (b) *Nine Minimum Controls Plan.* The permittee has developed a Nine Minimum Control (NMC) Plan consistent with the U.S. EPA Combined Sewer Overflow (CSO) Policy dated April, 19, 1994. The permittee shall implement its NMC Plan in accordance with the federal consent decree entered in the matter of the *United States v. The City of Kansas City, Missouri, 4:10-cv-0497*, including any amendment thereto. The permittee's NMC Plan meets the following technology-based requirements:
- Control 1 – Proper operation and regular maintenance programs for the sewer system and CSO outfalls;
 - Control 2 – Maximization use of the collection system for storage;
 - Control 3 – Review and modification of pretreatment requirements to ensure that CSO impacts are minimized;
 - Control 4 – Maximization of flow to the POTW for treatment;
 - Control 5 – Elimination of CSOs during dry weather;
 - Control 6 – Control of solid and floatable materials in CSOs;
 - Control 7 – Pollution prevention programs to reduce contaminants in CSOs;
 - Control 8 – Public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts; and
 - Control 9 – Monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.
- (c) *Long Term Control Plan.* The permittee submitted a Long-Term Control Plan (LTCP) on January 30, 2009, that is consistent with the U.S. EPA CSO Policy dated April 19, 1994, (59 FR 18688) and 10 CSR 20-7.015(10). The LTCP was approved by the Department on April 14, 2010. Pursuant to its approved work plans, the LTCP is included in the permittee's Overflow Control Plan (OCP) and incorporated into the federal consent decree entered in the matter of the *United States v. The City of Kansas City, Missouri, 4:10-cv-0497* in the US District Court for the Western District of Missouri on September 27, 2010. The consent decree has been subsequently amended. Any modifications or amendments to such consent decree are hereby incorporated into this permit.
- (d) *Reporting.* The permittee shall continue to submit an Annual Report as required by the federal consent decree entered in the matter of the *United States v. The City of Kansas City, Missouri, 4:10-cv-0497*, including any amendment thereto, that describes the permittee's efforts to demonstrate compliance with the Nine Minimum Controls plan performance criteria and its efforts to implement the LTCP through the consent decree for the previous calendar year. The permittee shall submit the Annual Report to the Department on the same date it submits the report to EPA.

F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS

| CSO Permitted Feature No. | Description | UTM Coordinates | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-watershed No. |
|----------------------------------|--|------------------------|--------------------------|------------------------|---|---|
| 006 | 51st St. and Ward Pkwy | X=361362; Y=4321938 | Sec. 31, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 007 | 50 th Terr. and Brush Creek | X=361394; Y=4322025 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 008 | Ward Pkwy and Westwood Rd | X=361430; y=4322126 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 009 | Ward Pkwy and Westwood Rd | X=361430; y=4322126 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 010 | 50 th and Brush Creek | X=361479; Y=4322154 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 011 | Roanoke and Brush Creek | X=361803; Y=4322375 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 012 | Roanoke and Brush Creek | X=361810 Y=4322329 | Sec. 30, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 013 | Ward Pkwy and Wornall | X=362231; Y=4322447 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 014 | Ward Pkwy and Wornall | X=362260; Y=4322436 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 015 | Wyandotte St and Ward Pkwy | X=362479; Y=4322477 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 016 | Main St. and Brush Creek | X=362641; Y=4322442 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 017 | 49th St and Volker Blvd | X=362925; Y=4322336 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 018 | Volker Blvd and Troost Ave | X=363742; Y=4322191 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 019 | Volker Blvd and Troost Ave | X=363869; Y=4322170 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 020 | Volker Blvd and The Paseo | X=364230; Y=4322377 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 021 | Volker Blvd and The Paseo | X=364318; Y=4322508 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| #22 eliminated | | | | | | |
| 023 | 47th and Woodland | X=364698; Y=4322713 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |

*MND= Metropolitan No-Discharge Stream per 10 CSR 20-7.031(6) and Table F

F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS (continued)

| CSO Permitted Feature No. | Description | UTM Coordinates | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-watershed No. |
|----------------------------------|--|-------------------------|--------------------------|--------------------------|---|---|
| 024 | Frontage Rd and Emanuel Cleaver II Blvd | X=365042; Y=4322619 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 025 | Emanuel Cleaver II Blvd and Prospect Ave | X=365445; Y=4322433 | Sec. 28, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 026 | Swope Pkwy and Agnes Ave | X=365925; Y=4322234 | Sec. 27, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 027 | 45th and Mersington | X=366810; Y=4322746 | Sec. 27, T49N, R33W | Tributary to Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 028 | 46th and Myrtle Ave | X=366990; Y=4322562 | Sec. 27, T49N, R33W | Tributary to Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 029 | Volker Blvd and Oak St | X=363080; Y=4322288 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 030 | Volker Blvd and Oak St | X=363080; Y=4322288 | Sec. 29, T49N, R33W | Brush Creek | Brush Creek (3986) 303(d) | 10300101-0105 |
| 031 | I-435 and Blue River | X=371064; Y=4330984 | Sec. 31, T50N, R32W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |
| 032 | St. John Ave and Bennington Ave | X=369882; Y=4330426 | Sec. 36, T50N, R33W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |
| 033 | Wilson and Bennington | X=370335; Y=4330076 | Sec. 36, T50N, R33W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |
| 034 | 8th St. at Blue River | X=370449; Y=4329122 | Sec. 01, T49N, R33W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |
| 035 eliminated | | | | | | |
| 036 | 18th St and Crystal Ave | X=370448; Y= 4327537 | Sec. 12, T49N, R33W | Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 037 | 35th and Blue River | X=369087; Y=4324737 | Sec. 13, T49N, R33W | Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 038 eliminated | | | | | | |
| 039 | 35th Street and Blue River | X=369045; Y=4324671 | Sec. 24, T49N, R33W | Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 040 | Lawn Ave and Vineyard Dr | X=367486; Y=4323533 | Sec. 23, T49N, R33W | Tributary to Blue River | Tributary to Blue River (C) (3960) | 10300101-0106 |
| 041 | 40th and Cleveland | X=366768; Y=4323732 | Sec. 22, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 042 eliminated | | | | | | |

*MND= Metropolitan No-Discharge Stream per 10 CSR 20-7.031(6) and Table F

F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS (continued)

| CSO Permitted Feature No. | Description | UTM Coordinates | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-watershed No. |
|----------------------------------|--------------------------|--------------------------|--------------------------|-------------------------|---|---|
| 043 | 40th and Cleveland | X=366794; Y=4323729 | Sec. 22, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 044 | 41st and Myrtle | X=366891; Y=4323622 | Sec. 22, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 045 | 41st and Myrtle | X=366951; Y=4323594 | Sec. 22, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 046 | 41st and Norton | X= 367053; Y= 4323577 | Sec. 22, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 047 | 41st and Jackson | X=367156; Y=4323532 | Sec. 23, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 048 | 45th and Chelsea Ave | X=367837; Y=4322685 | Sec. 26, T49N, R33W | Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 049 eliminated | | | | | | |
| 050 | Spruce Ave and Towers Rd | X=367255; Y=4323547 | Sec. 23, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 051 | Wilson Rd and Blue River | X=370775; Y=4329734 | Sec. 31, T50N, R32W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |
| 052 | Truman Rd and Blue River | X=370799; Y=4328198 | Sec. 06, T49N, R32W | Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 053 eliminated | | | | | | |
| 054 | 18th St and White Ave | X=369235; Y=4327688 | Sec. 12, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 055 | I-70 and White Ave | X=369055; Y=4325674 | Sec. 13, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0106 |
| 056 | 55th St. and Lister Ave | X=367611; Y=4320726 | Sec. 35, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0105 |
| 057 | 76th and Indiana | X=365914; Y=4316618 | Sec. 15, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 058 | 83rd St and McGee | X=362536; Y=4315408 | Sec. 20, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 059 | 85th and Tracy | X=363674; Y=4314833 | Sec. 21, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 060 | 58th St and Cypress Ave | X=367169; Y=4320208 | Sec. 35, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0105 |
| 061 | 58th and Elmwood | X=367308; Y=4320144 | Sec. 35, T49N, R33W | Tributary to Blue River | Blue River (418) 303(d), MND* | 10300101-0105 |

*MND= Metropolitan No-Discharge Stream per 10 CSR 20-7.031(6) and Table F

F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS (continued)

| CSO Permitted Feature No. | Description | UTM Coordinates | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-watershed No. |
|----------------------------------|-------------------------------------|------------------------|--------------------------|-------------------------|---|---|
| 062 | Yates Dr and Starlight Rd | X=367460; Y=4319093 | Sec. 02, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 063 | 70th and Cleveland | X=366410; Y=4317933 | Sec. 10, T48N, R33W | Tributary to Blue River | Tributary to Blue River (C) (3960) | 10300101-0105 |
| 064 | Gregory Blvd and Myrtle Ave | X=366593; Y=4317690 | Sec. 10, T48N, R33W | Tributary to Blue River | Tributary to Blue River (C) (3960) | 10300101-0105 |
| 065 | 83 rd and Troost Ave | X=363423; Y=4315433 | Sec. 17, T48N, R33W | Tributary to Blue River | Tributary to Blue River (C) (3960) | 10300101-0105 |
| 066 eliminated | | | | | | |
| 067 | Pico St and Main St | X=362251; Y=4315381 | Sec. 20, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 068 | 87th and Wayne Ave | X=363990; Y=4314550 | Sec. 21, T48N, R33W | Tributary to Blue River | Blue River (419) 303(d), MND* | 10300101-0105 |
| 069 | 77 th and Prospect | X=365121; Y=4316323 | Sec. 15, T48N, R33W | Tributary to Blue River | Tributary to Blue River (C) (3960) | 10300101-0105 |
| 070 eliminated | | | | | | |
| 071 eliminated | | | | | | |
| 072 | Hwy 9 at MO River | X=363403; Y=4330727 | Sec. 32, T50N, R33W | Missouri River | Missouri River (356) 303(d) | 10300101-0301 |
| 073 | West of Grand Ave and Lydia Ave | X=363977; Y=4331035 | Sec. 32, T50N, R33W | Missouri River | Missouri River (356) 303(d) | 10300101-0301 |
| 074 | North of Grand Ave and Lydia Avenue | X=364422; Y=4331269 | Sec. 33, T50N, R33W | Missouri River | Missouri River (356) 303(d) | 10300101-0301 |
| 075 | West of Front St and N. Kansas Ave | X=365968; Y=4332067 | Sec. 28, T50N, R33W | Missouri River | Missouri River (356) 303(d) | 10300101-0301 |
| 076 eliminated | | | | | | |
| 077 | Hwy 9 at MO River | X=363593; Y=4330826 | Sec. 32, T50N, R33W | Missouri River | Missouri River (356) 303(d) | 10300101-0301 |
| 078 eliminated | | | | | | |
| 079 | 51 st and Indiana | X=366270; Y=4321635 | Sec. 27, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 080 eliminated | | | | | | |

*MND= Metropolitan No-Discharge Stream per 10 CSR 20-7.031(6) and Table F

F. COMBINED SEWER SYSTEM OVERFLOW LOCATIONS (continued)

| CSO Permitted Feature No. | Description | UTM Coordinates | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-watershed No. |
|----------------------------------|------------------------------------|------------------------|--------------------------|-------------------------|---|---|
| 081 | 53 rd and Walrond | X=365996; Y=4321158 | Sec. 34, T49N, R33W | Tributary to Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 082 | 55th and College Ave | X=366005; Y=4320858 | Sec. 34, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 083 | 57th and Bellefontaine Ave | X=365904; Y=4320446 | Sec. 34, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 084 eliminated | | | | | | |
| 085 | 59th and Chestnut Ave | X=365524; Y=4320104 | Sec. 34, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 086 | South of 59th and Chestnut Ave | X=365505; Y=4319994 | Sec. 03, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 087 eliminated | | | | | | |
| 088 eliminated | | | | | | |
| 089 | Northeast of Park Ave and 62nd St | X=365051; Y=4319654 | Sec. 04, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 090 | 63rd and Woodland | X=364561; Y=4319435 | Sec. 04, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 091 | NW of 58th Terr and Bellefontaine | X=365782; Y=4320214 | Sec. 34, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 092 | Gregory Blvd and Tracy Ave | X=363773; Y=4317822 | Sec. 09, T48N, R33W | Tributary to Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 093 | Gregory Blvd and Tracy Ave | X=363804; Y=4317799 | Sec. 09, T48N, R33W | Tributary to Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 094 | 69th St and Lydia Ave | X=363981; Y=4318120 | Sec. 09, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 095 | 67th and Flora Ave | X=364127; Y=4318552 | Sec. 09, T48N, R33W | Tributary to Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 096 | 68th St and Woodland Ave | X=364368; Y=4318375 | Sec. 09, T48N, R33W | Tributary to Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 097 | 66 th Terrace and Flora | X=364161; Y=4318687 | Sec. 04, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 098 | 66 th Terrace and Flora | X=364161; Y=4318687 | Sec. 04, T48N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 099 | 56 th and Bellefontaine | X=365955; Y=4320640 | Sec. 34, T49N, R33W | Mill Creek | Mill Creek (4066) 303(d) | 10300101-0105 |
| 100 | 7300 Hawthorne Road | X=370641; Y=4330732 | Sec. 36, T50N, R33W | Blue River | Blue River (417) 303(d), MND* | 10300101-0106 |

*MND= Metropolitan No-Discharge Stream per 10 CSR 20-7.031(6) and Table F

G. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to pursue an appeal before the administrative hearing commission (AHC) pursuant to Sections 621.250 and 644.051.6 RSMo. To appeal, you must file a petition with the AHC within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

**MISSOURI DEPARTMENT OF NATURAL RESOURCES
STATEMENT OF BASIS
MO-0024911
KC BLUE RIVER WWTP**

This Statement of Basis (Statement) gives pertinent information regarding minor modifications to the above listed operating permit without the need for a public comment process. A Statement is not an enforceable part of a Missouri State Operating Permit.

Part I – Facility Information

Facility Type and Description: POTW - Rock box filter unit / 6 automatic bar screens / 6 aerated grit chambers / 4 hydro cyclone-type grit removal units / 4 primary clarifiers / 4 plastic media covered trickling filters with air handling systems / 4 final clarifiers / effluent pump station / chlorination / dechlorination / 2 sludge holding tanks / 2 anaerobic sludge digesters / 3 dissolved air flotation units / 2 belt presses / 1 sludge incinerator / ash storage lagoon / sludge/biosolids are incinerated, stabilized, landfilled, or land applied

Part II – Modification Rationale

This operating permit is hereby modified to reflect a typographic error in the definition of once per weekday. The definition was changed to “Once each weekday means: Monday, Tuesday, Wednesday, Thursday & Friday, except for Federal holidays”, as the previous definition did not reflect the correct number of Federal holidays. In addition, hyperlinks in the permit were updated due to revisions to the Department website.

No other changes were made at this time.

Part III – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit.

DATE OF STATEMENT OF BASIS: AUGUST 17, 2022

COMPLETED BY:

**BRANT FARRIS, ENVIRONMENTAL PROGRAM SPECIALIST
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT
(660) 385-8019
brant.farris@dnr.mo.gov**

MISSOURI DEPARTMENT OF NATURAL RESOURCES
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO-0024911
KC BLUE RIVER WWTP

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollutant Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)(A)2.], a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Major facility.

Part I – Facility Information

Facility Type: POTW

Facility Description: Rock box filter unit / 6 automatic bar screens / 6 aerated grit chambers / 4 hydro cyclone-type grit removal units / 4 primary clarifiers / 4 plastic media covered trickling filters with air handling systems / 4 final clarifiers / effluent pump station / chlorination / dechlorination / 2 sludge holding tanks / 2 anaerobic sludge digesters / 3 dissolved air flotation units / 2 belt presses / 1 sludge incinerator / ash storage lagoon / sludge/biosolids are incinerated, stabilized, landfilled, or land applied

Have any changes occurred at this facility or in the receiving water body that affects effluent limit derivation?

✓ No.

Application Date: 05/23/2016

Expiration Date: 11/15/2016

OUTFALL(S) TABLE:

| OUTFALL | DESIGN FLOW (CFS) | TREATMENT LEVEL | EFFLUENT TYPE |
|---------|-------------------|-------------------------|---------------|
| #001 | 162.75 | Equivalent to Secondary | Domestic |

Facility Performance History:

The wastewater treatment plant was last inspected by the Department on April 24, 2012. The conditions of the facility at the time of inspection were found to be satisfactory. The wastewater treatment plant was inspected by the EPA on March 7-10, 2017. The report noted effluent limit exceedances for multiple parameters in 2014, 2015, and 2016, failure to properly maintain the facility, failing to meet final effluent limits from samples collected during the inspection for BOD₅ and TSS. The City responded to the EPA's Notice of Potential National Pollution Discharge Elimination System (NPDES) Permit Violations (NOPV), which EPA found that it addressed the items cited in the NOPV.

The facility failed to meet final effluent limits for BOD₅ on the October and November 2015, February, March, and November 2016, and February and March 2017 Discharge Monitoring Reports (DMRs). The facility failed to meet final effluent limits for Cadmium on the September and December 2019 DMRs (recent review of these data indicates that the reported samples were actually non-detect). The facility failed to meet final effluent limits for Cyanide on the December 2015 and August 2018 DMRs. The facility failed to meet final effluent limits for Ammonia on the August 2015, August 2016, and on the May, June, and July 2018 DMRs. The facility failed to meet final effluent limits for pH on the February 2016 DMR. The facility failed to meet final effluent limits for TSS on the June, July, and November 2015, April and November 2016, February and March 2017, December 2018, March, May, and June 2019, and January and February 2020 DMRs.

Comments:

Changes in this permit for Outfall #001 include the addition of Total Kjeldahl Nitrogen, the addition of monitoring for Barium, Boron, Chloride, Cobalt, and Sulfate in the Expanded Effluent Test for the next permit renewal application, the revision of the frequency for flow to daily, the revision of the frequency for *E. coli* to once per week, the revision of the final effluent limits for Ammonia, the revision of monitoring frequency for Total Phosphorus and Nitrate + Nitrites from quarterly to monthly, the revision of pH limits, the revision to the final limits for Total Residual Chlorine, and the removal of Temperature, the removal of final effluent limits for Oil & Grease, Cyanide, Cadmium, Copper, and Phenol and change to monitoring only, the reduction in monitoring frequency to once per quarter for Oil & Grease, and the removal of Fluoride, Hardness, Total Nitrogen, Arsenic, Chromium III, Chromium VI, Lead, Manganese Mercury, Nickel, Thallium, Zinc, and TTO. Changes in this permit for Permitted Feature INF include the addition of Ammonia, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Total Phosphorus. Permitted Features 002, #003, and #004 were removed from the permit as all stormwater outfalls are now covered by Section **D. Special Condition #20**. See Part VI of the Fact Sheet for further information regarding the addition, revision, and removal of effluent and influent parameters. Special conditions were updated to include the addition of inflow and infiltration reporting requirements, reporting of Non-detects, bypass reporting requirements, pretreatment requirements, and the Electronic Discharge Monitoring Report (eDMR) Submission System.

Part II – Operator Certification Requirements

✓ This facility is required to have a certified operator.

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], the permittee shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.020(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Owned or operated by or for a

☒ - Municipalities

☐ - County

☐ - Public Sewer District

☐ - State agency

☐ - Public Water Supply Districts

☐ - Private Sewer Company regulated by the Public Service Commission

Each of the above entities are only applicable if they have a Population Equivalent greater than two hundred (200).

This facility currently requires a chief operator with an (A) Certification Level. Please see **Appendix - Classification Worksheet**. Modifications made to the wastewater treatment facility may cause the classification to be modified.

Operator's Name: Brent Herring
Certification Number: 15178
Certification Level: WW-A

The listing of the operator above only signifies that staff drafting this operating permit have reviewed appropriate Department records and determined that the name listed on the operating permit application has the correct and applicable Certification Level.

Part III – Operational Control Testing Requirements

Missouri Clean Water Commission regulation 10 CSR 20-9.010 requires certain publicly owned treatment works and privately owned facilities regulated by the Public Service Commission to conduct internal operational control monitoring to further ensure proper operation of the facility and to be a safeguard or early warning for potential plant upsets that could affect effluent quality. This requirement is only applicable if the publicly owned treatment works and privately owned facilities regulated by the Public Service Commission has a Population Equivalent greater than two hundred (200).

10 CSR 20-9.010(3) allows the Department to modify the monitoring frequency required in the rule based upon the Department's judgement of monitoring needs for process control at the specified facility.

✓ As per [10 CSR 20-9.010(4)], the facility is required to conduct operational monitoring. These operational monitoring reports are to be submitted to the Department along with the MSOP discharge monitoring reports.

- The facility is a mechanical plant and is required to conduct operational control monitoring as follows:

| Operational Monitoring Parameter | Frequency |
|------------------------------------|-------------|
| Precipitation | Daily (M-F) |
| Flow – Influent or Effluent | Daily (M-F) |
| pH – Influent | Daily (M-F) |
| pH – Anaerobic Digester | Daily (M-F) |
| Temperature –Anaerobic Digester | Daily (M-F) |
| Total Residual Chlorine (effluent) | Weekly§ |

- § The facility is approved for the following modified monitoring frequency:
- Total Residual Chlorine analyses of the effluent shall be performed weekly during the recreational season per Note 2 on Page 4 of the permit, in accordance with the measurement frequency outlined in Table A-1 on Page 3 of the permit.

Part IV – Receiving Stream Information

RECEIVING STREAM(S) TABLE: OUTFALL #001

| WATER-BODY NAME | CLASS | WBID | DESIGNATED USES* | 12-DIGIT HUC | DISTANCE TO CLASSIFIED SEGMENT (MI) |
|-----------------|-------|------|--|---------------|-------------------------------------|
| Missouri River | P | 356 | AQL, WBC-B, SCR, HHP, IRR, LWW, DWS, IND | 10300101-0301 | 0 |

*As per 10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(C)].

Uses found in the receiving streams table, above:

10 CSR 20-7.031(1)(C)1.:

AQL = Protection of aquatic life (Current narrative use(s) are defined to ensure the protection and propagation of fish shellfish and wildlife, which is further subcategorized as: **WWH** = Warm Water Habitat; **CDF** = Cold-water fishery (Current narrative use is cold-water habitat.); **CLF** = Cool-water fishery (Current narrative use is cool-water habitat); **EAH** = Ephemeral Aquatic Habitat; **MAH** = Modified Aquatic Habitat; **LAH** = Limited Aquatic Habitat. This permit uses AQL effluent limitations in 10 CSR 20-7.031 Table A for all habitat designations unless otherwise specified.)

10 CSR 20-7.031(1)(C)2.: Recreation in and on the water

WBC = Whole Body Contact recreation where the entire body is capable of being submerged;

WBC-A = Whole body contact recreation that supports swimming uses and has public access;

WBC-B = Whole body contact recreation that supports swimming;

SCR = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(C)3. to 7.:

HHP (formerly HHF) = Human Health Protection as it relates to the consumption of fish;

IRR = Irrigation for use on crops utilized for human or livestock consumption;

LWW = Livestock and wildlife watering (Current narrative use is defined as LWP = Livestock and Wildlife Protection);

DWS = Drinking Water Supply;

IND = Industrial water supply

10 CSR 20-7.031(1)(C)8-11.: Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)

WSA = Storm- and flood-water storage and attenuation; **WHP** = Habitat for resident and migratory wildlife species;

WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses; **WHC** = Hydrologic cycle maintenance.

10 CSR 20-7.031(6): **GRW** = Groundwater

RECEIVING STREAM(S) LOW-FLOW VALUES:

| RECEIVING STREAM | LOW-FLOW VALUES (CFS)* | | |
|--------------------|------------------------|----------|----------|
| | 1Q10 | 7Q10 | 30Q10 |
| Missouri River (P) | 18,002.9 | 19,042.7 | 20,362.1 |

* A mixing zone study was conducted by the U.S. EPA on February 13-14, 2008. The Mixing Zones and Zone of Initial Dilution flow values were calculated by the Department's Watershed Protection Section on June 24, 2020, using data from USGS Gauge 06893000. The Mixing Zone and Zone of Initial Dilutions flows were used to develop final effluent limits in this permit.

MIXING CONSIDERATIONS

MIXING CONSIDERATIONS TABLE:

| MIXING ZONE (CFS)* [10 CSR 20-7.031(5)(A)4.B.(II)(a)] | | | ZONE OF INITIAL DILUTION (CFS)* [10 CSR 20-7.031(5)(A)4.B.(II)(b)] | | |
|--|----------|----------|---|--------|--------|
| 1Q10 | 7Q10 | 30Q10 | 1Q10 | 7Q10 | 30Q10 |
| 4,890.02 | 4,890.02 | 4,890.02 | 292.43 | 292.43 | 292.43 |

* A mixing zone study was conducted by the U.S. EPA on February 13-14, 2008. The Mixing Zones and Zone of Initial Dilution flow values were calculated by the Department's Watershed Protection Section on June 24, 2020, using data from USGS Gauge 06893000. The Mixing Zone and Zone of Initial Dilutions flows were used to develop final effluent limits in this permit.

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Receiving Water Body's Water Quality

Currently, the Department has not conducted a stream survey for this waterbody. When a stream survey is conducted, more information may be available about the receiving stream.

Part V – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream, and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

- ✓ The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(40)] & [10 CSR 20-7.031(1)(O)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(o); 40 CFR Part 122.44(l)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- ✓ Limitations in this operating permit for the reissuance of this permit conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 CFR Part 122.44.
 - Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.
 - **Ammonia as N.** Effluent limitations were re-calculated for Ammonia. The Department previously followed the 2007 Ammonia Guidance method for derivation of ammonia limits. However, the EPA's Technical Support Document for Water Quality-based Toxic Controls (TSD) establishes other alternatives to limit derivation. The Department has determined that the approach established in Section 5.4.2 of the TSD, which allows for direct application of both the acute and chronic wasteload allocations (WLA) as permit limits for toxic pollutants, is more appropriate limit derivation approach. Using this method for a discharge to a waterbody where mixing is not allowed, the criterion continuous concentration (CCC) and the criterion maximum concentration (CMC) will equal the chronic and acute WLA respectively. The WLAs are then applied as effluent limits, per Section 5.4.2 of the TSD, where the CMC is the Daily Maximum and the CCC is the Monthly Average. The direct application of both acute and chronic criteria as WLA is also applicable for facilities that discharge into receiving waterbodies with mixing considerations. The CCC and CMC will need to be calculated into WLA with mixing considerations using the mass-balance equation. The newly established limitations are still protective of water quality.

- **Total Residual Chlorine (TRC).** Effluent limitations were re-calculated for TRC based on new information derived from discharge monitoring reports and on the current Missouri Water Quality Standards for TRC. The newly established limitations are still protective of water quality.
- **E. coli.** The previous permit contained once per weekday sampling frequencies. This permit contains weekly sampling frequencies as required by 10 CSR 20-7.015(9)(D)7.A. The permit is still protective of water quality.
- **Cyanide.** As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standard for Cyanide in the receiving stream. Therefore, final effluent limits for Cyanide have been removed and monitoring only is required to collect data over the permit cycle so this determination can be reassessed during the next renewal. The permit is still protective of water quality.
- **Total Recoverable Cadmium.** As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standard for Cadmium in the receiving stream. Therefore, final effluent limits for Cadmium have been removed and monitoring only is required to collect data over the permit cycle so this determination can be reassessed during the next renewal. The permit is still protective of water quality.
- **Total Recoverable Copper.** As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standard for Copper in the receiving stream. Therefore, final effluent limits for Copper have been removed and monitoring only is required to collect data over the permit cycle so this determination can be reassessed during the next renewal. The permit is still protective of water quality.
- **Phenol.** As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standard for Phenol in the receiving stream. Therefore, final effluent limits for Phenol have been removed and monitoring only is required to collect data over the permit cycle so this determination can be reassessed during the next renewal. The permit is still protective of water quality.
- **Oil and Grease.** The previous permit had final effluent limits of 15 mg/L as a daily maximum and 10 mg/L as a monthly average. During the drafting of this permit, the permit writer reviewed DMR data submitted by the permittee. Additionally, no evidence of an excursion of the water quality standard has been observed by the department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of the water quality standard. As a result, monitoring requirements have been included in this permit to determine if the discharge has the reasonable potential to cause or contribute to an excursion of the water quality standard. Data will be reviewed at renewal to reassess this determination. The monitoring frequency was also reduced to quarterly. The permit is still protective of water quality.
- **pH.** The previous permit contained final effluent limits of 6.5-9.0 SU. However, the permit writer has determined that final effluent limits of 6.0-9.0 SU are protective of the water quality standard [10 CSR 20-7.031(5)(E)], due to the buffering capacity of the mixing zone.
- **Temperature.** The Department has concluded that domestic wastewater treatment facilities have no reasonable potential to exceed Water Quality Standards for temperature. Due to the fact that this facility will have a minimal effect on temperature this parameter has been removed from the permit.
- **Fluoride, Arsenic, Chromium III, Chromium VI, Lead, Mercury, Nickel, Thallium, and Zinc.** As a result of a Reasonable Potential Analysis, it was determined that there is no reasonable potential to cause an excursion of water quality standards for • Fluoride, Arsenic, Chromium III, Chromium VI, Lead, Mercury, Nickel, Thallium, and Zinc in the receiving stream. Therefore, monitoring requirements have been removed. This determination will be reassessed at renewal. Please see **Appendix – RPA Results** for more information.
- **Manganese.** Manganese was removed as the receiving stream does not have Water Quality Standards for Groundwater.
- **Hardness.** Hardness was removed as effluent hardness is not applicable to calculate effluent limits.
- **Total Nitrogen.** Total Nitrogen was removed and replaced with Total Kjeldahl Nitrogen
- **Total Toxic Organics (TTO).** The previous permit contained annual sampling and reporting frequencies. This permit removes TTO. Monitoring for TTOs was established for certain Categorical Industrial Users discharging to POTWs, including but not limited to, Metal Finishing (40 CFR 433). The previous permit contained a requirement to sample and report TTOs once per year. A review of the TTO results shows compliance in accordance with 40 CFR 413.14(f). Due to consistency in compliance, the monitoring requirement for TTOs was removed. Toxicity in the effluent will be

sampled for with the Acute and Chronic WET tests. The permit is still protective of water quality and this determination will be reassessed at the time of renewal.

- ✓ The Department determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
- **General Criteria.** The previous permit contained a special condition which described a specific set of prohibitions related to general criteria found in 10 CSR 20-7.031(4). In order to comply with 40 CFR 122.44(d)(1), the permit writer has conducted reasonable potential determinations for each general criterion and established numeric effluent limitations where reasonable potential exists. While the removal of the previous permit special condition creates the appearance of backsliding, since this permit establishes numeric limitations where reasonable potential to cause or contribute to an excursion of the general criteria exists the permit maintains sufficient effluent limitations and monitoring requirements in order to protect water quality, this permit is equally protective as compared to the previous permit. Therefore, given this new information, and the fact that the previous permit special condition was not consistent with 40 CFR 122.44(d)(1), an error occurred in the establishment of the general criteria as a special condition of the previous permit. Please see Part VI – Effluent Limits Determination for more information regarding the reasonable potential determinations for each general criterion related to this facility.

ANTIDEGRADATION:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See <https://dnr.mo.gov/document-search/antidegradation-implementation-procedure>.

- ✓ No degradation proposed and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

For stormwater discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

- ✓ The facility must review and maintain stormwater BMPs as appropriate.

AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(2)(C)], ...An applicant may utilize a lower preference continuing authority by submitting, as part of the application, when a higher level authority is available, must submit information to the Department for review and approval, provided it does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

- ✓ Permittee is authorized to incinerate, landfill, or land apply, including transportation of biosolids to a land application site in accordance with Standard Conditions III. The City owns the primary land application site known as the Birmingham Land Application Site, located near the Birmingham Wastewater Treatment Plant. The City may also use contractor services to land apply at alternative sites.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

- ✓ The facility is not currently under Water Protection Program enforcement action.

ELECTRONIC DISCHARGE MONITORING REPORT (EDMR) SUBMISSION SYSTEM:

The U.S. Environmental Protection Agency (EPA) promulgated a final rule on October 22, 2015, to modernize Clean Water Act reporting for municipalities, industries, and other facilities by converting to an electronic data reporting system. This final rule requires regulated entities and state and federal regulators to use information technology to electronically report data required by the National Pollutant Discharge Elimination System (NPDES) permit program instead of filing paper reports. To comply with the federal rule, the Department is requiring all permittees to begin submitting discharge monitoring data and reports online. In an effort to aid facilities in the reporting of applicable information electronically, the Department has created several new forms including operational control monitoring forms and an I&I location and reduction form. These forms are optional and can be provided upon request to the Department.

Per 40 CFR 127.15 and 127.24, permitted facilities may request a temporary waiver for up to 5 years or a permanent waiver from electronic reporting from the Department. To obtain an electronic reporting waiver, a permittee must first submit an eDMR Waiver Request Form: <https://dnr.mo.gov/document-search/electronic-discharge-monitoring-report-waiver-request-form-mo-780-2692>. Each facility must make a request. If a single entity owns or operates more than one facility, then the entity must submit a separate request for each facility based on its specific circumstances. An approved waiver is non-transferable.

The Department must review and notify the facility within 120 calendar days of receipt if the waiver request has been approved or rejected [40 CFR 124.27(a)]. During the Department review period as well as after a waiver is granted, the facility must continue submitting a hard-copy of any reports required by their permit. The Department will enter data submitted in hard-copy from those facilities allowed to do so and electronically submit the data to the EPA on behalf of the facility.

✓ The permittee/facility is currently using the eDMR data reporting system.

NUMERIC LAKE NUTRIENT CRITERIA

✓ This facility does not discharge into a lake watershed where numeric lake nutrient criteria are applicable.

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users,
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation

✓ This permittee has an approved pretreatment program in accordance with the requirements of [40 CFR Part 403] and [10 CSR 20-6.100] and is expected to implement and enforce its approved program.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

✓ An RPA was conducted on appropriate parameters. Please see **APPENDIX – RPA RESULTS**.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

- ✓ Equivalent to Secondary Treatment is 65% removal [40 CFR Part 133.105(a)(3) & (b)(3)], however per 40 CFR part 133.103(a), percent removal requirements apply only during dry weather. When calculating percent removal efficiencies, the City may exclude influent data on corresponding days when rainfall exceeds 0.1 inches or snow melt is occurring.

SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(12)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur.

- ✓ The permittee has developed and is currently implementing a program for maintenance and repair of the collection system. The permittee shall continue to submit annual reports by March 31st as required by the federal consent decree entered in the matter of United States vs. City of Kansas City, Missouri, No. 4:10-CV-0497.

SCHEDULE OF COMPLIANCE (SOC):

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

- ✓ This permit does not contain an SOC.

SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM:

In accordance with [10 CSR 20-6.010(6)(A)], the Department may grant approval of a permittee's Sewer Extension Authority Supervised Program. These approved permittees regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility. The permittee shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. See <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/wastewater/construction-engineering>.

- ✓ The permittee's Sewer Extension Authority Supervised Program has been reauthorized. Please see **Appendix – Sewer Extension Authority Supervised Program Reauthorization Letter** for applicable conditions.

STORMWATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in June 2015], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally, in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 CFR 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and re-evaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. For further guidance, consult the antidegradation implementation procedure (<https://dnr.mo.gov/document-search/antidegradation-implementation-procedure>).

Alternative Analysis (AA) evaluation of the BMPs is a structured evaluation of BMPs that are reasonable and cost effective. The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why "no discharge" or "no exposure" is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure (AIP)*, Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the Department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs. The request shall be submitted in the form of an operating permit modification; the application is found at: <https://dnr.mo.gov/forms-applications>.

- ✓ 10 CSR 20-6.200 and 40 CFR 122.26(b)(14)(ix) includes treatment works treating domestic sewage or any other sewage sludge or wastewater treatment device or system, used in the storage treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated to the disposal of sewage sludge that is located within the confines of the facility, with a design flow of 1.0 MGD or more, or are required to have an approved pretreatment program under 40 CFR part 403, as an industrial activity in which permit coverage is required. In lieu of requiring sampling in the site-specific permit, the facility is required to develop and implement a Stormwater Pollution Prevention Plan (SWPPP).

A facility can apply for conditional exclusion for “no exposure” of industrial activities and materials to stormwater by submitting a permit modification via Form B2 (<https://dnr.mo.gov/document-search/form-b2-application-operating-permit-facilities-receive-primarily-domestic-waste-have-design-flow-more-100000-gallons-day-mo-780-1805>) appropriate application filing fees and a completed No Exposure Certification for Exclusion from NPDES Stormwater Permitting under Missouri Clean Water Law (<https://dnr.mo.gov/document-search/no-exposure-certification-exclusion-npdes-stormwater-permitting-under-missouri-clean-water-law-mo-780-2828>) to the Department’s Water Protection Program, Operating Permits Section. Upon receipt of the No Exposure Certification, the permit will be modified and the Special Condition to develop and implement a SWPPP will be removed.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

- ✓ This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(86)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

- ✓ Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C_e = \frac{(Q_e + Q_s)C - (Q_s \times C_s)}{(Q_e)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration C_e = effluent concentration
Cs = upstream concentration Q_e = effluent flow
Qs = upstream flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA’s “Technical Support Document For Water Quality-based Toxics Control” (EPA/505/2-90-001).

Number of Samples “n”:

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of “n” for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for “n” must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is “n = 4” at a minimum. For Total Ammonia as Nitrogen, “n = 30” is used.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

- ✓ A WLA study was either not submitted or determined not applicable by Department staff.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures that the provisions in the 10 CSR 20-

6.010(8)(A) and the Water Quality Standards 10 CSR 20-7.031(4)(D),(F),(G),(J)2.A & B are being met. Under [10 CSR 20-6.010(8)(B)], the Department may require other terms and conditions that it deems necessary to assure compliance with the Clean Water Act and related regulations of the Missouri Clean Water Commission. In addition the following MCWL apply: §§644.051.3 requires the Department to set permit conditions that comply with the MCWL and CWA; 644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits, pretreatment, etc...); and 644.051.5 is the basic authority to require testing conditions. WET test will be required by facilities meeting the following criteria:

- ☒ Facility is a designated Major.
- ☐ Facility continuously or routinely exceeds its design flow.
- ☐ Facility that exceeds its design population equivalent (PE) for BOD₅ whether or not its design flow is being exceeded.
- ☐ Facility (whether primarily domestic or industrial) that alters its production process throughout the year.
- ☐ Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- ☒ Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH₃)
- ☒ Facility is a municipality with a Design Flow \geq 22,500 gpd.
- ☐ Other – please justify.

✓ The permittee is required to conduct WET test for this facility.

40 CFR 122.41(M) - BYPASSES:

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from “bypassing” untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 CFR 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 CFR 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 CFR 122.41(l)(6) and per Missouri’s Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

✓ Bypasses occur or have occurred at this facility.

- Outfall #005 is no longer authorized to discharge as it is a Bypass..

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

✓ This facility discharges to a 303(d) listed stream. The Missouri River is listed on the 2018 Missouri 303(d) List for *E. coli*.

- It is unknown at this time if the facility is a source of the above listed pollutant or considered to contribute to the impairment of the Missouri River. Once a TMDL is developed, the permit may be modified to include WLAs from the TMDL.

✓ This facility discharges to a stream with an EPA approved TMDL. The TMDL for the Missouri River was approved by the EPA on November 3, 2006. The pollutants of concern were Chlordane and Polychlorinated Biphenyls. The TMDL discusses that there are no Missouri facilities which discharge either directly to the Missouri River, or a tributary to, that have a potential to discharge detectable amounts of PCBs or chlordane. Therefore, the KC Blue River WWTP is not considered a source of the pollutants of concern.

Part VI – Effluent Limits Determination

OUTFALL #001 – MAIN FACILITY OUTFALL

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

EFFLUENT LIMITATIONS TABLE:

| PARAMETER | Unit | Basis for Limits | Daily Maximum | Weekly Average | Monthly Average | Previous Permit Limit | Sampling Frequency | Reporting Frequency | Sample Type **** |
|----------------------------------|---------|------------------|---------------|----------------|------------------|-----------------------|---|---------------------|------------------|
| Flow | MGD | 1 | * | | * | */ | 1/day | monthly | T |
| BOD ₅ | mg/L | 1 | | 60 | 40 | 60/40 | 1/weekday | monthly | C |
| TSS | mg/L | 1 | | 60 | 40 | 60/40 | 1/weekday | monthly | C |
| <i>Escherichia coli</i> ** | #/100mL | 1, 3 | | 1,030 | 206 | 1,030/206 | 1/month | monthly | G |
| Ammonia as N (January) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Ammonia as N (February) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Ammonia as N (March) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Ammonia as N (April) | mg/L | 2, 3 | * | | * | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (May) | mg/L | 2, 3 | * | | * | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (June) | mg/L | 2, 3 | 58.1 | | 36.4 | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (July) | mg/L | 2, 3 | 66.7 | | 32.1 | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (August) | mg/L | 2, 3 | 71.6 | | 37.5 | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (September) | mg/L | 2, 3 | * | | * | 45.1/17.3 | 1/weekday | monthly | C |
| Ammonia as N (October) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Ammonia as N (November) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Ammonia as N (December) | mg/L | 2, 3 | * | | * | 70.1/27.1 | 1/weekday | monthly | C |
| Chlorine, Total Residual | µg/L | 1, 3 | < 130 | | < 130 | <130/<130 | 1/week | monthly | G |
| Total Phosphorus | mg/L | 1 | * | | * | */ | 1/month | monthly | C |
| Total Kjeldahl Nitrogen | mg/L | 1 | * | | * | *** | 1/month | monthly | C |
| Nitrite + Nitrate | mg/L | 1 | * | | * | */ | 1/month | monthly | C |
| Acute Whole Effluent Toxicity | TUa | 1, 9 | * | | | % survival | 2 acute and 2 chronic for next permit renewal | | C |
| Chronic Whole Effluent Toxicity | TUc | 1, 9 | * | | | *** | | | C |
| PARAMETER | Unit | Basis for Limits | Minimum | | Maximum | Previous Permit Limit | Sampling Frequency | Reporting Frequency | Sample Type |
| pH | SU | 1 | 6.0 | | 9.0 | 6.5-9.0 | 1/weekday | monthly | G |
| PARAMETER | Unit | Basis for Limits | Daily Minimum | | Monthly Avg. Min | Previous Permit Limit | Sampling Frequency | Reporting Frequency | Sample Type |
| BOD ₅ Percent Removal | % | 1 | | | 65 | 65 | 1/month | monthly | M |
| TSS Percent Removal | % | 1 | | | 65 | 65 | 1/month | monthly | M |

* - Monitoring requirement only.

** - #/100mL; the Monthly Average for *E. coli* is a geometric mean.

*** - Parameter not previously established in previous state operating permit.

**** - C = 24-hour composite

G = Grab

T = 24-hr. total

E = 24-hr. estimate

M = Measured/calculated

Basis for Limitations Codes:

- | | | |
|--|-----------------------------------|---|
| 1. State or Federal Regulation/Law | 5. Antidegradation Policy | 9. WET Test Policy |
| 2. Water Quality Standard (includes RPA) | 6. Water Quality Model | 10. Multiple Discharger Variance |
| 3. Water Quality Based Effluent Limits | 7. Best Professional Judgment | 11. Nutrient Criteria Implementation Plan |
| 4. Antidegradation Review | 8. TMDL or Permit in lieu of TMDL | |

| PARAMETER | Unit | Basis for Limits | Daily Maximum | Weekly Average | Monthly Average | Previous Permit Limit | Sampling Frequency | Reporting Frequency | Sample Type **** |
|--------------|------|------------------|---------------|----------------|-----------------|-----------------------|--------------------|---------------------|------------------|
| Cadmium, TR | µg/L | 7 | * | | * | 5.2/2.9 | 1/quarter | quarterly | G |
| Copper, TR | µg/L | 7 | * | | * | 88/39 | 1/quarter | quarterly | G |
| Cyanide, ATC | µg/L | 7 | * | | * | 44.8/19.3 | 1/quarter | quarterly | G |
| Oil & Grease | mg/L | 7 | * | | * | 15/10 | 1/quarter | quarterly | G |
| Phenol | µg/L | 7 | * | | * | 458/100 | 1/quarter | quarterly | G |

* - Monitoring requirement only.

** - #/100mL; the Monthly Average for *E. coli* is a geometric mean.

*** - Parameter not previously established in previous state operating permit.

**** - C = 24-hour composite

G = Grab

T = 24-hr. total

E = 24-hr. estimate

M = Measured/calculated

Basis for Limitations Codes:

- | | | |
|--|-----------------------------------|---|
| 1. State or Federal Regulation/Law | 5. Antidegradation Policy | 9. WET Test Policy |
| 2. Water Quality Standard (includes RPA) | 6. Water Quality Model | 10. Multiple Discharger Variance |
| 3. Water Quality Based Effluent Limits | 7. Best Professional Judgment | 11. Nutrient Criteria Implementation Plan |
| 4. Antidegradation Review | 8. TMDL or Permit in lieu of TMDL | |

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.
- **Biochemical Oxygen Demand (BOD₅).** Operating permit retains 60 mg/L as a Weekly Average and 40 mg/L as a Monthly Average from the previous permit. Effluent limits were established in accordance with 10 CSR 20-7.015(2)(A)3.D., which allows the Department to set more stringent effluent limits based on the facilities performance. This limit was found to have been established in the 1994 permit.
- **Total Suspended Solids (TSS).** Operating permit retains 60 mg/L as a Weekly Average and 40 mg/L as a Monthly Average from the previous permit. Effluent limits were established in accordance with 10 CSR 20-7.015(2)(A)3.D., which allows the Department to set more stringent effluent limits based on the facilities performance. This limit was found to have been established in the 1994 permit.
- ***Escherichia coli (E. coli).*** Monthly average of 206 per 100 mL as a geometric mean and Weekly Average of 1,030 per 100 mL as a geometric mean during the recreational season (April 1 – October 31), for discharges within two miles upstream of segments or lakes with Whole Body Contact Recreation (B) designated use of the receiving stream, as per 10 CSR 20-7.015(9)(B). An effluent limit for both monthly average and weekly average is required by 40 CFR 122.45(d). The Geometric Mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected. For example: Five *E. coli* samples were collected with results of 1, 4, 6, 10, and 5 (#/100mL). Geometric Mean = 5th root of (1)(4)(6)(10)(5) = 5th root of 1,200 = 4.1 #/100mL.
- **Total Ammonia Nitrogen.** Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(5)(B)7.C. & Table B3]. Background total ammonia nitrogen = 0.01 mg/L.

The Department previously followed the 2007 Ammonia Guidance method for derivation of ammonia limits. However, the EPA's Technical Support Document for Water Quality-based Toxic Controls (TSD) establishes other alternatives to limit derivation. The Department has determined that the approach established in Section 5.4.2 of the TSD, which allows for direct application of both the acute and chronic wasteload allocations (WLA) as permit limits for toxic pollutants, is more appropriate limit derivation approach. Using this method for a discharge to a waterbody where mixing is not allowed, the criterion continuous concentration (CCC) and the criterion maximum concentration (CMC) will equal the chronic and acute WLA respectively. The WLAs are then applied as effluent limits, per Section 5.4.2 of the TSD, where the CMC is the Daily Maximum and the CCC is the Monthly Average. The direct application of both acute and chronic criteria as WLA is also applicable for facilities that discharge into receiving waterbodies with mixing considerations. The CCC and CMC will need to be calculated into WLA with mixing considerations using the mass-balance equation:

$$C_e = \frac{(Q_e + Q_s)C - (Q_s \times C_s)}{(Q_e)}$$

Where C = downstream concentration C_e = effluent concentration
Cs = upstream concentration Q_e = effluent flow
Q_s = upstream flow

In the event that mixing considerations derive an AML less stringent than the MDL, the AML and MDL will be equal and based on the MDL.

| Month | Temp (°C)* | pH (SU)* | Total Ammonia Nitrogen CCC (mg/L) | Total Ammonia Nitrogen CMC (mg/L) |
|-----------|------------|----------|--------------------------------------|--------------------------------------|
| January | 2.3 | 7.4 | 2.7 | 22.7 |
| February | 2.7 | 7.4 | 2.7 | 23.0 |
| March | 9.1 | 7.4 | 2.8 | 24.4 |
| April | 15.8 | 7.4 | 2.3 | 21.9 |
| May | 20.3 | 7.5 | 1.9 | 21.0 |
| June | 26.0 | 7.5 | 1.2 | 20.8 |
| July | 28.8 | 7.4 | 1.0 | 23.9 |
| August | 28.1 | 7.3 | 1.2 | 25.6 |
| September | 23.5 | 7.3 | 1.5 | 25.7 |
| October | 16.1 | 7.3 | 2.4 | 26.8 |
| November | 10.3 | 7.3 | 2.9 | 26.3 |
| December | 4.0 | 7.4 | 2.7 | 21.9 |

* Calculated Zone of Initial Dilution and Mixing Zone pH values using the DESCON model to develop mixed pH values to use for calculating limits. Ecoregion data (Western Corn Belt Plains) and effluent data were used to calculate limits.

January – May, September – December: Monitoring requirement only. This data will be used during the next permit renewal

June

Chronic WLA: $C_e = ((162.75 + 4890.02042)1.2 - (4890.02042 * 0.01)) / 162.75$
 $C_e = 36.4$

Acute WLA: $C_e = ((162.75 + 292.42647)20.8 - (292.42647 * 0.01)) / 292.42647$
 $C_e = 58.1$

AML = WLA_c = 36.4 mg/L
MDL = WLA_a = 58.1 mg/L

July

Chronic WLA: $C_e = ((162.75 + 4890.02042)1 - (4890.02042 * 0.01)) / 162.75$
 $C_e = 32.1$

Acute WLA: $C_e = ((162.75 + 292.42647)23.9 - (292.42647 * 0.01)) / 292.42647$
 $C_e = 66.7$

AML = WLA_c = 32.1 mg/L
MDL = WLA_a = 66.7 mg/L

August

Chronic WLA: $C_e = ((162.75 + 4890.02042)1.2 - (4890.02042 * 0.01)) / 162.75$
 $C_e = 37.5$

Acute WLA: $C_e = ((162.75 + 292.42647)25.6 - (292.42647 * 0.01)) / 292.42647$
 $C_e = 71.6$

AML = WLA_c = 37.5 mg/L
MDL = WLA_a = 71.6 mg/L

- **Oil & Grease.** Monitoring requirement only. This data will be reviewed during the next permit renewal.

- **Total Residual Chlorine (TRC).** Warm-water Protection of Aquatic Life CCC = 11 µg/L, CMC = 19 µg/L [10 CSR 20-7.031, Table A]. Background TRC = 0.0 µg/L.

Chronic WLA: $C_e = ((162.75 + 4,890.02)11 - (4,890.02 * 0.0))/162.75$
 $C_e = 341.51 \text{ µg/L}$

Acute WLA: $C_e = ((162.75 + 292.43)19 - (292.43 * 0.0))/162.75$
 $C_e = 53.14 \text{ µg/L}$

$LTA_c = 341.51 (0.72861) = 248.83 \text{ µg/L}$ [CV = 0.28, 99th Percentile]
 $LTA_a = 53.14 (0.546) = 29.0 \text{ µg/L}$ [CV = 0.28, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

$MDL = 29.0 (1.83) = 53 \text{ µg/L}$ [CV = 0.28, 99th Percentile]
 $AML = 29.0 (1.25) = 36 \text{ µg/L}$ [CV = 0.28, 95th Percentile, n = 4]

The Water Quality Based Effluent Limit for Total Residual Chlorine was calculated to be 53 µg/L (daily maximum limit) and 26 µg/L (monthly average limit). These limits are below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The Department has determined the current acceptable ML for total residual chlorine to be 130 µg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 130 µg/L will be considered violations of the permit and values less than the minimum quantification level of 130 µg/L will be considered to be in compliance with the permit limitation.

- **Total Phosphorus and Total Nitrogen (Speciated).** Effluent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, and Nitrite + Nitrate are required per 10 CSR 20-7.015(9)(D)8.
- **pH.** 6.0-9.0 SU. pH limitations [10 CSR 20-7.015] are protective of the water quality standard [10 CSR 20-7.031(5)(E)], due to the assimilative capacity of the receiving stream.
- **Phenol.** Monitoring requirement only. This data will be reviewed during the next permit renewal.
- **Cyanide, Amenable to Chlorination.** Monitoring only requirements have been included in this permit. An RPA was conducted based on the current WQS and determined that there is no reasonable potential to violate the water quality standard for Cyanide, please see **Appendix – RPA Results**. This determination will be reassessed at the time of renewal.
- **Biochemical Oxygen Demand (BOD₅) Percent Removal.** In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 65% removal efficiency for BOD₅.
- **Total Suspended Solids (TSS) Percent Removal.** In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 65% removal efficiency for TSS.

Metals

Effluent limitations for total recoverable metals were developed using methods and procedures outlined in the “Technical Support Document for Water Quality-based Toxic Controls” (EPA/505/2-90-001) and “The Metals Translator: Guidance For Calculating a Total Recoverable Permit Limit from a Dissolved Criterion” (EPA 823-B-96-007). General warm-water fishery criteria apply. Ecoregion water hardness for Western Corn Belt Plains (EDU - Central Plains/Blackwater/Lamine) of 252 mg/L is used in the calculation below. This value represents the 50th percentile (median) for all watersheds in-stream hardness values through the Ecoregion.

Due to the absence of contemporaneous effluent and instream data for total recoverable metals, dissolved metals, hardness, and total suspended solids with which to calculate metals translators, partitioning between the dissolved and absorbed phases was assumed to be minimal (Section 5.7.3, EPA/505/2-90-001). Freshwater criteria conversion factors for dissolved metals were used as the metals translator as recommended in guidance (Section 1.3, 1.5.3, and Table 1, EPA 823-B-96-007). If concurrent site-specific data for total recoverable metals, dissolved metals, hardness, and total suspended solids are provided to the Department, partitioning evaluations may be considered and site-specific translators developed.

- **Cadmium, Total Recoverable.** Monitoring only requirements have been included in this permit. An RPA was conducted based on the current WQS and determined that there is no reasonable potential to violate the water quality standard for Cadmium, please see **Appendix – RPA Results**. This determination will be reassessed at the time of renewal.
- **Copper, Total Recoverable.** Monitoring only requirements have been included in this permit. An RPA was conducted based on the current WQS and determined that there is no reasonable potential to violate the water quality standard for Copper, please see **Appendix – RPA Results**. This determination will be reassessed at the time of renewal.

Whole Effluent Toxicity

- **Acute Whole Effluent Toxicity.** Monitoring requirement only. Monitoring is required to determine if reasonable potential exists for this facility’s discharge to exceed water quality standards.
 - Classified P with other than default Mixing Considerations, the AEC% is determined as follows:

$$\text{Acute AEC\%} = \{[(\text{design flow}_{\text{cfs}} + \text{ZID}_{7\text{Q}10}) / \text{design flow}_{\text{cfs}}]^{-1}\} \times 100 = \#\%$$
$$\text{Acute AEC\%} = \{[(162.75 + 292.43) / 162.75]^{-1}\} \times 100 = 36\%$$

- **Chronic Whole Effluent Toxicity.** Monitoring requirement only. Monitoring is required to determine if reasonable potential exists for this facility’s discharge to exceed water quality standards.
 - Classified P with other than default Mixing Considerations, the AEC% is determined as follows:
$$\text{Chronic AEC\%} = \{[(\text{design flow}_{\text{cfs}} + \text{MZ}_{7\text{Q}10}) / \text{design flow}_{\text{cfs}}]^{-1}\} \times 100 = \#\%$$
$$\text{Chronic AEC\%} = \{[(162.75 + 4,890.02) / 162.75]^{-1}\} \times 100 = 3\%$$
- **Total Recoverable Barium, Total Recoverable Boron, Chloride, Total Recoverable Cobalt, and Sulfate.** These parameters are added to the Expanded Effluent Test list that the facility conducts as part of the permit renewal application. These parameters were added as the facility receives landfill leachate and also receives industrial wastewater from industries that have the potential to contain these pollutants. The data will be reviewed at the next permit renewal to determine if a reasonable potential exists to violate water quality standards.

Parameters Removed.

- **Total Toxic Organics (TTO).** The previous permit contained a requirement to sample and report TTOs once per permit cycle. A review of the TTO results shows compliance in accordance with 40 CFR 413.14(f). Due to consistency in compliance, the monitoring requirement for TTOs was removed.
- **Fluoride, Arsenic, Chromium III, Chromium VI, Lead, Mercury, Nickel, Thallium, Zinc.** The previous permit contained a monitoring only requirement for these parameters. These parameters were removed as the permit writer did not observe a reasonable potential to violate Water Quality Standards for these parameters. The permit is still protective of water quality.
- **Hardness.** Hardness was removed as effluent hardness is not applicable to calculate effluent limits.
- **Total Nitrogen.** Total Nitrogen was removed and replaced with Total Kjeldahl Nitrogen
- **Manganese.** Manganese was removed as the receiving stream does not have Water Quality Standards for Groundwater.

Sampling Frequency Justification: Sampling and Reporting Frequency was retained from previous permit, except for Flow which was increased from once per weekday to daily, Total Phosphorus and Nitrate + Nitrite was increased from quarterly to monthly, and Oil & Grease was decreased from monthly to quarterly. The increase for Flow is due to the facility having flows that are impacted by rainfall events due to the CSO system, and that the facility is staffed year-round and has a flow monitoring device that records flow daily. Total Phosphorus and Nitrate + Nitrite frequencies are increased per 10 CSR 20-7.015(9)(D)8. The decrease for Oil & Grease was that the facility has been consistently meeting the limits and the permit writer did not observe a reasonable potential to violate Water Quality Standards. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)7.A.

WET Test Sampling Frequency Justification. WET Testing schedules and intervals are established in accordance with the Department's Permit Manual; Section 5.2 *Effluent Limits / WET Testing for Compliance Bio-monitoring*. It is recommended that WET testing be conducted during the period of lowest stream flow.

Acute and Chronic Whole Effluent Toxicity – The permittee shall perform a minimum of four whole effluent toxicity tests in the four and one-half year period prior to the next permit renewal application. The four tests shall consist of two chronic toxicity tests and two acute toxicity tests.

Sampling Type Justification: As per 10 CSR 20-7.015, samples collected for mechanical plants shall be a 24 hour composite sample. Grab samples, however, must be collected for pH, *E. coli*, TRC, Oil & Grease, and Cyanide, in accordance with recommended analytical methods. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

PERMITTED FEATURE INF – INFLUENT MONITORING

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

INFLUENT MONITORING TABLE:

| PARAMETER | Unit | Basis for Limits | Daily Maximum | Weekly Average | Monthly Average | Previous Permit Limit | Sampling Frequency | Reporting Frequency | Sample Type **** |
|-------------------------|------|------------------|---------------|----------------|-----------------|-----------------------|--------------------|---------------------|------------------|
| BOD ₅ | mg/L | 1 | | | * | * | 1/weekday | monthly | C |
| TSS | mg/L | 1 | | | * | * | 1/weekday | monthly | C |
| Ammonia as N | mg/L | 1 | * | | * | *** | 1/month | monthly | C |
| Total Phosphorus | mg/L | 1 | * | | * | *** | 1/month | monthly | C |
| Total Kjeldahl Nitrogen | mg/L | 1 | * | | * | *** | 1/month | monthly | C |
| Nitrite + Nitrate | mg/L | 1 | * | | * | *** | 1/month | monthly | C |

* - Monitoring requirement only.

*** - Parameter not previously established in previous state operating permit.

**** - C = Composite

G = Grab

Basis for Limitations Codes:

- | | | |
|--|-----------------------------------|---|
| 1. State or Federal Regulation/Law | 5. Antidegradation Policy | 9. WET Test Policy |
| 2. Water Quality Standard (includes RPA) | 6. Water Quality Model | 10. Multiple Discharger Variance |
| 3. Water Quality Based Effluent Limits | 7. Best Professional Judgment | 11. Nutrient Criteria Implementation Plan |
| 4. Antidegradation Review | 8. TMDL or Permit in lieu of TMDL | |

Influent Parameters

- **Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS)**. An influent sample is required to determine the removal efficiency. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals.
- **Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia**. Influent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia required per 10 CSR 20-7.015(9)(D)8.

Sampling Frequency Justification: The sampling and reporting frequencies for Total Phosphorus and Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia parameters were established to match the required sampling frequency of these parameters in the effluent, per [10 CSR 20-7.015(9)(D)8.]. The sampling and reporting frequencies for influent CBOD₅ and TSS have been established to match the required sampling frequency of the CBOD₅ and TSS percent removal requirement for Outfall #001.

Sampling Type Justification: Sample types for influent parameters were established to match the required sampling type of these parameters in the effluent. Samples should be analyzed as soon as possible after collection and/or properly preserved according to method requirements.

OUTFALL #001 – GENERAL CRITERIA CONSIDERATIONS:

In accordance with 40 CFR 122.44(d)(1), effluent limitations shall be placed into the permit for those pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The rule further states that pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above a narrative criterion within an applicable State water quality standard, the permit shall contain a numeric effluent limitation to protect that narrative criterion. In order to comply with this regulation, the permit writer will complete reasonable potential determinations on whether the discharge will violate any of the general criteria listed in 10 CSR 20-7.031(4). These specific requirements are listed below followed by derivation and discussion (the lettering matches that of the rule itself, under 10 CSR 20-7.031(4)). It should also be noted that Section 644.076.1, RSMo as well as Section D – Administrative Requirements of Standard Conditions Part I of this permit states that it shall be unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri that is in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law or any standard, rule or regulation promulgated by the commission.

- (A) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses. The discharge from this facility is made up of treated domestic wastewater. Based upon review of the Report of Compliance Inspection for the inspection conducted on March 7-10, 2017, no evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any

other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, this facility utilizes equivalent to secondary treatment technology and is currently in compliance with effluent limitations that are more stringent than the equivalent to secondary treatment technology based effluent limits established in 40 CFR 133 and there has been no indication to the Department that the stream has had issues maintaining beneficial uses as a result of this discharge. Based on the information reviewed during the drafting of this permit, these final effluent limitations appear to have protected against the excursion of this criterion in the past. Therefore, the discharge does not have the reasonable potential to cause or contribute to an excursion of this criterion.

- (B) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (C) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (D) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life. This permit contains final effluent limitations which are protective of both acute and chronic toxicity for various pollutants that are either expected to be discharged by domestic wastewater facilities or that were disclosed by this facility on the application for permit coverage. Based on the information reviewed during the drafting of this permit, it has been determined if the facility meets final effluent limitations established in this permit, there is no reasonable potential for the discharge to cause an excursion of this criterion.
- (E) Waters shall provide for the attainment and maintenance of water quality standards downstream including waters of another state. Please see (D) above as justification is the same.
- (F) There shall be no significant human health hazard from incidental contact with the water. Please see (D) above as justification is the same.
- (G) There shall be no acute toxicity to livestock or wildlife watering. Please see (D) above as justification is the same.
- (H) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community. Please see (A) above as justification is the same.
- (I) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247. The discharge from this facility is made up of treated domestic wastewater. No evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, any solid wastes received or produced at this facility are wholly contained in appropriate storage facilities, are not discharged, and are disposed of offsite. This discharge is subject to Standard Conditions Part III, which contains requirements for the management and disposal of sludge to prevent its discharge. Therefore, this discharge does not have reasonable potential to cause or contribute to an excursion of this criterion.

Part VII – Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

- ✓ The Department is required to make a “finding of affordability” on the new environmental requirement(s) within the permit. However, the facility chose to waive the finding of affordability requirement; therefore, no Cost Analysis for Compliance was conducted.

Part VIII – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

WATER QUALITY STANDARD REVISION:

In accordance with section 644.058, RSMo, the Department is required to utilize an evaluation of the environmental and economic impacts of modifications to water quality standards of twenty-five percent or more when making individual site-specific permit decisions.

- ✓ This operating permit does not contain requirements for a water quality standard that has changed twenty-five percent or more since the previous operating permit.

PERMIT SYNCHRONIZATION:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together and all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit.

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

- ✓ The Public Notice period for this operating permit was from January 29, 2021 to March 1, 2021. No responses received.

DATE OF FACT SHEET: MARCH 9, 2021

COMPLETED BY:

BRANT FARRIS, ENVIRONMENTAL SPECIALIST
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT
(660) 385-8019
brant.farris@dnr.mo.gov

Appendices

APPENDIX - CLASSIFICATION WORKSHEET:

| Item | Points Possible | Points Assigned |
|--|--|-----------------|
| Maximum Population Equivalent (P.E.) served , peak day | 1 pt./10,000 PE or major fraction thereof. (Max 10 pts.) | 10 |
| Design Flow (avg. day) or peak month's flow (avg. day) whichever is larger | 1 pt. / MGD or major fraction thereof. (Max 10 pts.) | 10 |
| Effluent Discharge | | |
| Missouri or Mississippi River | 0 | 0 |
| All other stream discharges except to losing streams and stream reaches supporting whole body contact recreation | 1 | |
| Discharge to lake or reservoir outside of designated whole body contact recreational area | 2 | |
| Discharge to losing stream, or stream, lake or reservoir area supporting whole body contact recreation | 3 | 3 |
| Direct reuse or recycle of effluent | 6 | |
| Land Application/Irrigation | | |
| Drip Irrigation | 3 | |
| Land application/irrigation | 5 | |
| Overland flow | 4 | |
| Variation in Raw Wastes (highest level only) | | |
| Variations do not exceed those normally or typically expected | 0 | |
| Reoccurring deviations or excessive variations of 100 to 200 percent in strength and/or flow | 2 | |
| Reoccurring deviations or excessive variations of more than 200 percent in strength and/or flow | 4 | |
| Department-approved pretreatment program | 6 | 6 |
| Preliminary Treatment | | |
| STEP systems (operated by the permittee) | 3 | |
| Screening and/or comminution | 3 | 3 |
| Grit removal | 3 | 3 |
| Plant pumping of main flow | 3 | |
| Flow equalization | 5 | |
| Primary Treatment | | |
| Primary clarifiers | 5 | 5 |
| Chemical addition (except chlorine, enzymes) | 4 | |
| Secondary Treatment | | |
| Trickling filter and other fixed film media with or without secondary clarifiers | 10 | 10 |
| Activated sludge (including aeration, oxidation ditches, sequencing batch reactors, membrane bioreactors, and contact stabilization) | 15 | |
| Stabilization ponds without aeration | 5 | |
| Aerated lagoon | 8 | |
| Advanced Lagoon Treatment – Aerobic cells, anaerobic cells, covers, or fixed film | 10 | |
| Biological, physical, or chemical | 12 | |
| Carbon regeneration | 4 | |
| Total from page ONE (1) | ---- | 50 |

APPENDIX - CLASSIFICATION WORKSHEET (CONTINUED):

| ITEM | POINTS POSSIBLE | POINTS ASSIGNED |
|--|-----------------|-----------------|
| Solids Handling | | |
| Sludge Holding | 5 | 5 |
| Anaerobic digestion | 10 | 10 |
| Aerobic digestion | 6 | |
| Evaporative sludge drying | 2 | |
| Mechanical dewatering | 8 | 8 |
| Solids reduction (incineration, wet oxidation) | 12 | 12 |
| Land application | 6 | 6 |
| Disinfection | | |
| Chlorination or comparable | 5 | 5 |
| On-site generation of disinfectant (except UV light) | 5 | |
| Dechlorination | 2 | 2 |
| UV light | 4 | |
| Required Laboratory Control Performed by Plant Personnel (highest level only) | | |
| Lab work done outside the plant | 0 | |
| Push – button or visual methods for simple test such as pH, settleable solids | 3 | |
| Additional procedures such as DO, COD, BOD, titrations, solids, volatile content | 5 | |
| More advanced determinations, such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc. | 7 | 7 |
| Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph | 10 | |
| Total from page TWO (2) | ---- | 55 |
| Total from page ONE (1) | --- | 50 |
| Grand Total | --- | 105 |

- ☒ - A: 71 points and greater
☐ - B: 51 points – 70 points
☐ - C: 26 points – 50 points
☐ - D: 0 points – 25 points

APPENDIX: RECEIVING STREAM LOW-FLOW VALUE:

| KC Blue River WWTF MO-0024911 (105 MGD Design Flow) | | | | | | | | |
|---|------------|-------------------|------------------------------------|-------------------------------|---------------------------------------|-----------------------------------|------------------------------|--------------------------------|
| | Flow (CFS) | Design Flow (CFS) | ZID Dilution (from 2008 dye study) | ZID based on 2008 study (CFS) | Default ZID - 1/40th streamflow (CFS) | MZ Dilution (from 2008 dye study) | MZ based on 2008 study (CFS) | Default MZ (1/4th stream flow) |
| 1Q10 | 18002.9 | 162.45915 | 2.8 | 292.42647 | 450.0725 | 30.1 | 4890.02042 | 4500.725 |
| 7Q10 | 19042.7 | 162.45915 | 2.8 | 292.42647 | 476.0675 | 30.1 | 4890.02042 | 4760.675 |
| 30Q10 | 20362.1 | 162.45915 | 2.8 | 292.42647 | 509.0525 | 30.1 | 4890.02042 | 5090.525 |

APPENDIX – RPA RESULTS:

| Parameter | CMC* | RWC Acute* | CCC* | RWC Chronic* | n** | Range max/min | CV*** | MF | RP Yes/No |
|---------------------------------|---------|---------------|-------|-----------------|--------|------------------|-------|----------|--------------|
| Ammonia as N – January (mg/L) | 22.7 | 14.09 | 2.7 | 1.28 | 87.00 | 32.2/6 | 0.30 | 1.22 | NO |
| Ammonia as N – February (mg/L) | 23.0 | 16.83 | 2.7 | 1.52 | 82.00 | 37.8/6.6 | 0.31 | 1.24 | NO |
| Ammonia as N – March (mg/L) | 24.4 | 13.14 | 2.8 | 1.19 | 95.00 | 30/6.6 | 0.32 | 1.22 | NO |
| Ammonia as N – April (mg/L) | 21.9 | 10.12 | 2.3 | 0.92 | 89.00 | 23.7/4.8 | 0.26 | 1.19 | NO |
| Ammonia as N – May (mg/L) | 21.0 | 12.81 | 1.9 | 1.16 | 89.00 | 27.3/4.5 | 0.41 | 1.31 | NO |
| Ammonia as N – June (mg/L) | 20.8 | 15.10 | 1.2 | 1.37 | 111.00 | 35/4.8 | 0.33 | 1.21 | YES |
| Ammonia as N – July (mg/L) | 23.9 | 11.88 | 1.0 | 1.08 | 113.00 | 28.5/5.5 | 0.27 | 1.17 | YES |
| Ammonia as N – August (mg/L) | 25.6 | 16.74 | 1.2 | 1.52 | 113.00 | 38/2.5 | 0.38 | 1.23 | YES |
| Ammonia as N – September (mg/L) | 25.7 | 11.84 | 1.5 | 1.08 | 111.00 | 27.7/3.7 | 0.31 | 1.19 | NO |
| Ammonia as N – October (mg/L) | 26.8 | 11.10 | 2.4 | 1.01 | 115.00 | 25.9/1.6 | 0.33 | 1.20 | NO |
| Ammonia as N – November (mg/L) | 26.3 | 11.91 | 2.9 | 1.08 | 103.00 | 28.3/3.1 | 0.27 | 1.18 | NO |
| Ammonia as N – December (mg/L) | 21.9 | 12.44 | 2.7 | 1.13 | 92.00 | 28.6/5.5 | 0.30 | 1.22 | NO |
| Arsenic, Total Recoverable | 340.0 | 1.74 | 150.0 | 0.16 | 19.00 | 2.1/0.0425 | 0.6 | 2.32 | NO |
| Cadmium, TR | 12.9 | 0.84 | 1.7 | 0.08 | 21.00 | 2.5/0.055 | 2.3 | 0.94 | NO |
| Chromium III, TR | 3,844.0 | 8.00 | 183.7 | 0.72 | 21.00 | 11/1.5 | 0.5 | 2.04 | NO |
| Chromium VI, Dissolved | 16.0 | 3.88 | 11.0 | 0.35 | 22.00 | 10/4.85 | 0.2 | 1.08 | NO |
| Copper, Total Recoverable | 33.4 | 27.47 | 20.6 | 2.47 | 21.00 | 37/5 | 0.5 | 2.08 | NO |
| Lead, Total Recoverable | 264.7 | 4.57 | 10.3 | 0.41 | 20.00 | 4.6/0.013 | 0.8 | 2.78 | NO |
| Mercury, Total Recoverable | 1.6 | 0.16 | 0.8 | 0.01 | 21.00 | 0.2/0.0125 | 1.3 | 2.18 | NO |
| Nickel, Total Recoverable | 1,026.1 | 23.95 | 114.0 | 2.16 | 21.00 | 20/0.2 | 1.1 | 3.35 | NO |
| Thallium, Total Recoverable | NA | NA | 6.3 | 0.36 | 21.00 | 5.9/0.014 | 3.4 | 1.90 | NO |
| Zinc, Total Recoverable | 262.7 | 30.52 | 260.6 | 2.75 | 21.00 | 56/6.6 | 0.3 | 1.52 | NO |
| Fluoride (mg/L) | NA | NA | 4.0 | 0.03 | 291.00 | 0.848/0.077 | 0.3 | 1.05 | NO |
| Total Residual Chlorine (mg/L) | 19.0 | 34.84 | 11.0 | 3.14 | 51.00 | 100/10 | 0.3 | 0.97 | YES |
| Cyanide, ATC | 22.0 | 11.97 | 5.2 | 1.08 | 63.00 | 25/2.5 | 1.0 | 1.34 | NO |
| Phenol | NA | NA | 100.0 | 3.34 | 20.00 | 38/0.39 | 1.49 | 2.73 | NO |
| Chloroform | NA | NA | 5.7 | 0.40 | 5.00 | 3.3/0.65 | 0.6 | 3.76 | NO |
| Bis(2-ethylhexyl) phthalate | NA | NA | 5.90 | 2.27 | 6 | 20.1/0.42 | 0.6 | 3.501629 | NO |

N/A – Not Applicable

* - Units are (µg/L) unless otherwise noted.

** - If the number of samples is 10 or greater, then the CV value must be used in the WQBEL for the applicable constituent. If the number of samples is < 10, then the default CV value must be used in the WQBEL for the applicable constituent.

*** - Coefficient of Variation (CV) is calculated by dividing the Standard Deviation of the sample set by the Mean of the same sample set.


RWC – Receiving Water Concentration. It is the concentration of a toxicant or the parameter toxicity in the receiving water after mixing (if applicable).

n – Is the number of samples.

MF – Multiplying Factor. 99% Confidence Level and 99% Probability Basis.

RP – Reasonable Potential. It is where an effluent is projected or calculated to cause an excursion above a water quality standard based on a number of factors including, as a minimum, the four factors listed in 40 CFR 122.44(d)(1)(ii).

Reasonable Potential Analysis is conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request.



Appendix – Sewer Extension Authority Supervised Program Reauthorization Letter



Mr. Terry Leeds, Director
Kansas City Water
4800 E. 63rd Street
Kansas City, MO 64130

RE: Kansas City Sewer Extension Authority Program Reauthorization, ACT235,
MO-0024911, Jackson County

Dear Mr. Leeds:

The Missouri Department of Natural Resources' Water Protection Program has reevaluated the Kansas City's Sewer Extension Authority Supervised Program (Program) and approved the reauthorization per 10 CSR 20-6.010(6). This Program delegates administrative responsibility of construction sewer extension permits to the City of Kansas City and reporting requirements are included in the associated Missouri State Operating Permits (MSOP).

The Program shall apply to construction permits for sewer extensions that discharge to the following MSOP(s):

- | | |
|--------------|--|
| • MO-0024911 | [Kansas City- Blue River WWTF, Jackson County] |
| • MO-0024929 | [Kansas City- Westside WWTF, Jackson County] |
| • MO-0048305 | [Kansas City- Rock Branch WWTF, Clay County] |
| • MO-0048313 | [Kansas City- Fishing River WWTF, Clay County] |
| • MO-0049531 | [Kansas City- Birmingham WWTF, Clay County] |
| • MO-0024961 | [Kansas City- Todd Creek WWTF, Platte County] |

Kansas City shall act as the continuing authority for the constructed collection system.

This approval is granted until it is reauthorized during the operating permit renewal. Enclosed are the Program conditions, annual reporting requirements, and renewal reauthorization requirements. The Program annual report must be submitted to the Department by April 30 of each year.

This reauthorization does not supersede any requirements of the operating permit or enforcement actions. Nothing in this reauthorization removes any obligations to comply with county or other local ordinances or restrictions.

Mr. Leeds
Page Two


If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to 10 CSR 20-1.020 and Section 621.250, RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Contact information for the AHC is: Administrative Hearing Commission, United States Post Office Bldg., Third Floor, 131 West High Street, P.O. Box 1557, Jefferson City, MO 65102, Phone: 573-751-2422, Fax: 573-751-5018, and Website: www.oa.mo.gov/ahc.

If you have any questions concerning this matter, please contact Ms. Leasue Meyers, of the Water Protection Program by phone at 573-751-7906, or by email at leasue.meyers@dnr.mo.gov or by mail at Department of Natural Resources, P.O. Box 176, Jefferson City, MO 65102.

Thank you for your efforts to help ensure clean water in Missouri.

Sincerely,

WATER PROTECTION PROGRAM



Chris Wieberg
Director

CW:lmt

Enclosure

c: Ms. Sherri Irving, Kansas City Water
Mr. Blake Anderson, PE, Kansas City Water
Ms. Karine Papikian, PE, Kansas City Water
Mr. Brant Farris, Domestic Wastewater Unit
Mr. Scott Honig, Kansas City Regional Office

Kansas City Sewer Extension Authority
Page One

Activity No. ACT235

SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM REAUTHORIZATION

I. CONDITIONS:

1. This approval is limited to sewer extensions proposed within Kansas City Water's boundaries for which the receiving wastewater treatment facility is owned, operated, and maintained by Kansas City.
2. Upon completion of accepted construction, Kansas City will become the continuing authority for the operation, maintenance, and modernization of the sewer extension.
3. Additional requirements may be necessary to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans" when funding from the Department is requested.
4. Any updates to the Kansas City Water's Standard Specifications, signed and sealed on December 3, 2019 will require a subsequent review and approval by the Department.
 - A. This approval is limited to only wastewater components. Other items contained in this standard specification and details such as drinking water, roadways, structural, mechanical, electrical, etc. were not reviewed.
5. This approval may be reopened and modified to comply with any new or amended design regulations in 10 CSR 20-6.010 and 10 CSR 20-8.

II. ANNUAL REPORTS:

Kansas City must submit an annual report by April 30th of each year to the Engineering Section. The electronic submittals may be emailed to DNR.WPPEngineerSection@dnr.mo.gov. The report shall contain the following for each sewer extension, per 10 CSR 20-6.010(6)(D)1:

1. Name of sewer extension;
2. Population or number of lots to be served;
3. Type of wastewater (i.e. domestic or industrial);
4. Design flow in gallons per day;

Kansas City Sewer Extension Authority
Page Two

Activity No. ACT235

5. Length of sewer and force main;
6. Capacity of each pump station, if applicable;
7. The ultimate receiving wastewater treatment facility;
8. Date sewer extension permit is issued;
9. Date sewer extension construction is accepted; and
10. The remaining capacity of each wastewater treatment facility.

III. REAUTHORIZATION REQUEST:

Kansas City must submit a request for reauthorization to the Engineering Section at least 180 days prior to the expiration date of the Kansas City Blue River Wastewater Treatment Facility Operating Permit, MO-0024911. The request shall contain the following, per 10 CSR 20-6.010(6)(E):

1. The current standard technical specifications and typical detail drawings signed, sealed, and dated by a Missouri registered professional engineer.
2. A current layout map, or maps, of the collection system or electronic demonstration. The map(s) shall show sewer sizes and lengths, manholes, cleanouts, pump stations, force mains, air release valves, other sewer appurtenances as necessary, and street names.
3. A list and current number of Missouri registered professional engineers and other qualified staff reviewing plans, issuing sewer extension permits, preparing reports, inspecting construction, and enforcing local and state requirements under the Program.
4. A written statement from Kansas City ensuring that permanent plans of all permitted and constructed sewer extensions records are maintained.

Leasue Meyers, EI
Engineering Section
leasue.meyers@dnr.mo.gov



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions

Section A – Sampling, Monitoring, and Recording

1. **Sampling Requirements.**
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.
2. **Monitoring Requirements.**
 - a. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The individual(s) who performed the sampling or measurements;
 - iii. The date(s) analyses were performed;
 - iv. The individual(s) who performed the analyses;
 - v. The analytical techniques or methods used; and
 - vi. The results of such analyses.
 - b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
4. **Test Procedures.** The analytical and sampling methods used shall conform to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is “sufficiently sensitive” when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility’s discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
5. **Record Retention.** Except for records of monitoring information required by the permit related to the permittee’s sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

6. **Illegal Activities.**
 - a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or both.
 - b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B – Reporting Requirements

1. **Planned Changes.**
 - a. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
 - iii. The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
 - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.
2. **Non-compliance Reporting.**
 - a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - iii. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
 - c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
3. **Anticipated Noncompliance.** The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
 4. **Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
 5. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
 6. **Other Information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.
 7. **Discharge Monitoring Reports.**
 - a. Monitoring results shall be reported at the intervals specified in the permit.
 - b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
 - c. Monitoring results shall be reported to the Department no later than the 28th day of the month following the end of the reporting period.
- b. Notice.
 - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
 - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
 - c. Prohibition of bypass.
 - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 3. The permittee submitted notices as required under paragraph 2. b. of this section.
 - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.
3. **Upset Requirements.**
 - a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B – Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
 - c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

Section C – Bypass/Upset Requirements

1. **Definitions.**
 - a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
 - b. *Severe Property Damage*: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - c. *Upset*: an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
2. **Bypass Requirements.**
 - a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

Section D – Administrative Requirements

1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- d. It is unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.
2. **Duty to Reapply.**
- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- c. A permittee with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
5. **Proper Operation and Maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
6. **Permit Actions.**
- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
- i. Violations of any terms or conditions of this permit or the law;
- ii. Having obtained this permit by misrepresentation or failure to disclose fully any relevant facts;
- iii. A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- iv. Any reason set forth in the Law or Regulations.
- b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
7. **Permit Transfer.**
- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
 - a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.
12. **Closure of Treatment Facilities.**
 - a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
 - b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.
13. **Signatory Requirement.**
 - a. All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
 - b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
 - c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
MAY 1, 2013

PART II - SPECIAL CONDITIONS – PUBLICLY OWNED
TREATMENT WORKS
SECTION A – INDUSTRIAL USERS

1. Definitions

Definitions as set forth in the Missouri Clean Water Laws and approved by the Missouri Clean Water Commission shall apply to terms used herein.

Significant Industrial User (SIU). Except as provided in the *General Pretreatment Regulation* 10 CSR 20-6.100, the term Significant Industrial User means:

1. All Industrial Users subject to Categorical Pretreatment Standards; and
2. Any other Industrial User that: discharges an average of 25,000 gallons per day or more of process wastewater to the Publicly-Owned Treatment Works (POTW) (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's or for violating any Pretreatment Standard or requirement.

Clean Water Act (CWA) is the the federal Clean Water Act of 1972, 33 U.S.C. § 1251 et seq. (2002).

2. Identification of Industrial Discharges

Pursuant to 40 CFR 122.44(j)(1), all POTWs shall identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR 403.

3. Application Information

Applications for renewal or modification of this permit must contain the information about industrial discharges to the POTW pursuant to 40 CFR 122.21(j)(6)

4. Notice to the Department

Pursuant to 40 CFR 122.42(b), all POTWs must provide adequate notice of the following:

1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging these pollutants; and
2. Any substantial change into the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
3. For purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

For POTWs without an approved pretreatment program, the notice of industrial discharges which was not included in the permit application shall be made as soon as practicable. For POTWs with an approved pretreatment program, notice is to be included in the annual pretreatment report required in the special conditions of this permit. Notice may be sent to:

Missouri Department of Natural Resources
Water Protection Program
Attn: Pretreatment Coordinator
P.O. Box 176
Jefferson City, MO 65102

STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
August 1, 2019

PART III – BIOSOLIDS AND SLUDGE FROM DOMESTIC TREATMENT FACILITIES

SECTION A – GENERAL REQUIREMENTS

1. PART III Standard Conditions pertain to biosolids and sludge requirements under the Missouri Clean Water Law and regulations for domestic and municipal wastewater and also incorporates federal sludge disposal requirements under 40 CFR Part 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR Part 503 for domestic biosolids and sludge.
2. PART III Standard Conditions apply only to biosolids and sludge generated at domestic wastewater treatment facilities, including public owned treatment works (POTW) and privately owned facilities.
3. Biosolids and Sludge Use and Disposal Practices:
 - a. The permittee is authorized to operate the biosolids and sludge generating, treatment, storage, use, and disposal facilities listed in the facility description of this permit.
 - b. The permittee shall not exceed the design sludge/biosolids volume listed in the facility description and shall not use biosolids or sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
 - c. For facilities operating under general operating permits that incorporate Standard Conditions PART III, the facility is authorized to operate the biosolids and sludge generating, treatment, storage, use and disposal facilities identified in the original operating permit application, subsequent renewal applications or subsequent written approval by the department.
4. Biosolids or Sludge Received from other Facilities:
 - a. Permittees may accept domestic wastewater biosolids or sludge from other facilities as long as the permittee's design sludge capacity is not exceeded and the treatment facility performance is not impaired.
 - b. The permittee shall obtain a signed statement from the biosolids or sludge generator or hauler that certifies the type and source of the sludge
5. Nothing in this permit precludes the initiation of legal action under local laws, except to the extent local laws are preempted by state law.
6. This permit does not preclude the enforcement of other applicable environmental regulations such as odor emissions under the Missouri Air Pollution Control Law and regulations.
7. This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable biosolids or sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
8. In addition to Standard Conditions PART III, the Department may include biosolids and sludge limitations in the special conditions portion or other sections of a site specific permit.
9. Exceptions to Standard Conditions PART III may be authorized on a case-by-case basis by the Department, as follows:
 - a. The Department may modify a site-specific permit following permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR § 124.10, and 40 CFR § 501.15(a)(2)(ix)(E).
 - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR Part 503.

SECTION B – DEFINITIONS

1. Best Management Practices are practices to prevent or reduce the pollution of waters of the state and include agronomic loading rates (nitrogen based), soil conservation practices, spill prevention and maintenance procedures and other site restrictions.
2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food, feed or fiber. The facility includes any structures necessary to store the biosolids until soil, weather, and crop conditions are favorable for land application.
4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR Part 503.
5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with 40 CFR Part 503.
6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
7. Feed crops are crops produced primarily for consumption by animals.
8. Fiber crops are crops such as flax and cotton.
9. Food crops are crops consumed by humans which include, but is not limited to, fruits, vegetables and tobacco.
10. Industrial wastewater means any wastewater, also known as process wastewater, not defined as domestic wastewater. Per 40 CFR Part 122.2, process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product. Land application of industrial wastewater, residuals or sludge is not authorized by Standard Conditions PART III.
11. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological contact systems, and other similar facilities. It does not include wastewater treatment lagoons or constructed wetlands for wastewater treatment.
12. Plant Available Nitrogen (PAN) is nitrogen that will be available to plants during the growing seasons after biosolids application.
13. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
14. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs), sewage sludge incinerator ash, or grit/screenings generated during preliminary treatment of domestic sewage.
15. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen or concrete lined basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
16. Septage is the sludge pumped from residential septic tanks, cesspools, portable toilets, Type III marine sanitation devices, or similar treatment works such as sludge holding structures from residential wastewater treatment facilities with design populations of less than 150 people. Septage does not include grease removed from grease traps at a restaurant or material removed from septic tanks and other similar treatment works that have received industrial wastewater. The standard for biosolids from septage is different from other sludges. See Section H for more information.

SECTION C – MECHANICAL WASTEWATER TREATMENT FACILITIES

1. Biosolids or sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and the requirements of Standard Conditions PART III or in accordance with Section A.3.c., above.
2. The permittee shall operate storage and treatment facilities, as defined by Section 644.016(23), RSMo, so that there is no biosolids or sludge discharged to waters of the state. Agricultural storm water discharges are exempt under the provisions of Section 644.059, RSMo.
3. Mechanical treatment plants shall have separate biosolids or sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove biosolids or sludge from these storage compartments on the required design schedule is a violation of this permit.

SECTION D – BIOSOLIDS OR SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR BY CONTRACT HAULER

1. Permittees that use contract haulers, under the authority of their operating permit, to dispose of biosolids or sludge, are responsible for compliance with all the terms of this permit. Contract haulers that assume the responsibility of the final disposal of biosolids or sludge, including biosolids land application, must obtain a Missouri State Operating Permit unless the hauler transports the biosolids or sludge to another permitted treatment facility.
2. Testing of biosolids or sludge, other than total solids content, is not required if biosolids or sludge are hauled to a permitted wastewater treatment facility, unless it is required by the accepting facility.

SECTION E – INCINERATION OF SLUDGE

1. Please be aware that sludge incineration facilities may be subject to the requirements of 40 CFR Part 503 Subpart E, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or, if the ash is determined to be hazardous, with 10 CSR 25.
3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, mass of sludge incinerated and mass of ash generated. Permittee shall also provide the name of the ash disposal facility and permit number if applicable.

SECTION F – SURFACE DISPOSAL SITES AND BIOSOLIDS AND SLUDGE LAGOONS

1. Please be aware that surface disposal sites of biosolids or sludge from wastewater treatment facilities may be subject to other laws including the requirements in 40 CFR Part 503 Subpart C, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
2. Biosolids or sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain biosolids or sludge storage lagoons as storage facilities, accumulated biosolids or sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of biosolids or sludge removed will be dependent on biosolids or sludge generation and accumulation in the facility. Enough biosolids or sludge must be removed to maintain adequate storage capacity in the facility.
 - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of biosolids or sludge on the bottom of the lagoon, upon prior approval of the Department; or
 - b. Permittee shall close the lagoon in accordance with Section I.

SECTION G – LAND APPLICATION OF BIOSOLIDS

1. The permittee shall not land apply biosolids unless land application is authorized in the facility description, the special conditions of the issued NPDES permit, or in accordance with Section A.3.c., above.
2. This permit only authorizes “Class A” or “Class B” biosolids derived from domestic wastewater to be land applied onto grass land, crop land, timber, or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
3. Class A Biosolids Requirements: Biosolids shall meet Class A requirements for application to public contact sites, residential lawns, home gardens or sold and/or given away in a bag or other container.
4. Class B biosolids that are land applied to agricultural and public contact sites shall comply with the following restrictions:
 - a. Food crops that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
 - b. Food crops below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for four months or longer prior to incorporation into the soil.
 - c. Food crops below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than four months prior to incorporation into the soil.
 - d. Animal grazing shall not be allowed for 30 days after application of biosolids.
 - e. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
 - f. Turf shall not be harvested for one year after application of biosolids if used for lawns or high public contact sites in close proximity to populated areas such as city parks or golf courses.
 - g. After Class B biosolids have been land applied to public contact sites with high potential for public exposure, as defined in 40 CFR § 503.31, such as city parks or golf courses, access must be restricted for 12 months.
 - h. After Class B biosolids have been land applied public contact sites with low potential for public exposure as defined in 40 CFR § 503.31, such as a rural land application or reclamation sites, access must be restricted for 30 days.
5. Pollutant limits
 - a. Biosolids shall be monitored to determine the quality for regulated pollutants listed in Table 1, below. Limits for any pollutants not listed below may be established in the permit.
 - b. The number of samples taken is directly related to the amount of biosolids or sludge produced by the facility (See Section J, below). Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to achieve pollutant concentration below those identified in Table 1, below.
 - c. Table 1 gives the ceiling concentration for biosolids. Biosolids which exceed the concentrations in Table 1 may not be land applied.

TABLE 1

| Biosolids ceiling concentration | |
|---------------------------------|------------------------------------|
| Pollutant | Milligrams per kilogram dry weight |
| Arsenic | 75 |
| Cadmium | 85 |
| Copper | 4,300 |
| Lead | 840 |
| Mercury | 57 |
| Molybdenum | 75 |
| Nickel | 420 |
| Selenium | 100 |
| Zinc | 7,500 |

- d. Table 2 below gives the low metal concentration for biosolids. Because of its higher quality, biosolids with pollutant concentrations below those listed in Table 2 can safely be applied to agricultural land, forest, public contact sites, lawns, home gardens or be given away without further analysis. Biosolids containing metals in concentrations above the low metals concentrations but below the ceiling concentration limits may be land applied but shall not exceed the annual loading rates in Table 3 and the cumulative loading rates in Table 4. The permittee is required to track pollutant loading onto application sites for parameters that have exceeded the low metal concentration limits.

TABLE 2

| Biosolids Low Metal Concentration | |
|-----------------------------------|------------------------------------|
| Pollutant | Milligrams per kilogram dry weight |
| Arsenic | 41 |
| Cadmium | 39 |
| Copper | 1,500 |
| Lead | 300 |
| Mercury | 17 |
| Nickel | 420 |
| Selenium | 100 |
| Zinc | 2,800 |

- e. Annual pollutant loading rate.

Table 3

| Biosolids Annual Loading Rate | |
|-------------------------------|--------------------------|
| Pollutant | Kg/ha (lbs./ac) per year |
| Arsenic | 2.0 (1.79) |
| Cadmium | 1.9 (1.70) |
| Copper | 75 (66.94) |
| Lead | 15 (13.39) |
| Mercury | 0.85 (0.76) |
| Nickel | 21 (18.74) |
| Selenium | 5.0 (4.46) |
| Zinc | 140 (124.96) |

- f. Cumulative pollutant loading rates.

Table 4

| Biosolids Cumulative Pollutant Loading Rate | |
|---|-----------------|
| Pollutant | Kg/ha (lbs./ac) |
| Arsenic | 41 (37) |
| Cadmium | 39 (35) |
| Copper | 1500 (1339) |
| Lead | 300 (268) |
| Mercury | 17 (15) |
| Nickel | 420 (375) |
| Selenium | 100 (89) |
| Zinc | 2800 (2499) |

6. Best Management Practices. The permittee shall use the following best management practices during land application activities to prevent the discharge of biosolids to waters of the state.
- Biosolids shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under § 4 of the Endangered Species Act or its designated critical habitat.
 - Apply biosolids only at the agronomic rate of nitrogen needed (see 5.c. of this section).
 - The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop

nitrogen removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.

- i. PAN can be determined as follows:
(Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹).
¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volatilization factors and mineralization rates can be utilized on a case-by-case basis.
- ii. Crop nutrient production/removal to be based on crop specific nitrogen needs and realistic yield goals. **NOTE:** There are a number of reference documents on the Missouri Department of Natural Resources website that are informative to implement best management practices in the proper management of biosolids, including crop specific nitrogen needs, realistic yields on a county by county basis and other supporting references.
- iii. Biosolids that are applied at agronomic rates shall not cause the annual pollutant loading rates identified in Table 3 to be exceeded.
- d. Buffer zones are as follows:
 - i. 300 feet of a water supply well, sinkhole, water supply reservoir or water supply intake in a stream;
 - ii. 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstanding state resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
 - iii. 150 feet of dwellings or public use areas;
 - iv. 100 feet (35 feet if biosolids application is down-gradient or the buffer zone is entirely vegetated) of lake, pond, wetlands or gaining streams (perennial or intermittent);
 - v. 50 feet of a property line. Buffer distances from property lines may be waived with written permission from neighboring property owner.
 - vi. For the application of dry, cake or liquid biosolids that are subsurface injected, buffer zones identified in 5.d.i. through 5.d.iii above, may be reduced to 100 feet. The buffer zone may be reduced to 35 feet if the buffer zone is permanently vegetated. Subsurface injection does not include methods or technology reflective of combination surface/shallow soil incorporation.
- e. Slope limitation for application sites are as follows:
 - i. For slopes less than or equal to 6 percent, no rate limitation;
 - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels;
 - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
 - iv. Dry, cake or liquid biosolids that are subsurface injected, may be applied on slopes not to exceed 20 percent. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation.
- f. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- g. Biosolids may be land applied to sites with soil that are snow covered, frozen, or saturated with liquid when site restrictions or other controls are provided to prevent pollutants from being discharged to waters of the state during snowmelt or stormwater runoff. During inclement weather or unfavorable soil conditions use the following management practices:
 - i. A maximum field slope of 6% and a minimum 300 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be utilized for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation;
 - ii. A maximum field slope of 2% and 100 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be used for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation;
 - iii. Other best management practices approved by the Department.

SECTION H – SEPTAGE

1. Haulers that land apply septage must obtain a state permit. An operating permit is not required for septage haulers who transport septage to another permitted treatment facility for disposal.
2. Do not apply more than 30,000 gallons of septage per acre per year or the volume otherwise stipulated in the operating permit.
3. Septic tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to mechanical treatment facilities.
4. Septage must comply with Class B biosolids regarding pathogen and vector attraction reduction requirements before it may be applied to crops, pastures or timberland. To meet required pathogen and vector reduction requirements, mix 50 pounds of hydrated lime for every 1,000 gallons of septage and maintain a septage pH of at least 12 pH standard units for 30 minutes or more prior to application.
5. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.
6. As residential septage contains relatively low levels of metals, the testing of metals in septage is not required.

SECTION I– CLOSURE REQUIREMENTS

1. This section applies to all wastewater facilities (mechanical and lagoons) and sludge or biosolids storage and treatment facilities. It does not apply to land application sites.
2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all sludges and/or biosolids. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20 – 6.010 and 10 CSR 20 – 6.015.
3. Biosolids or sludge that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
 - a. Biosolids and sludge shall meet the monitoring and land application limits for agricultural rates as referenced in Section G, above.
 - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
 - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre. Alternative, site-specific application rates may be included in the closure plan for department consideration.
 - i. PAN can be determined as follows:
$$(\text{Nitrate} + \text{nitrite nitrogen}) + (\text{organic nitrogen} \times 0.2) + (\text{ammonia nitrogen} \times \text{volatilization factor}^1).$$
¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volatilization factors and mineralization rates can be utilized on a case-by-case basis.
4. Domestic wastewater treatment lagoons with a design treatment capacity less than or equal to 150 persons, are “similar treatment works” under the definition of septage. Therefore the sludge within the lagoons may be treated as septage during closure activities. See Section B, above. Under the septage category, residuals may be left in place as follows:
 - a. Testing for metals or fecal coliform is not required.
 - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
 - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
5. Biosolids or sludge left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, and unless otherwise approved, the lagoon berm shall be demolished, and the site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion. Alternative biosolids or sludge and soil mixing ratios may be included in the closure plan for department consideration.
6. Lagoon and earthen structure closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200.
7. When closing a mechanical wastewater plant, all biosolids or sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
 - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to stormwater per 10 CSR 20-6.200. The site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate

- surface water drainage without creating erosion.
- b. Hazardous Waste shall not be land applied or disposed during mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations pursuant to 10 CSR 25.
 - c. After demolition of the mechanical plant, the site must only contain clean fill defined in Section 260.200.1(6) RSMo as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill, reclamation, or other beneficial use. Other solid wastes must be removed.
8. If biosolids or sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or I, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for on-site sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR Part 503, Subpart C.

SECTION J – MONITORING FREQUENCY

1. At a minimum, biosolids or sludge shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

TABLE 5

| Biosolids or Sludge produced and disposed (Dry Tons per Year) | Monitoring Frequency (See Notes 1, and 2) | | |
|---|--|---|----------------------------------|
| | Metals, Pathogens and Vectors, Total Phosphorus, Total Potassium | Nitrogen TKN, Nitrogen PAN ¹ | Priority Pollutants ² |
| 319 or less | 1/year | 1 per month | 1/year |
| 320 to 1650 | 4/year | 1 per month | 1/year |
| 1651 to 16,500 | 6/year | 1 per month | 1/year |
| 16,501+ | 12/year | 1 per month | 1/year |

¹ Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

² Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) are required only for permit holders that must have a pre-treatment program. Monitoring requirements may be modified and incorporated into the operating permit by the Department on a case-by-case basis.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

2. Permittees that operate wastewater treatment lagoons, peak flow equalization basins, combined sewer overflow basins or biosolids or sludge lagoons that are cleaned out once a year or less, may choose to sample only when the biosolids or sludge is removed or the lagoon is closed. Test one composite sample for each 319 dry tons of biosolids or sludge removed from the lagoon during the reporting year or during lagoon closure. Composite sample must represent various areas at one-foot depth.
3. Additional testing may be required in the special conditions or other sections of the permit.
4. Biosolids and sludge monitoring shall be conducted in accordance with federal regulation 40 CFR § 503.8, Sampling and analysis.

SECTION K – RECORD KEEPING AND REPORTING REQUIREMENTS

1. The permittee shall maintain records on file at the facility for at least five years for the items listed in Standard Conditions PART III and any additional items in the Special Conditions section of this permit. This shall include dates when the biosolids or sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
2. Reporting period
 - a. By February 19th of each year, applicable facilities shall submit an annual report for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and biosolids or sludge disposal facilities.
 - b. Permittees with wastewater treatment lagoons shall submit the above annual report only when biosolids or sludge are removed from the lagoon during the report period or when the lagoon is closed.
3. Report Form. The annual report shall be prepared on report forms provided by the Department or equivalent forms approved by the Department.
4. Reports shall be submitted as follows:
Major facilities, which are those serving 10,000 persons or more or with a design flow equal to or greater than 1 million gallons per day or that are required to have an approved pretreatment program, shall report to both the Department and EPA if the facility land applied, disposed of biosolids by surface disposal, or operated a sewage sludge incinerator. All other facilities shall maintain their biosolids or sludge records and keep them available to Department personnel upon request. State reports shall be submitted to the address listed as follows:

DNR regional or other applicable office listed in the
permit (see cover letter of permit)
ATTN: Sludge Coordinator

Reports to EPA must be electronically submitted online via the Central Data Exchange at: <https://cdx.epa.gov/> Additional information is available at: <https://www.epa.gov/biosolids/compliance-and-annual-reporting-guidance-about-clean-water-act-laws>

5. Annual report contents. The annual report shall include the following:
 - a. Biosolids and sludge testing performed. If testing was conducted at a greater frequency than what is required by the permit, all test results must be included in the report.
 - b. Biosolids or sludge quantity shall be reported as dry tons for the quantity produced and/or disposed.
 - c. Gallons and % solids data used to calculate the dry ton amounts.
 - d. Description of any unusual operating conditions.
 - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
 - i. This must include the name and address for the hauler and sludge facility. If hauled to a municipal wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that facility.
 - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.
 - f. Contract Hauler Activities:

If using a contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate biosolids or sludge use permit.
 - g. Land Application Sites:
 - i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as a legal description for nearest ¼, ¼, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
 - ii. If the “Low Metals” criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
 - iii. Report the method used for compliance with pathogen and vector attraction requirements.
 - iv. Report soil test results for pH and phosphorus. If no soil was tested during the year, report the last date when tested and the results.

RECEIVED

MAY 23 2016



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH

Water Protection Program

**FORM B2 – APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE
PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS
PER DAY**

| | |
|--|--------------------------|
| FACILITY NAME <i>Kansas City, Blue River Wastewater Treatment Facility</i> | |
| PERMIT NO. <i>MO-0024911</i> | COUNTY <i>Jackson</i> |
| APPLICATION OVERVIEW | |
| <p>Form B2 has been developed in a modular format and consists of Parts A, B and C and a Supplemental Application Information (Parts D, E, F and G) packet. All applicants must complete Parts A, B and C. Some applicants must also complete parts of the Supplemental Application Information packet. The following items explain which parts of Form B2 you must complete. Submittal of an incomplete application may result in the application being returned.</p> | |
| BASIC APPLICATION INFORMATION | |
| <p>A. Basic Application Information for all Applicants. All applicants must complete Part A. B. Additional Application Information for all Applicants. All applicants must complete Part B. C. Certification. All applicants must complete Part C.</p> | |
| SUPPLEMENTAL APPLICATION INFORMATION | |
| <p>D. Expanded Effluent Testing Data. A treatment works that discharges effluent to surface water of the United States and meets one or more of the following criteria must complete <i>Part D - Expanded Effluent Testing Data</i>:</p> <ol style="list-style-type: none"> Has a design flow rate greater than or equal to 1 million gallons per day. Is required to have or currently has a pretreatment program. Is otherwise required by the permitting authority to provide the information. <p>E. Toxicity Testing Data. A treatment works that meets one or more of the following criteria must complete <i>Part E - Toxicity Testing Data</i>:</p> <ol style="list-style-type: none"> Has a design flow rate greater than or equal to 1 million gallons per day. Is required to have or currently has a pretreatment program. Is otherwise required by the permitting authority to provide the information. <p>F. Industrial User Discharges and Resource Conservation and Recovery Act / Comprehensive Environmental Response, Compensation and Liability Act Wastes. A treatment works that accepts process wastewater from any significant industrial users, also known as SIUs, or receives a Resource Conservation and Recovery Act or CERCLA wastes must complete <i>Part F - Industrial User Discharges and Resource Conservation and Recovery Act /CERCLA Wastes</i>.</p> <p>SIUs are defined as:</p> <ol style="list-style-type: none"> All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N. Any other industrial user that meets one or more of the following: <ol style="list-style-type: none"> Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions). Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant. Is designated as an SIU by the control authority. Is otherwise required by the permitting authority to provide the information. <p>G. Combined Sewer Systems. A treatment works that has a combined sewer system must complete <i>Part G - Combined Sewer Systems</i>.</p> | |
| ALL APPLICANTS MUST COMPLETE PARTS A, B and C | |

RECEIVED

MAY 23 2016

Water Protection Program



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH
**FORM B2 – APPLICATION FOR AN OPERATING PERMIT FOR
FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND
HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY**

FOR AGENCY USE ONLY

CHECK NUMBER

DATE
RECEIVED
5/23/16

FEE SUBMITTED

PART A – BASIC APPLICATION INFORMATION**1. THIS APPLICATION IS FOR:**

- ☐ An operating permit for a new or unpermitted facility. Construction Permit # _____
(Please include completed Antidegradation Review or request to conduct an Antidegradation Review, see instructions)
- ☒ An operating permit renewal: Permit #MO-0024911 Expiration Date 11/15/2016
- ☐ An operating permit modification: Permit #MO-_____ Reason: _____

1.1 Is the appropriate fee included with the application (see instructions for appropriate fee)? ☒ YES ☐ NO

2. FACILITY

NAME *Kansas City, Blue River Wastewater Treatment Facility* TELEPHONE NUMBER WITH AREA CODE *816-513-7200*

ADDRESS (PHYSICAL) *7300 Hawthorne Road* CITY *Kansas City* STATE *MO* ZIP *64120*

2.1 **LEGAL DESCRIPTION** (Facility Site): *NW 1/4, NW 1/4, 1/4, Sec. 25, T 50N, R 32 W* COUNTY *Jackson*

2.2 UTM Coordinates Easting (X): *2789959.74* Northing (Y): *1075248.48*
For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

2.3 Name of receiving stream: *Missouri River and tributary to Missouri River*

2.4 Number of Outfalls: *1* wastewater outfalls, *3* stormwater outfalls, *0* instream monitoring sites

3. OWNER

NAME *City of Kansas City MO* E-MAIL ADDRESS *N/A* TELEPHONE NUMBER WITH AREA CODE *816-513-7200*

ADDRESS *414 East 12th Street* CITY *Kansas City* STATE *MO* ZIP *64130*

3.1 Request review of draft permit prior to Public Notice? ☒ YES ☐ NO

3.2 Are you a Publically Owned Treatment Works (POTW)? ☒ YES ☐ NO

3.3 Are you a Privately Owned Treatment Facility? ☐ YES ☒ NO

3.4 Are you a Privately Owned Treatment Facility regulated by the Public Service Commission (PSC)? ☐ YES ☒ NO

4. CONTINUING AUTHORITY: Permanent organization which will serve as the continuing authority for the operation, maintenance and modernization of the facility.

NAME *KCMO Water Services* EMAIL ADDRESS *N/A* TELEPHONE WITH AREA CODE *816-513-0504*

ADDRESS *4800 East 63rd Street* CITY *Kansas City* STATE *MO* ZIP *64130*

If the Continuing Authority is different than the Owner, please include a copy of the contract agreement between the two parties and a description of the responsibilities of both parties within the agreement.

5. OPERATOR

NAME *Hans B Newsom* TITLE *Utility Superintendent* CERTIFICATE NUMBER (IF APPLICABLE) *6075*

E-MAIL ADDRESS *hans.newsom@kcmo.org* TELEPHONE NUMBER WITH AREA CODE *(816) 513-7225*

6. FACILITY CONTACT

NAME *Hans B. Newsom* TITLE *Utility Superintendent*

E-MAIL ADDRESS *hans.newsom@kcmo.org* TELEPHONE NUMBER WITH AREA CODE *(816) 513-7225*

ADDRESS *7300 Hawthorne Road* CITY *Kansas City* STATE *MO* ZIP CODE *64120*

| | | |
|--|---------------------------|--------------------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 |
|--|---------------------------|--------------------|


PART A – BASIC APPLICATION INFORMATION

7. FACILITY INFORMATION


7.1 Process Flow Diagram or Schematic. Provide a diagram showing the processes of the treatment plant. Show all of the treatment units, including disinfection (e.g. – Chlorination and Dechlorination), influents, and outfalls. Indicate any treatment process changes in the routing of wastewater during dry weather and peak wet weather. Include a brief narrative description of the diagram. Attach sheets as necessary.

1. Preliminary Treatment: rock box, coarse and fine barscreens, hydrocyclone grit removal and aerated grit chambers
2. Primary Treatment: gravity clarifiers
3. Secondary Treatment: high rate trickling filter and gravity clarifiers
4. Sodium hypochlorite Disinfection
5. Sodium Bisulfite Dechlorination
6. All sludge from the Blue River WWTP, Westside WWTP (MO-0024929), and Birmingham WWTP (MO-0049531) is dewatered as needed and fed to a sludge holding tank.
6. A portion of the sludge is dewatered and incinerated. Ash is accumulated in ash lagoon.
7. Another portion of the sludge is anaerobically (mesophilic) digested.
8. Remaining Sludge is dewatered and landfilled.
9. Digested sludge is pumped to Birmingham Land Application Facility (MO-0049531) for land application

See attached page with flow diagram for Blue River WWTP



| | | |
|---|---|--|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO-0024911 | OUTFALL NO. 001 |
| PART A – BASIC APPLICATION INFORMATION | | |
| 7. FACILITY INFORMATION (continued) | | |
| <p>7.2 Topographic Map. Attach to this application a topographic map of the area extending at least one mile beyond facility property boundaries. This map must show the outline of the facility and the following information.</p> <ul style="list-style-type: none"> a. The area surrounding the treatment plant, including all unit processes. b. The location of the downstream landowner(s). (See Item 10.) c. The major pipes or other structures through which wastewater enters the treatment works and the pipes or other structures through which treated wastewater is discharged from the treatment plant. Include outfalls from bypass piping, if applicable. d. The actual point of discharge. e. Wells, springs, other surface water bodies and drinking water wells that are: 1) within ¼ mile of the property boundaries of the treatment works, and 2) listed in public record or otherwise known to the applicant. f. Any areas where the sewage sludge produced by the treatment works is stored, treated, or disposed. g. If the treatment works receives waste that is classified as hazardous under the Resource Conservation and Recovery Act (RCRA) by truck, rail, or special pipe, show on the map where that hazardous waste enters the treatment works and where it is treated, stored, or disposed. | | |
| 7.3 Facility SIC Code: 4952 | Discharge SIC Code: 4952 | |
| 7.4 Number of people presently connected or population equivalent (P.E.): 750,000 Design P.E. 850,000 | | |
| <p>7.5 Connections to the facility:</p> <p>Number of units presently connected:</p> <p>Homes 100,000 Trailers 5,000 Apartments 10,000 Other (including industrial) _____</p> <p>Number of Commercial Establishments: _____</p> | | |
| 7.6 Design Flow 105 MGD | Actual Flow 70.5 MGD | |
| <p>7.7 Will discharge be continuous through the year? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Discharge will occur during the following months: How many days of the week will discharge occur?</p> <p style="text-align: center;">Will occur during all months and 7 days a week</p> | | |
| <p>7.8 Is industrial waste discharged to the facility? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>If yes, please describe the number and types of industries that discharge to your facility.</p> <p><i>Forty-two (42) industries discharge to the facility: twelve (12) metal finishers, two (2) commercial laundries, one (1) meat processing plant, one (1) lawn mower blade manufacturer, two (2) soybean processors, three (3) pharmaceutical manufacturers, seven (7) hospitals/medical centers, four (4) hazardous/non-hazardous treatment, storage, and disposal facilities, two (2) packaging manufacturers, two (2) railroad facilities, one (1) lab equipment manufacturer, one (1) electrical equipment manufacturer, two (2) medical research facilities, one (1) beverage manufacturer, and one (1) food processing equipment manufacturer. In addition, one (1) sanitary landfill discharges leachate to the wastewater treatment facility.</i></p> <p>Refer to the APPLICATION OVERVIEW to determine whether additional information is needed for Part F.</p> | | |
| 7.9 Does the facility accept or process leachate from landfills? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> | | |
| 7.10 Is wastewater land applied? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | | |
| If yes, is Form I attached? Yes <input type="checkbox"/> No <input type="checkbox"/> | | |
| 7.11 Does the facility discharge to a losing stream or sinkhole? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | | |
| 7.12 Has a wasteload allocation study been completed for this facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | | |
| 8. LABORATORY CONTROL INFORMATION | | |
| LABORATORY WORK CONDUCTED BY PLANT PERSONNEL | | |
| Lab work conducted outside of plant. | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> |
| Push-button or visual methods for simple test such as pH, settleable solids. | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> |
| Additional procedures such as Dissolved Oxygen, Chemical Oxygen Demand, Biological Oxygen Demand, titrations, solids, volatile content. | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> |
| More advanced determinations such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc. | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> |
| Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph. | Yes <input type="checkbox"/> | No <input checked="" type="checkbox"/> |



UP RR

HAWTH

PLANT

ADDITIONAL

ESTATE OF

THOMAS WEST

LOT 4

X=2789959.74 Y=1075247.48


0

71b1

600





OUTFALL #001



| | | | | | |
|---|--|---|---|----------------------------------|--------------------------|
| FACILITY NAME <i>KC Blue River Wastewater Treatment Facility</i> | | PERMIT NO. <i>MO- 0024911</i> | | OUTFALL NO. <i>001</i> | |
| PART A – BASIC APPLICATION INFORMATION | | | | | |
| 9. SLUDGE HANDLING, USE AND DISPOSAL | | | | | |
| 9.1 Is the sludge a hazardous waste as defined by 10 CSR 25? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | | | | | |
| 9.2 Sludge production (Including sludge received from others): Design Dry Tons/Year <i>56,479</i> Actual Dry Tons/Year | | | | | |
| 9.3 Sludge storage provided: <i>350,000</i> Cubic feet; <i>9</i> Days of storage; <i>3.6</i> Average percent solids of sludge; <input type="checkbox"/> No sludge storage is provided. <input type="checkbox"/> Sludge is stored in lagoon. | | | | | |
| 9.4 Type of storage: <div style="display: inline-block; width: 45%; vertical-align: top;"> <input checked="" type="checkbox"/> Holding Tank <input type="checkbox"/> Basin <input type="checkbox"/> Concrete Pad </div> <div style="display: inline-block; width: 45%; vertical-align: top;"> <input type="checkbox"/> Building <input type="checkbox"/> Lagoon <input checked="" type="checkbox"/> Other (Please describe) <i>Stabilize sludge lagoons</i> </div> | | | | | |
| 9.5 Sludge Treatment: <div style="display: flex; justify-content: space-between;"> <div> <input checked="" type="checkbox"/> Anaerobic Digester <input type="checkbox"/> Storage Tank <input type="checkbox"/> Aerobic Digester <input type="checkbox"/> Air or Heat Drying </div> <div> <input type="checkbox"/> Lime Stabilization <input type="checkbox"/> Composting </div> <div> <input checked="" type="checkbox"/> Lagoon <input type="checkbox"/> Other (Attach Description) </div> </div> | | | | | |
| 9.6 Sludge use or disposal: <div style="display: flex; justify-content: space-between;"> <div> <input checked="" type="checkbox"/> Land Application <input type="checkbox"/> Contract Hauler <input type="checkbox"/> Hauled to Another Treatment Facility <input type="checkbox"/> Surface Disposal (Sludge Disposal Lagoon, Sludge Held For More Than Two Years) <input type="checkbox"/> Other (Attach Explanation Sheet) _____ </div> <div> <input checked="" type="checkbox"/> Solid Waste Landfill <input checked="" type="checkbox"/> Incineration </div> </div> | | | | | |
| 9.7 Person responsible for hauling sludge to disposal facility: <input checked="" type="checkbox"/> By Applicant <input type="checkbox"/> By Others (complete below) | | | | | |
| NAME <i>City of Kansas City, MO</i> | | | E-MAIL ADDRESS <i>hans.newsom@kcmo.org</i> | | |
| ADDRESS <i>7300 Hawthorne Road</i> | | CITY <i>Kansas City</i> | | STATE <i>MO</i> | ZIP CODE <i>64120</i> |
| CONTACT PERSON <i>Hans B. Newsom</i> | | TELEPHONE WITH AREA CODE <i>(816) 513-7225</i> | | PERMIT NO. <i>MO- 0024911</i> | |
| 9.8 Sludge use or disposal facility: <input checked="" type="checkbox"/> By Applicant <input type="checkbox"/> By Others (Please complete below) | | | | | |
| NAME <i>Birmingham WWTP Land Application Facility</i> | | | E-MAIL ADDRESS <i>timothy.walters@kcmo.org</i> | | |
| ADDRESS <i>10801 NE 28th St</i> | | CITY <i>Kansas City</i> | | STATE <i>MO</i> | ZIP CODE <i>64161</i> |
| CONTACT PERSON <i>Timothy Walters</i> | | TELEPHONE WITH AREA CODE <i>(816) 719-0469</i> | | PERMIT NO. <i>MO- 0049531</i> | |
| 9.9 Does the sludge or biosolids disposal comply with Federal Sludge Regulation 40 CFR 503? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (Please explain) | | | | | |
| END OF PART A | | | | | |

| | | | | |
|---|--|---------------------------|---|--|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 | | |
| PART B – ADDITIONAL APPLICATION INFORMATION | | | | |
| 10. COLLECTION SYSTEM | | | | |
| 10.1 Length of sanitary sewer collection system in miles <u>888 miles (Separate) 851 miles (Combined)</u> | | | | |
| 10.2 Does significant infiltration occur in the collection system? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If yes, briefly explain any steps underway or planned to minimize inflow and infiltration: <i>See 13 for projects that will decrease the amount of infiltration in the collection system. Additional ongoing efforts include: sewer cleaning, CCTV investigation, Cast-in-Place-Pipe relining, rehabilitation of manholes</i> | | | | |
| 11. BYPASSING | | | | |
| Does any bypassing occur anywhere in the collection system or at the treatment facility? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> If yes, explain: <i>Bypassing can occur in the combined sewer portion of the service area if the sewer system is overwhelmed by storm events</i> | | | | |
| 12. OPERATION AND MAINTENANCE PERFORMED BY CONTRACTOR(S) | | | | |
| Are any operational or maintenance aspects (related to wastewater treatment and effluent quality) of the treatment works the responsibility of the contractor? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If Yes, list the name, address, telephone number and status of each contractor and describe the contractor's responsibilities. (Attach additional pages if necessary.) | | | | |
| NAME | | | | |
| MAILING ADDRESS | | | | |
| TELEPHONE NUMBER WITH AREA CODE | EMAIL ADDRESS | | | |
| RESPONSIBILITIES OF CONTRACTOR | | | | |
| 13. SCHEDULED IMPROVEMENTS AND SCHEDULES OF IMPLEMENTATION | | | | |
| Provide information about any uncompleted implementation schedule or uncompleted plans for improvements that will affect the wastewater treatment, effluent quality, or design capacity of the treatment works. If the treatment works has several different implementation schedules or is planning several improvements, submit separate responses for each. | | | | |
| <table style="width: 100%;"> <tr> <td style="vertical-align: top; width: 50%;"> Current Projects (Planned Completion): <i>I/I Reduction: Blue River Central- Project 1 (2017)</i> <i>I/I Reduction: Blue River Central- Project 2 (2017)</i> <i>I/I Reduction: Blue River North- Project 1 (2018)</i> <i>I/I Reduction: Blue River South- Projects 1 & 2 (2017)</i> <i>I/I Reduction: Blue River South- Project 3 (2017)</i> <i>I/I Reduction: Blue River South- Project 4 (2019)</i> <i>I/I Reduction: Blue River South- Project 5 (2018)</i> <i>Sewer Separation: Outfall 067 (2019)</i> <i>Sewer Separation: Outfall 099 (2018)</i> <i>Sewer Pipe Consolidation: Outfall 063 (2018)</i> <i>NEID Sewer Separation DS 006 (2017)</i> </td> <td style="vertical-align: top; width: 50%;"> Future Projects (Start Date): <i>I/I Reduction: Round Grove Creek (2017)</i> <i>I/I Reduction: Little Blue River- Projects 1 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 2 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 3 (2018)</i> <i>Small Sewer Rehabilitation: Lower Blue River (2018)</i> </td> </tr> </table> | | | Current Projects (Planned Completion): <i>I/I Reduction: Blue River Central- Project 1 (2017)</i> <i>I/I Reduction: Blue River Central- Project 2 (2017)</i> <i>I/I Reduction: Blue River North- Project 1 (2018)</i> <i>I/I Reduction: Blue River South- Projects 1 & 2 (2017)</i> <i>I/I Reduction: Blue River South- Project 3 (2017)</i> <i>I/I Reduction: Blue River South- Project 4 (2019)</i> <i>I/I Reduction: Blue River South- Project 5 (2018)</i> <i>Sewer Separation: Outfall 067 (2019)</i> <i>Sewer Separation: Outfall 099 (2018)</i> <i>Sewer Pipe Consolidation: Outfall 063 (2018)</i> <i>NEID Sewer Separation DS 006 (2017)</i> | Future Projects (Start Date): <i>I/I Reduction: Round Grove Creek (2017)</i> <i>I/I Reduction: Little Blue River- Projects 1 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 2 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 3 (2018)</i> <i>Small Sewer Rehabilitation: Lower Blue River (2018)</i> |
| Current Projects (Planned Completion): <i>I/I Reduction: Blue River Central- Project 1 (2017)</i> <i>I/I Reduction: Blue River Central- Project 2 (2017)</i> <i>I/I Reduction: Blue River North- Project 1 (2018)</i> <i>I/I Reduction: Blue River South- Projects 1 & 2 (2017)</i> <i>I/I Reduction: Blue River South- Project 3 (2017)</i> <i>I/I Reduction: Blue River South- Project 4 (2019)</i> <i>I/I Reduction: Blue River South- Project 5 (2018)</i> <i>Sewer Separation: Outfall 067 (2019)</i> <i>Sewer Separation: Outfall 099 (2018)</i> <i>Sewer Pipe Consolidation: Outfall 063 (2018)</i> <i>NEID Sewer Separation DS 006 (2017)</i> | Future Projects (Start Date): <i>I/I Reduction: Round Grove Creek (2017)</i> <i>I/I Reduction: Little Blue River- Projects 1 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 2 (2018)</i> <i>I/I Reduction: Little Blue River- Projects 3 (2018)</i> <i>Small Sewer Rehabilitation: Lower Blue River (2018)</i> | | | |

| | | | | | | | | |
|---|-------------------------|---------------------------|-------------------------|--------------------|-------------------|-------------------|---------|---|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | | PERMIT NO. MO- 0024911 | | OUTFALL NO. 001 | | | | |
| PART B – ADDITIONAL APPLICATION INFORMATION | | | | | | | | |
| 14. EFFLUENT TESTING DATA | | | | | | | | |
| Applicants must provide effluent testing data for the following parameters. Provide the indicated effluent data for each outfall through which effluent is discharged . Do not include information of combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than four and one-half years apart. | | | | | | | | |
| Outfall Number | | | | | | | | |
| PARAMETER | MAXIMUM DAILY VALUE | | AVERAGE DAILY VALUE | | | | | |
| | Value | Units | Value | Units | Number of Samples | | | |
| pH (Minimum) | 6.5 | S.U. | — | S.U. | 360 | | | |
| pH (Maximum) | 8.7 | S.U. | — | S.U. | 360 | | | |
| Flow Rate | 159.2 | MGD | 70.5 | MGD | 365 | | | |
| *For pH report a minimum and a maximum daily value | | | | | | | | |
| POLLUTANT | MAXIMUM DAILY DISCHARGE | | AVERAGE DAILY DISCHARGE | | | ANALYTICAL METHOD | ML/MDL | |
| | Conc. | Units | Conc. | Units | Number of Samples | | | |
| Conventional and Nonconventional Compounds | | | | | | | | |
| BIOCHEMICAL OXYGEN DEMAND (Report One) | BOD ₅ | 158 | mg/L | 33.0 | mg/L | 257 | SM5210B | 2 |
| | CBOD ₅ | — | mg/L | — | mg/L | — | — | — |
| E. COLI | 435,200 | #/100 mL | 17.8 | #/100 mL | 154 | SM9223A.B | 10 | |
| TOTAL SUSPENDED SOLIDS (TSS) | 120 | mg/L | 39.5 | mg/L | 258 | SM2540 | 1 | |
| AMMONIA (as N) | 38 | mg/L | 16.1 | mg/L | 261 | SM4500 - NH3C | 0.13 | |
| CHLORINE* (TOTAL RESIDUAL, TRC) | 0.1 | mg/L | 0.004 | mg/L | 31 | SM4500 - CIG | 0.1 | |
| DISSOLVED OXYGEN | 10.0 | mg/L | 7.7 | mg/L | 360 | | | |
| OIL and GREASE | 5.5 | mg/L | 3.5 | mg/L | 12 | SM5520B | 1.4 | |
| OTHER | | mg/L | | mg/L | | | | |
| *Report only if facility chlorinates | | | | | | | | |
| END OF PART B | | | | | | | | |

| | | |
|--|---|--------------------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 |
| PART C – CERTIFICATION | | |
| 15. CERTIFICATION | | |
| <p>All applicants must complete the Certification Section. This certification must be signed by an officer of the company or city official. All applicants must complete all applicable sections as explained in the Application Overview. By signing this certification statement, applicants confirm that they have reviewed the entire form and have completed all sections that apply to the facility for which this application is submitted.</p> | | |
| ALL APPLICANTS MUST COMPLETE THE FOLLOWING CERTIFICATION. | | |
| <p>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</p> | | |
| PRINTED NAME Terry Leeds | OFFICIAL TITLE (MUST BE AN OFFICER OF THE COMPANY OR CITY OFFICIAL) Water Services Department Director | |
| SIGNATURE  |  | |
| TELEPHONE NUMBER WITH AREA CODE 816-513-0504 | | |
| DATE SIGNED 5/16/16 | | |
| <p>Upon request of the permitting authority, you must submit any other information necessary to assess wastewater treatment practices at the treatment works or identify appropriate permitting requirements.</p> | | |
| <p>Send Completed Form to:</p> <p style="text-align: center;">Department of Natural Resources Water Protection Program ATTN: NPDES Permits and Engineering Section P.O. Box 176 Jefferson City, MO 65102</p> | | |
| END OF PART C | | |
| REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH PARTS OF FORM B2 YOU MUST COMPLETE. | | |
| <p>Do not complete the remainder of this application, unless at least one of the following statements applies to your facility:</p> <ol style="list-style-type: none"> 1. Your facility design flow is equal to or greater than 1,000,000 gallons per day. 2. Your facility is a pretreatment treatment works. 3. Your facility is a combined sewer system. | | |
| <p>Submittal of an incomplete application may result in the application being returned. Permit fees for returned applications shall be forfeited. Permit fees for applications being processed by the department that are withdrawn by the applicant shall be forfeited.</p> | | |

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL

| | | |
|---|----------------------------------|---------------------------|
| FACILITY NAME <i>KC Blue River Wastewater Treatment Facility</i> | PERMIT NO. <i>MO- 0024911</i> | OUTFALL NO. <i>001</i> |
|---|----------------------------------|---------------------------|

PART D – EXPANDED EFFLUENT TESTING DATA
16. EXPANDED EFFLUENT TESTING DATA

Refer to the APPLICATION OVERVIEW to determine whether Part D applies to the treatment works.

If the treatment works has a design flow greater than or equal to 1 million gallons per day or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information **for each outfall through which effluent is discharged**. Do not include information of combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. Indicate in the blank rows provided below any data you may have on pollutants not specifically listed in this form. At a minimum, effluent testing data must be based on at least **three pollutant scans** and must be no more than four and one-half years apart.

Outfall Number (Complete Once for Each Outfall Discharging Effluent to Waters of the State.)

| POLLUTANT | MAXIMUM DAILY DISCHARGE | | | | AVERAGE DAILY DISCHARGE | | | | | ANALYTICAL METHOD | ML/MDL |
|---|-------------------------|-------|------|-------|-------------------------|-------|------|-------|----------------|-------------------|--------|
| | Conc. | Units | Mass | Units | Conc. | Units | Mass | Units | No. of Samples | | |
| METALS (TOTAL RECOVERABLE), CYANIDE, PHENOLS AND HARDNESS | | | | | | | | | | | |
| ANTIMONY | 0.7 | ug/L | | | 0.63 | ug/L | | | 4 | EPA 200.8 | 0.029 |
| ARSENIC | 1.73 | ug/L | | | 1.34 | ug/L | | | 4 | EPA 200.8 | 0.085 |
| BERYLLIUM | <0.04 | ug/L | | | <0.04 | ug/L | | | 4 | EPA 200.7 | 0.04 |
| CADMIUM | <0.11 | ug/L | | | <0.11 | ug/L | | | 4 | EPA 200.7 | 0.11 |
| CHROMIUM III | — | ug/L | | | — | ug/L | | | — | — | — |
| CHROMIUM VI | <9.8 | ug/L | | | <9.8 | ug/L | | | 4 | SM3500CrB | 9.8 |
| COPPER | 6.0 | ug/L | | | 4.5 | ug/L | | | 4 | EPA 200.7 | 0.26 |
| LEAD | 3.85 | ug/L | | | 2.23 | ug/L | | | 4 | EPA 200.8 | 0.013 |
| MERCURY | 0.2 | ug/L | | | 0.07 | ug/L | | | 4 | EPA 245.1 | 0.084 |
| NICKEL | 4.0 | ug/L | | | 3.0 | ug/L | | | 4 | EPA 200.7 | 0.4 |
| SELENIUM | 2.7 | ug/L | | | 2.3 | ug/L | | | 4 | EPA 200.8 | 0.068 |
| SILVER | <0.74 | ug/L | | | <0.74 | ug/L | | | 4 | EPA 200.7 | 0.74 |
| THALLIUM | <0.028 | ug/L | | | <0.028 | ug/L | | | 4 | EPA 200.8 | 0.028 |
| ZINC | 45 | ug/L | | | 39 | ug/L | | | 4 | EPA 200.7 | 0.16 |
| CYANIDE | 45 | ug/L | | | 9.6 | ug/L | | | 12 | SM4500CNE | 5 |
| TOTAL PHENOLIC COMPOUNDS | 0.188 | mg/L | | | 0.048 | mg/L | | | 4 | SM5530 C | 0.002 |
| HARDNESS (as CaCO ₃) | | | | | | | | | | | |
| VOLATILE ORGANIC COMPOUNDS | | | | | | | | | | | |
| ACROLEIN | <1.98 | ug/L | | | <1.98 | ug/L | | | 3 | EPA 624 | 1.98 |
| ACRYLONITRILE | <1.49 | ug/L | | | <1.49 | ug/L | | | 3 | EPA 624 | 1.49 |
| BENZENE | <0.5 | ug/L | | | <0.5 | ug/L | | | 3 | EPA 624 | 0.5 |
| BROMOFORM | <1.04 | ug/L | | | <1.04 | ug/L | | | 3 | EPA 624 | 1.04 |
| CARBON TETRACHLORIDE | <1.03 | ug/L | | | <1.03 | ug/L | | | 3 | EPA 624 | 1.03 |
| CHLOROBENZENE | <1.49 | ug/L | | | <1.49 | ug/L | | | 3 | EPA 624 | 1.49 |

| | | |
|--|---------------------------|--------------------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 |
|--|---------------------------|--------------------|

PART D – EXPANDED EFFLUENT TESTING DATA

16. EXPANDED EFFLUENT TESTING DATA

Complete Once for Each Outfall Discharging Effluent to Waters of the State

| POLLUTANT | MAXIMUM DAILY DISCHARGE | | | | AVERAGE DAILY DISCHARGE | | | | | ANALYTICAL METHOD | ML/MDL |
|----------------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|----------------|-------------------|--------|
| | Conc. | Units | Mass | Units | Conc. | Units | Mass | Units | No. of Samples | | |
| CHLORODIBROMO-METHANE | <0.51 | ug/L | | | <0.51 | ug/L | | | 3 | EPA 624 | 0.51 |
| CHLOROETHANE | <0.68 | ug/L | | | <0.68 | ug/L | | | 3 | EPA 624 | 0.68 |
| 2-CHLORO-ETHYL VINYL ETHER | <0.5 | ug/L | | | <0.5 | ug/L | | | 3 | EPA 624 | 0.5 |
| CHLOROFORM | 2.2 | ug/L | | | 1.5 | ug/L | | | 3 | EPA 624 | 1.3 |
| DICHLOROBROMO-METHANE | <1.35 | ug/L | | | <1.35 | ug/L | | | 3 | EPA 624 | 1.35 |
| 1,1-DICHLORO-ETHANE | <0.59 | ug/L | | | <0.59 | ug/L | | | 3 | EPA 624 | 0.59 |
| 1,2-DICHLORO-ETHANE | <1.52 | ug/L | | | <1.52 | ug/L | | | 3 | EPA 624 | 1.52 |
| TRANS-1,2-DICHLOROETHYLENE | <1.43 | ug/L | | | <1.43 | ug/L | | | 3 | EPA 624 | 1.43 |
| 1,1-DICHLORO-ETHYLENE | <1.26 | ug/L | | | <1.26 | ug/L | | | 3 | EPA 624 | 1.26 |
| 1,2-DICHLORO-PROPANE | <0.51 | ug/L | | | <0.51 | ug/L | | | 3 | EPA 624 | 0.51 |
| 1,3-DICHLORO-PROPYLENE | <1.31 | ug/L | | | <1.31 | ug/L | | | 3 | EPA 624 | 1.31 |
| ETHYLBENZENE | <1.37 | ug/L | | | <1.37 | ug/L | | | 3 | EPA 624 | 1.37 |
| METHYL BROMIDE | <0.54 | ug/L | | | <0.54 | ug/L | | | 3 | EPA 624 | 0.54 |
| METHYL CHLORIDE | <0.61 | ug/L | | | <0.61 | ug/L | | | 3 | EPA 624 | 0.61 |
| METHYLENE CHLORIDE | <1.32 | ug/L | | | <1.32 | ug/L | | | 3 | EPA 624 | 1.32 |
| 1,1,2,2-TETRA-CHLOROETHANE | <0.87 | ug/L | | | <0.87 | ug/L | | | 3 | EPA 624 | 0.87 |
| TETRACHLORO-ETHANE | <1.38 | ug/L | | | <1.38 | ug/L | | | 3 | EPA 624 | 1.38 |
| TOLUENE | <1.34 | ug/L | | | <1.34 | ug/L | | | 3 | EPA 624 | 1.34 |
| 1,1,1-TRICHLORO-ETHANE | <1.2 | ug/L | | | <1.2 | ug/L | | | 3 | EPA 624 | 1.2 |
| 1,1,2-TRICHLORO-ETHANE | <0.63 | ug/L | | | <0.63 | ug/L | | | 3 | EPA 624 | 0.63 |
| TRICHLORETHYLENE | <1.39 | ug/L | | | <1.39 | ug/L | | | 3 | EPA 624 | 1.39 |
| VINYL CHLORIDE | <1.28 | ug/L | | | <1.28 | ug/L | | | 3 | EPA 624 | 1.28 |

ACID-EXTRACTABLE COMPOUNDS

| | | | | | | | | | | | |
|----------------------|-------|------|--|--|-------|------|--|--|---|---------|------|
| P-CHLORO-M-CRESOL | <2 | ug/L | | | <2 | ug/L | | | 3 | EPA 624 | 2 |
| 2-CHLOROPHENOL | <2.4 | ug/L | | | <2.4 | ug/L | | | 3 | EPA 624 | 2.4 |
| 2,4-DICHLOROPHENOL | <2.3 | ug/L | | | <2.3 | ug/L | | | 3 | EPA 624 | 2.3 |
| 2,4-DIMETHYLPHENOL | <1.8 | ug/L | | | <1.8 | ug/L | | | 3 | EPA 624 | 1.8 |
| 4,6-DINITRO-O-CRESOL | <2.2 | ug/L | | | <2.2 | ug/L | | | 3 | EPA 624 | 2.2 |
| 2,4-DINITROPHENOL | <2.8 | ug/L | | | <2.8 | ug/L | | | 3 | EPA 624 | 2.8 |
| 2-NITROPHENOL | <1.9 | ug/L | | | <1.9 | ug/L | | | 3 | EPA 624 | 1.9 |
| 4-NITROPHENOL | <0.96 | ug/L | | | <0.96 | ug/L | | | 3 | EPA 624 | 0.96 |

| | | |
|--|---------------------------|--------------------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 |
|--|---------------------------|--------------------|

PART D – EXPANDED EFFLUENT TESTING DATA

16. EXPANDED EFFLUENT TESTING DATA

Complete Once for Each Outfall Discharging Effluent to Waters of the State.

| POLLUTANT | MAXIMUM DAILY DISCHARGE | | | | AVERAGE DAILY DISCHARGE | | | | | ANALYTICAL METHOD | ML/MDL |
|--------------------------------|-------------------------|-------|------|-------|-------------------------|-------|------|-------|----------------|-------------------|--------|
| | Conc. | Units | Mass | Units | Conc. | Units | Mass | Units | No. of Samples | | |
| PENTACHLOROPHENOL | <3.4 | ug/L | | | <3.4 | ug/L | | | 3 | EPA 625 | 3.4 |
| PHENOL | <0.78 | ug/L | | | <0.78 | ug/L | | | 3 | EPA 625 | 0.78 |
| 2,4,6-TRICHLOROPHENOL | <1.8 | ug/L | | | <1.8 | ug/L | | | 3 | EPA 625 | 1.8 |
| BASE-NEUTRAL COMPOUNDS | | | | | | | | | | | |
| ACENAPHTHENE | <0.82 | ug/L | | | <0.82 | ug/L | | | 3 | EPA 625 | 0.82 |
| ACENAPHTHYLENE | <1.1 | ug/L | | | <1.1 | ug/L | | | 3 | EPA 625 | 1.1 |
| ANTHRACENE | <0.74 | ug/L | | | <0.74 | ug/L | | | 3 | EPA 625 | 0.74 |
| BENZIDINE | <1.6 | ug/L | | | <1.6 | ug/L | | | 3 | EPA 625 | 1.6 |
| BENZO(A)ANTHRACENE | <1.3 | ug/L | | | <1.3 | ug/L | | | 3 | EPA 625 | 1.3 |
| BENZO(A)PYRENE | <1.5 | ug/L | | | <1.5 | ug/L | | | 3 | EPA 625 | 1.5 |
| 3,4-BENZO-FLUORANTHENE | <1.9 | ug/L | | | <1.9 | ug/L | | | 3 | EPA 625 | 1.9 |
| BENZO(GH) PHERYLENE | <1.2 | ug/L | | | <1.2 | ug/L | | | 3 | EPA 625 | 1.2 |
| BENZO(K) FLUORANTHENE | <1.9 | ug/L | | | <1.9 | ug/L | | | 3 | EPA 625 | 1.9 |
| BIS (2-CHLOROTHOXY) METHANE | <1.3 | ug/L | | | <1.3 | ug/L | | | 3 | EPA 625 | 1.3 |
| BIS (2-CHLOROETHYL) – ETHER | <1.5 | ug/L | | | <1.5 | ug/L | | | 3 | EPA 625 | 1.5 |
| BIS (2-CHLOROISO-PROPYL) ETHER | <1.0 | ug/L | | | <1.0 | ug/L | | | 3 | EPA 625 | 1.0 |
| BIS (2-ETHYLHEXYL) PHTHALATE | 42.66 | ug/L | | | 15.48 | ug/L | | | 3 | EPA 625 | 0.84 |
| 4-BROMOPHENYL PHENYL ETHER | <0.86 | ug/L | | | <0.86 | ug/L | | | 3 | EPA 625 | 0.86 |
| BUTYL BENZYL PHTHALATE | <1.3 | ug/L | | | <1.3 | ug/L | | | 3 | EPA 625 | 1.3 |
| 2-CHLORONAPH-THALENE | <0.69 | ug/L | | | <0.69 | ug/L | | | 3 | EPA 625 | 0.69 |
| 4-CHLORPHENYL PHENYL ETHER | <0.9 | ug/L | | | <0.9 | ug/L | | | 3 | EPA 625 | 0.9 |
| CHRYSENE | <1.3 | ug/L | | | <1.3 | ug/L | | | 3 | EPA 625 | 1.3 |
| DI-N-BUTYL PHTHALATE | <1.1 | ug/L | | | <1.1 | ug/L | | | 3 | EPA 625 | 1.1 |
| DI-N-OCTYL PHTHALATE | <0.74 | ug/L | | | <0.74 | ug/L | | | 3 | EPA 625 | 0.74 |
| DIBENZO (A,H) ANTHRACENE | <1.7 | ug/L | | | <1.7 | ug/L | | | 3 | EPA 625 | 1.7 |
| 1,2-DICHLORO-BENZENE | <0.94 | ug/L | | | <0.94 | ug/L | | | 3 | EPA 625 | 0.94 |
| 1,3-DICHLORO-BENZENE | <0.58 | ug/L | | | <0.58 | ug/L | | | 3 | EPA 625 | 0.58 |
| 1,4-DICHLORO-BENZENE | <0.58 | ug/L | | | <0.58 | ug/L | | | 3 | EPA 625 | 0.58 |
| 3,3-DICHLORO-BENZIDINE | <1.6 | ug/L | | | <1.6 | ug/L | | | 3 | EPA 625 | 1.6 |
| DIETHYL PHTHALATE | <0.99 | ug/L | | | <0.99 | ug/L | | | 3 | EPA 625 | 0.99 |
| DIMETHYL PHTHALATE | <1.4 | ug/L | | | <1.4 | ug/L | | | 3 | EPA 625 | 1.4 |

| MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL | | | |
|--|-------------------------------------|-------------------------------------|-------------------------------------|
| FACILITY NAME <i>KC Blue River Wastewater Treatment Facility</i> | PERMIT NO. <i>MO- 0024911</i> | OUTFALL NO. <i>001</i> | |
| PART E – TOXICITY TESTING DATA | | | |
| 17. TOXICITY TESTING DATA | | | |
| Refer to the APPLICATION OVERVIEW to determine whether Part E applies to the treatment works. | | | |
| Publicly owned treatment works, or POTWs, meeting one or more of the following criteria must provide the results of whole effluent toxicity tests for acute or chronic toxicity for each of the facility's discharge points. | | | |
| <div style="margin-left: 20px;"> A. POTWs with a design flow rate greater than or equal to 1 million gallons per day B. POTWs with a pretreatment program (or those that are required to have one under 40 CFR Part 403) C. POTWs required by the permitting authority to submit data for these parameters </div> <ul style="list-style-type: none"> At a minimum, these results must include quarterly testing for a 12-month period within the past one year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the application, provided the results show no appreciable toxicity, and testing for acute or chronic toxicity, depending on the range of receiving water dilution. Do not include information about combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. If EPA methods were not used, report the reason for using alternative methods. If test summaries are available that contain all of the information requested below, they may be submitted in place of Part E. If no biomonitoring data is required, do not complete Part E. Refer to the application overview for directions on which other sections of the form to complete. | | | |
| Indicate the number of whole effluent toxicity tests conducted in the past four and one-half years: <u>0</u> chronic <u>9</u> acute | | | |
| Complete the following chart for the last three whole effluent toxicity tests. Allow one column per test. Copy this page if more than three tests are being reported. | | | |
| | Most Recent | 2 ND Most Recent | 3 RD Most Recent |
| A. Test Information | | | |
| Test Method Number | <i>EPA 821-C-02-006</i> | <i>EPA 821-C-02-006</i> | <i>EPA 821-C-02-006</i> |
| Final Report Number | <i>60211175</i> | <i>60200323</i> | <i>60186076</i> |
| Outfall Number | <i>001</i> | <i>001</i> | <i>001</i> |
| Dates Sample Collected | <i>1/13/2016</i> | <i>8/11/2015</i> | <i>1/13/2015</i> |
| Date Test Started | <i>1/14/2016</i> | <i>8/12/2015</i> | <i>1/14/2015</i> |
| Duration | <i>48 HRS</i> | <i>48 HRS</i> | <i>48 HRS</i> |
| B. Toxicity Test Methods Followed | | | |
| Manual Title | <i>US EPA Manual</i> | <i>US EPA Manual</i> | <i>US EPA Manual</i> |
| Edition Number and Year of Publication | <i>Nov 2002</i> | <i>Nov 2002</i> | <i>Nov 2002</i> |
| Page Number(s) | | | |
| C. Sample collection method(s) used. For multiple grab samples, indicate the number of grab samples used | | | |
| 24-Hour Composite | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Grab | | | |
| D. Indicate where the sample was taken in relation to disinfection (Check all that apply for each) | | | |
| Before Disinfection | | | |
| After Disinfection | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| After Dechlorination | | | |
| E. Describe the point in the treatment process at which the sample was collected | | | |
| Sample Was Collected: | <i>Final Effluent</i> | <i>Final Effluent</i> | <i>Final Effluent</i> |
| F. Indicate whether the test was intended to assess chronic toxicity, acute toxicity, or both | | | |
| Chronic Toxicity | | | |
| Acute Toxicity | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| G. Provide the type of test performed | | | |
| Static | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Static-renewal | | | |
| Flow-through | | | |
| H. Source of dilution water. If laboratory water, specify type; if receiving water, specify source | | | |
| Laboratory Water | | | |
| Receiving Water | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |

| | | | |
|--|---------------------------|-----------------------------|-----------------------------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 | |
| PART E – TOXICITY TESTING DATA | | | |
| 17. TOXICITY TESTING DATA (continued) | | | |
| | Most Recent | 2 ND Most Recent | 3 RD Most Recent |
| I. Type of dilution water. If salt water, specify "natural" or type of artificial sea salts or brine used. | | | |
| Fresh Water | X | X | X |
| Salt Water | | | |
| J. Percentage of effluent used for all concentrations in the test series | | | |
| | 100% | 100% | 100% |
| | | | |
| | | | |
| K. Parameters measured during the test (State whether parameter meets test method specifications) | | | |
| pH | 7.66 | 7.51 | 7.79 |
| Salinity | | | |
| Temperature | 25 C | 25 C | 25 C |
| Ammonia | | 17.7 mg/L | |
| Dissolved Oxygen | 8.00 mg/L | 7.10 mg/L | 6.60 mg/L |
| L. Test Results | | | |
| Acute: | | | |
| Percent Survival in 100% Effluent | 100% / 100% | 100% / 60% | 100% / 80% |
| LC ₅₀ | > 100% / >100% | > 100% / 89.83% | > 100% / >78.77% |
| 95% C.I. | | | |
| Control Percent Survival | 100% / 100% | 100% / 100% | 100% / 100% |
| Other (Describe) | | | |
| Chronic: | | | |
| NOEC | | | |
| IC ₂₅ | | | |
| Control Percent Survival | | | |
| Other (Describe) | | | |
| M. Quality Control/ Quality Assurance | | | |
| Is reference toxicant data available? | Yes | Yes | Yes |
| Was reference toxicant test within acceptable bounds? | Yes | Yes | Yes |
| What date was reference toxicant test run (MM/DD/YYYY)? | 1/11/2016 | 7/22/2015 | 1/17/2015 |
| Other (Describe) | | | |
| Is the treatment works involved in a toxicity reduction evaluation? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| If yes, describe: | | | |
| | | | |
| If you have submitted biomonitoring test information, or information regarding the cause of toxicity, within the past four and one-half years, provide the dates the information was submitted to the permitting authority and a summary of the results. | | | |
| Date Submitted (MM/DD/YYYY) 2/28/2016, 9/28/2015, 2/28/2015 | | | |
| Summary of Results (See Instructions) | | | |
| All Passed | | | |
| END OF PART E | | | |
| REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE. | | | |

| MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL | | | | |
|---|--|---------------------------|--------------------|-----------|
| FACILITY NAME KC Blue River Wastewater Treatment Facility | | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 | |
| PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES | | | | |
| Refer to the APPLICATION OVERVIEW to determine whether Part F applies to the treatment works. | | | | |
| 18. GENERAL INFORMATION | | | | |
| 18.1 Does the treatment works have, or is it subject to, an approved pretreatment program? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | |
| 18.2 Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs). Provide the number of each of the following types of industrial users that discharge to the treatment works: Number of non-categorical SIUs <u>2</u> Number of CIUs <u>43</u> | | | | |
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | | |
| NAME | | | | |
| MAILING ADDRESS | | | CITY | STATE ZIP |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge | | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): Raw Material(s): | | | | |
| 19.3 Flow Rate | | | | |
| a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | | |
| b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? | | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input type="checkbox"/> No If Yes, describe each episode | | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>A1 Paint, Powder and Sandblasting</i> | | | |
| MAILING ADDRESS: <i>7601 E 12th Street</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64126</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Powder coating and painting of steel fabricated parts</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Powder coating and industrial wet paint</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 500 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 100 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Ace ImageWear</i> | | | |
| MAILING ADDRESS: <i>4120 Truman Road</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Laundry service</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Laundry detergent and cleaning chemicals, wash water</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 40,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 5,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|--|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Artcraft Nameplate and Engraving</i> | | | |
| MAILING ADDRESS: <i>1130 Elmwood Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64124</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Engraver</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>silk screening, lithographing, etching, embossing, stamping, hot stamping, digital printing & plotting machines, 4 color ink jet printing, mechanical and laser engraving</i> Raw Material(s): <i>Paper, Ink, printing plates, solvents, fountain solution, metal dust and engraving waste</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 4,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|--|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Bount International</i> | | | |
| MAILING ADDRESS: <i>4840 E. 12th St.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture lawn mower blades</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>lawn mower blades</i> Raw Material(s): <i>various grades of cold rolled steel</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 3,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,500 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Cargill, Inc.</i> | | | |
| MAILING ADDRESS: <i>PO Box 33413</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Soybean crush plant. Process soybeans into four major products: soybean meal, soybean oil, soy hulls, and soy hull pellets.</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Soybean meal, soybean oil, soy hulls, and soy hull pellets</i> Raw Material(s): <i>soybeans</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 89,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 36,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Catalent</i> | | | |
| MAILING ADDRESS: <i>PO Box 9724</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64134</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Pharmaceutical research and development. Manufacture of pharmaceutical products and clinical supplies.</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Pharmaceutical products and clinical supplies</i> Raw Material(s): <i>Hydrochloric acid, methanol, acetone, acetonitrile, starches, sugars, active pharmaceutical ingredients, ethanol</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 12,000 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 32,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>439.47</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Hubzone 1, Inc.</i> | | | |
| MAILING ADDRESS: <i>7605 E. 12th St., Suite B</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64125</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Painting and Powder Coatings</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Painted and powder coated parts</i> Raw Material(s): <i>Paint, powder coating, steel</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,000 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 150 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Department of Veteran Affairs, VA Medical Center</i> | | | |
| MAILING ADDRESS: <i>4801 Linwood Blvd.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64128</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 166,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Duraseal Coatings Company, LLC</i> | | | |
| MAILING ADDRESS: <i>3456 E 155th Street</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64147</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Coatings</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Coated pipes, tubing, couplings, valves, etc</i> Raw Material(s): <i>Solvents, coating overspray and waste</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 3,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 100 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>433.17</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Environmental Specialists, Inc.</i> | | | |
| MAILING ADDRESS: <i>3001 E. 83rd St.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64132</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Recover oil and hydrocarbons from non-hazardous wastewater usually impacted with petroleum products from a spill or accident, preventive maintenance activities of pipeline companies, or cleaning of vac trucks or frac tanks used in maintenance activities.</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Emergency clean up of waste water from industrial and commercial sources</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>varies gpd</i> <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>200 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>437.15 & 437.25</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>G&K Services</i> | | | |
| MAILING ADDRESS: <i>1745 Reynolds Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Textile leasing and laundering service</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Laundry detergent and cleaning chemicals, wash water</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>40,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>600 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Gateway Packaging Co.</i> | | | |
| MAILING ADDRESS: <i>5910 Winner Rd.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64125</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Packaging Manufacturer</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>paper bags</i> Raw Material(s): <i>paper, glue, and ink</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>1,400 gpd</i> <input checked="" type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>700 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Hazmat, Inc.</i> | | | |
| MAILING ADDRESS: <i>6300 Stadium Drive</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64129</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Environmental clean-up</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Packaging</i> Raw Material(s): <i>Paper, plastic, foil, ink, solvents, adhesives, printing wastes</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>437.46</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Jackson Plating & Polishing, Inc.</i> | | | |
| MAILING ADDRESS: <i>2641 Jackson Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Plating and Polishing</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Plating, polishing, etching, embossing, stamping, hot stamping, mechanical and laser engraving</i> Raw Material(s): <i>Cleaning baths, plating baths, electroplated parts</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 60 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 100 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>413.14A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|----------------------|--------------|---------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: KC Southern Railway | | | |
| MAILING ADDRESS: PO Box 219335 | CITY: Kansas City | STATE: MO | ZIP: 64121 |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge Locomotive maintenance and repair, railroad freight hauling, switching yard | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): Service/Transportation Raw Material(s): Oil, petroleum products, stormwater generated on site | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 3300 gpd <input checked="" type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 280 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|----------------------|--------------|--------------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: KCMO Regional HHW Center | | | |
| MAILING ADDRESS: 4707 Deramus St. | CITY: Kansas City | STATE: MO | ZIP: Kindred Hospital |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge Household Hazardous Waste Disposal | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): None (service industry) Raw Material(s): Adhesives, antifreeze, batteries, brake fluid, bleach, disinfectants, fluorescent lights, gasoline, fuel, oils, paint, pest poison, solvents, household chemicals, etc | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 300 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 437.46 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Kindred Hospital</i> | | | |
| MAILING ADDRESS: <i>8701 Troost Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64131</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 10,400 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Labconco Corp.</i> | | | |
| MAILING ADDRESS: <i>8811 Prospect Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64132</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacturing</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Manufacturer and supplier of laboratory equipment</i> Raw Material(s): <i>Steel, epoxy powder paint and chemicals in the wash system (Galaxy 752 Detergent, Galaxy 758 Phosphate, Galaxy 745 Non-Chromate sealer)</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 7,800 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,900 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>433.17</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|----------------------|--------------|---------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: LPF High Performance Coatings | | | |
| MAILING ADDRESS: 5000 E. 59th St. | CITY: Kansas City | STATE: MO | ZIP: 64130 |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge Coatings and sandblasting | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): Paint and coatings applied to pipes, tubing, couplings, valves, etc Raw Material(s): Paint and powder coatings, washline chemicals, and cleaning solvents | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 175 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|----------------------|--------------|---------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: Milbank Manufacturing | | | |
| MAILING ADDRESS: PO Box 419028 | CITY: Kansas City | STATE: MO | ZIP: 64141 |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge Manufacture of electric meter sockets, enclosures, and related electrical equipment | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): Meters, Enclosed Controls, Generators Raw Material(s): Steel, aluminum, copper, insulating material, powder paint | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 10,250 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Missouri MPP Corp.</i> | | | |
| MAILING ADDRESS: <i>2800 Truman Rd.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Electroplating</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Electroplated metal products</i> Raw Material(s): <i>Nickel, zinc, caustic soda, sulfuric acid, muriatic acid, potassium chloride, zinc chloride, sodium cyanide</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>11,400 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>1,300 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>433.17</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Missouri Plating Co.</i> | | | |
| MAILING ADDRESS: <i>7001 E. 13th St.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64126</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Plating</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Zinc plating, decorative nickel plating, lacquering</i> Raw Material(s): <i>Nickel, zinc, brass, caustic soda, sulfuric acid, muriatic acid, potassium chloride, zinc chloride, sodium cyanide, copper cyanide, zinc cyanide</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>19,100 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>2,100 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>413.14c</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Mondi Bags USA, LLC</i> | | | |
| MAILING ADDRESS: <i>3244 Gardner Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture of multiwall bags, roll print, and industrial wrap</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Multiwall bags, roll print, and industrial wrap</i> Raw Material(s): <i>Paper, ink, polyethylene and polypropylene film, adhesive, lacquer</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>2,100 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>5,600 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>MRI Global</i> | | | |
| MAILING ADDRESS: <i>425 Volker Boulevard</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64110</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Research</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Pharmaceuticals</i> Raw Material(s): <i>Chemical, pharmaceutical, and lab waste, etc</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>13,500 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>4,700 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>North American Galvanizing Co.</i> | | | |
| MAILING ADDRESS: <i>7700 E. 12th St.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64126</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hot dip galvanizing of steel parts</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Galvanized metal products</i> Raw Material(s): <i>Zinc, sodium hydroxide, hydrochloric acid, zinc ammonium chloride, fabricated steel</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 480 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 420.120 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Nostrum Laboratories, Inc.</i> | | | |
| MAILING ADDRESS: <i>1800 N. Topping Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture of generic prescription pharmaceuticals</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Pharmaceuticals</i> Raw Material(s): <i>Carbamazepine USP, Prosalv 50 USP, Sodium lauryl sulfate USP, SureleaseOpadry clear, Theophylline 400 mg, Glyceryl Behenate USP, Aerosil, Magnesium Sterate, Sucralfate, Isopropyl Alcohol, Povidone, Lysol, Steris DA, Sodium Bicarbonate, Piroxicam USP, Lactose Monohydrate, Corn Starch, Ajax, Windex, Bleach</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 3,880 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,900 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 439.46 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|--|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>P-Americas, LLC</i> | | | |
| MAILING ADDRESS: <i>6050 Manchester Tfwy</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64130</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture of beverages</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Packaged wholesale food</i> Raw Material(s): <i>Water, sweeteners, flavorings, etc.</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <div style="display: flex; justify-content: space-between;">91,500 gpd<input checked="" type="checkbox"/> Continuous<input type="checkbox"/> Intermittent</div> b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <div style="display: flex; justify-content: space-between;">20,000 gpd<input checked="" type="checkbox"/> Continuous<input type="checkbox"/> Intermittent</div> | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <div style="display: flex; justify-content: flex-end;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</div> If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|---|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Paseo Cargill Energy, LLC</i> | | | |
| MAILING ADDRESS: <i>PO Box 33413</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Biodiesel plant</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Biodiesel and food grade glycerin</i> Raw Material(s): <i>soybean oil, methanol, sodium methylate, caustic soda, hydrochloric acid</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <div style="display: flex; justify-content: space-between;">108,000 gpd<input checked="" type="checkbox"/> Continuous<input type="checkbox"/> Intermittent</div> b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <div style="display: flex; justify-content: space-between;">22,300 gpd<input checked="" type="checkbox"/> Continuous<input type="checkbox"/> Intermittent</div> | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <div style="display: flex; justify-content: flex-end;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</div> If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|---|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Paulo Products</i> | | | |
| MAILING ADDRESS: <i>4827 Chelsea Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64130</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Metal heat treating and metal finishing (black oxide)</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Heat treated customer parts</i> Raw Material(s): <i>Quench oil, heat treat (class 1 nitrate-nitrite salt), chloride salt, alkaline cleaners</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 10,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 1,350 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 413.14b | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
|--|-----------------------------|---------------------|----------------------|
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Research Medical Center</i> | | | |
| MAILING ADDRESS: <i>2316 E. Meyer Blvd.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64132</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 75,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|---------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>RMF Steel Company</i> | | | |
| MAILING ADDRESS: <i>4417 E. 119th St.</i> | CITY: <i>Grandview</i> | STATE: <i>MO</i> | ZIP: <i>64030</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture of food processing equipment</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Steel Food Service Equipment</i> Raw Material(s): <i>Steel, plastic, and metal byproducts, oil, petroleum products, paint overspray and waste, coolant, etc</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 2,000 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 2,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 433.17 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Saint Joseph Medical Center</i> | | | |
| MAILING ADDRESS: <i>1000 Carondelet Dr.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64114</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 105,500 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 0 gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Saint Luke's Hospital</i> | | | |
| MAILING ADDRESS: <i>901 E 104th Street</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64131</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>0 gpd</i> <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>280,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Saint Luke's North Hospital</i> | | | |
| MAILING ADDRESS: <i>5830 Northwest Barry Road</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64154</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Hospital</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Boiler system chemicals, lab chemicals, radiology, pharmacy</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>13,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>14,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Sanofi</i> | | | |
| MAILING ADDRESS: <i>PO Box 9720</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64134</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Manufacture prescription and non-prescription pharmaceutical products</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Pharmaceuticals</i> Raw Material(s): <i>Acetone, Acetyl tributyl citrate, Alcohol SDA-3A, Carnauba wax, Colloidal silicon dioxide, croscarmellose sodium, diethyl phthalate, diltiazem hydrochloride, empty gel caps, eudragit RL, eudragit RD, FDC Blue #1, Fexofenadine HCl, Glycerin, hypromellose, isopropyl alcohol, magnesium</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 96,000 gpd <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 35,000 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? 439.46 | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Smithfield Farmland</i> | | | |
| MAILING ADDRESS: <i>13825 Wyandotte</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64145</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Meat processing</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Meat products</i> Raw Material(s): <i>Pork, water, food grade ham additives, wood for natural smoking of hams, meat conditioner</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 187,200 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. 16,200 gpd <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? N/A | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|--|--------------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Southeast Sanitary Landfill, LLC</i> | | | |
| MAILING ADDRESS: <i>5605 Moreau River Access Road</i> | CITY: <i>Jefferson City</i> | STATE: <i>MO</i> | ZIP: <i>64132</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Landfill leachate collection</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Residential, industrial, and commercial waste</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>17,300 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>0 gpd</i> <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Stowers Institute for Medical Research</i> | | | |
| MAILING ADDRESS: <i>1000 E. 50th St.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64110</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Research</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Pharmaceuticals</i> Raw Material(s): <i>Chemical, pharmaceutical, and lab waste, etc</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>0 gpd</i> <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>121,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Superior Metal Treating & Equipment</i> | | | |
| MAILING ADDRESS: <i>2540 Indiana Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Coatings and metal treating</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Metal products</i> Raw Material(s): <i>Steel, solvents, paints, and coatings</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>9,300 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>27,900 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>413.44</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Union Pacific Railroad</i> | | | |
| MAILING ADDRESS: <i>1400 W 52nd Street</i> | CITY: <i>Denver</i> | STATE: <i>CO</i> | ZIP: <i>80221</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Railroad</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Service/Transportation</i> Raw Material(s): <i>#2 diesel fuel, lube oil, locomotive cleaner, corrosion inhibitor, journal oil, hydraulic oil, soap</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>36,400 gpd</i> <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>7,300 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|--|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>US Plating & Surface Finishing</i> | | | |
| MAILING ADDRESS: <i>1341 Montgall Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Plating & anodizing</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Zinc plating, decorative nickel plating, lacquering</i> Raw Material(s): <i>Nickel sulfate, sulfuric acid, chromic acid, zinc chloride, stannous sulphate</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>400 gpd</i> <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>2,400 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>433.17</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| | | | |
|---|-----------------------------|---------------------|----------------------|
| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS | | | |
| INFORMATION | | | |
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Valicor Environmental Services, LLC</i> | | | |
| MAILING ADDRESS: <i>1717 N. Topping Ave.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64120</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Non-hazardous centralized waste pretreatment and discharge facility</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>Used Oil</i> Raw Material(s): <i>Sulfuric acid, sodium hydroxide, specialty polymers</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>60,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>150 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>437.47</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

| 19. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION | | | |
|---|-----------------------------|---------------------|----------------------|
| Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary. | | | |
| NAME: <i>Walker Towel & Uniform Service</i> | | | |
| MAILING ADDRESS: <i>2601 Truman Rd.</i> | CITY: <i>Kansas City</i> | STATE: <i>MO</i> | ZIP: <i>64127</i> |
| 19.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge <i>Industrial laundry</i> | | | |
| 19.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): <i>None (service industry)</i> Raw Material(s): <i>Water, steam, surfactants, alkalis</i> | | | |
| 19.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>68,600 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. <i>1,000 gpd</i> <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent | | | |
| 19.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory? <i>N/A</i> | | | |
| 19.5 Problems at the Treatment Works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, describe each episode | | | |

MAY 23 2016

Water Protection Program

| | | |
|---|---------------------------|-----------------|
| MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL | | |
| FACILITY NAME KC Blue River Wastewater Treatment Facility | PERMIT NO. MO- 0024911 | OUTFALL NO. 001 |
| PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES | | |
| 20. RCRA HAZARDOUS WASTE RECEIVED BY TRUCK, RAIL, OR DEDICATED PIPELINE | | |
| 20.1 Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| 20.2 Method by which RCRA waste is received. (Check all that apply) <input type="checkbox"/> Truck <input type="checkbox"/> Rail <input type="checkbox"/> Dedicated Pipe | | |
| 20.3 Waste Description | | |
| EPA Hazardous Waste Number | Amount (volume or mass) | Units |
| | | |
| | | |
| | | |
| 21. CERCLA (SUPERFUND) WASTEWATER, RCRA REMEDIATION/CORRECTIVE ACTION WASTEWATER, AND OTHER REMEDIAL ACTIVITY WASTEWATER | | |
| 21.1 Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Provide a list of sites and the requested information for each current and future site. | | |
| 21.2 Waste Origin. Describe the site and type of facility at which the CERCLA/RCRA/or other remedial waste originates (or is expected to originate in the next five years). <i>Former Tronox wood treating plant. Groundwater is being treated under RCRA Permit No. MOD007128978 Treated groundwater is discharged under an Industrial Wastewater Discharge Permit issued to Greenfield Environmental Multistate Trust, LLC.</i> | | |
| 21.3 List the hazardous constituents that are received (or are expected to be received). Included data on volume and concentration, if known. (Attach additional sheets if necessary) <i>Treated groundwater containing 0.024 mg/L phenols and 0.75 ug/L phenanthrene Average volume discharged is 5140 gpd. Average is based on the two samples collected since operations restarted in October 2015</i> | | |
| 21.4 Waste Treatment | | |
| a. Is this waste treated (or will it be treated) prior to entering the treatment works? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If Yes, describe the treatment (provide information about the removal efficiency): <i>Groundwater is pumped to the primary oil/water tank for Dense Non-Aqueous Phase Liquid, or DNAPL, separation and settling. Water then flows to the secondary oil/water tank or additional settling of DNAPL. Water then flows to a holding tank. From the holding tank it flows to the biological treatment tank where nutrients and a moving bed biofilm reactor treat organic constituents. Effluent from the biologic treatment tank discharges to the sewer.</i> | | |
| b. Is the discharge (or will the discharge be) continuous or intermittent? <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Intermittent If intermittent, describe the discharge schedule: | | |
| END OF PART F | | |
| REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE. | | |

| | | |
|--|----------------------------------|------------------------|
| MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL | | |
| FACILITY NAME <i>KC Blue River Wastewater Treatment Facility</i> | PERMIT NO. <i>MO- 0024911</i> | OUTFALL NO. <i>001</i> |
| PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES | | |
| 20. RCRA HAZARDOUS WASTE RECEIVED BY TRUCK, RAIL, OR DEDICATED PIPELINE | | |
| 20.1 Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| 20.2 Method by which RCRA waste is received. (Check all that apply) <input type="checkbox"/> Truck <input type="checkbox"/> Rail <input type="checkbox"/> Dedicated Pipe | | |
| 20.3 Waste Description | | |
| EPA Hazardous Waste Number | Amount (volume or mass) | Units |
| | | |
| | | |
| | | |
| 21. CERCLA (SUPERFUND) WASTEWATER, RCRA REMEDIATION/CORRECTIVE ACTION WASTEWATER, AND OTHER REMEDIAL ACTIVITY WASTEWATER | | |
| 21.1 Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Provide a list of sites and the requested information for each current and future site. | | |
| 21.2 Waste Origin. Describe the site and type of facility at which the CERCLA/RCRA/or other remedial waste originates (or is expected to originate in the next five years). <i>Former waste oil management facility. Groundwater is being treated under RCRA permit no. MOD073027609 Treated groundwater is discharged under an Industrial Wastewater Discharge Permit issued to Quality Analytical Services.</i> | | |
| 21.3 List the hazardous constituents that are received (or are expected to be received). Included data on volume and concentration, if known. (Attach additional sheets if necessary) <i>Treated groundwater containing 7.7 ug/L lead. Average volume discharged is 7,660 gpd. Average is based on 5 samples collected from Oct 2014 - Jan 2016.</i> | | |
| 21.4 Waste Treatment | | |
| a. Is this waste treated (or will it be treated) prior to entering the treatment works? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No If Yes, describe the treatment (provide information about the removal efficiency): <i>Groundwater is pumped to a holding tank then routed through two granular activated carbon vessels prior to discharge</i> | | |
| b. Is the discharge (or will the discharge be) continuous or intermittent? <input type="checkbox"/> Continuous <input checked="" type="checkbox"/> Intermittent If intermittent, describe the discharge schedule: <i>Approximately 7-8 discharge events per day of 1,250 gal each.</i> | | |
| END OF PART F | | |
| REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE. | | |

NPDES Permit Application

23.1 and 23.3

| CSO No. | Description | UTM Coordinates | | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-Watershed No. |
|---------|----------------------------------|-----------------|------------|--------------------------------|--------------------------|------------------------------------|--------------------------------|
| 006 | 50th & Stateline | X= 361374 | Y= 4321912 | NE 1/4 NW 1/4 Sec 31 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 007 | 50th Terrace & Brush Creek | X= 361400 | Y= 4322004 | SE 1/4 SW 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 008 | 49th Terrace & Westwood Road | X= 361450 | Y= 4322126 | SE 1/4 SW 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 009 | 50th & Holly | X= 361450 | Y= 4322126 | SE 1/4 SW 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 010 | 50th & Brush Creek | X= 361498 | Y= 4322126 | SE 1/4 SW 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 011 | Roanoke & Brush Creek | X= 361815 | Y= 4322367 | SW 1/4 SE 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 012 | Summit & Brush Creek | X= 361814 | Y= 4322305 | SW 1/4 SE 1/4 Sec 30 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 013 | 47th & Wornall | X= 362249 | Y= 4322421 | NW 1/4 SW 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 014 | 49th & Wornall | X= 362273 | Y= 4322420 | NW 1/4 SW 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 015 | Nichols Road & Wornall | X= 362490 | Y= 4322478 | NW 1/4 SW 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 016 | Main Street & Brush Creek | X= 362754 | Y= 4322412 | NE 1/4 SW 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 017 | 46th Terrace & Wornall | X= 362944 | Y= 4322316 | NE 1/4 SE 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 018 | 48th & Harrison | X= 363760 | Y= 4322179 | NE 1/4 SE 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 019 | 49th & Troost | X= 363879 | Y= 4322146 | SW 1/4 SW 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 020 | 48th & The Paseo | X= 364244 | Y= 4322355 | NE 1/4 SW 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 021 | 47th & The Paseo | X= 364318 | Y= 4322508 | NE 1/4 SW 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 022 | Virginia & Brush Creek Boulevard | X= 364200 | Y= 4322778 | SW 1/4 NW 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 023 | 46th & Woodland | X= 364706 | Y= 4322687 | SE 1/4 NW 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 024 | 45th & Garfield | X= 365065 | Y= 4322588 | SW 1/4 NE 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 025 | 46th & Prospect | X= 365447 | Y= 4322427 | NE 1/4 SE 1/4 Sec 28 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 026 | 49th & Chestnut | X= 365925 | Y= 4322234 | NE 1/4 SW 1/4 Sec 27 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 027 | 45th & Mersington | X= 366823 | Y= 4322743 | SE 1/4 NE 1/4 Sec 27 T49N R33W | Tributary to Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 028 | 46th & Norton | X= 366989 | Y= 4322555 | SE 1/4 NE 1/4 Sec 27 T49N R33W | Tributary to Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 029 | 51st Terrace & Brookside | X= 36290 | Y= 4321676 | NE 1/4 NW 1/4 Sec 32 T49N R33W | Tributary to Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 030 | 4200 Brush Creek | X= 363569 | Y= 4322274 | NE 1/4 SE 1/4 Sec 29 T49N R33W | Brush Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 031 | Gardner Avenue at MO River | X= 371070 | Y= 4330967 | NW 1/4 NW 1/4 Sec 31 T50N R32W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |
| 032 | Belmont Ave & Belmont Blvd | X= 370454 | Y= 4329991 | NE 1/4 SE 1/4 Sec 36 T50B R33W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |
| 033 | Wilson & Bennington | X= 370335 | Y= 4330085 | NE 1/4 SE 1/4 Sec 36 T50N R33W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |
| 034 | 8th Street at Blue River | X= 370440 | Y= 4329127 | NE 1/4 NE 1/4 Sec 01 T49N R33W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |
| 035 | Truman Road at Blue River | X= 370809 | Y= 4328196 | SW 1/4 SW 1/4 Sec 06 T49N R32W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 036 | 18th Street at Blue River | X= 370437 | Y= 4327524 | NE 1/4 NE 1/4 Sec 12 T49N R33W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 037 | 35th Street at Blue River | X= 369093 | Y= 4324740 | SW 1/4 SW 1/4 Sec 13 T49N R33W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 038 | 37th Street & White | X= 368989 | Y= 4324279 | NW 1/4 NW 1/4 Sec 24 T49N R33W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |

| CSO No. | Description | UTM Coordinates | | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-Watershed No. |
|---------|-----------------------------|-----------------|------------|--------------------------------|-------------------------------------|---------------------------------|--------------------------------|
| 039 | 33rd Terrace & Topping | X= 369044 | Y= 4324679 | NW 1/4 NW 1/4 Sec 24 T49N R33W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 040 | 41st & Elmwood | X= 367486 | Y= 4323533 | SW 1/4 SW 1/4 Sec 23 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 041 | 40th & Cleveland | X= 366744 | Y= 4323731 | NE 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 042 | 40th Terrace & Monroe | X= 366657 | Y= 4323810 | NW 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 043 | 40th Terrace & Cleveland | X= 366816 | Y= 4323699 | NW 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 044 | 40th Terrace & Myrtle | X= 366910 | Y= 4323605 | NW 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 045 | 41st & Myrtle | X= 366958 | Y= 4323573 | SE 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 046 | 41st & Norton | X= 367054 | Y= 4323572 | SE 1/4 SE 1/4 Sec 22 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 047 | 41st & Jackson | X= 367173 | Y= 4323508 | SW 1/4 SW 1/4 Sec 23 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 048 | 45th Terrace & Lister | X= 367833 | Y= 4322695 | SE 1/4 NW 1/4 Sec 26 T49N R33W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 049 | 41st & Spruce | X= 367270 | Y= 4323537 | SW 1/4 SW 1/4 Sec 23 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 050 | Spruce & Towers Road | X= 367246 | Y= 4323538 | SW 1/4 SW 1/4 Sec 23 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 051 | Skiles & Winner Road | X= 370785 | Y= 4329708 | SW 1/4 SW 1/4 Sec 31 T50N R32W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |
| 052 | Truman & Crystal | X= 370833 | Y= 4328196 | SW 1/4 SW 1/4 Sec 06 T49N R32W | Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 053 | 12th & Frisco Railroad | X= 367672 | Y= 4328781 | SW 1/4 NW 1/4 Sec 02 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 054 | 17th & Belmont | X= 369238 | Y= 4327667 | NW 1/4 NW 1/4 Sec 12 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 055 | I-70 & White | X= 369060 | Y= 4325666 | SW 1/4 NW 1/4 Sec 13 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 056 | 55th & Elmwood | X= 367607 | Y= 4320725 | NE 1/4 SW 1/4 Sec 35 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 057 | 76th & Indiana | X= 365926 | Y= 4316622 | NW 1/4 NW 1/4 Sec 15 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 058 | 83rd Terrace & McGee | X= 362559 | Y= 4315384 | NE 1/4 NW 1/4 Sec 20 T48N R33W | Dyke Branch | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 059 | 85th & Tracy | X= 363680 | Y= 4314810 | SW 1/4 NW 1/4 Sec 21 T48N R33W | Dyke Branch | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 060 | 58th & Kensington | X= 367165 | Y= 4320209 | SW 1/4 SW 1/4 Sec 35 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 061 | 58th & Elmwood | X= 367309 | Y= 4320144 | SW 1/4 SW 1/4 Sec 35 T49N R33W | Unnamed Tributary to the Blue River | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 062 | 63rd Terrace & Elmwood | X= 367459 | Y= 4319093 | NE 1/4 SW 1/4 Sec 02 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 063 | 69th & Cleveland | X= 366405 | Y= 4317939 | SW 1/4 NE 1/4 Sec 10 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 064 | Gregory & Mersington | X= 366594 | Y= 4317690 | SE 1/4 NE 1/4 Sec 10 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 065 | 81st Terrace & Campbell | X= 363471 | Y= 4315214 | SE 1/4 NE 1/4 Sec 20 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 066 | 84th & Main | X= 362269 | Y= 4315328 | NE 1/4 NW 1/4 Sec 20 T48N R33W | Dyke Branch | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 067 | 83rd & Main | X= 362270 | Y= 4315359 | NE 1/4 NW 1/4 Sec 20 T48N R33W | Dyke Branch | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 068 | 85th & Flora | X= 363989 | Y= 4314558 | SE 1/4 NW 1/4 Sec 21 T48N R33W | Dyke Branch | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 069 | 77th & Prospect | X= 365126 | Y= 4316296 | SW 1/4 NW 1/4 Sec 15 T48N R33W | Unnamed Tributary to the Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 070 | Meyer at Blue River | X= 367834 | Y= 4318470 | SW 1/4 SE 1/4 Sec 02 T48N R33W | Blue River | Blue River (419) (303 (d), MND) | 10300101-0105 |
| 071 | Delaware Street at MO River | X= 362918 | Y= 4330458 | Sec 32 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 072 | Main Street at MO River | X= 363403 | Y= 4330727 | Sec 32 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 073 | Gillis Avenue at MO River | X= 363985 | Y= 4331025 | Sec 32 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |

| CSO No. | Description | UTM Coordinates | | Legal Description | Receiving Water | First Classified Stream & ID | USGS Basin & Sub-Watershed No. |
|---------|---------------------------------|-----------------|------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|
| 074 | Lydia Avenue at MO River | X= 364421 | Y= 4331264 | Sec 33 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 075 | Prospect Avenue at MO River | X= 365973 | Y= 4332070 | Sec 28 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 076 | Chouteau Trafficway at MO River | X= 367752 | Y= 4333613 | Sec 18 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 077 | Holmes Street at MO River | X= 363597 | Y= 4330816 | Sec 32 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 078 | Lydia Avenue at MO River | X= 364445 | Y= 4331264 | Sec 33 T50N R33W | Missouri River | Missouri River (356) (303 (d)) | 10300101-0301 |
| 079 | 51st & Indiana | X= 366275 | Y= 4321611 | NW 1/4 NE 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 080 | 53rd & Walrond | X= 366014 | Y= 4321242 | SE 1/4 NW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 081 | 53rd Terrace & Walrond | X= 366003 | Y= 4321153 | SE 1/4 NW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 082 | 55th & Indiana | X= 366022 | Y= 4320845 | SE 1/4 NW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 083 | 57th & Agnes | X= 365919 | Y= 4320446 | NW 1/4 SW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 084 | 58th & S. Benton | X= 365608 | Y= 4320256 | SW 1/4 SW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 085 | 59th & Prospect | X= 365528 | Y= 4320082 | SW 1/4 SW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 086 | 60th Terrace & Montgall | X= 365476 | Y= 4319723 | NW 1/4 NW 1/4 Sec 03 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 087 | 60th & Prospect | X= 365306 | Y= 4319889 | NW 1/4 NW 1/4 Sec 03 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0106 |
| 088 | 60th Terrace & Wabash | X= 365206 | Y= 4319805 | NE 1/4 NE 1/4 Sec 04 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 089 | 61st Terrace & Park | X= 365063 | Y= 4319628 | SE 1/4 NE 1/4 Sec 04 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 090 | 63rd & Highland | X= 364342 | Y= 4319399 | SE 1/4 NW 1/4 Sec 04 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 091 | 59th & Bellefontaine | X= 365794 | Y= 4320201 | SW 1/4 SW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 092 | Gregory & Tracy | X= 363780 | Y= 4317799 | SW 1/4 NW 1/4 Sec 09 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 093 | Gregory & Tracy | X= 363804 | Y= 4317799 | SW 1/4 NW 1/4 Sec 09 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 094 | 69th Terrace & Lydia | X= 363987 | Y= 4318081 | SE 1/4 NW 1/4 Sec 09 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 095 | 69th & Flora | X= 364154 | Y= 4318533 | NE 1/4 NW 1/4 Sec 09 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 096 | 68th & Woodland | X= 364368 | Y= 4318375 | NW 1/4 NW 1/4 Sec 09 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 097 | 66th Terrace & Flora | X= 364156 | Y= 4318687 | SE 1/4 SW 1/4 Sec 04 T48N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 098 | 66th Terrace & Woodland | X= 364434 | Y= 4318674 | SW 1/4 SE 1/4 Sec 04 T48N R33W | Unnamed Tributary to Mill Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 099 | 56th & Bellefontaine | X= 365970 | Y= 4320630 | NE 1/4 SW 1/4 Sec 34 T49N R33W | Townfork (Mill) Creek | Blue River (418) (303 (d), MND) | 10300101-0105 |
| 100 | 7300 Hawthorne Road | X= 370643 | Y= 4329802 | SE 1/4 SE 1/4 Sec 36 T50N R33W | Blue River | Blue River (417) (303 (d), MND) | 10300101-0106 |

INSTRUCTIONS FOR COMPLETING FORM B2
APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND
HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY. Form 780-1805
(Facilities less than or equal to 100,000 gallons per day of domestic waste must use Form B - 780-1512.)

PART A – BASIC APPLICATION INFORMATION

1. Check the appropriate box. **Do not check more than one item.** Operating permits refer to permits issued by the Department of Natural Resources, Water Protection Program. If an Antidegradation Review has not been conducted, please submit the application located at the following link to the Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, MO 65102: dnr.mo.gov/forms/780-1893-f.pdf.

1.1 **Fees Information:**

DOMESTIC OPERATING PERMIT FEES – PRIVATE

Annual operating permit fees are based on flow.

| Annual fee/Design flow | Annual fee/Design flow | Annual fee/Design flow |
|---------------------------|-----------------------------|-------------------------------|
| \$100.....<5,000 gpd | \$375.....10,000-10,999 gpd | \$650.....16,000-16,999 gpd |
| \$150.....5,000-5,999 gpd | \$400.....11,000-11,999 gpd | \$800.....17,000-19,999 gpd |
| \$175.....6,000-6,999 gpd | \$450.....12,000-12,999 gpd | \$1,000.....20,000-22,999 gpd |
| \$200.....7,000-7,999 gpd | \$500.....13,000-13,999 gpd | \$2,000.....23,000-24,999 gpd |
| \$225.....8,000-8,999 gpd | \$550.....14,000-14,999 gpd | \$2,500.....25,000-29,999 gpd |
| \$250.....9,000-9,999 gpd | \$600.....15,000-15,999 gpd | \$3,000.....30,000 gpd -1 mgd |

New domestic wastewater treatment facilities must submit the annual fee with the original application.

If the application is for a site-specific permit re-issuance, send no fees. You will be invoiced separately by the department on the anniversary date of the original permit. Permit fees must be current for the department to reissue the operating permit. Late fees of two percent per month are charged and added to outstanding annual fees.

PUBLIC SEWER SYSTEM OPERATING PERMIT FEES (City, Public Sewer District, Public Water District, or other publicly owned treatment works). Annual fee is based on number of service connections. The table of fees is in 10 CSR 20-6.011 and is available at www.sos.mo.gov/adrules/csr/current/10csr/10c20-6a.pdf. New Public Sewer System facilities should not submit any fee as the department will invoice the permittee.

OPERATING PERMIT MODIFICATIONS, including transfers, are subject to the following fees:


- a. Municipals - \$200 each.
- b. All others - \$100 each.

Note: Facility name or address changes where owner, operator and continuing authority remain the same are not considered transfers.


2. Name of Facility – Include the name by which this facility is locally known. Example: Southwest Sewage Treatment Plant, Country Club Mobile Home Park, etc. Provide the street address or location of the facility. If the facility lacks a street name or route number, provide the names of the closest intersection, highway, country road, etc.
- 2.1 Self-explanatory.
- 2.2 Global Positioning System, or GPS, is a satellite-based navigation system. The department prefers that a GPS receiver is used and the displayed coordinates submitted. If access to a GPS receiver is not available, use a mapping system to approximate the coordinates; the department's mapping system is available at www.dnr.mo.gov/internetmapviewer/.
- 2.3-2.4 Self-explanatory.
3. Owner – Provide the legal name, mailing address, phone number, and e-mail address of the owner.
- 3.1 Prior to submitting a permit to public notice, the Department of Natural Resources shall provide the permit applicant 15 days to review the draft permit for nonsubstantive drafting errors. In the interest of expediting permit issuance, permit applicants may waive the opportunity to review draft permits prior to public notice.
- 3.2-3.4 Self-explanatory.
4. Continuing Authority – Provide information for the permanent organization which will serve as the continuing authority for the operation, maintenance, and modernization of the facility. The regulatory requirement regarding continuing authority is available at www.sos.mo.gov/adrules/csr/current/10csr/10c20-6a.pdf or contact the Department of Natural Resources Water Protection Program (see contact information below).
5. Operator – Provide the name, certificate number, title, mailing address, phone number, and e-mail address of the operator of the facility.
6. Provide the name, title, mailing address, work phone number, and e-mail address of a person who is thoroughly familiar with the operation of the facility and with the facts reported in this application and who can be contacted by the department.

7.1 Process Flow Diagram Examples

WASTEWATER TREATMENT LAGOON



WASTEWATER TREATMENT FACILITY



7.2 A topographic map is available on the web at www.dnr.mo.gov/internetmapviewer/ or from the Department of Natural Resources' Geological Survey in Rolla at 573-368-2125.

7.3 For Standard Industrial Codes visit www.osha.gov/pls/imis/sicsearch.html and for the North American Industry Classification System, visit www.census.gov/nalcs or contact the Department of Natural Resources Water Protection Program.

7.4-7.8 Self – explanatory.

7.9 If wastewater is land applied please submit form I: www.dnr.mo.gov/forms/780-1686-f.pdf.

7.10-8. Self-explanatory

9.1 A copy of 10 CSR 25 is available at www.sos.mo.gov/adrules/csr/current/10csr/10csr.asp#10-25.

9.2-9.9 Self – explanatory.

**INSTRUCTIONS FOR COMPLETING FORM B2
APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND
HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY
(continued)**

PART B – ADDITIONAL APPLICATION INFORMATION

10.-14. Self-explanatory

PART C – CERTIFICATION

15. Signature – All applications must be signed as follows and the signatures must be original:
- a. For a corporation, by an officer having responsibility for the overall operation of the regulated facility or activity or for environmental matters.
 - b. For a partnership or sole proprietorship, by a general partner or the proprietor.
 - c. For a municipal, state, federal or other public facility, by either a principal executive officer or by an individual having overall responsibility for environmental matters at the facility.

PART D – EXPANDED EFFLUENT TESTING DATA

16. Self-explanatory. ML/MDL means minimum limit or minimum detection limit.

PART E – TOXICITY TESTING DATA

17. Self-explanatory.

PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES

18. Federal regulations are available through the U.S. Government Printing Office at www.gpoaccess.gov/cfr/index.html.
- 18.1 Self-explanatory
- 18.2 A non-categorical significant industrial user is an industrial user that is not a CIU and meets one or more of the following:
- i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - ii. Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - iii. Is designated as an SIU by the control authority.

- 19.-21.4 Self-explanatory.

PART G – COMBINED SEWER SYSTEMS

- 22.-23.4 Self-explanatory.

Submittal of an incomplete application may result in the application being returned.

This completed form and any attachments along with the applicable permit fees, should be submitted to:

Department of Natural Resources
Water Protection Program
ATTN: NPDES Permits and Engineering Section
P.O. Box 176
Jefferson City, MO 65102

If there are any questions concerning this form, contact the appropriate Department of Natural Resources regional office or the Water Protection Program at 573-751-6825. A map of the department's regional offices with addresses and phone numbers is available at www.dnr.mo.gov/regions/ro-map.pdf.