# STATE OF MISSOURI

# **DEPARTMENT OF NATURAL RESOURCES**

# MISSOURI CLEAN WATER COMMISSION



# **MISSOURI STATE OPERATING PERMIT**

In compliance with the Missouri Clean Water Law, (Chapter 644 RSMo, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

MO-0030970
City of St. Peters
One St. Peters Centre Boulevard, St. Peters, MO 63376
Same as above
Same as above
St. Peters Spencer Creek Sewage Treatment Plant
100 Ecology Drive, St. Peters, MO 63376
See Page 2

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

# FACILITY DESCRIPTION

See Page 2

This permit authorizes only wastewater and stormwater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas.

February 1, 2022 Effective Date

April 1, 2022 Modification Date

December 31, 2024 **Expiration Date** 

Chris Wieberg, Director, Water Protymon Program

#### FACILITY DESCRIPTION (continued):

#### Outfall #001 - POTW

The use or operation of this facility shall be by or under the supervision of a Certified <u>A</u> Operator. Influent lift station / first flush concrete basin / four (4) earthen basins used for flow equalization or sludge storage / mechanical screening / grit removal / two (2) oxidation ditches / three (3) clarifiers / UV disinfection / reaeration tank with effluent pump station / two (2) aerated sludge holding tanks / two (2) sludge presses / sludge is composted in eight (8) aerated compost bins / "Class A" composted biosolids are sold and distributed from the facility / "Class B" biosolids are land applied

Design population equivalent is 82,194. Design flow is 9.5 MGD. Actual flow is 5.9 MGD. Design sludge production is 3,800 dry tons/year, but may vary due to composting sludge/biosolids from other wastewater treatment facilities.

Legal Description:	Land Grant 1799, St. Charles County
UTM Coordinates:	X = 707945, Y = 4297652
Receiving Stream:	Spencer Creek (C) (3960)
First Classified Stream and ID:	100K Extent-Remaining Streams (C) (3960)
USGS Basin & Sub-watershed No.:	(07110009-0105)

Permitted Feature INF - Influent Monitoring Location - Headworks Building, following screening and grit removal

OUTFALL <u>#001</u>

# TABLE A-1. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in **Table A-1** shall become effective on <u>February 1, 2022</u> and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

#### Limit Set: M

	FINAL EFF		FLUENT LIMITATIONS		MONITORING REQUIREMENTS	
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	MGD	*		*	once/day	24 hr. total
Biochemical Oxygen Demand <sub>5</sub>	mg/L		22	15	once/month	composite**
Total Suspended Solids	mg/L		33	18	once/month	composite**
E. coli (Note 1, Page 4)	#/100mL		1,030	206	once/week	grab
Total Phosphorus	mg/L	*		*	once/month	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/month	composite**
Nitrite + Nitrate	mg/L	*		*	once/month	composite**
Ammonia as N (January) Ammonia as N (February) Ammonia as N (March) Ammonia as N (April) Ammonia as N (April) Ammonia as N (June) Ammonia as N (July) Ammonia as N (August) Ammonia as N (September) Ammonia as N (October) Ammonia as N (November) Ammonia as N (December)	mg/L	* * * * * * 32.9 *		* * * * * 3.1 *	once/month	composite**
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.0		9.0	once/month	grab
EFFLUENT PARAMET	ER(S)		UNITS	MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Biochemical Oxygen Demand <sub>5</sub> – Percent Removal (Note 2, Pa		2, Page 4)	%	85	once/month	calculated
Total Suspended Solids – Percent Removal (Note 2, Page 4)			%	85	once/month	calculated
MONITORING REPORTS SHALL BE SUBMI NO DISCHARGE OF FLOATING SOLIDS OR	TTED <u>MONT</u> VISIBLE FOA	` <u>HLY</u> ; THE NE AM IN OTHER	EXT REPORT THAN TRACI	IS DUE <u>MAR</u> E AMOUNTS.	<u>RCH 28, 2022</u> . THERE	E SHALL BE
Limit Set: Q						
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Oil & Grease	mg/L	15		10	once/quarter <sup>†</sup>	grab
MONITORING REPORTS SHALL BE SUBMI	TTED OLAR	TERLY THE	NEXT REPOR	T IS DUE A	PRIL 28 2022 THER	E SHALL BE

NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

\* Monitoring requirement only.

\*\* A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

\*\*\* pH is measured in pH units and is not to be averaged.

† See table on Page 5 for quarterly sampling.

Page 4 of 11 Permit No. MO-0030970

- Note 1 Effluent limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean. The Weekly Average for *E. coli* will be expressed as a geometric mean if more than one (1) sample is collected during a calendar week (Sunday through Saturday).
- Note 2 Influent sampling for  $BOD_5$  and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected at the influent and effluent monitoring locations during the same month. Calculate Percent Removal by using the following formula: [(Average Influent Concentration – Average Effluent Concentration) / Average Influent Concentration] x 100% = Percent Removal. The Average Influent and Average Effluent concentration values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

OUTFALL <u>#001</u>	TABLE A-2.           #001         INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS						
The permittee is the final effluen limitations in Ta discharges shall	The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. In accordance with 10 CSR 20-7.031, the final effluent limitations outlined in <b>Table A-3</b> must be achieved as soon as possible but no later than <u>February 1, 2032</u> . These interim effluent limitations in <b>Table A-2</b> are effective beginning <u>February 1, 2022</u> and remain in effect through <u>January 31, 2032</u> or as soon as possible. Such discharges shall be controlled limited and monitored by the permittee as specified below:						
יין דענענע		LINITS	INTI L	ERIM EFFLU IMITATION	JENT IS	MONITORING RE	QUIREMENTS
LITLU.	ENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: Q							
Chloride		mg/L	*		*	once/quarter <sup>†</sup>	composite**
MONITORING	REPORTS SHALL BE SUBMIT	TED <b>QUART</b>	ERLY; THE	FIRST REPO	RT IS DUE <u>AF</u>	PRIL 28, 2022.	
OUTFALL <u>#001</u>	OUTFALL     TABLE A-3.       #001     FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS						
The permittee is limitations in <b>T</b> a specified below	The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations in <b>Table A-3</b> shall become effective on <u>February 1, 2032</u> . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
		FINAL EFFLUENT LIMITATIONS MONITORING REQUIREMENTS				QUIREMENTS	
EFFLU.	ENI PAKAMETEK(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: Q							
Chloride		mg/L	301.2		210.6	once/quarter <sup>†</sup>	composite**
MONITORING REPORTS SHALL BE SUBMITTED <b>QUARTERLY</b> ; THE FIRST REPORT IS DUE <u>APRIL 28, 2032</u> .							

\* Monitoring requirement only.

\*\* A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

<sup>†</sup> See table below for quarterly sampling.

	Quarterly Minimum Sampling Requirements					
Quarter	Months	Quarterly Effluent Parameters	Report is Due			
First	January, February, March	Sample at least once during any month of the quarter	April 28th			
Second	April, May, June	Sample at least once during any month of the quarter	July 28th			
Third	July, August, September	Sample at least once during any month of the quarter	October 28 <sup>th</sup>			
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th			

PERMITTED FEATURE INF

#### TABLE B-1. INFLUENT MONITORING REQUIREMENTS

The monitoring requirements in **Table B-1** shall become effective on <u>February 1, 2022</u> and remain in effect until expiration of the permit. The influent wastewater shall be monitored by the permittee as specified below:

			MON	ITORING RE(	QUIREMENTS	
PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: IM						•
Biochemical Oxygen Demand <sub>5</sub> (Note 2)	mg/L			*	once/month	composite**
Total Suspended Solids (Note 2)	mg/L			*	once/month	composite**
Ammonia as N	mg/L	*		*	once/month	composite**
Total Phosphorus	mg/L	*		*	once/month	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/month	composite**
Nitrite + Nitrate	mg/L	*		*	once/month	composite**
MONITORING REPORTS SHALL BE SUBMITTED <b>MONTHLY</b> : THE FIRST REPORT IS DUE MARCH 28, 2022.						

\* Monitoring requirement only.

\*\* A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

Note 2 – Influent sampling for  $BOD_5$  and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected at the influent and effluent monitoring locations during the same month. Calculate Percent Removal by using the following formula: [(Average Influent Concentration – Average Effluent Concentration) / Average Influent Concentration] x 100% = Percent Removal. The Average Influent and Average Effluent concentration values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

## **D. SCHEDULE OF COMPLIANCE**

The facility shall attain compliance with final effluent limitations in Table A-3 as soon as possible but in no case later than **ten** (10) **years** of the effective date of this permit. The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limits every 12 months from the effective date of this permit.

- 1. For the 1<sup>st</sup>, 2<sup>nd</sup>, and 3<sup>rd</sup> years of this schedule of compliance, the permittee shall submit annual interim progress reports detailing progress made in developing a budget and acquiring consultant services, as needed, to outline and develop a chloride evaluation plan for the discharge of Outfall #001. The first report is due **February 1, 2023**, or sooner, with subsequent reports due annually.
- 2. For the 4<sup>th</sup>, 5<sup>th</sup>, and 6<sup>th</sup> years of this schedule of compliance, the permittee shall submit annual interim progress reports which evaluate the potential mechanisms for chloride reduction, which may include, but are not limited to:
  - (a) Identifying other sources of chlorides discharging to the St. Peters Spencer Creek STP and eliminate or regulate through the pretreatment program,
  - (b) Outfall relocation for the St. Peters Spencer Creek STP to allow for mixing, and/or
  - (c) Any other potential chloride treatment technologies.
  - The fourth report is due **February 1, 2026**, or sooner, with subsequent results due annually.
- 3. For the 7<sup>th</sup>, 8<sup>th</sup>, 9<sup>th</sup>, and 10<sup>th</sup> years of this schedule of compliance, the permittee shall submit annual interim progress reports which indicates the budget, the chloride reduction plan, and the selected method(s) to reduce chloride discharges from Outfall #001. The seventh report is due **February 1, 2027** or sooner, with subsequent reports due annually.

Please submit progress reports to the Missouri Department of Natural Resources via the Electronic Discharge Monitoring Report (eDMR) Submission System. During this schedule of compliance, the facility may choose to submit a request for site-specific criteria and associated site-specific effluent limitations per 10 CSR 7.015(9)(A).

### **E. STANDARD CONDITIONS**

In addition to specified conditions stated herein, this permit is subject to the attached <u>Parts I, II, & III</u> standard conditions dated <u>August 1, 2014, May 1, 2013, and August 1, 2019</u>, and hereby incorporated as though fully set forth herein. The permittee has been granted approval for alternative compost testing frequency in accordance with Standard Conditions Part III. This approval is limited to the monitoring frequency as listed below and does not apply to the other requirements outlined in Standard Conditions Part III. The applicable alternative monitoring frequencies are:

Compost Testing Parameter	Frequency	Sample Location
Priority Pollutants	Once per permit cycle	Sludge Holding Tanks

#### **F. SPECIAL CONDITIONS**

- 1. <u>Electronic Discharge Monitoring Report (eDMR) Submission System</u>. Per 40 C.F.R. Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent monitoring data and any report required by the permit (unless specifically directed otherwise by the permit) shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally consistent set of data about the NPDES program.
  - (a) eDMR Registration Requirements. The permittee must register with the Department's eDMR system through the Missouri Gateway for Environmental Management (MoGEM) before the first report is due. Registration and other information regarding MoGEM can be found at <u>https://dnr.mo.gov/mogem</u>. Information about the eDMR system can be found at <u>https://dnr.mo.gov/env/wpp/edmr.htm</u>. The first user shall register as an Organization Official and the association to the facility must be approved by the Department. Regarding Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit unless a waiver is granted by the department. See paragraph (c) below.
  - (b) Electronic Submissions. To access the eDMR system, use the following link in your web browser: <u>https://apps5.mo.gov/mogems/welcome.action</u> If you experience difficulties with using the eDMR system you may contact <u>edmr@dnr.mo.gov</u> or call 855-789-3889 or 573-526-2082 for assistance.
  - (c) Waivers from Electronic Reporting. The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the department in compliance with 40 C.F.R. Part 127. Only permittees with an approved waiver request may submit monitoring data and reports on paper to the Department for the period that the approved electronic reporting waiver is effective. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: <u>http://dnr.mo.gov/forms/780-2692-f.pdf</u>. The department will either approve or deny this electronic reporting waiver request within 120 calendar days.
- 2. The full implementation of this operating permit, which includes implementation of any applicable schedules of compliance, shall constitute compliance with all applicable federal and state statutes and regulations in accordance with §644.051.16, RSMo, and the Clean Water Act (CWA) section 402(k); however, this permit may be reopened and modified, or alternatively revoked and reissued:
  - (a) To comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) To incorporate an approved pretreatment program or modification thereto pursuant to 40 C.F.R. § 403.8(c) or 40 C.F.R. § 403.18(e), respectively.
- 3. All outfalls must be clearly marked in the field.
- 4. Report as no-discharge when a discharge does not occur during the report period.
- 5. Reporting of Non-Detects:
  - (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
  - (b) The permittee shall not report a sample result as "Non-Detect" without also reporting the detection limit of the test. Reporting as "Non Detect" without also including the detection limit will be considered failure to report, which is a violation of this permit.
  - (c) The permittee shall provide the "Non-Detect" sample result using the less than sign and the minimum detection limit (e.g. <10).

### F. SPECIAL CONDITIONS (continued)

- (d) Where the permit contains a Minimum Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
- (e) See Standard Conditions Part I, Section A, #4 regarding proper detection limits used for sample analysis.
- (f) When a parameter is not detected above ML, the permittee must report the data qualifier signifying less than ML for that parameter (e.g.,  $< 50 \mu g/L$ , if the ML for the parameter is  $50 \mu g/L$ ). For reporting an average based on a mix of values detected and not detected, assign a value of "0" for all non-detects for that reporting period and report the average of all the results.
- 6. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).
- 7. The permittee shall comply with any applicable requirements listed in 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. To request a modification of the operational control testing requirements listed in 10 CSR 20-9, the permittee shall submit a permit modification and fee to the Department requesting a deviation from the operational control monitoring requirements. Upon approval of the request, the Department will modify the permit.
- 8. The permittee shall develop and implement a program for maintenance and repair of its collection system. The permittee may compare collection system performance results and other data with the benchmarks used in the Departments' Capacity, Management, Operation, And Maintenance (CMOM) Model located at <a href="http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc">http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc</a>. Additional information regarding the Departments' CMOM Model is available at <a href="http://dnr.mo.gov/pubs/pub2574.htm">http://dnr.mo.gov/pubs/pub2574.htm</a>.

The permittee shall also submit a report via the Electronic Discharge Monitoring Report (eDMR) Submission System annually, by January 28<sup>th</sup>, for the previous calendar year. The report shall contain the following information:

- (a) A summary of the efforts to locate and eliminate specific sources of excessive infiltration and inflow into the collection system serving the facility for the previous year.
- (b) A summary of the general maintenance and repairs to the collection system serving the facility for the previous year.
- (c) A summary of any planned maintenance and repairs to the collection system serving the facility for the upcoming calendar year. This list shall include locations (GPS, 911 address, manhole number, etc.) and actions to be taken.
- 9. Bypasses are not authorized at this facility unless they meet the criteria in 40 C.F.R. § 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 C.F.R. § 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2. Bypasses are to be reported to the St. Louis Regional Office during normal business hours or by using the online Sanitary Sewer Overflow/Facility Bypass Application located at: <u>https://dnr.mo.gov/mogem/</u> or the Environmental Emergency Response spill-line at 573-634-2436 outside of normal business hours. Once an electronic reporting system compliant with 40 C.F.R. Part 127, the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, is available all bypasses must be reported electronically via the new system. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
- 10. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.
- 11. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
- 12. An all-weather access road to the treatment facility shall be maintained.
- 13. The outfall sewer shall be protected and maintained against the effects of floodwater, ice, or other hazards as to reasonably insure its structural stability, freedom from stoppage, and that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
- 14. The storage basin(s) shall be operated and maintained to ensure their structural integrity, which includes maintaining adequate freeboard and keeping the berms free of deep-rooted vegetation, animal dens, or other potential sources of damage.

#### F. SPECIAL CONDITIONS (continued)

15. The facility shall ensure that adequate provisions are provided to prevent or minimize surface water intrusion into the storage basin and to divert stormwater runoff around the storage basin and protect embankments from erosion.

#### 16. Expanded Effluent Testing

Permittee must sample and analyze for the pollutants listed in Form B2 – Application for Operating Permit for Facilities That Receive Primarily Domestic Waste And Have A Design Flow More Than 100,000 Gallons Per Day (MO-780-1805 dated 02-19), Part D – Expanded Effluent Testing Data, #18. The permittee shall provide this data with the permit renewal application. A minimum of three samples taken within four and one-half years prior to the date of the permit application must be provided. Samples must be representative of the seasonal variation in the discharge from each outfall. Approved and sufficiently sensitive testing methods listed in 40 C.F.R. § 136.3 must be utilized. A method is "sufficiently sensitive" when; 1) The method minimum level is at or below the level of the applicable water quality criterion for the measured pollutant or pollutant parameter; or 2) the method minimum level is above the applicable water quality criterion, but the amount of the pollutant or pollutant parameter in a facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or 3) the method has the lowest minimum level of the analytical methods approved under 40 C.F.R. Part 136. These methods are also required for parameters listed as monitoring only, as the data collected may be used to determine if numeric limitations need to be established.

17. <u>Stormwater Pollution Prevention Plan (SWPPP)</u>: A SWPPP must be implemented upon permit issuance. Through implementation of the SWPPP, the permittee shall minimize the release of pollutants in stormwater from the facility to the waters of the state. The SWPPP shall be developed in consultation with the concepts and methods described in the following document: <u>Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators</u>, (Document number EPA 833-B-09-002) published by the United States Environmental Protection Agency (USEPA) in June 2015.

- (a) The SWPPP must identify any stormwater outfall from the facility and Best Management Practices (BMPs) used to prevent or reduce the discharge of contaminants in stormwater. The stormwater outfalls shall either be marked in the field or clearly marked on a map and maintained with the SWPPP.
- (b) The SWPPP must include a schedule and procedures for a <u>once per month</u> routine site inspection.
  - (1) The monthly routine inspection shall be documented in a brief written report, which shall include:
    - i. The person(s) conducting the inspection.
    - ii. The inspection date and time.
    - iii. Weather information for the day of the inspection.
    - iv. Precipitation information for the entire period since the last inspection.
    - v. Description of the discharges observed, including visual quality of the discharges (sheen, turbid, etc.).
    - vi. Condition of BMPs
    - vii. If BMPs were replaced or repaired.
    - viii. Observations and evaluations of BMP effectiveness.
  - (2) Any deficiency observed during the routine inspection must be corrected within seven (7) days and the actions taken to correct the deficiencies shall be included with the written report.
  - (3) The routine inspection reports must be kept onsite with the SWPPP and maintained for a period of five (5) years.
  - (4) The routine inspection reports shall be made available to Department personnel upon request.
- (c) The SWPPP must include a schedule and procedures for a <u>once per year</u> comprehensive site inspection.
  - (1) The annual comprehensive inspection shall be documented in a written report, which shall include:
    - i. The person(s) conducting the inspection.
    - ii. The inspection date and time.
    - iii. Findings from the areas of your facility that were examined;
    - iv. All observations relating to the implementation of your control measures including:
      - 1. Previously unidentified discharges from the site,
      - 2. Previously unidentified pollutants in existing discharges,
      - 3. Evidence of, or the potential for, pollutants entering the drainage system;
      - 4. Evidence of pollutants discharging to receiving waters at all facility outfall(s), and the condition of and around the outfall, and
      - 5. Additional control measures needed to address any conditions requiring corrective action identified during the inspection.
    - v. Any required revisions to the SWPPP resulting from the inspection;
    - vi. Any incidence of noncompliance observed or a certification stating that the facility is in compliance with Special Condition F.18.
  - (2) Any deficiency observed during the comprehensive inspection must be corrected within seven (7) days and the actions taken to correct the deficiencies shall be included with the written report.
  - (3) The comprehensive inspection reports must be kept onsite with the SWPPP and maintained for a period of five (5) years.
  - (4) The comprehensive inspection reports shall be made available to Department personnel upon request.

#### F. SPECIAL CONDITIONS (continued)

- (d) The SWPPP must be kept on-site and should not be sent to the Department unless specifically requested.
- (e) The SWPPP must be reviewed and updated at a minimum once per permit cycle, as site conditions or control measures change.
- 18. The permittee shall select, install, use, operate, and maintain the Best Management Practices prescribed in the SWPPP.
  - (a) Permittee shall adhere to the following minimum Best Management Practices (BMPs):
    - (1) Minimize the exposure of industrial material storage areas, loading and unloading areas, dumpsters and other disposal areas, maintenance activities, and fueling operations to rain, snow, snowmelt, and runoff, by locating industrial materials and activities inside or protecting them with storm resistant coverings, if warranted and practicable.
    - (2) Provide good housekeeping practices on the site to prevent potential pollution sources from coming into contact with stormwater and provide collection facilities and arrange for proper disposal of waste products, including sludge.
    - (3) Implement a maintenance program to ensure that the structural control measures and industrial equipment is kept in good operating condition and to prevent or minimize leaks and other releases of pollutants.
    - (4) Prevent or minimize the spillage or leaks of fluids, oil, grease, fuel, etc. from equipment and vehicle maintenance, equipment and vehicle cleaning, or activities.
    - (5) Provide sediment and erosion control sufficient to prevent or control sediment loss off of the property. This could include the use of straw bales, silt fences, or sediment basins, if needed.
    - (6) Provide stormwater runoff controls to divert, infiltrate, reuse, contain, or otherwise minimize pollutants in the stormwater discharge.
    - (7) Enclose or cover storage piles of salt or piles containing salt, used for deicing or other commercial or industrial purposes.
    - (8) Provide training to all employees who; work in areas where industrial materials or activities are exposed to stormwater, are responsible for stormwater inspections, are members of the Pollution Prevention Team. Training must cover the specific control measures and monitoring, inspection, planning, reporting and documentation requirements of this permit. Training is recommended annually for any applicable staff and whenever a new employee is hired who meets the description above.
    - (9) Eliminate and prevent unauthorized non-stormwater discharges at the facility.
    - (10) Minimize generation of dust and off-site tracking of raw, final, or waste materials by implementing appropriate control measures.
- 19. <u>Pretreatment:</u> The permittee shall implement and enforce its approved pretreatment program in accordance with the requirements of 10 CSR 20-6.100. The approved pretreatment program is hereby incorporated by reference.
  - (a) The permittee shall submit to the Department via the Electronic Discharge Monitoring Report (eDMR) Submission System on or before <u>March 31<sup>st</sup></u> of each year a report briefly describing its pretreatment activities during the previous calendar year. At a minimum, the report shall include the following:
    - (1) An updated list of the Permittee's Industrial Users, including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The Permittee shall provide a brief explanation of each deletion. This list shall identify which Industrial Users are subject to categorical pretreatment Standards and specify which Standards are applicable to each Industrial User. The list shall indicate which Industrial Users are subject to local standards that are more stringent than the categorical Pretreatment Standards. The Permittee shall also list the Industrial Users that are subject only to local Requirements;
    - (2) A summary of the status of Industrial User compliance over the reporting period;
    - (3) A summary of compliance and enforcement activities (including inspections) conducted by the Permittee during the reporting period; and
    - (4) Any other relevant information requested by the Department.
  - (b) Pursuant to 40 C.F.R. § 122.44(j)(2)(ii), the permittee shall submit to the Department a written technical evaluation of the need to revise local limits under 40 CFR 403.5(c)(1) by <u>August 1, 2022</u>. Please contact the Department's pretreatment coordinator for further guidance. Should revision of local limits be deemed necessary, it is recommended that revisions follow the US Environmental Protection Agency's guidance document *Local Limits Development Guidance*. EPA833-R04-002A. July 2004.

Page 10 of 11 Permit No. MO-0030970

#### 20. Sewer Extension Authority Supervised Program

The Department approved the Sewer Extension Authority Supervised Program for the City of St. Peters to regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility on November 1, 2017. The City of St. Peters shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. This approval may be modified or revoked by the Department if the wastewater collection, transportation, or treatment facilities reach their design capacity, if the treatment facility falls into chronic noncompliance with the permit, or if the permittee fails to follow the terms and conditions of the submitted and approved program.

This permit may be reopened and modified or alternatively revoked and reissued to incorporate new or modified conditions to the Sewer Extension Authority Supervised Program, if information indicates changes are necessary to assure compliance with Missouri's Clean Water Law and associated regulations. When any of the above mentioned conditions occur, the permittee will be notified prior to any modifications of this permit condition. Plans and specifications for all projects which include a proposed sanitary sewer overflow must be submitted to the Department to provide record information for location and size of the sanitary sewer overflow.

An annual report on the Sewer Extension Authority Supervised Program must be submitted by <u>January 28</u> of each year to the Missouri Department of Natural Resources' Water Protection Program's Engineering Section. Please see **Appendix – Sewer Extension Authority Supervised Program Reauthorization Letter** for applicable conditions.

The Department's Water Protection Program's Engineering Section will reevaluate the City's Sewer Extension Authority Supervised Program for reauthorization when they file an application for permit renewal to determine if it is current, complete, and meets the requirements of 10 CSR 20-8 Minimum Design Standards. Once the Sewer Extension Authority Supervised Program is reauthorized or denied, this condition will be updated accordingly.

- 21. Biosolids Composting Requirements for General Public Use:
  - (a) Applicability. A sewage sludge compost product will be considered suitable for general public use when the permittee meets the requirements under this permit special condition. General public use means the compost is for crops and vegetation including use in residential areas, public use areas and for horticulture, silviculture and agricultural uses.
  - (b) Composting Facility Description.
    - (1) Raw materials will consist of dewatered sewage sludge or biosolids, wood chips, yard waste, or other compostable materials.
  - (c) If the compost is to be distributed to the public it shall meet the Class A requirements for pathogen reduction by having undergone one of the Processes to Further Reduce Pathogens found in Appendix B of 40 C.F.R. § 503.
  - (d) The permittee will maintain a detailed operations plan for the composting process.
  - (e) Information Sheet for Users.

An information/instruction sheet shall be provided to each user of compost to provide information on the origin of the compost, appropriate application rates, and other pertinent information for proper handling and use of the compost.

(f) Annual Use Rate. Compost that is land applied by the permit holder shall not exceed the most restrictive of the following criteria:

(1) Application rates shall not exceed the annual plant available nutrient requirements for nitrogen and phosphorus based on the vegetation to be grown, a realistic crop yield goal, soil testing results, and testing of the compost for nutrient content.

- (g) One Time or Occasional Use Rates. Compost that is used by the permit holder for soil amendments or land reclamation shall not exceed a total of 200 dry tons per acre on either a one time basis or a cumulative total over a five year period. Subsequent application rates shall not exceed the annual use rate listed above. The compost shall be incorporated into the soil by tillage practices as soon as practical after application.
- (h) Final Compost Monitoring.

Composite samples of the final compost product shall be collected at representative locations and monitored as described in 40 C.F.R. § 503 and Standard Conditions Part III.

- (i) Records and Reporting Requirements.
  - (1) Time, locations, and results shall be recorded for each monitoring requirement and maintained for at least five years. Copies of these records shall be made available to the Department upon request.
  - (2) The total quantity of compost distributed during the year must be recorded.
  - (3) An annual report shall be submitted by <u>February 19</u> summarizing compost activities monitoring. A copy of the individual laboratory reports and daily records need not be submitted unless requested by the Department. The reports shall be submitted to the Department via eDMR and to the EPA Region VII office as part of the annual sludge report.
- (j) Composted biosolids that do not meet the requirements for general public use may still be land applied in accordance with permit Standard Conditions Part III.

Page 11 of 11 Permit No. MO-0030970

- 22. <u>Renewal Application Requirements</u>. Per 40 CFR 122.21(j)(5)(iv), the applicant shall provide the results of four WET tests as follows:
  - (a) Results of a minimum of four quarterly tests for a year, from the year preceding the permit application, or
  - (b) Results from four tests performed at least annually in the four and one half year period prior to the application, provided the results show no appreciable toxicity using safety factor determined by the permitting authority.

#### **G. NOTICE OF RIGHT TO APPEAL**

If you were adversely affected by this decision, you may be entitled to pursue an appeal before the administrative hearing commission (AHC) pursuant to Sections 621.250 and 644.051.6 RSMo. To appeal, you must file a petition with the AHC within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission U.S. Post Office Building, Third Floor 131 West High Street, P.O. Box 1557 Jefferson City, MO 65102-1557 Phone: 573-751-2422 Fax: 573-751-5018 Website: https://ahc.mo.gov

# Missouri Department of Natural Resources Factsheet Addendum For Pretreatment Program Modification #MO-0030970 St. Peters Spencer Creek Sewage Treatment Plant

This addendum gives pertinent information regarding minor/simple modification(s) to the above listed operating permit for a public comment process. An addendum is not an enforceable part of a Missouri State Operating Permit.

In accordance with the state Clean Water Law, Chapter 644, RSMo and the Federal Clean Water Act, the city of St. Peters has an approved pretreatment program to meet the requirements of 40 CFR Part 403 and 10 CSR 20-6.100. The Department, as Approval Authority, reviewed the proposed program modifications and, by issuance if this permit, grants its approval as required by 40 CFR 403.18 and 10 CSR 20-6.100.

# Part I – Proposed Pretreatment Program Modification

☐ - The Department is required to Public Notice this program modification

The public notice of the Department of Natural Resources' intent to approve the city of St. Peters' pretreatment program modification has ended as of June 28, 2021. Due to delay in the permit renewal, the approval for this pretreatment modification was delayed. The pretreatment program is hereby approved pursuant to 40 CFR 403.18 (adopted in 10 CSR 20-6.100) and the city of St. Peters should proceed to implement the pretreatment program requirements.

City of St. Peters (city) modified its sewer user ordinance to include updated local limits after conducting a detailed reevaluation of local limit analysis that is part of this program modification. City of St. Peters Spencer Creek Sewage Treatment Plant established maximum allowable industrial loadings (MAILs) for the 15 EPA National Pollutants of Concern (POCs) and chloride. This ordinance change removed established maximum daily average concentration limits for previously established POCs and established monthly average limits MAILs (Exhibit B, 715.040 D) to be allocated to permitted industrial users based on need for a specific POCs. For these POCs, the revision of the local limits has increased the MAILs. St. Peter's ordinance also 1) clarified surcharge limits fees for conventional parameters (Exhibit A), 2) added authority for a monitoring waiver for categorical parameters, and 3) clarified definitions and the manager's authority in limit development. The city also updated its Enforcement Response Plan (ERP), which escalates enforcement action and references the city's updated legal authority. These changes could have a significant impact on the operation of the program, pursuant to 40 CFR 403.18(b)(7).

## Part II – Reason for the NPDES Permit Modification

In accordance with 40 CFR 403.18(e), "all modifications shall be incorporated into the POTW's NPDES permit upon approval. The permit will be modified to incorporate the approved modification in accordance with 40 CFR 122.63(g)." Upon the consent of the permittee, the Director may modify a permit to make the corrections or allowances for changes in the permitted activity listed in this section, without following the procedures of part 124. Any permit modification not processed as a minor modification under this section must be made for cause and with part 124 draft permit and public notice as required in § 122.62. Minor modifications include:

(g) Incorporate conditions of a POTW pretreatment program that has been approved in accordance with the procedures in 40 CFR 403.11 (or a modification thereto that has been approved in accordance with the procedures in 40 CFR 403.18) as enforceable conditions of the POTW's permits.

Date of addendum: 02/16/2022 Completed by: Todd Blanc, Missouri Industrial Pretreatment Coordinator Water Protection Program 314-416-2064 todd.blanc@dnr.mo.gov

# MISSOURI DEPARTMENT OF NATURAL RESOURCES FACT SHEET FOR THE PURPOSE OF RENEWAL OF MO-0030970

## ST. PETERS SPENCER CREEK SEWAGE TREATMENT PLANT

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollutant Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of <u>five</u> (5) years unless otherwise specified.

As per [40 C.F.R. Part 124.8(a)] and [10 CSR 20-6.020(1)(A)2.], a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Major facility.

# Part I – Facility Information

Facility Type: POTW

<u>Facility Description</u>: Influent lift station / first flush concrete basin / four (4) earthen basins used for flow equalization or sludge storage / mechanical screening / grit removal / two (2) oxidation ditches / three (3) clarifiers / UV disinfection / reaeration tank with effluent pump station / two (2) aerated sludge holding tanks / two (2) sludge presses / sludge is composted in eight (8) aerated compost bins / "Class A" composted biosolids are sold and distributed from the facility / "Class B" biosolids are land applied

Design population equivalent is 82,194.

Design flow is 9.5 MGD. Actual flow is 5.9 MGD.

Design sludge production is 3,800 dry tons/year, but may vary due to composting sludge/biosolids from other wastewater treatment facilities.

Application Date:	05/31/19
Expiration Date:	12/31/19

#### **OUTFALL(S) TABLE:**

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	14.7	Secondary	Municipal

#### Facility Performance History:

This facility was last inspected on September 6, 2018. The conditions of the facility at the time of inspection were found to be satisfactory.

Comments:

Changes in this permit include:

- The addition of monthly influent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia; and a schedule of compliance to meet final effluent limits for Chloride;
- The reduction of sampling and reporting frequencies for effluent BOD<sub>5</sub>, TSS, pH, and Ammonia from weekly to monthly;
- The removal of Acute and Chronic WET test requirements (See Special Condition #22), and instream monitoring;
- The increase of sampling and reporting frequencies for effluent Total Phosphorus and Total Nitrogen (speciated) from quarterly to monthly; and
- The revision of final effluent limits for Ammonia in accordance with the 2019 Total Ammonia Nitrogen Criteria Implementation Guidance.

See Part VI of the Fact Sheet for further information regarding the addition, revision, and removal of effluent parameters. Special conditions were updated to include expanded effluent testing requirements.

# Part II – Operator Certification Requirements

 $\checkmark$  This facility is required to have a certified operator.

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], the permittee shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.020(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Owned or operated by or for a

a of operated by of for a	
Municipalities	- State agency
- County	- Public Water Supply Districts
- Public Sewer District	- Private Sewer Company regulated by the Public Service Commission

Each of the above entities are only applicable if they have a Population Equivalent greater than two hundred (200).

This facility currently requires a chief operator with an  $\underline{A}$  Certification Level. Please see **Appendix - Classification Worksheet**. Modifications made to the wastewater treatment facility may cause the classification to be modified.

Operator's Name:	Heather Wierciak
Certification Number:	9818
Certification Level:	WW-A

The listing of the operator above only signifies that staff drafting this operating permit have reviewed appropriate Department records and determined that the name listed on the operating permit application has the correct and applicable Certification Level.

# Part III – Operational Control Testing Requirements

Missouri Clean Water Commission regulation 10 CSR 20-9.010 requires certain publicly owned treatment works and privately owned facilities regulated by the Public Service Commission to conduct internal operational control monitoring to further ensure proper operation of the facility and to be a safeguard or early warning for potential plant upsets that could affect effluent quality. This requirement is only applicable if the publicly owned treatment works and privately owned facilities regulated by the Public Service Commission has a Population Equivalent greater than two hundred (200).

10 CSR 20-9.010(3) allows the Department to modify the monitoring frequency required in the rule based upon the Department's judgement of monitoring needs for process control at the specified facility.

- ✓ As per [10 CSR 20-9.010(4))], the facility is required to conduct operational monitoring. These operational monitoring reports are to be submitted to the Department along with the MSOP discharge monitoring reports.
  - ✓ The facility is a mechanical plant and is required to conduct operational control monitoring as follows:

Operational Monitoring Parameter	Frequency
Precipitation	Daily (M-F)
Flow – Influent or Effluent	Daily (M-F)
pH – Influent	Daily (M-F)
Temperature (Aeration basin)	Daily (M-F)
TSS – Influent	Weekly
TSS – Mixed Liquor	Weekly
Settleability – Mixed Liquor	Daily (M-F)
Dissolved Oxygen – Mixed Liquor	Daily (M-F)

# Part IV – Receiving Stream Information

#### **RECEIVING STREAM(S) TABLE: OUTFALL #001**

WATER-BODY NAME	CLASS	WBID	DESIGNATED USES*	12-DIGIT HUC	DISTANCE TO CLASSIFIED SEGMENT (MI)
100K Extent Remaining Streams	С	3960	AQL, HHP, IRR, LWW, SCR, WBC-B	07110000 0105	0
Spencer Creek	С	224	AQL, HHP, IRR, LWW, SCR	0/110009-0105	0.33

\*As per 10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1<sup>st</sup> classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(C)].

Uses found in the receiving streams table, above:

10 CSR 20-7.031(1)(C)1.:

AQL = Protection of aquatic life (Current narrative use(s) are defined to ensure the protection and propagation of fish shellfish and wildlife, which is further subcategorized as: WWH = Warm Water Habitat; CDF = Cold-water fishery (Current narrative use is cold-water habitat.); CLF = Cool-water fishery (Current narrative use is cool-water habitat.); EAH = Ephemeral Aquatic Habitat; MAH = Modified Aquatic Habitat; LAH = Limited Aquatic Habitat. This permit uses AQL effluent limitations in 10 CSR 20-7.031 Table A for all habitat designations unless otherwise specified.)

10 CSR 20-7.031(1)(C)2.: Recreation in and on the water

WBC = Whole Body Contact recreation where the entire body is capable of being submerged;

**WBC-A** = Whole body contact recreation that supports swimming uses and has public access;

**WBC-B** = Whole body contact recreation that supports swimming;

**SCR** = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(C)3. to 7.:

**HHP** (formerly HHF) = Human Health Protection as it relates to the consumption of fish;

**IRR** = Irrigation for use on crops utilized for human or livestock consumption;

**LWW** = Livestock and wildlife watering (Current narrative use is defined as LWP = Livestock and Wildlife Protection); **DWS** = Drinking Water Supply;

**IND** = Industrial water supply

10 CSR 20-7.031(1)(C)8-11.: Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)

WSA = Storm- and flood-water storage and attenuation; WHP = Habitat for resident and migratory wildlife species;

WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses; WHC = Hydrologic cycle maintenance.

10 CSR 20-7.031(6): **GRW** = Groundwater

#### **RECEIVING STREAM(S) LOW-FLOW VALUES:**

DECENTING STREAM	LOW-FLOW VALUES (CFS)					
RECEIVING STREAM	1Q10	7Q10	30Q10			
100K Extent Remaining Streams	0	0	0			

#### MIXING CONSIDERATIONS TABLE:

	AIXING ZONE (CFS)		ZONE OF INITIAL DILUTION (CFS)			
[10  CSR  207.031(5)(A)4.B.(1)(a)]			[10  CSK  20- 1.031(3)(A)4.B(1)(0)]			
1Q10	7Q10	30Q10	1Q10	7Q10	30Q10	
0	0	0	0	0	N/A	

#### Receiving Water Body's Water Quality

Currently, the Department has not conducted a stream survey for this waterbody. When a stream survey is conducted, more information may be available about the receiving stream.

# Part V – Rationale and Derivation of Effluent Limitations & Permit Conditions

#### **ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:**

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream, and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

✓ The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(40)] & [10 CSR 20-7.031(1)(O)], or is an existing facility.

#### ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA § 303(d)(4); CWA §402(o); 40 C.F.R. § 122.44(l)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- ✓ Limitations in this operating permit for the reissuance of this permit conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 C.F.R. § 122.44.
  - Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.
    - <u>Ammonia as N</u>. Effluent limitations were re-calculated for Ammonia. The Department previously followed the 2007 Ammonia Guidance method for derivation of ammonia limits. However, the EPA's Technical Support Document for Water Quality-based Toxic Controls (TSD) establishes other alternatives to limit derivation. The Department has determined that the approach established in Section 5.4.2 of the TSD, which allows for direct application of both the acute and chronic wasteload allocations (WLA) as permit limits for toxic pollutants, is more appropriate limit derivation approach. Using this method for a discharge to a waterbody where mixing is not allowed, the criterion continuous concentration (CCC) and the criterion maximum concentration (CMC) will equal the chronic and acute WLA respectively. The WLAs are then applied as effluent limits, per Section 5.4.2 of the TSD, where the CMC is the Daily Maximum and the CCC is the Monthly Average. The direct application of both acute and chronic criteria as WLA is also applicable for facilities that discharge into receiving waterbodies with mixing considerations. The CCC and CMC will need to be calculated into WLA with mixing considerations using the mass-balance equation. The newly established limitations are still protective of water quality.
    - <u>Acute and Chronic WET Test Requirements</u>. The previous permit contained requirements for conducting Acute and Chronic WET tests. The facility has passed previous Acute and Chronic WET tests. The permit writer made a reasonable potential determination which concluded the facility does not have reasonable potential to exceed narrative water quality standards for acute and chronic toxicity at this time and the requirements have been removed from this permit. In order for a complete renewal application to be submitted the permittee must include appropriate WET test results. Federal regulations do not dictate the type of WET tests to be conducted (acute or chronic), therefore, the City may choose to submit the results of only acute WET tests to satisfy the application requirements set forth in 40 C.F.R. § 122.21. This permit remains protective of water quality and this determination will be reassessed at renewal.

- <u>Instream Total Phosphorus and Total Nitrogen Monitoring</u>. The previous permit contained upstream instream monitoring requirements for Total Phosphorus and Total Nitrogen. The Department has made a determination that monitoring of background nutrients is not needed. This permit is still protective of water quality and this determination will be reassessed at the time of renewal.
- <u>**pH**</u>. The previous permit contained final effluent limits of 6.5-9.0 SU. The permit writer reviewed discharge monitoring reports and determined there is no reasonable potential for the discharge to exceed the water quality standard of 6.5-9.0 SU. As a result, the limits for pH were reduced to 6.0-9.0 SU, which is consistent with 10 CSR 20-7.015. This permit is still protective of water quality and this determination will be reassessed at renewal.
- <u>Sampling and Reporting Frequencies</u>. The previous permit contained weekly sampling and reporting frequencies for BOD<sub>5</sub>, TSS, Ammonia, and pH, and monthly sampling and reporting frequencies for Oil & Grease. This permit contains monthly and quarterly sampling and reporting frequencies, respectively, due to consistency amongst effluent data and compliance with effluent limits. The permit is still protective of water quality.
- The Department determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
  - <u>General Criteria</u>. The previous permit contained a special condition which described a specific set of prohibitions related to general criteria found in 10 CSR 20-7.031(4). In order to comply with 40 C.F.R. § 122.44(d)(1), the permit writer has conducted reasonable potential determinations for each general criterion and established numeric effluent limitations where reasonable potential exists. While the removal of the previous permit special condition creates the appearance of backsliding, since this permit establishes numeric limitations where reasonable potential to cause or contribute to an excursion of the general criteria exists the permit maintains sufficient effluent limitations and monitoring requirements in order to protect water quality, this permit is equally protective as compared to the previous permit. Therefore, given this new information, and the fact that the previous permit special condition was not consistent with 40 C.F.R. § 122.44(d)(1), an error occurred in the establishment of the general criteria as a special condition of the previous permit. Please see Part VI Effluent Limits Determination for more information regarding the reasonable potential determinations for each general criterion related to this facility.

#### **ANTIDEGRADATION:**

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See <a href="http://dnr.mo.gov/env/wpp/permits/antideg-implementation.htm">http://dnr.mo.gov/env/wpp/permits/antideg-implementation.htm</a>

 No degradation proposed and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

For stormwater discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

✓ The facility does not have stormwater discharges or the stormwater outfalls onsite have no industrial exposure.

#### AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(2)(C)], An applicant may utilize a lower preference continuing authority by submitting, as part of the application, when a higher level authority is available, must submit information to the Department for review and approval, provided it does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

#### **BIOSOLIDS & SEWAGE SLUDGE:**

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

✓ Permittee is authorized to land apply biosolids in accordance with Standard Conditions III.

#### **COMPLIANCE AND ENFORCEMENT:**

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

✓ The facility is not currently under Water Protection Program enforcement action.

#### ELECTRONIC DISCHARGE MONITORING REPORT (EDMR) SUBMISSION SYSTEM:

The U.S. Environmental Protection Agency (EPA) promulgated a final rule on October 22, 2015, to modernize Clean Water Act reporting for municipalities, industries, and other facilities by converting to an electronic data reporting system. This final rule requires regulated entities and state and federal regulators to use information technology to electronically report data required by the National Pollutant Discharge Elimination System (NPDES) permit program instead of filing paper reports. To comply with the federal rule, the Department is requiring all permittees to begin submitting discharge monitoring data and reports online. In an effort to aid facilities in the reporting of applicable information electronically, the Department has created several new forms including operational control monitoring forms and an I&I location and reduction form. These forms are optional and found on the Department's website at the following locations:

Operational Monitoring Lagoon: <u>http://dnr.mo.gov/forms/780-2801-f.pdf</u> Operational Monitoring Mechanical: <u>http://dnr.mo.gov/forms/780-2800-f.pdf</u> I&I Report: <u>http://dnr.mo.gov/forms/780-2690-f.pdf</u>

Per 40 C.F.R. §§ 127.15 and 127.24, permitted facilities may request a temporary waiver for up to 5 years or a permanent waiver from electronic reporting from the Department. To obtain an electronic reporting waiver, a permittee must first submit an eDMR Waiver Request Form: <u>http://dnr.mo.gov/forms/780-2692-f.pdf</u>. Each facility must make a request. If a single entity owns or operates more than one facility, then the entity must submit a separate request for each facility based on its specific circumstances. An approved waiver is non-transferable.

The Department must review and notify the facility within 120 calendar days of receipt if the waiver request has been approved or rejected [40 C.F.R. § 124.27(a)]. During the Department review period as well as after a waiver is granted, the facility must continue submitting a hard-copy of any reports required by their permit. The Department will enter data submitted in hard-copy from those facilities allowed to do so and electronically submit the data to the EPA on behalf of the facility.

✓ The permittee/facility is currently using the eDMR data reporting system.

#### NUMERIC LAKE NUTRIENT CRITERIA

✓ This facility does not discharge into a lake watershed where numeric lake nutrient criteria are applicable.

#### **PRETREATMENT PROGRAM:**

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 C.F.R. § 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users,
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation
- ✓ This permittee has an approved pretreatment program in accordance with the requirements of [40 C.F.R. Part 403] and [10 CSR 20-6.100] and is expected to implement and enforce its approved program.

#### **REASONABLE POTENTIAL ANALYSIS (RPA):**

Federal regulation [40 C.F.R. § 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 C.F.R. § 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

✓ An RPA was conducted on appropriate parameters. Please see APPENDIX – RPA RESULTS.

#### **REMOVAL EFFICIENCY:**

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD<sub>5</sub>) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

✓ Secondary Treatment is 85 percent removal [40 C.F.R. § 133.102(a)(3) & (b)(3)].

#### SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(12)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur. The permit requires that the permittee submit an annual report to the Department for the previous calendar year that contains a summary of efforts taken by the permittee to locate and eliminate sources of excess I&I, a summary of general maintenance and repairs to the collection system, and a summary of any planned maintenance and repairs to the collection system.

✓ At this time, the Department recommends the US EPA's Guide for Evaluating Capacity, Management, Operation and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems (Document # EPA 305-B-05-002) or the Departments' CMOM Model located at <u>http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc</u>. For additional information regarding the Departments' CMOM Model, see the CMOM Plan Model Guidance document at <u>http://dnr.mo.gov/pubs/pub2574.htm</u>. The CMOM identifies some of the criteria used to evaluate a collection system's management, operation, and maintenance and was intended for use by the EPA, state, regulated community, and/or third party entities. The CMOM is applicable to small, medium, and large systems; both public and privately owned; and both regional and satellite collection systems. The CMOM does not substitute for the Clean Water Act, the Missouri Clean Water Law, and both federal and state regulations, as it is not a regulation.

#### SCHEDULE OF COMPLIANCE (SOC)

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 C.F.R. § 122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 C.F.R. § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

#### A SOC is not allowed:

- For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 C.F.R. § 125.3.
- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study that may result in site-specific criteria or alternative effluent limits. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOCs, and attain a greater level of consistency, on April 9, 2015, the Department issued an updated policy on development of SOCs. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as a Cost Analysis for Compliance.

- ✓ The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(11)]. The facility has been given a schedule of compliance to meet final effluent limits for Chloride.
  - The facility has been granted ten (10) years to meet effluent limitations for Chloride at Outfall #001, which is reasonable in accordance with 40 C.F.R. § 122.47(a)(2) due to the difficulty of treating chloride in wastewater. All changes will require varying degrees of operational control, study, or infrastructure changes. The Department is providing the following options for the facility to meet the onus of as soon as practicable while keeping all options open for future compliance. These include, but are not limited to: identifying sources of chlorides discharging to the St. Peters Spencer Creek STP and eliminate or regulate through the pretreatment program, outfall relocation to allow for mixing, or other potential chloride treatment technologies.
  - It is because of these permutations, the Department is granting a ten (10) year schedule of compliance as iterative infrastructure and technological changes take time to gather information, plan, and obtain funding approvals.

Year(s)	Milestone(s)
1 – 3	Develop budgeting and acquire consultant services as needed to outline and develop a chloride evaluation plan for the discharge of Outfall #001.
4 - 6	Evaluate potential mechanisms for chloride reduction.
7 – 10	Develop budget, provide chloride reduction plan, and select method(s) to reduce chloride discharge from Outfall #001.

#### Milestones during the Ten (10) Year Schedule of Compliance

#### SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM:

In accordance with [10 CSR 20-6.010(6)(A)], the Department may grant approval of a permittee's Sewer Extension Authority Supervised Program. These approved permittees regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility. The permittee shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. See <a href="http://dnr.mo.gov/env/wpp/permits/sewer-extension.htm">http://dnr.mo.gov/env/wpp/permits/sewer-extension.htm</a>.

✓ The permittee's Sewer Extension Authority Supervised Program is currently under review for reauthorization.

#### **STORMWATER POLLUTION PREVENTION PLAN (SWPPP):**

In accordance with 40 C.F.R. § 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in June 2015], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 C.F.R. § 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and re-evaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. For further guidance, consult the antidegradation implementation procedure (http://dnr.mo.gov/env/wpp/docs/AIP050212.pdf).

Alternative Analysis (AA) evaluation of the BMPs is a structured evaluation of BMPs that are reasonable and cost effective. The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why "no discharge" or "no exposure" is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure* (AIP), Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review; and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the Department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs. The request shall be submitted in the form of an operating permit modification; the application is found at: http://dnr.mo.gov/forms/index.html.

✓ 10 CSR 20-6.200 and 40 C.F.R. § 122.26(b)(14)(ix) includes treatment works treating domestic sewage or any other sewage sludge or wastewater treatment device or system, used in the storage treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated to the disposal of sewage sludge that is located within the confines of the facility, with a design flow of 1.0 MGD or more, or are required to have an approved pretreatment program under 40 C.F.R. part 403, as an industrial activity in which permit coverage is required. In lieu of requiring sampling in the site-specific permit, the facility is required to develop and implement a Stormwater Pollution Prevention Plan (SWPPP).

A facility can apply for conditional exclusion for "no exposure" of industrial activities and materials to stormwater by submitting a permit modification via Form B2 (<u>http://dnr.mo.gov/forms/780-1805-f.pdf</u>) appropriate application filing fees and a completed No Exposure Certification for Exclusion from NPDES Stormwater Permitting under Missouri Clean Water Law (<u>https://dnr.mo.gov/forms/780-2828-f.pdf</u>) to the Department's Water Protection Program, Operating Permits Section. Upon approval of the No Exposure Certification, the permit will be modified and the Special Condition to develop and implement a SWPPP will be removed.

#### VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

 $\checkmark$  This operating permit is not drafted under premises of a petition for variance.

#### WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(86)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

✓ Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$Ce = \frac{(Qe + Qs)C - (Qs \times Cs)}{(Qe)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where	C = downstream concentration	Ce = effluent concentration
	Cs = upstream concentration	Qe = effluent flow
	Qs = upstream flow	

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

#### Number of Samples "n":

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of "n" for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for "n" must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is "n = 4" at a minimum. For Total Ammonia as Nitrogen, "n = 30" is used.

#### WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

✓ A WLA study was either not submitted or determined not applicable by Department staff.

#### WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures that the provisions in the 10 CSR 20-6.010(8)(A) and the Water Quality Standards 10 CSR 20-7.031(4)(D),(F),(G),(J)2.A & B are being met. Under [10 CSR 20-6.010(8)(B)], the Department may require other terms and conditions that it deems necessary to assure compliance with the Clean Water Act and related regulations of the Missouri Clean Water Commission. In addition the following MCWL apply: §§§644.051.3 requires the Department to set permit conditions that comply with the MCWL and CWA; 644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits, pretreatment, etc...); and 644.051.5 is the basic authority to require testing conditions. WET test will be required by facilities meeting the following criteria:

- Facility is a designated Major.
- Facility continuously or routinely exceeds its design flow.
- Facility that exceeds its design population equivalent (PE) for BOD<sub>5</sub> whether or not its design flow is being exceeded.
- Facility (whether primarily domestic or industrial) that alters its production process throughout the year.
- Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH<sub>3</sub>)
- Facility is a municipality with a Design Flow  $\geq$  22,500 gpd.
- Other please justify.
- ✓ At this time, the permittee is not required to conduct WET test for this facility. The previous permit contained requirements for conducting Acute and Chronic WET tests. The facility has passed previous WET tests and has shown consistent compliance with effluent limits. Therefore, the permit writer has made a reasonable potential determination which concluded the facility does not have reasonable potential to exceed narrative water quality standards for acute and chronic toxicity at this time and the acute and chronic WET testing requirements have been removed from this permit and will be revaluated at renewal. However, in order for a complete renewal application to be submitted, the permittee must include results for at least three WET tests. Federal regulations do not dictate the type of WET tests to be conducted (acute or chronic); therefore, the City may choose to submit the results of only acute WET tests to satisfy the application requirements set forth in 40 C.F.R. § 122.21. This permit remains protective of water quality.

#### 40 C.F.R. § 122.41(M) - BYPASSES:

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from "bypassing" untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 C.F.R. § 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 C.F.R. § 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 C.F.R. § 122.41(l)(6) and per Missouri's Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

✓ This facility does not anticipate bypassing.

#### 303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

✓ This facility discharges to Tributary to Spencer Creek, approximately 0.33 miles upstream from Spencer Creek (C) (224), which is listed on the 2018 Missouri 303(d) List for Chloride. This facility is considered to be a source of or has the potential to contribute to the impairment of Chloride. Once a TMDL is developed, the permit will be modified to include WLAs from the TMDL.

# Part VI – Effluent Limits Determination

#### **OUTFALL #001 – MAIN FACILITY OUTFALL**

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

#### **EFFLUENT LIMITATIONS TABLE:**

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
Flow	MGD	1	*		*	*/*	1/day	monthly	Т
BOD <sub>5</sub>	mg/L	1		22	15	22/15	1/month	monthly	С
TSS	mg/L	1		33	18	33/18	1/month	monthly	С
Escherichia coli**	#/100mL	1, 3		1,030	206	1,030/206	1/week	monthly	G
Total Phosphorus	mg/L	1	*		*	*/*	1/month	monthly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	*/*	1/month	monthly	С
Nitrite + Nitrate	mg/L	1	*		*	*/*	1/month	monthly	С
Ammonia as N (January) (February) (March) (April) (May) (June) (July) (August) (September) (October) (November) (December)	mg/L	2, 3	* * * * * * * * * * * * * * * * *		* * * * * 3.1 *	Apr – Sep: 5.5/1.0 Oct - Mar: 12.1/2.4	1/month	monthly	С
Oil & Grease	mg/L	1, 3	15		10	15/10	1/quarter	quarterly	G
Chloride	mg/L	2	301.2		210.6	*/*	1/quarter	quarterly	С
PARAMETER	Unit	Basis for Limits	Minimum		Maximum	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
рН	SU	1	6.5		9.0	6.5-9.0	1/month	monthly	G
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
BOD <sub>5</sub> Percent Removal	%	1			85	85	1/month	monthly	М
TSS Percent Removal	%	1			85	85	1/month	monthly	М

\* - Monitoring requirement only.

\*\* - #/100mL; the Monthly Average for E. coli is a geometric mean.

\*\*\* - Parameter not previously established in previous state operating permit.

#### **Basis for Limitations Codes:**

- State or Federal Regulation/Law 1.
- Water Quality Standard (includes RPA) 2
- 3. Water Quality Based Effluent Limits 4.
  - Antidegradation Review
- 5 Antidegradation Policy
- Water Quality Model 6.
- Best Professional Judgment 7. 8

TMDL or Permit in lieu of TMDL

\*\*\*\* - C = 24-hour composite

G = GrabT = 24-hr. total

M = Measured/calculated

9. WET Test Policy

10. Multiple Discharger Variance

11. Nutrient Criteria Implementation Plan

- **OUTFALL #001 DERIVATION AND DISCUSSION OF LIMITS:**
- Flow. In accordance with [40 C.F.R. § 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.
- Biochemical Oxygen Demand (BOD<sub>5</sub>). Operating permit retains 22 mg/L as a Weekly Average and 15 mg/L as a Monthly • Average, which were established in the 2008 Water Quality Review Sheet. The effluent limits were reassessed and verified that they are still protective of water quality. Please see the attached Water Quality Review Sheet.

- <u>Total Suspended Solids (TSS)</u>. Operating permit retains 33 mg/L as a Weekly Average and 18 mg/L as a Monthly Average, which were established in the 2008 Water Quality Review Sheet. The effluent limits were reassessed and verified that they are still protective of water quality. Please see the attached Water Quality Review Sheet.
- <u>Escherichia coli (E. coli)</u>. Monthly average of 206 per 100 mL as a geometric mean and Weekly Average of 1,030 per 100 mL as a geometric mean during the recreational season (April 1 October 31), for discharges within two miles upstream of segments or lakes with Whole Body Contact Recreation (B) designated use of the receiving stream, as per 10 CSR 20-7.015(9)(B). An effluent limit for both monthly average and weekly average is required by 40 C.F.R. § 122.45(d). The Geometric Mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected. For example: Five *E. coli* samples were collected with results of 1, 4, 6, 10, and 5 (#/100mL). Geometric Mean = 5<sup>th</sup> root of (1)(4)(6)(10)(5) = 5<sup>th</sup> root of 1,200 = 4.1 #/100mL.
- <u>Total Ammonia Nitrogen</u>. Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(5)(B)7.C. & Table B3]. Background total ammonia nitrogen = 0.01 mg/L. No mixing considerations allowed; therefore, WLA = appropriate criterion.

The Department previously followed the 2007 Ammonia Guidance method for derivation of ammonia limits. However, the EPA's Technical Support Document for Water Quality-based Toxic Controls (TSD) establishes other alternatives to limit derivation. The Department has determined that the approach established in Section 5.4.2 of the TSD, which allows for direct application of both the acute and chronic wasteload allocations (WLA) as permit limits for toxic pollutants, is more appropriate limit derivation approach. Using this method for a discharge to a waterbody where mixing is not allowed, the criterion continuous concentration (CCC) and the criterion maximum concentration (CMC) will equal the chronic and acute WLA respectively. The WLAs are then applied as effluent limits, per Section 5.4.2 of the TSD, where the CMC is the Daily Maximum and the CCC is the Monthly Average. The direct application of both acute and chronic criteria as WLA is also applicable for facilities that discharge into receiving waterbodies with mixing considerations. The CCC and CMC will need to be calculated into WLA with mixing considerations using the mass-balance equation:

$$Ce = \frac{(Qe + Qs)C - (Qs \times Cs)}{(Qe)}$$

 $\begin{array}{ll} \mbox{Where} & C = \mbox{downstream concentration} & Ce = \mbox{effluent concentration} \\ Cs = \mbox{upstream concentration} & Qe = \mbox{effluent flow} \\ Qs = \mbox{upstream flow} & \end{array}$ 

In the event that mixing considerations derive an AML less stringent than the MDL, the AML and MDL will be equal and based on the MDL.

Month	Temp (°C)*	pH (SU)*	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
January	14.9	7.2	5.3	29.5
February	14.3	7.2	5.4	29.5
March	14.5	7.1	5.6	32.9
April	16.7	7.1	4.9	32.9
May	20.8	7.1	3.8	32.9
June	23.2	7.2	3.0	28.7
July	25.0	7.0	3.0	34.6
August	24.4	7.0	3.1	36.1
September	24.6	7.0	3.0	34.6
October	23.8	7.1	3.1	32.9
November	17.5	7.0	4.9	36.1
December	15.6	6.9	5.7	39.2

\* Site-specific temperature, pH, and ammonia data were provided by the permittee.

#### <u>January – September; November – December</u>

Monitoring only for the above listed months. The reasonable potential analysis determined that Ammonia in this facility's discharge is unlikely to exceed water quality standards for Ammonia in these months.

## <u>October</u>

Chronic WLA:  $C_e = ((14.7 + 0.0)3.1 - (0.0 * 0.01))/14.7 = 3.1 \text{ mg/L}$ 

Acute WLA:  $C_e = ((14.7 + 0.0)32.9 - (0.0 * 0.01))/14.7 = 32.9 \text{ mg/L}$ 

> $[CV = 0.26, 99^{th} Percentile]$  $[CV = 0.26, 99^{th} Percentile]$

Chronic WLA = AML = **3.1** mg/L Acute WLA = MDL = **32.9** mg/L

- <u>Oil & Grease</u>. Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- <u>Total Phosphorus and Total Nitrogen (Speciated)</u>. Effluent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, and Nitrite + Nitrate are required per 10 CSR 20-7.015(9)(D)8.
- <u>pH</u>. 6.0-9.0 SU, per 10 CSR 20-7.015. This facility does not have reasonable potential to exceed the water quality standard for pH (6.5-9.0, per 10 CSR 20-7.030), and it was determined that the requirements listed in 10 CSR 20-7.015 are applicable.
- <u>Chloride</u>. Protection of Aquatic Life Chronic Criteria = 230 mg/L, Acute Criteria = 860 mg/L.

Chronic WLA:  $C_e = ((14.7 + 0.0)230 - (0.0 * 0.0))/14.7 = 230 \text{ mg/L}$ 

Acute WLA:  $C_e = ((14.7 + 0.0)860 - (0.0 * 0.0))/14.7 = 860 \text{ mg/L}$ 

$LTA_c = 230$	(0.57) = 489.82  mg/L
$LTA_a = 860$	(0.746) = 171.57  mg/L

Use most protective number of LTA<sub>c</sub> or LTA<sub>a</sub>.

MDL = 171.57 (1.76) = 301.2 mg/L	$[CV = 0.26, 99^{th} Percentile]$
AML = 171.57 (1.23) = 210.6 mg/L	$[CV = 0.26, 95^{th} Percentile, n = 4]$

- <u>Biochemical Oxygen Demand (BOD<sub>5</sub>) Percent Removal</u>. In accordance with 40 C.F.R. Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD<sub>5</sub> and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for BOD<sub>5</sub>.
- <u>Total Suspended Solids (TSS) Percent Removal</u>. In accordance with 40 C.F.R. Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD<sub>5</sub> and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for TSS.

**Sampling Frequency Justification**: Due to compliance with effluent limits and consistency amongst effluent data, BOD<sub>5</sub>, TSS, Ammonia, and pH were reduced from weekly to monthly sampling and reporting frequencies and Oil & Grease was reduced from monthly to quarterly. As per 10 CSR 20-7.015(9)(D)8.B., the sampling and reporting frequencies for influent Total Phosphorus, Total Kjeldahl Nitrogen, and Nitrite + Nitrate were increased from quarterly to monthly. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)7.A.

**Sampling Type Justification**: As per 10 CSR 20-7.015, samples collected for mechanical plants shall be a 24 hour composite sample. Grab samples, however, must be collected for pH, *E. coli*, and Oil & Grease in accordance with recommended analytical methods. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

#### **PERMITTED FEATURE INF – INFLUENT MONITORING**

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

#### **INFLUENT MONITORING TABLE:**

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
BOD <sub>5</sub>	mg/L	1			*	***	1/month	monthly	С
TSS	mg/L	1			*	***	1/month	monthly	С
Ammonia as N	mg/L	1	*		*	***	1/month	monthly	С
Total Phosphorus	mg/L	1	*		*	***	1/month	monthly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	***	1/month	monthly	С
Nitrite + Nitrate	mg/L	1	*		*	***	1/month	monthly	С
* - Monitoring requirement only.									

\*\*\* - Parameter not previously established in previous state operating permit.

**Basis for Limitations Codes:** 

- State or Federal Regulation/Law 1.
- Water Quality Standard (includes RPA) 2.
- 3. Water Quality Based Effluent Limits
- 4. Antidegradation Review
- 5. Antidegradation Policy 6.
  - Water Quality Model
  - 7. Best Professional Judgment
  - TMDL or Permit in lieu of TMDL 8.
- 9. WET Test Policy
- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

#### **Influent Parameters**

- Biochemical Oxygen Demand (BOD<sub>5</sub>) and Total Suspended Solids (TSS). An influent sample is required to determine the • removal efficiency. In accordance with 40 C.F.R. Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD<sub>5</sub> and TSS for Publicly Owned Treatment Works (POTWs)/municipals.
- Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia. Influent monitoring for Total Phosphorus, Total . Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia required per 10 CSR 20-7.015(9)(D)8.

Sampling Frequency Justification: The sampling and reporting frequencies for Total Phosphorus and Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia parameters were established to match the required sampling frequency of these parameters in the effluent, per [10 CSR 20-7.015(9)(D)8.]. The sampling and reporting frequencies for influent BOD<sub>5</sub> and TSS have been established to match the required sampling frequency of these parameters in the effluent.

Sampling Type Justification: Sample types for influent parameters were established to match the required sampling type of these parameters in the effluent. Samples should be analyzed as soon as possible after collection and/or properly preserved according to method requirements.

#### **OUTFALL #001 – GENERAL CRITERIA CONSIDERATIONS:**

In accordance with 40 C.F.R. § 122.44(d)(1), effluent limitations shall be placed into the permit for those pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The rule further states that pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above a narrative criterion within an applicable State water quality standard, the permit shall contain a numeric effluent limitation to protect that narrative criterion. In order to comply with this regulation, the permit writer will complete reasonable potential determinations on whether the discharge will violate any of the general criteria listed in 10 CSR 20-7.031(4). These specific requirements are listed below followed by derivation and discussion (the lettering matches that of the rule itself, under 10 CSR 20-7.031(4)). It should also be noted that Section 644.076.1, RSMo as well as Section D – Administrative Requirements of Standard Conditions Part I of this permit states that it shall be unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri that is in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law or any standard, rule or regulation promulgated by the commission.

- (A) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses. The discharge from this facility is made up of treated domestic wastewater. Based upon review of the Report of Compliance Inspection for the inspection conducted on September 6, 2018, no evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, this facility utilizes secondary treatment technology and is currently in compliance with the secondary treatment technology based effluent limits established in this permit and there has been no indication to the Department that the stream has had issues maintaining beneficial uses as a result of this discharge. Based on the information reviewed during the drafting of this permit, these final effluent limitations appear to have protected against the excursion of this criterion in the past. Therefore, the discharge does not have the reasonable potential to cause or contribute to an excursion of this criterion.
- (B) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of <u>beneficial uses</u>. Please see (A) above as justification is the same.
- (C) <u>Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full</u> <u>maintenance of beneficial uses</u>. Please see (A) above as justification is the same.
- (D) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life. This permit contains final effluent limitations which are protective of both acute and chronic toxicity for various pollutants that are either expected to be discharged by domestic wastewater facilities or that were disclosed by this facility on the application for permit coverage. Based on the information reviewed during the drafting of this permit, it has been determined if the facility meets final effluent limitations established in this permit, there is no reasonable potential for the discharge to cause an excursion of this criterion.
- (E) <u>Waters shall provide for the attainment and maintenance of water quality standards downstream including waters of another state</u>. Please see (D) above as justification is the same.
- (F) <u>There shall be no significant human health hazard from incidental contact with the water</u>. Please see (D) above as justification is the same.
- (G) There shall be no acute toxicity to livestock or wildlife watering. Please see (D) above as justification is the same.
- (H) <u>Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community</u>. Please see (A) above as justification is the same.
- (I) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247. The discharge from this facility is made up of treated domestic wastewater. No evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, any solid wastes received or produced at this facility are wholly contained in appropriate storage facilities, are not discharged, and are disposed of offsite. This discharge is subject to Standard Conditions Part III, which contains requirements for the management and disposal of sludge to prevent its discharge. Therefore, this discharge does not have reasonable potential to cause or contribute to an excursion of this criterion.

# Part VII - Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

✓ The Department is required to determine "findings of affordability" because the permit applies to a combined or separate sanitary sewer system for a publicly-owned treatment works.

**Cost Analysis for Compliance -** The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

The following table summarizes the results of the cost analysis. See **Appendix – Cost Analysis for Compliance** for detailed information.

#### Summary Table. Cost Analysis for Compliance Summary for the City of St. Peters

New Permit Requirements							
Effluent Total Phosphorus, Total Kjeldahl Nitrogen (TKN), and Nitrite + Nitrate (increased from quarterly to monthly), and new effluent limits for Chloride; monthly influent Total Phosphorus, TKN, Nitrite + Nitrate, and Ammonia							
Estimated Annual Cost Annual Median Household Income (MHI) Estimated Monthly User Rate User Rate as a Perc							
\$6,960	\$79,758	\$18.40	0.28%				

In addition to the new sampling requirements above, this permit also includes a ten (10) year schedule of compliance to meet final effluent limits for Chloride. It is expected that the City, through their approved pretreatment program, will locate and evaluate potential sources of chlorides within the collection system and take necessary steps to control chloride loading to the treatment system to comply with the effluent limitations.

# Part VIII – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

#### WATER QUALITY STANDARD REVISION:

In accordance with section 644.058, RSMo, the Department is required to utilize an evaluation of the environmental and economic impacts of modifications to water quality standards of twenty-five percent or more when making individual site-specific permit decisions.

This operating permit does not contain requirements for a water quality standard that has changed twenty-five percent or more since the previous operating permit.

#### **PERMIT SYNCHRONIZATION:**

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. With permit synchronization, this permit will expire in the 4<sup>th</sup> Quarter of calendar year 2024.

#### **PUBLIC NOTICE:**

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

✓ This permit was initially placed on Public Notice from June 5, 2020 to July 6, 2020. Comments were submitted by SUEZ WTS Services USA, Inc. (SUEZ) on July 1, 2020. As per 40 C.F.R. § 124.17(a), the Department is required to issue a response to comments when a final permit is issued. The Department failed to issue a response to the comments submitted by SUEZ when this permit was issued on August 20, 2020, and as a result, this permit was revoked and reissued following a public notice period.

The second Public Notice period for this operating permit was from January 29, 2021 to March 1, 2021. Public Notice comments were submitted by the City of St. Peters and Locke Lord LLP on behalf of SUEZ Water Technologies (SUEZ). Responses to the Public Notice of this operating permit did not warrant the modification of effluent limits; however, following a discussion with MDNR, the City of St. Peters, and SUEZ, the schedule of compliance to meet final effluent limits for Chloride was extended to ten (10) years. Additionally, the Cost Analysis for Compliance was updated to include cost for the City of St. Peters to implement Chloride as a local limit into the pretreatment permit for SUEZ.

DATE OF FACT SHEET: APRIL 24, 2020; REVISED: JANUARY 13, 2022

COMPLETED BY: ASHLEY KEELY, ENVIRONMENTAL SPECIALIST MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT 573-751-7326 ashley.keely@dnr.mo.gov

BRANT FARRIS, ENVIRONMENTAL SPECIALIST MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT 660-385-8019 brant.farris@dnr.mo.gov

# **Appendices**

# **APPENDIX - CLASSIFICATION WORKSHEET:**

Item	Points Possible	Points Assigned
Maximum Population Equivalent (P.E.) served , peak day	1 pt./10,000 PE or major fraction thereof (Max 10 pts)	8
Design Flow (avg. day) or peak month's flow (avg. day) whichever is larger	1 pt. / MGD or major fraction thereof. (Max 10 pts.)	10
Effluent Discharge		
Missouri or Mississippi River	0	
All other stream discharges except to losing streams and stream reaches supporting whole body contact recreation	1	
Discharge to lake or reservoir outside of designated whole body contact recreational area	2	
Discharge to losing stream, lake or reservoir area supporting whole body contact recreation	3	
Direct reuse or recycle of effluent	6	
Land Application/Irriga	tion	
Drip Irrigation	3	
Land application/irrigation	5	
Overland flow	4	
Variation in Raw Wastes (higher	st level only)	
Variations do not exceed those normally or typically expected	0	
Reoccurring deviations or excessive variations of 100 to 200 percent in strength and/or flow	2	2
Reoccurring deviations or excessive variations of more than 200 percent in strength and/or flow	4	
Department-approved pretreatment program	6	
Preliminary Treatment	nt	
STEP systems (operated by the permittee)	3	
Screening and/or comminution	3	3
Grit removal	3	3
Plant pumping of main flow	3	3
Flow equalization	5	5
Primary Treatment		
Primary clarifiers	5	
Chemical addition (except chlorine, enzymes)	4	
Secondary Treatmen	ıt	
Trickling filter and other fixed film media with or without secondary clarifiers	10	
Activated sludge (including aeration, oxidation ditches, sequencing batch reactors, membrane bioreactors, and contact stabilization)	15	15
Stabilization ponds without aeration	5	
Aerated lagoon	8	
Advanced Lagoon Treatment – Aerobic cells, anaerobic cells, covers, or fixed film	10	
Biological, physical, or chemical	12	
Carbon regeneration	4	
Total from page ONE (1)		49

### **APPENDIX - CLASSIFICATION WORKSHEET (CONTINUED):**

Ітем	POINTS POSSIBLE	POINTS ASSIGNED		
Solids Handling				
Sludge Holding	5	5		
Anaerobic digestion	10			
Aerobic digestion	6			
Evaporative sludge drying	2			
Mechanical dewatering	8	8		
Solids reduction (incineration, wet oxidation)	12			
Land application	6	6		
Disinfection				
Chlorination or comparable	5			
On-site generation of disinfectant (except UV light)	5			
Dechlorination	2			
UV light	4	4		
Required Laboratory Control Performed by Plant Personnel (highest level only)				
Lab work done outside the plant	0			
Push – button or visual methods for simple test such as pH, settleable solids	3			
Additional procedures such as DO, COD, BOD, titrations, solids, volatile content	5	5		
More advanced determinations, such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc.	7			
Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph	10			
Total from page <b>TWO (2)</b>		28		
Total from page <b>ONE</b> (1)		49		
Grand Total		77		

□ - A: 71 points and greater
 □ - B: 51 points - 70 points
 □ - C: 26 points - 50 points

 $\Box$  - D: 0 points – 25 points

#### **APPENDIX – RPA RESULTS:**

Parameter	CMC*	RWC Acute*	CCC*	RWC Chronic*	n**	Range max/min	CV***	MF	RP Yes/No
Ammonia as N - January (mg/L)	29.5	0.89	5.3	0.894865272	15	0.43/0.0465	0.71	2.081082	NO
Ammonia as N - February (mg/L)	29.5	2.04	5.4	2.043714195	12	0.69/0.0135	0.90	2.9619046	NO
Ammonia as N - March (mg/L)	32.9	2.38	5.6	2.379679369	12	0.78/0.05	0.93	3.050871	NO
Ammonia as N – April (mg/L)	32.9	0.19	4.9	0.192729294	11	0.15/0.065	0.31	1.284862	NO
Ammonia as N – May (mg/L)	32.9	1.50	3.8	1.5	10	0.5/0.15	0.60	3	NO
Ammonia as N – June (mg/L)	28.7	0.50	3.0	0.495	8	0.15/0.15	0.60	3.3	NO
Ammonia as N – July (mg/L)	34.6	0.45	3.0	0.45	10	0.15/0.15	0.00	3	NO
Ammonia as N – August (mg/L)	36.1	2.37	3.1	2.368	9	0.74/0.015	0.60	3.2	NO
Ammonia as N – September (mg/L)	34.6	0.53	3.0	0.528	8	0.16/0.015	0.60	3.3	NO
Ammonia as N – October (mg/L)	32.9	3.66	3.1	3.663898012	11	0.87/0.015	1.21	4.211377	YES
Ammonia as N – November (mg/L)	36.1	0.50	4.9	0.495	8	0.15/0.015	0.60	3.3	NO
Ammonia as N – December (mg/L)	39.2	1.31	5.7	1.312	9	0.41/0.0465	0.60	3.2	NO
Chloride (mg/L)	860	490.43	230	490.43	11	300.0/72.0	0.26	1.63	YES

N/A - Not Applicable

\* - Units are (mg/L) unless otherwise noted.

\*\* - If the number of samples is 10 or greater, then the CV value must be used in the WQBEL for the applicable constituent. If the number of samples is < 10, then the default CV value must be used in the WQBEL for the applicable constituent.

\*\*\* - Coefficient of Variation (CV) is calculated by dividing the Standard Deviation of the sample set by the Mean of the same sample set.

RWC – Receiving Water Concentration. It is the concentration of a toxicant or the parameter toxicity in the receiving water after mixing (if applicable).

n-Is the number of samples.

MF - Multiplying Factor. 99% Confidence Level and 99% Probability Basis.

RP – Reasonable Potential. It is where an effluent is projected or calculated to cause an excursion above a water quality standard based on a number of factors including, as a minimum, the four factors listed in 40 C.F.R. § 122.44(d)(1)(ii).

Reasonable Potential Analysis is conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request.

### **APPENDIX – ALTERNATIVE:**



#### **APPENDIX – COST ANALYSIS FOR COMPLIANCE:**

#### Missouri Department of Natural Resources Water Protection Program Cost Analysis for Compliance (In accordance with RSMo 644.145)

#### St. Peters Spencer Creek STP, Permit Renewal City of St. Peters Missouri State Operating Permit #MO-0030970

Section 644.145 RSMo requires the Department of Natural Resources (Department) to make a "finding of affordability" when "issuing permits under" or "enforcing provisions of" state or federal clean water laws "pertaining to any portion of a combined or separate sanitary sewer system for publicly-owned treatment works." This cost analysis does not dictate how the permittee will comply with new permit requirements.

#### **New Permit Requirements**

The permit requires compliance with new monitoring requirements for effluent Total Phosphorus, Total Kjeldahl Nitrogen (TKN), and Nitrite + Nitrate (increased from quarterly to monthly); influent Total Phosphorus, TKN, Nitrite + Nitrate, and Ammonia.

This permit also includes a ten (10) year schedule of compliance to meet final effluent limits for Chloride. It is expected that the City, through their approved pretreatment program, will locate and evaluate potential sources of chlorides within the collection system and take necessary steps to control chloride loading to the treatment system to comply with the effluent limitations. The City of St. Peters provided costs for implementing the new permit requirement into their pretreatment program.

#### Connections

The number of connections was reported by the permittee on the Financial Questionnaire.

Connection Type	Number		
Residential	18,731		
Commercial & Industrial	950		
Total	19,681		

#### **Data Collection for this Analysis**

This cost analysis is based on data available to the Department as provided by the permittee and data obtained from readily available sources. For the most accurate analysis, it is essential that the permittee provides the Department with current information about the City's financial and socioeconomic situation. The financial questionnaire available to permittees on the Department's website (<u>http://dnr.mo.gov/forms/780-2511-f.pdf</u>) is a required attachment to the permit renewal application. If the financial questionnaire is not submitted with the renewal application, the Department sends a request to complete the form with the welcome correspondence. If certain data was not provided by the permittee to the Department and the data is not obtainable through readily available sources, this analysis will state that the information is "unknown".

#### Eight Criteria of 644.145 RSMo

The Department must consider the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with new permit requirements.

#### (1) A community's financial capability and ability to raise or secure necessary funding;

Criterion 1 Table. Current Financial Information for the City of St. Peters			
Current Monthly User Rates per 5,000 gallons*	\$18.37		
Median Household Income (MHI) <sup>1</sup>	\$79,758		
Current Annual Operating Costs (excludes depreciation)	\$4,025,511		

\*User Rates were reported by the permittee on the Financial Questionnaire.

# (2) Affordability of pollution control options for the individuals or households at or below the median household income level of the community;

The following tables outline the estimated costs of the new permit requirements:

Criterion 2A Table. Estimated Cost Breakdown of New Permit Requirements				
New Requirement	Frequency	Estimated Cost	Estimated Annual Cost	
Total Phosphorus – Influent	Monthly	\$24	\$288	
Total Kjeldahl Nitrogen – Influent	Monthly	\$33	\$396	
Nitrate + Nitrite – Influent	Monthly	\$40	\$480	
Ammonia – Influent	Monthly	\$20	\$240	
Total Phosphorus – Effluent	Monthly (Increased from Quarterly)	\$24	\$192	
Total Kjeldahl Nitrogen – Effluent	Monthly (Increased from Quarterly)	\$33	\$264	
Nitrate + Nitrite – Effluent	Monthly (Increased from Quarterly)	\$40	\$320	
Chloride + Field Sampling Event*	Total of 50 Samples (\$115/sample)	\$5,750	\$1,150**	
Previous Chloride Studies/Evaluations*	Once during the permit cycle (30 hours)	\$4,500	\$900**	
Local Limit Calculations/Report*	Once during the permit cycle (20 hours)	\$3,000	\$600**	
Program Modification*	Once during the permit cycle (5 hours)	\$750	\$150**	
Data Evaluations*	Once during the permit cycle (30 hours)	\$4,500	\$900**	
Industry Communications*	Once during the permit cycle (16 hours)	\$2,400	\$480**	
Public Notice Process*	Once during the permit cycle (2 hours)	\$300	\$60**	
Ordinance Adoption*	Once during the permit cycle (2 hours)	\$300	\$60**	
Update Permits*	Once during the permit cycle (16 hours)	\$2,400	\$480**	
Total Estimated Annual Cost of New Permit	\$6,960			

\* Cost estimates were provided to the Department by the City of St. Peters via email on May 7, 2021. Hourly rate is \$150.

\*\* The total estimated cost for the addition of the new Chloride requirement into their pretreatment program is \$23,900. Because this analysis calculates a user rate based on the annual cost of compliance with new requirements, the pretreatment related costs were divided by 5 to reflect the total cost over a permit cycle.

Criterion 2B Table. Estimated Costs for New Permit Requirements				
(1)	Estimated Annual Cost	\$6,960		
(2)	Estimated Monthly User Cost for New Requirements <sup>2</sup>	\$0.03		
	Estimated Monthly User Cost for New Requirements as a Percent of MHI <sup>3</sup>	0.0004%		
(3)	Total Monthly User Cost*	\$18.40		
	Total Monthly User Cost as a Percent of MHI <sup>4</sup>	0.277%		

\* Current User Rate + Estimated Monthly Costs of New Sampling Requirements

Due to the minimal cost associated with new permit requirements, the Department anticipates an extremely low to no rate increase will be necessary, which could impact individuals or households of this community.
#### (3) An evaluation of the overall costs and environmental benefits of the control technologies;

This analysis is being conducted based on new requirements in the permit, which will not require the addition of new control technologies at the facility. However, the new sampling requirements are being established in order to provide data regarding the health of the receiving stream's aquatic life and to ensure that the existing permit limits are providing adequate protection of aquatic life. Improved wastewater provides benefits such as avoided health costs due to water-related illness, enhanced environmental ecosystem quality, and improved natural resources. The preservation of natural resources has been proven to increase the economic value and sustainability of the surrounding communities. Maintaining Missouri's water quality standards fulfills the goal of restoring and maintaining the chemical, physical, and biological integrity of the receiving stream; and, where attainable, it achieves a level of water quality that provides for the protection and propagation of fish, shellfish, wildlife, and recreation in and on the water.

#### **Nutrient Monitoring**

Nutrients are mineral compounds that are required for organisms to grow and thrive. Of the six (6) elemental macronutrients, nitrogen, and phosphorus are generally not readily available and limit growth of organisms. Excess nitrogen and phosphorus will cause a shift in the ecosystem's food web. Once excess nitrogen and phosphorous are introduced into a waterbody, some species' populations will dramatically increase, while other populations will not be able to sustain life. Competition and productivity are two factors in which nutrients can alter aquatic ecosystems and the designated uses of a waterbody. For example, designated uses, such as drinking water sources and recreational uses, become impaired when algal blooms take over a waterbody. These blooms can cause foul tastes and odors in the drinking water, unsightly appearance, and fish mortality in the waterbody. Some algae also produce toxins that may cause serious adverse health conditions such as liver damage, tumor promotion, paralysis, and kidney damage. The monitoring requirements for nitrogen and phosphorus have been added to the permit to provide data regarding the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

#### Chlorides

The major sources of chloride in surface waters are deicing salt, urban and agricultural runoff, and discharges from municipal wastewater plants, industrial plants, and the drilling of oil and gas wells. Chloride compounds are highly soluble; however, chloride ions do not degrade in the environment and tend to stay in solution once dissolved. High concentrations of chlorides can harm the osmoregulation of aquatic organisms; however, low levels can still negatively impact fish, aquatic bugs, and amphibians.

# (4) Inclusion of ongoing costs of operating and maintaining the existing wastewater collection and treatment system, including payments on outstanding debts for wastewater collection and treatment systems when calculating projected rates:

The community reported that their outstanding debt for their current wastewater collection and treatment systems is \$671,225.68. The community reported that each user pays \$18.37 monthly, of which, \$1.08 is used toward payments on the current outstanding debt.

- (5) An inclusion of ways to reduce economic impacts on distressed populations in the community, including but not limited to low and fixed income populations. This requirement includes but is not limited to:
  - (a) Allowing adequate time in implementation schedules to mitigate potential adverse impacts on distressed populations resulting from the costs of the improvements and taking into consideration local community economic considerations.

324,697,79

(b) Allowing for reasonable accommodations for regulated entities when inflexible standards and fines would impose a disproportionate financial hardship in light of the environmental benefits to be gained.

The following table characterizes the current overall socioeconomic condition of the community as compared to the overall socioeconomic condition of Missouri. The following information was compiled using the latest U.S. Census data.

	No.	Administrative Unit	St. Peters City	Missouri State	United States
	1	Population (2019)	57,273	6,104,910	324
	2	Percent Change in Population (2000-2019)	11.5%	9.1%	
	3	2019 Median Household Income (in 2020 Dollars)	\$79.758	\$56.145	

#### Criterion 5 Table. Socioeconomic Data <sup>1, 5-9</sup> for the City of St. Peters

2	Percent Change in Population (2000-2019)	11.5%	9.1%	15.49
3	2019 Median Household Income (in 2020 Dollars)	\$79,758	\$56,145	\$63,61
4	Percent Change in Median Household Income (2000-2019)	-11.3%	-4.7%	-2.5%
5	Median Age (2019)	39.5	38.6	38.
6	Change in Median Age in Years (2000-2019)	5.3	2.5	2.
7	Unemployment Rate (2019)	3.9%	4.6%	5.3%
8	Percent of Population Below Poverty Level (2019)	3.2%	13.7%	13.49
9	Percent of Household Received Food Stamps (2019)	2.9%	11.1%	11.79
10	(Primary) County Where the Community Is Located	St. Charles County		

# (6) An assessment of other community investments and operating costs relating to environmental improvements and public health protection;

The community reported general upgrades and maintenance to the collection system.

(7) An assessment of factors set forth in the United States Environmental Protection Agency's guidance, including but not limited to the "Combined Sewer Overflow Guidance for Financial Capability Assessment and Schedule Development" that may ease the cost burdens of implementing wet weather control plans, including but not limited to small system considerations, the attainability of water quality standards, and the development of wet weather standards;

The new requirements associated with this permit will not impose a financial burden on the community, nor will they require the City of St. Peters to seek funding from an outside source.

### (8) An assessment of any other relevant local community economic conditions.

The community reported economic growth resulting in the reduction of the property tax rate since 1970.

### **Conclusion and Finding**

As a result of new regulations, the Department is proposing modifications to the current operating permit that may require the permittee to increase monitoring. The Department has considered the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with the new permit requirements.

This analysis examined whether the new sampling requirements affect the ability of an individual customer or household to pay a utility bill without undue hardship or unreasonable sacrifice in the essential lifestyle or spending patterns of the individual or household. After reviewing the above criteria, the Department finds that the new sampling requirements may result in a low burden with regard to the community's overall financial capability and a low financial impact for most individual customers/households; therefore, the new permit requirements are affordable.

### References

 2019 MHI in 2019 Dollar: United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, Table B19013: Median Household Income in the Past 12 Months (in 2019 Inflation-Adjusted Dollars).

https://data.census.gov/cedsci/table?q=B19013&g=0400000US29.160000&tid=ACSDT5Y2019.B19013&hidePreview=false.

(B) 2000 MHI in 1999 Dollar: (1) For United States, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-1 Part 1. United States Summary, Table 5. Work Status and Income in 1999: 2000, Washington, DC. <u>https://www.census.gov/prod/cen2000/phc-2-1-pt1.pdf</u>.

(2) For Missouri State, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-27, Missouri, Table 10. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf.

(C) 2020 CPI, 2019 CPI and 1999 CPI: U.S. Department of Labor Bureau of Labor Statistics (2020) Consumer Price Index - All Urban Consumers, U.S. City Average. All Items. 1982-84=100. https://data.bls.gov/pdg/SurveyOutputServlet.

(D) 2019 MHI in 2020 Dollar = 2019 MHI in 2019 Dollar x 2020 CPI /2019 CPI; 2000 MHI in 2020 Dollar = 2000 MHI in 1999 Dollar x 2020 CPI /1999 CPI.

(E) Percent Change in Median Household Income (2000-2019) = (2019 MHI in 2020 Dollar - 2000 MHI in 2020 Dollar) / (2000 MHI in 2020 Dollar).

- 2. ((6,960/19,681)/12 = (0.03) (Estimated Monthly User Cost for New Requirements)
- 3. (\$0.03/(\$79,758/12))100% = 0.0004% (New Sampling Only)
- 4. (\$18.40/(\$79,758/12))100% = 0.277% (Total User Cost)
- 5. Total Population in 2019: United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, Table B01003: Total Population Universe: Total Population.

 $\underline{https://data.census.gov/cedsci/table?q=B01003\&g=0400000US29.160000\&tid=ACSDT5Y2019.B01003\&tidePreview=false.pdf and a start of the start of the$ 

(B) Total Population in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC. https://www.census.gov/prod/cen2000/phc-1-1-pt1.pdf.

(2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Place of Birth, Residence in 1995, and Language: 2000, Washington, DC. <u>http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf</u>.

(C) Percent Change in Population (2000-2019) = (Total Population in 2019 - Total Population in 2000) / (Total Population in 2000).
6. Median Age in 2019: United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, Table B01002: Median Age by Sex - Universe: Total population.

https://data.census.gov/cedsci/table?q=B01002&g=0400000US29.160000&tid=ACSDT5Y2019.B01002&hidePreview=false.

(B) Median Age in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC., Page 2. https://www.census.gov/prod/cen2000/phc-1-1-pt1.pdf.

(2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Place of Birth, Residence in 1995, and Language: 2000, Washington, DC. http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf.

(C) Change in Median Age in Years (2000-2019) = (Median Age in 2019 - Median Age in 2000).

- United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, B23025: Employment Status for the Population 16 Years and Over - Universe: Population 16 years and Over.
- $\underline{https://data.census.gov/cedsci/table?q=B23025\&g=0400000US29.160000\&tid=ACSDT5Y2019.B23025\&hidePreview=false.weighted the second sec$
- 8. United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, Table S1701: Poverty Status in the Past 12 Months. https://data.census.gov/cedsci/table?q=S1701&g=0400000US29.160000&tid=ACSST5Y2019.S1701&hidePreview=false.
- 9. United States Census Bureau. 2015-2019 American Community Survey 5-Year Estimates, Table B2201: Food Stamps/Supplemental Nutrition Assistance Program (SNAP) - Universe: Households. <u>https://data.census.gov/cedsci/table?q=Receipt%20of%20Food%20Stamps&g=0400000US29.050000,29.160000&tid=ACSST5Y2019.S2201& hidePreview=true</u>



These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

# Part I – General Conditions

# Section A - Sampling, Monitoring, and Recording

### 1. Sampling Requirements.

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.

### 2. Monitoring Requirements.

a.

- Records of monitoring information shall include:
- i. The date, exact place, and time of sampling or measurements;
- ii. The individual(s) who performed the sampling or measurements;
- iii. The date(s) analyses were performed;
- iv. The individual(s) who performed the analyses;
- v. The analytical techniques or methods used; and
- vi. The results of such analyses.
- b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
- 3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
- Test Procedures. The analytical and sampling methods used shall conform 4. to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is "sufficiently sensitive" when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility's discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
- 5. Record Retention. Except for records of monitoring information required by the permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

#### 6. Illegal Activities.

- a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than (4) years, or both.
- b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

# Section B - Reporting Requirements

### 1. Planned Changes.

- The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
  - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
  - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
  - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
  - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.

### 2. Non-compliance Reporting.

a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
  - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
  - ii. Any upset which exceeds any effluent limitation in the permit.
  - Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
- c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
- 3. Anticipated Noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
- 4. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
- 5. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
- 6. **Other Information**. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

### 7. Discharge Monitoring Reports.

- a. Monitoring results shall be reported at the intervals specified in the permit.
- b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
- c. Monitoring results shall be reported to the Department no later than the  $28^{th}$  day of the month following the end of the reporting period.

# Section C - Bypass/Upset Requirements

### 1. Definitions.

- a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
- b. Severe Property Damage: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- c. *Upset:* an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

#### 2. Bypass Requirements.

a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

- b. Notice.
  - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
  - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
- c. Prohibition of bypass.
  - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
    - 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
    - 3. The permittee submitted notices as required under paragraph 2. b. of this section.
  - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.

### 3. Upset Requirements.

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
  - ii. The permitted facility was at the time being properly operated; and
  - iii. The permittee submitted notice of the upset as required in Section B

     Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
     iv. The permittee complied with any remedial measures required under
  - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
- c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

# Section D - Administrative Requirements

- 1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
  - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
  - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- It is unlawful for any person to cause or permit any discharge of water d. contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

#### 2. Duty to Reapply.

- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission

for applications to be submitted later than the expiration date of the existing permit.)

- c. A permittees with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- 3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- 4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
- 5. Proper Operation and Maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

#### 6. Permit Actions.

- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
  - i. Violations of any terms or conditions of this permit or the law;ii. Having obtained this permit by misrepresentation or failure to
  - disclose fully any relevant facts;A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized
  - discharge; or
  - iv. Any reason set forth in the Law or Regulations.
- b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

#### 7. Permit Transfer.

- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
- 8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- 9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.



- 10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
- 11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
  - Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
  - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
  - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
  - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.

#### 12. Closure of Treatment Facilities.

- a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
- b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.

#### 13. Signatory Requirement.

- a. All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
- b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
- c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
- 14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.



### PART II - SPECIAL CONDITIONS – PUBLICLY OWNED TREATMENT WORKS SECTION A – INDUSTRIAL USERS

# 1. Definitions

Definitions as set forth in the Missouri Clean Water Laws and approved by the Missouri Clean Water Commission shall apply to terms used herein.

Significant Industrial User (SIU). Except as provided in the *General Pretreatment Regulation* 10 CSR 20-6.100, the term Significant Industrial User means:

- 1. All Industrial Users subject to Categorical Pretreatment Standards; and
- 2. Any other Industrial User that: discharges an average of 25,000 gallons per day or more of process wastewater to the Publicly-Owned Treatment Works (POTW) (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's or for violating any Pretreatment Standard or requirement.

Clean Water Act (CWA) is the the federal Clean Water Act of 1972, 33 U.S.C. § 1251 et seq. (2002).

# 2. Identification of Industrial Discharges

Pursuant to 40 CFR 122.44(j)(1), all POTWs shall identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR 403.

# 3. Application Information

Applications for renewal or modification of this permit must contain the information about industrial discharges to the POTW pursuant to 40 CFR 122.21(j)(6)

# 4. Notice to the Department

Pursuant to 40 CFR 122.42(b), all POTWs must provide adequate notice of the following:

- Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging these pollutants; and
- 2. Any substantial change into the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- 3. For purposes of this paragraph, adequate notice shall include information on:
  - i. the quality and quantity of effluent introduced into the POTW, and
  - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

For POTWs without an approved pretreatment program, the notice of industrial discharges which was not included in the permit application shall be made as soon as practicable. For POTWs with an approved pretreatment program, notice is to be included in the annual pretreatment report required in the special conditions of this permit. Notice may be sent to:

> Missouri Department of Natural Resources Water Protection Program Attn: Pretreatment Coordinator P.O. Box 176 Jefferson City, MO 65102

# PART III - BIOSOLIDS AND SLUDGE FROM DOMESTIC TREATMENT FACILITIES

### SECTION A - GENERAL REQUIREMENTS

- PART III Standard Conditions pertain to biosolids and sludge requirements under the Missouri Clean Water Law and regulations for domestic and municipal wastewater and also incorporates federal sludge disposal requirements under 40 CFR Part 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR Part 503 for domestic biosolids and sludge.
- 2. PART III Standard Conditions apply only to biosolids and sludge generated at domestic wastewater treatment facilities, including public owned treatment works (POTW) and privately owned facilities.
- 3. Biosolids and Sludge Use and Disposal Practices:
  - a. The permittee is authorized to operate the biosolids and sludge generating, treatment, storage, use, and disposal facilities listed in the facility description of this permit.
  - b. The permittee shall not exceed the design sludge/biosolids volume listed in the facility description and shall not use biosolids or sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
  - c. For facilities operating under general operating permits that incorporate Standard Conditions PART III, the facility is authorized to operate the biosolids and sludge generating, treatment, storage, use and disposal facilities identified in the original operating permit application, subsequent renewal applications or subsequent written approval by the department.
- 4. Biosolids or Sludge Received from other Facilities:
  - a. Permittees may accept domestic wastewater biosolids or sludge from other facilities as long as the permittee's design sludge capacity is not exceeded and the treatment facility performance is not impaired.
  - b. The permittee shall obtain a signed statement from the biosolids or sludge generator or hauler that certifies the type and source of the sludge
- 5. Nothing in this permit precludes the initiation of legal action under local laws, except to the extent local laws are preempted by state law.
- 6. This permit does not preclude the enforcement of other applicable environmental regulations such as odor emissions under the Missouri Air Pollution Control Lawand regulations.
- This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable biosolids or sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
- 8. In addition to Standard Conditions PARTIII, the Department may include biosolids and sludge limitations in the special conditions portion or other sections of a site specific permit.
- 9. Exceptions to Standard Conditions PARTIII may be authorized on a case-by-case basis by the Department, as follows:
  - a. The Department may modify a site-specific permit following permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR § 124.10, and 40 CFR § 501.15(a)(2)(ix)(E).
  - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR Part 503.

# SECTION B - DEFINITIONS

- 1. Best Management Practices are practices to prevent or reduce the pollution of waters of the state and include agronomic loading rates (nitrogen based), soil conservation practices, spill prevention and maintenance procedures and other site restrictions.
- 2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
- 3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food, feed or fiber. The facility includes any structures necessary to store the biosolids untilsoil, weather, and crop conditions are favorable for land application.
- 4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR Part 503.
- 5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with 40 CFR Part 503.
- 6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
- 7. Feed crops are crops produced primarily for consumption by animals.
- 8. Fiber crops are crops such as flax and cotton.
- 9. Food crops are crops consumed by humans which include, but is not limted to, fruits, vegetables and tobacco.
- 10. Industrial wastewater means any wastewater, also known as process wastewater, not defined as domestic wastewater. Per 40 CFR Part 122.2, process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product. Land application of industrial wastewater, residuals or sludge is not authorized by Standard Conditions PART III.
- 11. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological contact systems, and other similar facilities. It does not include wastewater treatment lagoons or constructed wetlands for wastewater treatment.
- 12. Plant Available Nitrogen (PAN) is nitrogen that will be available to plants during the growing seasons after biosolids application.
- 13. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
- 14. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs), sewage sludge incinerator ash, or grit/screenings generated during preliminary treatment of domestic sewage.
- 15. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen or concrete lined basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
- 16. Septage is the sludge pumped from residential septic tanks, cesspools, portable toilets, Type III marine sanitation devices, or similar treatment works such as sludge holding structures from residential wastewater treatment facilities with design populations of less than 150 people. Septage does not include grease removed from grease traps at a restaurant or material removed from septic tanks and other similar treatment works that have received industrial wastewater. The standard for biosolids from septage is different from other sludges. See Section H for more information.

# SECTION C-MECHANICAL WASTEWATER TREATMENT FACILITIES

- 1. Biosolids or sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and the requirements of Standard Conditions PART III or in accordance with Section A.3.c., above.
- The permittee shall operate storage and treatment facilities, as defined by Section 644.016(23), RSMo, so that there is no biosolids or sludge discharged to waters of the state. Agricultural storm water discharges are exempt under the provisions of Section 644.059, RSMo.
- 3. Mechanical treatment plants shall have separate biosolids or sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove biosolids or sludge from these storage compartments on the required design schedule is a violation of this permit.

# SECTION D – BIOSOLIDS OR SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR BY CONTRACT HAULER

- 1. Permittees that use contract haulers, under the authority of their operating permit, to dispose of biosolids or sludge, are responsible for compliance with all the terms of this permit. Contract haulers that assume the responsibility of the final disposal of biosolids or sludge, including biosolids land application, must obtain a Missouri State Operating Permit unless the hauler transports the biosolids or sludge to another permitted treatment facility.
- 2. Testing of biosolids or sludge, other than total solids content, is not required if biosolids or sludge are hauled to a permitted wastewater treatment facility, unless it is required by the accepting facility.

# SECTION E- INCINERATION OF SLUDGE

- Please be aware that sludge incineration facilities may be subject to the requirements of 40 CFR Part 503 Subpart E, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or, if the ash is determined to be hazardous, with 10 CSR 25.
- 3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, mass of sludge incinerated and mass of ash generated. Permittee shall also provide the name of the ash disposal facility and permit number if applicable.

# Section $F-Surface\ Disposal\ Sites\ and\ Biosolids\ and\ Sludge\ Lagoons$

- Please be aware that surface disposal sites of biosolids or sludge from wastewater treatment facilities may be subject to other laws including the requirements in 40 CFR Part 503 Subpart C, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Biosolids or sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain biosolids or sludge storage lagoons as storage facilities, accumulated biosolids or sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of biosolids or sludge removed will be dependent on biosolids or sludge generation and accumulation in the facility. Enough biosolids or sludge must be removed to maintain adequate storage capacity in the facility.
  - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of biosolids or sludge on the bottom of the lagoon, upon prior approval of the Department; or
  - b. Permittee shall close the lagoon in accordance with Section I.

# SECTION G - LAND APPLICATION OF BIOSOLIDS

- 1. The permittee shall not land apply biosolids unless land application is authorized in the facility description, the special conditions of the issued NPDES permit, or in accordance with Section A.3.c., above.
- 2. This permit only authorizes "Class A" or "Class B" biosolids derived from domestic wastewater to be land applied onto grass land, crop land, timber, or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
- 3. Class A Biosolids Requirements: Biosolids shall meet Class A requirements for application to public contact sites, residential lawns, home gardens or sold and/or given away in a bag or other container.
- 4. Class B biosolids that are land applied to agricultural and public contact sites shall comply with the following restrictions:
  - a. Food crops that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
  - b. Food crops below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for four months or longer prior to incorporation into the soil.
  - c. Food crops below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than four months prior to incorporation into the soil.
  - d. Animal grazing shall not be allowed for 30 days after application of biosolids.
  - e. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
  - f. Turf shall not be harvested for one year after application of biosolids if used for lawns or high public contact sites in close proximity to populated areas such as city parks or golf courses.
  - g. After Class B biosolids have been land applied to public contact sites with high potential for public exposure, as defined in 40 CFR § 503.31, such as city parks or golf courses, access must be restricted for 12 months.
  - h. After Class B biosolids have been land applied public contact sites with low potential for public exposure as defined in 40 CFR § 503.31, such as a rural land application or reclamation sites, access must be restricted for 30 days.
- 5. Pollutant limits
  - a. Biosolids shall be monitored to determine the quality for regulated pollutants listed in Table 1, below. Limits for any pollutants not listed below may be established in the permit.
  - b. The number of samples taken is directly related to the amount of biosolids or sludge produced by the facility (See Section J, below). Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to achieve pollutant concentration below those identified in Table 1, below.
  - c. Table 1 gives the ceiling concentration for biosolids. Biosolids which exceed the concentrations in Table 1 may not be land applied.

TABLE 1

Biosolids ceiling concentration				
Pollutant	Milligrams per kilogram dry weight			
Arsenic	75			
Cadmium	85			
Copper	4,300			
Lead	840			
Mercury	57			
Molybdenum	75			
Nickel	420			
Selenium	100			
Zinc	7,500			

d. Table 2 below gives the low metal concentration for biosolids. Because of its higher quality, biosolids with pollutant concentrations below those listed in Table 2 can safely be applied to agricultural land, forest, public contact sites, lawns, home gardens or be given away without further analysis. Biosolids containing metals in concentrations above the low metals concentrations but below the ceiling concentration limits may be land applied but shall not exceed the annual loading rates in Table 3 and the cumulative loading rates in Table 4. The permittee is required to track polluntant loading onto application sites for parameters that have exceeded the low metal concentration limits.

TABLE 2					
Biosolids Low Metal Concentration					
Pollutant	Milligrams per kilogram dry weight				
Arsenic	41				
Cadmium	39				
Copper	1,500				
Lead	300				
Mercury	17				
Nickel	420				
Selenium	100				
Zinc	2,800				

e. Annual pollutant loading rate.

Ta	bl	e	3	
			_	

Biosolids Annual Loading Rate				
Pollutant	Kg/ha (lbs./ac) per year			
Arsenic	2.0 (1.79)			
Cadmium	1.9 (1.70)			
Copper	75 (66.94)			
Lead	15 (13.39)			
Mercury	0.85 (0.76)			
Nickel	21 (18.74)			
Selenium	5.0 (4.46)			
Zinc	140 (124.96)			

f. Cumulative pollutant loading rates.

с.

Ta	ble	4	

Biosolids Cumulative Pollutant Loading Rate				
Pollutant	Kg/ha (lbs./ac)			
Arsenic	41 (37)			
Cadmium	39 (35)			
Copper	1500 (1339)			
Lead	300 (268)			
Mercury	17 (15)			
Nickel	420 (375)			
Selenium	100 (89)			
Zinc	2800 (2499)			

- 6. Best Management Practices. The permittee shall use the following best management practices during land application activities to prevent the discharge of biosolids to waters of the state.
  - a. Biosolids shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under § 4 of the Endangered Species Act or its designated critical habitat.
  - b. Apply biosolids only at the agronomic rate of nitrogen needed (see 5.c. of this section).
    - The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop

nitrogen removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.

i. PAN can be determined as follows:

(Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor<sup>1</sup>). <sup>1</sup> Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis.

- ii. Crop nutrient production/removal to be based on crop specific nitrogen needs and realistic yield goals. NO TE: There are a number of reference documents on the Missouri Department of Natural Resources website that are informative to implement best management practices in the proper management of biosolids, including crop specific nitrogen needs, realistic yields on a county by county basis and other supporting references.
- iii. Biosolids that are applied at agronomic rates shall not cause the annual pollutant loading rates identified in Table 3 to be exceeded.
- d. Buffer zones are as follows:
  - i. 300 feet of a water supply well, sinkhole, water supply reservoir or water supply intake in a stream;
  - ii. 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstandingstate resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
  - iii. 150 feet of dwellings or public use areas;
  - iv. 100 feet (35 feet if biosolids application is down-gradient or the buffer zone is entirely vegetated) of lake, pond, wetlands or gaining streams (perennial or intermittent);
  - v. 50 feet of a property line. Buffer distances from property lines may be waived with written permission from neighboring property owner.
  - vi. For the application of dry, cake or liquid biosolids that are subsurface injected, buffer zones identified in 5.d.i. through 5.d.iii above, may be reduced to 100 feet. The buffer zone may be reduced to 35 feet if the buffer zone is permanently vegetated. Subsurface injection does not include methods or technology reflective of combination surface/shallow soil incorporation.
- e. Slope limitation for application sites are as follows:
  - i. For slopes less than or equal to 6 percent, no rate limitation;
  - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels;
  - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
  - iv. Dry, cake or liquid biosolids that are subsurface injected, may be applied on slopes not to exceed 20
    percent. Subsurface injection does not include the use of methods or technology reflective of combination
    surface/shallow soil incorporation.
- f. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- g. Biosolids may be land applied to sites with soil that are snow covered, frozen, or saturated with liquid when site restrictions or other controls are provided to prevent pollutants from being discharged to waters of the state during snowmelt or stormwater runoff. During inclement weather or unfavorable soil conditions use the following management practices:
  - i. A maximum field slope of 6% and a minimum 300 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be utilized for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of mthods or technology refletive of combination surface/shallow soil incorporation;
  - ii. A maximum field slope of 2% and 100 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be used for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not included the use of methods or technology refletive of combination surface/shallow soil incorporation;
  - iii. Other best management practices approved by the Department.

# SECTION H – SEPTAGE

- 1. Haulers that land apply septage must obtain a state permit. An operating permit is not required for septage haulers who transport septage to another permitted treatment facility for disposal.
- 2. Do not apply more than 30,000 gallons of septage per acre per year or the volume otherwise stipulated in the operating permit.
- 3. Septic tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to mechanical treatment facilities.
- 4. Septage must comply with Class B biosolids regarding pathogen and vector attraction reduction requirements before it may be applied to crops, pastures or timberland. To meet required pathogen and vector reduction requirements, mix 50 pounds of hydrated lime for every 1,000 gallons of septage and maintain a septage pH of at least 12 pH standard units for 30 minutes or more prior to application.
- 5. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.
- 6. As residential septage contains relatively low levels of metals, the testing of metals in septage is not required.

### SECTION I- CLOSURE REQUIREMENTS

- 1. This section applies to all wastewater facilities (mechanical and lagoons) and sludge or biosolids storage and treatment facilities. It does not apply to land application sites.
- 2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all sludges and/or biosolids. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20 6.010 and 10 CSR 20 6.015.
- 3. Biosolids or sludge that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
  - a. Biosolids and sludge shall meet the monitoring and land application limits for agricultural rates as referenced in Section G, above.
  - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
  - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre. Alternative, site-specific application rates may be included in the closure plan for department consideration.
    - i. PAN can be determined as follows:
      - (Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor<sup>1</sup>).
      - $^{1}$  Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis
- 4. Domestic wastewater treatment lagoons with a design treatment capacity less than or equal to 150 persons, are "similar treatment works" under the definition of septage. Therefore the sludge within the lagoons may be treated as septage during closure activities. See Section B, above. Under the septage category, residuals may be left in place as follows:
  - a. Testing for metals or fecal coliform is not required.
  - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
  - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
- 5. Biosolids or sludge left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, and unless otherwise approved, the lagoon berm shall be demolished, and the site shall be graded and contain ≥70% vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion. Alternative biosolids or sludge and soil mixing ratios may be included in the closure plan for department consideration.
- 6. Lagoon and earthen structure closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200.
- 7. When closing a mechanical wastewater plant, all biosolids or sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
  - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to storm water per 10 CSR 20-6.200. The site shall be graded and contain  $\geq$ 70% vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate

surface water drainage without creating erosion.

- b. Hazardous Waste shall not be land applied or disposed during mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations pursuant to 10 CSR 25.
- c. After demolition of the mechanical plant, the site must only contain clean fill defined in Section 260.200.1(6) RSMo as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill, reclamation, or other beneficial use. Other solid wastes must be removed.
- 8. If biosolids or sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or I, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for on-site sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR Part 503, Subpart C.

# SECTION J – MONITORING FREQUENCY

1. At a minimum, biosolids or sludge shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

<u>FABLE 5</u>					
Biosolids or Sludge	Monitoring Freq	equency (See Notes 1, and 2)			
produced and disposed (Dry Tons per Year)	Metals, Pathogens and Vectors, Total Phosphorus, Total Potassium	Nitrogen TKN, Nitrogen PAN <sup>1</sup>	Priority Pollutants <sup>2</sup>		
319 or less	1/year	1 per month	1/year		
320 to 1650	4/year	1 per month	1/year		
1651 to 16,500	6/year	1 per month	1/year		
16,501+	12/year	1 per month	1/year		

<sup>1</sup>Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

<sup>2</sup> Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) are required only for permit holders that must have a pre-treatment program. Monitoring requirements may be modified and incorporated into the operating permit by the Department on a case-by-case basis.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

- 2. Permittees that operate wastewater treatment lagoons, peak flow equalization basins, combined sewer overflow basins or biosolids or sludge lagoons that are cleaned out once a year or less, may choose to sample only when the biosolids or sludge is removed or the lagoon is closed. Test one composite sample for each 319 dry tons of biosolids or sludge removed from the lagoon during the reporting year or during lagoon closure. Composite sample must represent various areas at one-foot depth.
- 3. Additional testing may be required in the special conditions or other sections of the permit.
- 4. Biosolids and sludge monitoring shall be conducted in accordance with federal regulation 40 CFR § 503.8, Sampling and analysis.

# SECTION K – RECORD KEEPING AND REPORTING REQUIREMENTS

- 1. The permittee shall maintain records on file at the facility for at least five years for the items listed in Standard Conditions PART III and any additional items in the Special Conditions section of this permit. This shall include dates when the biosolids or sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
- 2. Reporting period
  - a. By February 19<sup>th</sup> of each year, applicable facilities shall submit an annual report for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and biosolids or sludge disposal facilities.
  - b. Permittees with wastewater treatment lagoons shall submit the above annual report only when biosolids or sludge are removed from the lagoon during the report period or when the lagoon is closed.
- 3. Report Form. The annual report shall be prepared on report forms provided by the Department or equivalent forms approved by the Department.
- 4. Reports shall be submitted as follows:

Major facilities, which are those serving 10,000 persons or more or with a design flow equal to or greater than 1 million gallons per day or that are required to have an approved pretreatment program, shall report to both the Department and EPA if the facility land applied, disposed of biosolids by surface disposal, or operated a sewage sludge incinerator. All other facilities shall maintain their biosolids or sludge records and keep them available to Department personnel upon request. State reports shall be submitted to the address listed as follows:

DNR regional or other applicable office listed in the permit (see cover letter of permit) ATTN: Sludge Coordinator Reports to EPA must be electronically submitted online via the Central Data Exchange at: https://cdx.epa.gov/ Additional information is available at: <u>https://www.epa.gov/biosolids/compliance-and-annual-reporting-guidance-about-clean-water-act-laws</u>

- 5. Annual report contents. The annual report shall include the following:
  - a. Biosolids and sludge testing performed. If testing was conducted at a greater frequency than what is required by the permit, all test results must be included in the report.
  - b. Biosolids or sludge quantity shall be reported as dry tons for the quantity produced and/or disposed.
  - c. Gallons and % solids data used to calculate the dry ton amounts.
  - d. Description of any unusual operating conditions.
  - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
    - i. This must include the name and address for the hauler and sludge facility. If hauled to a municipal wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that facility.
    - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.
  - f. Contract Hauler Activities:

If using a contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate biosolids or sludge use permit.

- g. Land Application Sites:
  - i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as alegal description for nearest <sup>1</sup>/<sub>4</sub>, <sup>1</sup>/<sub>4</sub>, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
  - ii. If the "Low Metals" criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
  - iii. Report the method used for compliance with pathogen and vector attraction requirements.
  - iv. Report soil test results for pH and phosphorus. If no soil was tested during the year, report the last date when tested and the results.

# MISSOURI DEPARTMENT OF NATURAL RESOURCES

G	###
2	

# WATER PROTECTION PROGRAM FORM B2 – APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY

FACILITY NAME

St. Peters Spencer Creek STP PERMIT NO.

MO-0030970

COUNTY St. Charles

# APPLICATION OVERVIEW

Form B2 has been developed in a modular format and consists of Parts A, B and C and a Supplemental Application Information (Parts D, E, F and G) packet. All applicants must complete Parts A, B and C. Some applicants must also complete parts of the Supplemental Application Information packet. The following items explain which parts of Form B2 you must complete. Submittal of an incomplete application may result in the application being returned.

# BASIC APPLICATION INFORMATION

- A. Basic application information for all applicants. All applicants must complete Part A.
- B. Additional application information for all applicants. All applicants must complete Part B.
- C. Certification. All applicants must complete Part C.

# SUPPLEMENTAL APPLICATION INFORMATION

- D. Expanded Effluent Testing Data. A treatment works that discharges effluent to surface water of the United States and meets one or more of the following criteria must complete *Part D Expanded Effluent Testing Data*:
  - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
  - 2. Is required to have or currently has a pretreatment program.
  - 3. Is otherwise required by the permitting authority to provide the information.
- E. Toxicity Testing Data. A treatment works that meets one or more of the following criteria must complete Part E -Toxicity Testing Data:
  - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
  - 2. Is required to have or currently has a pretreatment program.
  - 3. Is otherwise required by the permitting authority to provide the information.
- F. Industrial User Discharges and Resource Conservation and Recovery Act / Comprehensive Environmental Response, Compensation and Liability Act Wastes. A treatment works that accepts process wastewater from any significant industrial users, also known as SIUs, or receives a Resource Conservation and Recovery Act or CERCLA wastes must complete Part F Industrial User Discharges and Resource Conservation and Recovery Act /CERCLA Wastes.

SIUs are defined as:

- 1. All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N.
- 2. Any other industrial user that meets one or more of the following:
  - i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
  - ii. Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
  - iii. Is designated as an SIU by the control authority.
  - iv. Is otherwise required by the permitting authority to provide the information.
- G. Combined Sewer Systems. A treatment works that has a combined sewer system must complete *Part G Combined Sewer Systems.*

ALL APPLICANTS MUST COMPLETE PARTS A, B and C

MO 780-1805 (02-19)

# rec'd via email 05/30/19

MISSOURI DEPARTMENT OF NATURAL RESC WATER PROTECTION PROGRAM	DURCES			<b>FO</b> CHE	R AGENC	Y USE ONLY
FACILITIES THAT RECEIVE PRIMARI HAVE A DESIGN FLOW MORE THAN	LY DON 100,000	MESTIC WA	ASTE AND S PER DAY	JET	E RECEIVED	FEE SUBMITTED
PART A – BASIC APPLICATION INFORMATION						
An operating permit for a new or unpermitted facility	/.	Construc	tion Permit #			
(Include completed Antidegradation Review or requ ✓ An operating permit renewal: Permit #MO- 003097	est to con	iduct an Antid Expiratio	egradation Revie n Date <u>12/31/20</u>	w, see ir 19	nstructions) —	)
An operating permit modification: Permit #MO		Reason:				
<b>1.1</b> Is the appropriate fee included with the application (s	ee instruc	tions for appr	opriate fee)?		🗌 YES	VNO
2. FACILITY						
NAME				TELEPHC		ITH AREA CODE
				STATE	7-6600, exi	ZIP CODE
100 Ecology Dr.	St. Pete	rs		MO		63376
2.1 LEGAL DESCRIPTION (Facility Site): Sec. SE 1/	4 , <sup>T</sup> 47N	, R 4E			COUNTY St. Charles	
2.2 UTM Coordinates Easting (X): 707540.0 Northi	ng (Y): <u>4</u>	297629.02				
For Universal Transverse Mercator (UTM), Zone 18	5 North re	ferenced to N	orth American D	atum 198	83 (NAD83	)
2.3 Name of receiving stream: Spencer Creek						
2.4 Number of Outfalls: wastewater outfal	ls: 1	stormwater o	utfalls: 2 ins	tream m	onitoring si	tes:
3. OWNER: The owner of the regulated activity/discl property on which the activity or discharge is occu	harge bei urring.	ng applied fo	or and is not neo	TELEPHC	/ the owne	r of the real
City of St. Peters	b	malach@stpe	tersmo.net	636-47	7-6600, ext	1301
ADDRESS One St. Peters Centre Blvd	St. Peter	rs		STATE MO	6	ZIP CODE 53376
3.1 Request review of draft permit prior to Public Notice	e? 🖸	Z YES	NO			
3.2 Are you a Publically Owned Treatment Works (POT If yes, is the Financial Questionnaire attached?	W)?		NO NO See: <u>https:/</u>	/dnr.mo.	gov/forms/	780-2511-f.pdf
3.3 Are you a Privately Owned Treatment Facility?	<u> </u>	YES V	NO			
3.4 Are you a Privately Owned Treatment Facility regula	ated by th	e Public Servi		(PSC)?		
4. CONTINUING AUTHORITY: Permanent organization maintenance and modernization of the facility.	on which	will serve as	the continuing	authorn	ty for the c	operation,
NAME City of St. Peters	h	malach@stpe	tersmo net	636-47	7~6600. ext	t. 1301
ADDRESS				STATE		ZIP CODE
One St. Peters Centre Blvd	St. Pete	rs		MO		63376
If the Continuing Authority is different than the Owner, includ description of the responsibilities of both parties within the ag	e a copy greement.	of the contrac	t agreement betv	veen the	two parties	s and a
5. OPERATOR	T 7171 E					
Heather Wierciak	Lead Wa	astewater Pla	nt Operator	9818	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	(
EMAIL ADDRESS TELEPHONE NUMBER WITH AREA CODE			J			
hwierciak@stpetersmo.net	636-477	-6600, ext. 15	073			
NAME	1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.	TITLE				n tereze tertile si terte (1997)
LIM Myers		TELEPHONE	T UTIIITIES	CODE		
tmyers@stpetersmo.net		636-477-6	6600, ext. 1573			
ADDRESS				STATE		ZIP CODE
100 ECOIOGY Dr.	SI. Pete	15				Page 2

St. Peters Spencer Creek STP	MO- 0030970	001				
PART A – BASIC APPLICATION INFORMATION						
7. FACILITY INFORMATION						
7.1 Process Flow Diagram or Schemati treatment units, including disinfection are taken. Indicate any treatment pro Include a brief narrative description of Attach sheets as necessary.	7.1 Process Flow Diagram or Schematic. Provide a diagram showing the processes of the treatment plant. Show all of the treatment units, including disinfection (e.g. – Chlorination and Dechlorination), influents, and outfalls. Specify where samples are taken. Indicate any treatment process changes in the routing of wastewater during dry weather and peak wet weather. Include a brief narrative description of the diagram. Attach sheets as necessary.					
See attached diagram and figure:						
Treatment Description: Submersible pumps headworks. The headworks contains mecha diverted into a series of five extraneous flow	lift flow from the gravity sewers in the headwanical screening, grit removal, and influent san basins, when needed.	orks, force mains pump directly into the mpling. Excess wet weather flow can be				
Wastewater leaves the headworks and flows the clarifiers flows through a UV disinfection, Creek at Outfall 001. During high Spencer C	to two parallel oxidation ditches, before bein effluent flow meter, re-aeration basin, effluer Creek stream levels, effluent is pumped to Spe	g split into three final clarifiers, effluent from it sampling, then gravity discharge to Spencer encer Creek.				
RAS is returned to the oxidation ditches and building located at the adjacent composting f mixed with yard waste, and other compostab 503 regulations. The compost is also certifie	WAS is held in two aerated holding tanks. S facility. Sludge is dewatered on two belt filter oles, and composted in an Aerated Static Pile ad through the US Compost Council STA Tes	ludge is then pumped to the dewatering presses. De-watered biosolids are then composting system in accordance to EPA ting program.				
As a backup to the dewatering facility the Cit flow basins or sludge storage lagoons.	ty has also retained two sludge storage lagoo	ns, which can function as either extraneous				
Class A compost is sold and distributed from may also accepts biosolids from outsides sol these purposes since December 2017.	the composting site. The City is also permiting urces for land application or composting. How	ted to land apply Class B biosolids. The City wever, has not accepted biosolids for either of				
The treatment facility has a backup generato power supply, but has an independent prima	or to support the treatment process. The com ry feed from the wastewater treatment plant.	posting facility does not have a secondary				
A SCADA system is used to assist in monito	ring and operating the plant.					



			10/15/08 CONFORMED TO ADDENDUM	DATE REVISIONS AND RECORD OF ISSUE NO. BY CK APT	CYGNET ID: Procurement Manadement XREF1:	WF: AC4. dwg XREF2:	SAVED: FRE33224, 5/21/2019 4:32:42 PM XREF3:	PLOTTED: FRE33224, 5/21/2019 4:32:45 PM XREF4:	USER: FRE33224 DWG VER: 1000 XREF5:
			Black & Veatch Corporation	15450 Seath Outar Fenty Drive Suits 200 Chestarfield: Missouri 63017	636.532.7940 Engineering License No. 1646	PROFESSIONAL CERTIFICATION. I HEREBY CERTIFY THAT THIS INCUMENT WAS PREAMED OR APPROVED BY	BENJAMIN P. FREESE	AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MISSOURL.	LICENSE NO.: 2005022102 EXPIRATION: 12-31-2009
נבן הבדבסי אורפיטווסי	OI. FEIENO, MIOOUNI	SPENCER CREEK WASTEWATER	TREATMENT PLANT EXPANSION			GENERAI		FLANT JUTEMALIU	
DES DE CHL DA	SIGI TAII ECKL PRO TE: IF EASI	VED. LED. VED. VED. F	+11S 1 TO 1 4 S 4	BPF BPF UWLK TJR 9/5 1) 11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		3 00ES DRA SCA NO 15 1 79		T G 1	s s

FACILIT	Y NAME ters Spencer Creek STP	PERMIT NO. MO- 0030970	OUTFALL NO. 001				
PAR	A - BASIC APPLICATION INFORM	ATION					
7.	FACILITY INFORMATION (continue	d)					
7.2	<ul> <li>Map. Attach to this application an ae boundaries. This map must show the following website: <u>https://modnr.maps</u></li> <li>a. The area surrounding the treatm</li> <li>b. The major pipes or other structure through which treated wastewate applicable.</li> <li>c. The actual point of discharge.</li> <li>d. Wells, springs, other surface wat the treatment works, and 2) lister</li> <li>e. Any areas where the sewage slut f. If the treatment works receives w (RCRA) by truck, rail, or special it is treated, stored, or disposed.</li> </ul>	erial or topographic main e outline of the facility <u>s arcqis.com/apps/we</u> ent plant, including al res through which was er is discharged from the bodies and drinkin d in public record or o dge produced by the vaste that is classified pipe, show on the ma	ap of the area ext and the following <u>bappviewer/index</u> I unit processes. stewater enters the the treatment plan g water wells that therwise known t treatment works I as hazardous ur p where that haza	tending at lea g information. <u>x.html?id=1d8</u> ne treatment nt. Include o t are: 1) within to the applica is stored, trea nder the Reso ardous waste	ast one mile beyon A map can be on <u>31212e0854478</u> works and the pl utfalls from bypa n ¼ mile of the p nt. ated, or disposed purce Conservation enters the treat	ond facility property obtained by visiting the <u>ca0dae87c33c8c5ce</u> ipes or other structures ass piping, if property boundaries of d. ion and Recovery Act ment works and where	
7.3	Facility SIC Code:		Discharge SIC	Code: 4952			
7.4	Number of people presently connected	d or population equiv	l alent (P.E.): <u>46</u>	<u>3,72</u> 0	Design P.E.	82194	
7.5	Connections to the facility: Number of units presently connecte Residential: <u>18,73</u> 1 Commericia	ed: 19,681 I: <u>950 </u> Industria	I Incl w/ Com				
7.6	Design Flow 9.5- mgd		Actual Flow 5.4-	-mgd (2018 A	AD)		
7.7	Will discharge be continuous through Discharge will occur during the follow How many days of the week will disch	the year? Yes ing months: arge occur?		No 🗌			
7.8	Is industrial wastewater discharged to If yes, describe the number and types See Attached Sheets	the facility? of industries that dis	Yes 🖌	cility. Attach s	No 🗌 sheets as neces	sary	
	Refer to the APPLICATION OVERVIE	W to determine whet	her additional info	ormation is n	eeded for Part F		
7.9	Does the facility accept or process lea	chate from landfills?:		Yes 🗌	No 🖌		
7.10	Is wastewater land applied? If yes, please attach Form I See: http://www.see.com/	os://dnr.mo.gov/forms	/780-1686-f.pdf	Yes 🗌	No 🔽		
7.11	Does the facility discharge to a losing	stream or sinkhole?		Yes 🗌	No 🔽		
7.12	Has a wasteload allocation study bee	n completed for this fa	acility?	Yes 🗌	No 🔽		
8.	LABORATORY CONTROL INFORM	ATION	The second				
			INFI				
	LABORATORY WORK CONDUCTED	) BY PLANT PERSO	WI When her				
	LABORATORY WORK CONDUCTED Lab work conducted outside of plant.	) BY PLANT PERSOI			Yes 🔽	No 🗖	
	LABORATORY WORK CONDUCTED Lab work conducted outside of plant. Push-button or visual methods for sin	DBY PLANT PERSON	settleable solids.		Yes 🔽 Yes 🔽	No 🗖 No 🗖	
	LABORATORY WORK CONDUCTED Lab work conducted outside of plant. Push-button or visual methods for sin Additional procedures such as Dissolv Oxygen Demand, titrations, solids, vo	D BY PLANT PERSOF nple test such as pH, ved Oxygen, Chemica latile content.	settleable solids. al Oxygen Deman	nd, Biological	Yes 🗹 Yes 🗹 Yes 🔽	No 🗌 No 🗍 No 🗌	
	LABORATORY WORK CONDUCTED Lab work conducted outside of plant. Push-button or visual methods for sin Additional procedures such as Dissolv Oxygen Demand, titrations, solids, vo More advanced determinations such a nutrients, total oils, phenols, etc.	D BY PLANT PERSOF nple test such as pH, ved Oxygen, Chemica latile content. as BOD seeding proce	settleable solids. al Oxygen Deman edures, fecal colif	nd, Biological form,	Yes ☑ Yes ☑ Yes ☑ Yes ☑	No 🗌 No 🗍 No 🗍	



1-mi Radius from WWTP





FACILI		PERMIT NO.		OUTFALL NO		
St. Pe		MO- 003079				
Q Q						
0.4	le the eludre e hererdeue weet	a as defined by 10 CCD 2	52 Vac 🗖			·····································
9.1		e as defined by TO CSR 2				<u> </u>
9.2	Sludge production (Including slu	udge received from others	): Design Dry Tons/Y	'ear 3800 Ac	tual Dry To	ons/Year 1148
9.3	Sludge storage provided: <u>521k</u>	Cubic feet; <u>300</u> Days	of storage; <u>1-2</u> A	verage percent	solids of sl	udge;
	□ No sludge storage is provide	ed. 🔲 Sludge is stored in	lagoon.			
9.4	Type of storage:	<ul> <li>✓ Holding Tank</li> <li>□ Basin</li> <li>□ Concrete Pad</li> </ul>	☐ Building ☑ Lagoon ☐ Other (D	escribe)		
9.5	Sludge Treatment:			<u>,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,</u>		
	☐ Anaerobic Digester   ☑ St □ Aerobic Digester   □ Ai	orage Tank r or Heat Drying	☐ Lime Stabilization ☑ Composting	☑ Lag ☐ Oth	oon er (Attach	Description)
9.6	Sludge use or disposal:					
	<ul> <li>✓ Land Application</li> <li>✓ Co</li> <li>☐ Surface Disposal (Sludge Di</li> <li>✓ Other (Attach Explanation S</li> </ul>	ontract Hauler	led to Another Treatm eld For More Than Tw and Application since	nent Facility vo Years) 2009	Solid N	Waste Landfill ration
9.7	Person responsible for hauling s	sludge to disposal facility: Others (complete below)				
NAME				EMAIL ADDRESS		
Sludg	e is dewatered and composted o	n-site. No land applicatio	n since 2009			
ADDRE	SS	CIT	Y		SIAIE	ZIP CODE
CONTA	CT PERSON	TEL	EPHONE NUMBER WITH ARE	A CODE	PERMIT NO	).
					MO	
9.8	Sludge use or disposal facility:				1 100-	
	🖌 By Applicant 🗌 By O	thers (Complete below)		51114 ADD0500		
NAME				EMAIL ADDRESS		
ADDRE	SS	CIT	Y		STATE	ZIP CODE
CONTA	CT PERSON	TEL	FPHONE NUMBER WITH ARE	A CODE	PERMIT NO	) >
CONT					MO	
9.9	Does the sludge or biosolids d	isposal comply with Feder	al Sludge Regulation	40 CFR 503?		
		END	OF PART A			
MO 78	30-1805 (02-19)			en en sine este la contra de 1939, 1940 y	e egyel a start feri de tart.	Page 5

FACILITY NAME St. Peters Spencer Creek STP	PERMIT NO. MO- 030979		OUTFALL NO. 001	
PART B - ADDITIONAL APPLICATION INI	FORMATION	I		
10. COLLECTION SYSTEM				
10.1 Are there any municipal satellite colle	ction systems connected	to this facility? 🛛	Yes 🗌 No	
If yes, please list all connected to this	facility, contact phone nu	mber and length of e	ach collection sy	stem
FACILITY		CONTACT PHO	NE NUMBER	LENGTH OF SYSTEM (FEET OR MILES)
East Central Missouri Water & Sewer Author	ity (ECMWSA)	Kevin Dunn, 636-56	61-3737	27.1-miles
10.2 Length of sanitary sewer collection sy	ystem in miles (If available	e, include totals from	satellite collectio	n systems) <u>294</u> miles
10.3 Does significant infiltration occur in th	ne collection system?	ZYes 🗌 No		
If yes, briefly explain any steps unde	rway or planned to minimi	ze inflow and infiltrat	ion:	
Have budgeted \$125,000/yr for Sanitary Sew	ver Evaluation Studies (SS	SES). These studies	are prioritizing a	reas for sewer system
rehabilitation. 5-yr Sanitary Sewer CIP sched	dule: 2021/22 202	2/23 2023/24	4	
Pipe Lining: \$299,000 \$424,000	\$449,000 \$44	9,000 \$449,00	0	
MH Rehab: \$ 50,000 \$ 55,000	\$ 60,000 \$ 6	5,000 \$ 70,00	00	
Misc. Repairs: \$25,000 \$25,000	\$ 25,000 \$ 2	25,000 \$ 25,00	00	
	collection quatern or at the	traatmant faailitu?		egender einer die einersteligene zieren einersteligen. 1
If yes, explain:	collection system of at the	fileatment lacinty?		1
	FREADUSD BY AGUTE			
12. OPERATION AND MAINTENANCE F	PERFORMED BY CONTR	ACTOR(S)		
Are any operational or maintenance aspects	(related to wastewater tre	eatment and effluent	quality) of the tre	atment works the
responsibility of the contractor?				
If Yes list the name address telephone nur	mber and status of each o	ontractor and describ	be the contractor	s responsibilities.
(Attach additional pages if necessary.)				
NAME				
MAILING ADDRESS				
TELEPHONE NUMBER WITH AREA CODE	EN	AIL ADDRESS		
RESPONSIBILITIES OF CONTRACTOR				
13. SCHEDULED IMPROVEMENTS AND	D SCHEDULES OF IMPL	EMENTATION		-to that will affect the
Provide information about any uncompleted	implementation schedule	or uncompleted plan	atment works ha	s several different
implementation schedules or is planning sev	veral improvements, subm	it separate response	s for each.	
None	,	, , ,		

FACILITY NAME	rook STD		PERMIT NO.			OUTFALL	OUTFALL NO.				
PART B - ADDITIO		ICATION IN		J							
14. EFFLUENT	ESTING F			•							
Applicants must pro through which efflur reported must be ba comply with QA/QC not addressed by 40 more than four and idx?SID=2d29852e2	Applicants must provide effluent testing data for the following parameters. Provide the indicated effluent data for each outfall through which effluent is discharged. Do not include information of combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than four and one-half years apart. See 40 CFR 136.3 for sufficiently sensitive methods: <a href="https://www.ecfr.gov/cgi-bin/text-idx?SID=2d29852e2dcdf91badc043bd5fc3d4df&amp;mc=true&amp;node=se40.25.136_13&amp;rgn=div§ion">https://www.ecfr.gov/cgi-bin/text-idx?SID=2d29852e2dcdf91badc043bd5fc3d4df&amp;mc=true&amp;node=se40.25.136_13&amp;rgn=div&amp;section</a>										
Outfall Number											
MAXIMUM DAILY VALUE AVERAGE DAILY VALUE											
	METER		Va	alue	Units	Value	Units	Numb	er of Samples		
pH (Minimum) 7.48 S.U. 6.89 S.U. 10											
pH (Maximum) 7.75 S.U. 7.29 S.U. 10											
Flow Rate 9.170 MGD 5.668 MGD 10											
*For pH report a mir	*For pH report a minimum and a maximum daily value										
POLLUTAN	MAXIMU DISCI	JM DAILY AVERAGE DAILY DI HARGE			ISCHARGE	ANALY	TICAL	ML/MDL			
		Conc.	Units	Conc.	Units	Number of Samples	METHOD				
Conventional and N	onconventi	onal Compoi	unds				-				
BIOCHEMICAL	BOD₅	37	mg/L	3.85	mg/L	10	SM5210B		22W/15M		
(Report One)	CBOD₅	NA	mg/L	NA	mg/L	NA	NA		NA		
E. COLI		146.7	#/100 mL	58.2	#/100 mL	6	SM9223 B	-QT	1030W/206M		
TOTAL SUSPENDE SOLIDS (TSS)	D	12.4	mg/L	3.2	mg/L	10	SM2540 D		33W/18M		
TOTAL PHOSPHOR	ิเปร	4.2	mg/L	3.6	mg/L	4	EPA 200.7	*	monitoring		
TOTAL KJELDAHL NITROGEN		1.25	mg/L	1.1	mg/L	4	SM4500NH	H3D1997	montoring		
NITRITES + NITRA	TES	31.25	mg/L	19.5	mg/L	4	EPA 300.0	I	monitoring		
AMMONIA AS N		1.0	mg/L	.17	mg/L	10	EPA 350.1		5.5W/1.0M		
CHLORINE* (TOTAL RESIDUAL	, TRC)	NA	mg/L	NA	mg/L	NA	NA		NA		
DISSOLVED OXYG	EN	8.02	mg/L	4.44	mg/L	10	Hach 1036	0	NA		
OIL and GREASE		7.1	mg/L	2.76	mg/L	10	EPA 1664		15W/10M		
OTHER:		NA	mg/L	NA	mg/L	NA	NA		NA		
*Report only if facilit	y chlorinate	es									
				END OF F	PART B						
MO 780-1805 (02-19)									Page 7		

EACULTY NAME	PERMIT NO	OUTFALL NO.
St. Peters Spencer Creek STP	MO- 030979	001
PART C - CERTIFICATION		A design of the second of the second s
15. ELECTRONIC DISCHARGE MONIT	ORING REPORT (eDMR) S	JBMISSION SYSTEM
Per 40 CFR Part 127 National Pollutant Disc and monitoring shall be submitted by the per consistent set of data. <b>One of the following</b> visit <u>https://dnr.mo.gov/forms/780-2204-f.pdf</u>	harge Elimination System (I mittee via an electronic syst g must be checked in orde to access the eDMR applic	IPDES) Electronic Reporting Rule, reporting of effluent limits em to ensure timely, complete, accurate, and nationally- r for this application to be considered complete. Please ation.
- You have completed and submitted with	n this permit application the	equired documentation to participate in the eDMR system.
You have previously submitted the request eDMR system.	ired documentation to partic	ipate in the eDMR system and/or you are currently using the
You have submitted a written request for waivers.	or a waiver from electronic re	porting. See instructions for further information regarding
16. JETPAY		
Permit fees may be payed online by credit c and make an online payment.	ard or eCheck through a sys	tem called JetPay. Use the URL provided to access JetPay
New Site Specific Permit: <u>https://magic.</u> Construction Permits: <u>https://magic.colle</u> Modification Fee: <u>https://magic.collector</u>	collectorsolutions.com/magic actorsolutions.com/magic-ui/ solutions.com/magic-ui/payr	<u>&gt;-ui/payments/mo-natural-resources/591/</u> payments/mo-natural-resources/592/ nents/mo-natural-resources/596/
17. CERTIFICATION		
All applicants must complete the Certification applicants must complete all applicable sect applicants confirm that they have reviewed to application is submitted.	n Section. This certification r ions as explained in the App he entire form and have con	nust be signed by an officer of the company or city official. All lication Overview. By signing this certification statement, apleted all sections that apply to the facility for which this
ALL APPLICANTS MUST COMPLETE THE	E FOLLOWING CERTIFICA	TION.
I certify under penalty of law that this docum with a system designed to assure that qualif inquiry of the person or persons who manag information submitted is, to the best of my ke penalties for submitting false information, inc	ent and all attachments wer ied personnel properly gathe je the system or those perso nowledge and belief, true, ac cluding the possibility of fine	Prepared under my direction or supervision in accordance or and evaluate the information submitted. Based on my ns directly responsible for gathering the information, the ocurate and complete. I am aware that there are significant and imprisonment for knowing violations.
PRINTED NAME	OFFI	CIAL TITLE (MUST BE AN OFFICER OF THE COMPANY OR CITY OFFICIAL)
Russ Batzel	City	Administrator
SIGNATURE CLISSIFIC REAL		
636-477-6600, ext 1202		
DATE SIGNED		
5-22-19		
Upon request of the permitting authority, you at the treatment works or identify appropriat	u must submit any other info e permitting requirements.	rmation necessary to assess wastewater treatment practices
Send Completed Form to:		
A	Department of Natura Water Protection TTN: NPDES Permits and F P.O. Box 1	I Resources Program Engineering Section 76
	Jefferson City, MO 6	5102-0176
DEEER TO THE ADDUCATION OV		
Do not complete the remainder of this applie 1. Your facility design flow is 2. Your facility is a pretreatm 3. Your facility is a combined	cation, unless at least one of equal to or greater than 1,0 nent treatment works. d sewer system.	the following statements applies to your facility: 00,000 gallons per day.
Submittal of an incomplete application may forfeited. Permit fees for applications being	result in the application bein processed by the departme	g returned. Permit fees for returned applications shall be nt that are withdrawn by the applicant shall be forfeited.

MAKE ADDITIONAL C	MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL										
FACILITY NAME St. Peters Spencer Cree	ek STP		PERMI MO-	т NO. 003097	0			001	LL NO.		
PART D – EXPANDED	EFFLUE	NT TEST	ING DAT	A							
18. EXPANDED EFI	FLUENT	TESTING	DATA								
Refer to the APPLICAT	ION OVE	RVIEW to	o determi	ne wheth	ner Part D	applies	to the trea	tment wo	rks.		
If the treatment works has a design flow greater than or equal to 1 MGD or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information <b>for each outfall through which effluent is discharged</b> . Do not include information of combined sewer overflows in this section. All information reported must be based on data collected and analyzed using sufficiently sensitive methods found in 40 CFR Part 136. See 40 CFR 136.3 for sufficiently sensitive methods: <u>https://www.ecfr.gov/cgi-bin/text-idx?SID=2d29852e2dcdf91badc043bd5fc3d4df&amp;mc=true&amp;node=se40.25.136_13&amp;rgn=div8</u> . In addition, all data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least <b>three pollutant scans</b> and must be no more than four and one-half years prior to the date of the permit application submittal. In the blank rows provided at the end of this list, include any additional data for pollutants not specifically listed in this form. Information may be written in the blanks below or provided as attached documents containing the laboratory test results.											
	MAXIN		Y DISCH	ARGE		AVERAG	E DAILY I	DISCHAF	RGE		
POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	ML/MDL
METALS (TOTAL RECOV	/ERABLE	), CYANID	E, PHENC		HARDNES	SS	I				L
ALUMINUM	0.12	mg/l			0.0807	mg/l			3	EPA 200.7	
ANTIMONY	<0.010	mg/l			<0.010	mg/l			3	EPA 200.7	
ARSENIC	<0.015	mg/l			<0.015	mg/l			3	EPA 200.7	
BERYLLIUM	<0.001	mg/l			<0.001	mg/l			3	EPA 200.7	
CADMIUM	<0.001	mg/l			<0.001	mg/l			3	EPA 200.7	
	<0.005	mg/l			<0.005	mg/l			3	calc	
	<0.002	mg/l			<0.002	mg/l			3	EPA 200.7	
COPPER	0.0066	mg/l			0.0059	mg/l			3	EPA 200.7	
IRON	0.13	mg/l			0.0987	mg/l			3	EPA 200.7	
LEAD	<0.010	mg/l			<0.010	mg/l			3	EPA 200.7	
MERCURY	<.0002	mg/l			<.0002	mg/l			3	EPA 245.1/S	
NICKEL	0.0045	mg/l			.00405	mg/l			3	EPA 200.7	
SELENIUM	<0.010	mg/l			<0.010	mg/l			3	EPA 200.7	
SILVER	<0.002	mg/l			<0.002	mg/l			3	EPA 200.7	
THALLIUM	<0.020	mg/l			<0.020	mg/l			3	EPA 200.7	
ZINC	0.049	mg/l			0.0405	mg/l			3	EPA 200.7	
CYANIDE	<0.005	mg/l			<0.005	mg/l			3	SM4500-CN	
TOTAL PHENOLIC COMPOUNDS	<0.050	mg/l			<0.050	mg/l			3	EPA 420.1	
HARDNESS (as CaCO <sub>3</sub> )	180	mg/l			180	mg/l			2	Calc	
VOLATILE ORGANIC CO	MPOUNE	S	·····	r	<del></del>	1	1		Τ_		
ACROLEIN	<50	ug/l			<50	ug/l			3	EPA 624	
ACRYLONITRILE	<10	ug/l			<10	ug/l			3	EPA 624	
BENZENE	<5.0	ug/l			<5.0	ug/l	ļ		3	EPA 624	
BROMOFORM	<5.0	ug/l			<5.0	ug/l			3	EPA 624	
TETRACHLORIDE MO 780-1805 (02-19)	<5.0	ug/l			<5.0	ug/l			3	EPA 624	Page 9

CHICAGE         Inc. Boot         Inc. Boot         Inc. Boot           DRATE DESTRATIONED EFFLUENT TESTING DATA           Complete Onde for Ear-Outfall Discharjing Effluent to Walers of In-State           MAXIMUMDALY DISCHARCE         AVERAGE DAILY DISCHARCE           COLOPACIÓN COLSPAN         COLOPACIÓN COLSPAN <th coladingec<="" colspan="4" th=""><th>FACILITY NAME</th><th colspan="6">Y NAME PERMIT NO.</th><th></th><th>00TF</th><th>ALL NO.</th><th></th><th></th></th>	<th>FACILITY NAME</th> <th colspan="6">Y NAME PERMIT NO.</th> <th></th> <th>00TF</th> <th>ALL NO.</th> <th></th> <th></th>				FACILITY NAME	Y NAME PERMIT NO.							00TF	ALL NO.		
3. EXPANDED EFFLUENT TESTING UNITANDEL SUBJECT IN UNITANDEL SUBJECT ON CONTRACTOR OF CaNADAL SUBJECT ON CONTRACTOR OF CANA	PART D - EXPANDED		NT TES		<u></u>	<u>,</u>										
colspacecolspac	18. EXPANDED EF	FLUENT	TESTING	) DATA												
POLLUTANT         MAXIMUM DAILY DISCHARG         EVERAGE DAILY DISCHARG         Main         MANALYTICAL METHOD         MANALYTICAL METHOD         Mass         Units         Same         Composition         Same         Composition         Same         Composition         Same         Composition         Same         Units         Mass         Units         <	Complete Once for Eac	h Outfall	Discharg	ing Efflue	ent to Wa	ters of th	e State									
POLLUTANT         Conc.         Units         Mass         Units         Conc.         Units         Mass         Units         Mass         Units         Samples         METHOD         MUMDL           CHLOROSER/CEN         <5.0		MAXIN		Y DISCH	HARGE		AVERAG	E DAILY	DISCHA	RGE						
CHLOROSENSEXE         5.0         ug/l         6.0         ug/l         3         EPA 624           CHLOROSENSEXE         <0.0	POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	ML/MDL				
CHLORODERGNO- METHAKE <s.0< th="">         ug/l          S.0         ug/l         I         S.0         Ug/l         I         S.0         EPA 624           CHLOROETHANE         &lt;10</s.0<>	CHLOROBENZENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
CHLOROETHANE         <10         ug/l         <10         ug/l         J         EPA 624           2CHLOROETHAVUNYL ETHER         <10.0	CHLORODIBROMO- METHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
2-0-II.000-ETT-VLVIVVL ETHER       <10.0	CHLOROETHANE	<10	ug/l			<10	ug/l			3	EPA 624					
CHLOROPORM         <5.0         ug/l         <5.0	2-CHLORO-ETHYLVINYL ETHER	<10.0	ug/l			<10.0	ug/l			3	EPA 624					
DICILIDOGENEONOC METHANE         <5.0         ug/l         <	CHLOROFORM	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
1.1-DICHLORO-ETHANE       <5.0	DICHLOROBROMO- METHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
1.2-DICHLORO-ETHANE       <5.0	1,1-DICHLORO-ETHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
TRANS-12- DICHLOROPTHYLENE         <10.0         ug/l          S         EPA 624           11-DICHLOROP- ETHYLENE         <5.0	1,2-DICHLORO-ETHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
11-DOPLORO- ETHYLENE         <5.0         ug/l         <         <5.0         ug/l          3         EPA 624           1.2-DICHLORO-PROPANE         <5.0	TRANS-1,2- DICHLOROETHYLENE	<10.0	ug/l			<10.0	ug/l			3	EPA 624					
1.2-DICHLORO-PROPANE       <5.0	1,1-DICHLORO- ETHYLENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
13.DOPLORCO- PROPYLENE       <10.0       ug/l       <10.0       ug/l       S       EPA 624*         ETHYLENZENE       <5.0	1,2-DICHLORO-PROPANE	<5.0	ug/l			<5.0	ug/i			3	EPA 624					
ETHYLBROMIDE         <5.0         ug/l         <         <         S.0         ug/l         S.0 <t< td=""><td>1,3-DICHLORO- PROPYLENE</td><td>&lt;10.0</td><td>ug/l</td><td></td><td></td><td>&lt;10.0</td><td>ug/l</td><td></td><td></td><td>3</td><td>EPA 624*</td><td></td></t<>	1,3-DICHLORO- PROPYLENE	<10.0	ug/l			<10.0	ug/l			3	EPA 624*					
METHYL BROMIDE         <10.0         ug/l         <10.0         ug/l         3         EPA 624           METHYL CHLORIDE         <5.0	ETHYLBENZENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
METHYL CHLORIDE         <5.0         ug/l         <         <5.0         ug/l         3         EPA 624           METHYLENE CHLORIDE         <5.0	METHYL BROMIDE	<10.0	ug/l	-		<10.0	ug/l			3	EPA 624					
METHYLENE CHLORIDE         <5.0         ug/l         <5.0         ug/l         <5.0         ug/l         3         EPA 624           1.1.2TETRA- CHLOROETHANE         <5.0	METHYL CHLORIDE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
1.1.2.2-TETRA- CHLOROETHANE       <5.0	METHYLENE CHLORIDE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
TETRACHLORO-ETHANE         <5.0         ug/l         <5.0         ug/l         3         EPA 624           TOLUENE         <5.0	1,1,2,2-TETRA- CHLOROETHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
TOLUENE       <5.0       ug/l       <5.0       ug/l       3       EPA 624         1.1.1-TRICHLORO-       <5.0	TETRACHLORO-ETHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
1,1,1-TRICHLORO- ETHANE       <5.0	TOLUENE	<5.0	ug/l	-		<5.0	ug/l			3	EPA 624					
1.1.2-TRICHLORO- ETHANE       <5.0	1,1,1-TRICHLORO- ETHANE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
TRICH       <5.0	1,1,2-TRICHLORO-	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
VINYL CHLORIDE       <5.0       ug/l       <5.0       ug/l       3       EPA 624         ACID-EXTRACTABLE COMPOUNDS         P-CHLORO-M-CRESOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2-CHLOROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2-CHLOROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2-CHLOROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2.4-DICHLOROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2.4-DICHLOROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2.4-DINTROPHENOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2.4-DINITROPHENOL       <20.0       ug/l       8.3       ug/l       3       EPA 625         2.4-DINITROPHENOL       <20.0       ug/l       8.3       ug/l       3       EPA 625         2.4-DINITROPHENOL       <20.0       ug/l       8.3       ug/l       3       EPA 625         2.NITROPHENOL       <0       ug/l	TRICHLOROETHYLENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
ACID-EXTRACTABLE COMPOUNDS         P-CHLORO-M-CRESOL       <10.0	VINYL CHLORIDE	<5.0	ug/l			<5.0	ug/l			3	EPA 624					
P-CHLORO-M-CRESOL       <10.0       ug/l       <10.0       ug/l       3       EPA 625         2-CHLOROPHENOL       <10.0	ACID-EXTRACTABLE C		DS						_L							
2-CHLOROPHENOL       <10.0	P-CHLORO-M-CRESOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625					
2,4-DICHLOROPHENOL       <10.0	2-CHLOROPHENOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625					
2,4-DIMETHYLPHENOL       <10.0	2,4-DICHLOROPHENOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625					
4,6-DINITRO-O-CRESOL       <50.0	2,4-DIMETHYLPHENOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625					
2,4-DINITROPHENOL       <20.0	4,6-DINITRO-O-CRESOL	<50.0	ug/l			18.3	ug/l			3	EPA 625*					
2-NITROPHENOL         <10.0         ug/l         <10.0         ug/l         3         EPA 625           4-NITROPHENOL         <20.0	2,4-DINITROPHENOL	<20.0	ug/l			8.3	ug/l			3	EPA 625					
4-NITROPHENOL <20.0 ug/l 8.3 ug/l 3 EPA 625	2-NITROPHENOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625					
	4-NITROPHENOL	<20.0	ug/l			8.3	ug/l			3	EPA 625					

MO 780-1805 (02-19)

FACILITY NAME St. Peters Spencer Cree		PERMI MO-	T NO. 003097	0			001F	OUTFALL NO. 001			
PART D - EXPANDED	EFFLUE	ENT TES	TING DA	ТА							
18. EXPANDED EF	FLUENT	TESTING	<b>DATA</b>								
Complete Once for Ead	ch Outfall	Discharg	ing Efflue	ent to Wa	ters of th	e State.				· • • • • • • • • • • • • • • • • • • •	
	MAXIN		Y DISCH	HARGE		AVERAG	E DAILY	DISCHA	RGE	ANALYTICAL	N.AL
POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	
PENTACHLOROPHENOL	<50.0	ug/l			18.3	ug/l			3	EPA 625	
PHENOL	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
2,4,6-TRICHLOROPHENOL	<20.0	ug/l			8.3	ug/l			3	EPA 625	
BASE-NEUTRAL COMPO	DUNDS										
ACENAPHTHENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
ACENAPHTHYLENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
ANTHRACENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BENZIDINE	<80.0	ug/l			28.3	ug/l			3	EPA 625*	
BENZO(A)ANTHRACENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BENZO(A)PYRENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
3,4-BENZO-	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BENZO(GH) PHERYLENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BENZO(K)	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BIS (2-CHLOROTHOXY) METHANE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BIS (2-CHLOROETHYL) – ETHER	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BIS (2-CHLOROISO- PROPYL) ETHER	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BIS (2-ETHYLHEXYL) PHTHALATE	<12.0	ug/l			5.3	ug/l			3	EPA 625	
4-BROMOPHENYL PHENYL ETHER	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
BUTYL BENZYL PHTHALATE	<10.0	ug/i			<10.0	ug/l			3	EPA 625	
2-CHLORONAPH- THALENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
4-CHLORPHENYL PHENYL ETHER	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
CHRYSENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
DI-N-BUTYL PHTHALATE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
DI-N-OCTYL PHTHALATE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
DIBENZO (A,H) ANTHRACENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
1,2-DICHLORO-BENZENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624	
1,3-DICHLORO-BENZENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624	
1,4-DICHLORO-BENZENE	<5.0	ug/l			<5.0	ug/l			3	EPA 624	
3,3-DICHLORO- BENZIDINE	<20.0	ug/l			8.3	ug/l			3	EPA 625	
DIETHYL PHTHALATE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
DIMETHYL PHTHALATE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	

FACILITY NAME St. Peters Spencer Creek	STP	РЕГМІТ NO. МО- 0030970 001				Michigan					
PART D - EXPANDED I	FFLUEN										
18. EXPANDED EFFI	UENT T	ESTING D	ATA								
Complete Once for Each	Outfall D	ischarging	g Effluent	to Wate	rs of the	State.					
	MAXIN		Y DISCH	IARGE	ļ	AVERAG	E DAILY	DISCHA	RGE	ANALYTICAL	
POLLUTANT	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples	METHOD	
2,4-DINITRO-TOLUENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
2,6-DINITRO-TOLUENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
1,2-DIPHENYL-HYDRAZINE	<10.0	ug/l			<10.0	ug/l			1	EPA 625*	
FLUORANTHENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
FLUORENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
HEXACHLOROBENZENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
HEXACHLOROBUTADIENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
HEXACHLOROCYCLO- PENTADIENE	<20.0	ug/l			8.3	ug/l			3	EPA 625	
HEXACHLOROETHANE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
INDENO (1,2,3-CD) PYRENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
ISOPHORONE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
NAPHTHALENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
NITROBENZENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
N-NITROSODI- PROPYLAMINE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
N-NITROSODI- METHYLAMINE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
N-NITROSODI- PHENYLAMINE	<10.0	ug/l			<10.0	ug/i			1	EPA 625	
PHENANTHRENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
PYRENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
1,2,4-TRICHLOROBENZENE	<10.0	ug/l			<10.0	ug/l			3	EPA 625	
Use this space (or a sepa	arate she	et) to prov	vide inforr	nation or	n other po	ollutants r	not specif	ically liste	ed in this forr	n.	· · · · · · · · · · · · · · · · · · ·
see attached document											
		<b>.</b>	1	E	ND OF P	ART D					

Pollutant	Max Conc.	Unit	Avg. Conc.	Unit	# of Samples	Method
1,1-Dichloroethane	<5.0	ug/l	<5.0	ug/l	3	EPA 624
Surrogate: 1,2-Dichloroethane-d4	90%	59.6-134	81.70%	59.6-134	3	EPA 624
Bromodichloromethane	<5.0	ug/l	<5.0	ug/l	3	EPA 624
Surrogate: Bromofluorobenzene	115%	59.3-148	115.30%	59.3-148	3	EPA 624
Trichloroethene	<5.0	ug/l	<5.0	ug/l	3	EPA 624
2,3,7,8 TCDD Screen	<50.0	ug/l	<50.0	ug/l	3	EPA 625*
Surrogate: 2,4,6-Tribromophenol	55%	10-102	47%	10-102	2	EPA 625*
Surrogate: 2-Fluorobiphenyl	46%	12.2-95.2	44.50%	12.2-95.2	2	EPA 625*
Surrogate: 2-Fluorophenol	22%	10-48.3	19%	10-48.3	2	EPA 625*
Azobenzene	<10.0	ug/l	<10.0	ug/l	2	EPA 625*
Diphenylamine	<10.0	ug/l	<10.0	ug/l	2	EPA 625*
Surrogate: Nitrobenzene-d5	50%	18.9-92.4	47.50%	18.9-92.4	2	EPA 625*
Surrogate: Phenol-d5	15%	10-32.4	13%	10-32.4	2	EPA 625*
Surrogate: p-Terphenyl-d14	62%	15.8-107	59%	15.8-107	2	EPA 625*

# <u>City of St. Peters Wastewater Treatment Plant Expanded Effluent Study, Part D</u> <u>Pollutants Not Listed on the Permit Application</u>

MAKE ADDITIONAL COPIES OF THIS FORM	FOR EACH OUTFALL								
FACILITY NAME	PERMIT NO.	OUTFALL NO.							
	MO- 0030970	<u> </u>							
PARTE - TOXICITY TESTING DATA		la de la centra de la della del construcción de la centra de la construcción de la construcción de la construc Nova de la construcción de la const							
19. TOXICITY TESTING DATA									
Refer to the APPLICATION OVERVIEW to dete	ermine whether Part E applies	s to the treatment works.							
<ul> <li>Publicly owned treatment works, or POTWs, meeting one or more of the following criteria must provide the results of whole effluent toxicity tests for acute or chronic toxicity for each of the facility's discharge points.</li> <li>A. POTWs with a design flow rate greater than or equal to 1 million gallons per day</li> <li>B. POTWs with a pretreatment program (or those that are required to have one under 40 CFR Part 403)</li> <li>C. POTWs required by the permitting authority to submit data for these parameters</li> <li>At a minimum, these results must include quarterly testing for a 12-month period within the past one year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the application, provided the results show no appreciable toxicity, and testing for acute or chronic toxicity, depending on the range of receiving water dilution. Do not include information about combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136.</li> <li>If EPA methods were not used, report the reason for using alternative methods. If test summaries are available that contain all of the information requested below, they may be submitted in place of Part E. If no biomonitoring data is required, do not complete Part E. Refer to the application overview for directions on which other sections of the form to complete.</li> </ul>									
Indicate the number of whole effluent toxicity te	ests conducted in the past fou	r and one-half years:c	hronic <u>9</u> acute						
Complete the following chart for the last three three tests are being reported.	whole effluent toxicity test	s. Allow one column per test.	Copy this page if more than						
	Most Recent	2 <sup>ND</sup> Most Recent	3 <sup>RD</sup> Most Recent						
A. Test Information									
Test Method Number	EPA 600/4-90/027	EPA 1000.0, 1002.0	EPA 600/4-90/027						
Final Report Number	EAS Log # 2308833	Ref# 6026185	EAS Log # 2016607						
Outfall Number	001	001	001						
Dates Sample Collected	January 7-8, 2019	January 8-12, 2018	January 9-10, 2017						
Date Test Started	January 9, 2019	January 9, 2018	January 11, 2017						
Duration	48 hours	7 days	48 hours						
B. Toxicity Test Methods Followed									
Manual Title	EPA-821-R-02-012	EPA-821-R-02-013	EPA-821-R-02-012						
Edition Number and Year of Publication	5th Ed.	Toxistat Version 3.4	5th Ed.						
Page Number(s)									
C. Sample collection method(s) used. For mul	tiple grab samples, indicate t	he number of grab samples use	ed						
24-Hour Composite	24 hour composite	24 hour composite	24 hour composite						
Grab									
D. Indicate where the sample was taken in rela	tion to disinfection (Check a	Il that apply for each)							
Before Disinfection									
After Disinfection									
After Dechlorination									
E. Describe the point in the treatment process	at which the sample was coll	ected							
Sample Was Collected:	after UV	after UV	after UV						
F. Indicate whether the test was intended to as	ssess chronic toxicity, acute to	oxicity, or both							
Chronic Toxicity									
Acute Toxicity									
G. Provide the type of test performed		I	•						
Static									
Static-renewal		Image: A state of the state							
Flow-through									
H. Source of dilution water. If laboratory water	, specify type; if receiving wa	ter, specify source	· · · · · · · · · · · · · · · · · · ·						
Laboratory Water									
Receiving Water	Receiving Water								
MO 780-1805 (02-19)			Page 13						

FACILITY NAME St. Peters Spencer Creek STP	PERMIT NO.         OUTFALL NO.           MO0030970         001								
PART E - TOXICITY TESTING DATA									
19. TOXICITY TESTING DATA (continued	n								
	Most Recent	Second Most Recent	Third Most Recent						
I Type of dilution water If salt water specify	"natural" or type of artificial	sea salts or brine used.							
Fresh Water	unstream water	upstream water	upstream water						
Salt Water									
J Percentage of effluent used for all concentrations in the test series									
	6 25 12 5 25 50 100	0.6 25 12 5 25 50 100	6.25.12.5.25.50.100						
	0.20, 12.0, 20,000, 100								
K Parameters measured during the test (Stat	e whether parameter meets	test method specifications)							
nH	7.63	7 42	7.60						
Salinity	1172	1519	1622						
Temperature	5*0	25*C	12*C						
Ammonia	0.043		< 05						
Dissolved Oxygen	10.1	7.10	10.8						
Test Results		l'•							
Acute									
Percent Survival in 100% Effluent	100		100						
	>100		>100						
95% C I	95		95						
Control Percent Survival	100		100						
Other (Describe)	100								
Chronic:	l								
NOEC		100							
		>100							
Control Percent Sun/ival		100							
M. Quality Control/ Quality Assurance									
Is reforence toxicant data available?	Vec	Ves	Ves						
Was reference toxicant test within	yes		, yes						
acceptable bounds?	yes	yes	yes						
What date was reference toxicant test run (MM/DD/YYYY)?	01/09/2019	routinely performed	01/04/2017						
Other (Describe)									
Is the treatment works involved in a toxicity re If yes, describe:	duction evaluation?	]Yes 🛛 No							
If you have submitted biomonitoring test inforr years, provide the dates the information was s	nation, or information regard submitted to the permitting a	ling the cause of toxicity, within uthority and a summary of the r	the past four and one-half esults.						
Date Submitted (MM/DD/YYYY)									
Summary of Results (See Instructions)									
REFER TO THE APPLICATION OVERVIEW	END OF PAR TO DETERMINE WHICH C	T E OTHER PARTS OF FORM B2 Y	OU MUST COMPLETE.						

MAKE	ADDITIONAL COPIES OF THIS FOR	RM FOR EACH OUTF	ALL			
FACILIT	SPENCER CREEK WWTP	PERMIT NO. MO-0030970	OUTFALL NO. 001			
PART	F – INDUSTRIAL USER DISCHARGE	ES AND RCRA/CERC	LA WASTES			
Refer	to the APPLICATION OVERVIEW to d	etermine whether Part	F applies to the treatme	ent works.		
19.	GENERAL INFORMATION					
19.1	Does the treatment works have, or is	it subject to, an approv	ed pretreatment progra	n?		
19.2	Number of Significant Industrial Users following types of industrial users that Number of non-categorical SIUs 1	(SIUs) and Categorica discharge to the treatr —	al Industrial Users (CIUs nent works:	). Provide the nun	nber of eac	ch of the
20.	INDUSTRIES CONTRIBUTING MORE SIGNIFICANT INDUSTRIAL USERS	E THAN 5 PERCENT (	OF THE ACTUAL FLOW	V TO THE FACILI	IY OR OT	HER
Suppl reque	y the following information for each SIL sted for each. Submit additional pages	<ol> <li>If more than one SII as necessary.</li> </ol>	J discharges to the treat	ment works, provi	de the info	rmation
RB M	ANUFACTURING LLC					
MAILING 30 AF	ADDRESS		ST. PETI	ERS	STATE MO	ZIP CODE 63376
<b>20.1</b> Manufa	Describe all of the industrial processe acture of disinfecting wipes, dishwashir	s that affect or contribung and laundry cleanin	ute to the SIU's discharg g products, and househ	e old cleaners and re	medies.	
20.2	Describe all of the principle processes	s and raw materials that	at affect or contribute to	the SIU's discharg	e.	
	Principal Product(s): Lysol wipes and English, Spray N	cleaners, Finish tabs and NWash, and RidX	d Jet Dry, Resolve, Woolite	, Lime-A-Way, Calgo	n, Glass Pl	us, Old
	Raw Material(s): SEE ATTACHED					
20.3	Flow Rate					
	a. PROCESS WASTEWATER FLOW collection system in gallons per d 25,000 gpd  Cont	RATE. Indicate the av ay, or gpd, and whethe inuous	verage daily volume of p er the discharge is contin Intermittent	rocess wastewate nuous or intermitte	r discharge nt.	ed into the
	b. NON-PROCESS WASTEWATER F the collection system in gallons p 16,000 gpd	LOW RATE. Indicate er day, or gpd, and wh inuous	the average daily volum ether the discharge is co Intermittent	ne of non-process continuous or intern	wastewate nittent.	r discharged into
20.4	Pretreatment Standards. Indicate whe	ether the SIU is subjec	t to the following:			
	a. Local Limits	🗹 Yes	🗖 No			
	b. Categorical Pretreatment Standa	rds 🔲 Yes	🔽 No			
	If subject to categorical pretreatment s	standards, which categ	ory and subcategory?			
20.5	Problems at the treatment works attrib (e.g., upsets, interference) at the treat Yes I No	buted to waste dischar tment works in the pas	ged by the SIU. Has the t three years?	SIU caused or co	ntributed t	o any problems
	If Yes, describe each episode					
780-	1805 (09-16)					Page 15
Outfall 001

### PART F - INDUSTRIAL USER DISCHRGES AND RECRA/CERCLA WASTES

#### **RB Manufacturing LLC con't.**

#### 20.3 Flow Rate

a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent.

RB Manufacturing LLC has two permitted outfalls, both subject to local limit standards.

- Outfall 001 discharges the wastewater from the facilities pretreatment process, which treats an average of approximately 20,000 gpd. The other wastes that make up the discharge at this outfall are reject RO/Softwater and sanitary waste.
- Outfall 002 discharges an average of 5,000 gpd. This discharge is made up of sanitary waste and has the potential to contain wastewater from the production floor from rinsing and washing operations. RB Manufacturing is currently requesting that this outfall be removed from permit claiming that it is only sanitary waste and not process water.

H-Hachnent A

BULK TANK INVENTORY INFORMATION FORM (STP-WI-MIXHH-0009)

HEALTHINGTER DATE: Tánk Part# Tank # Description. Size (g]s), 238 A&B 380053 Effectenz 6,800 313 0010802 Accusol 568 10,000 0004322-Sodium Lauryl Ether 314 10,000 Sulfate Total Cap 146,000 Calloam 315 10,000 Alkylbenzene 317 373246 10,000 Sulfonic Acid (Pilot - Calsoft 318 140000 lbs tot 10,000 LAS-99) Dissolvine GL-45-319 10,000 0110495 SLA Dissolvine GL-45-0110495 320 10,000 SLA 329 0044791 Mineral OII (Conosol) 14,500 330 n/a Waste Water 10,000 331 \* 520139 Asphaitic Black 7,000 Peroxide 50% Tech 401 359559 13,000 Grade 402 \* 0208989 Ethanol SDA 40-2 10,000 403 369421 Plurafac 11,000 405 354148 8TC 8358 10.000 407 \* 355512 Glycol Ether PNB 10,000 408 363512 APG 325N 10.000 Cocount Fatty Acid 411 376112 7,600 409 378661 cumenesulphonate, 10,000 410 520941 10,950 MEA 412 355604 10,000 \* Ammonyx LO Sodium Lauryl 413 \* 520295 10,000 Sulfate 29% 414 8171458 Alfonic TDA6 10,245 415 N/A Waste Water 10,245 416 N/A Waste Water 15,000 417 \* 0046248 Alpha Step MC48 10,000 418 354136 Triethanolamine 10,000 Peroxide 50% EPA 419 8002875 6,000 Grade Ethoxylated Alcohol 501 363568 15.000 3EO Ethoxylated Alcohol 504 363668 15,000 3EO 502 361709 Dowanol DPnB 15,000 503 359209 Accusol 445N 10,000 Ethoxylated Alcohol 363567 505 15,000 ວງ7ຄົາອິເເນ 10,000 506 363587 Ethoxylated Alcohol Citric Acid 50% . 507 368058 15,000 Hydroxyacetic Acid 508 354391 10,000 70% 509 520294 Dowfax 3B2 10,000 Caustic Soda 50% 365179 10,000 510 Membrane Sodjum silicate, 10,400 511 358174 47.5% Sodium silicale, 512 358174 10,00 47.5% otassium hydroxide 354144 10,00 601 45% 602 363913 10,00 Propylene Glycol 15% Sodium 364086 15,00 603 Hypochlorite Silo 2 371739 Soda Ash railca Silo 3 0244074 Sodium Bicarbonate railca



 Squallons:
 a. Gallons in tank ~ (inches of liquid x Gallons/inch) + Cone Gallons
 These tank must be pumper or

 b. Lbs. in tank ~ Gallons in tank x Lbs/Gallon
 1. roofed
 State ondary

 1. roofed
 2. Secondary
 8. Cathodis

 Containment
 3. Single-walled
 4. Double-walled
 6. Leak Detection
 6. Overfill Protection
 7. Inspection Manhole
 Protection

STP-FRM-MIXHH-0005

.

**REVISION 06** 

1 of 1

MAK	E ADDITIONAL COPIES OF THIS FO	RM FOR EACH OU	TFALL					
FACILIT	SPENCER CREEK WWTP	PERMIT NO. MO- 0030970	)	OUTFALL NO.	001			
PAR	PART F INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES							
Refer	Refer to the APPLICATION OVERVIEW to determine whether Part F applies to the treatment works.							
19.	GENERAL INFORMATION							
19.1	<b>19.1</b> Does the treatment works have, or is it subject to, an approved pretreatment program?         ✓ Yes       □ No							
19.2	<ul> <li>19.2 Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs). Provide the number of each of the following types of industrial users that discharge to the treatment works:</li> <li>Number of non-categorical SIUs</li> <li>Number of CIUs</li> </ul>							
20.	INDUSTRIES CONTRIBUTING MOR SIGNIFICANT INDUSTRIAL USERS	RE THAN 5 PERCEN	T OF THE ACTUAL I	LOW TO THE F	ACILITY OR OT	HER		
Supp reque	ly the following information for each Sleasted for each. Submit additional page	IU. If more than one es as necessary.	SIU discharges to the	treatment works,	provide the info	rmation		
NAME SUE	Z WTS SERVICES USA, INC.							
MAILING P.O	G ADDRESS BOX 1148		CITY ST.	PETERS	STATE MO	ZIP CODE 63376		
20.1	Describe all of the industrial process	es that affect or cont	ribute to the SIU's disc	charge				
20.2	Describe all of the principle process	es and raw materials	that affect or contribut	te to the SIU's dis	charge.			
20.2	Principal Product(s): Regenerated in	on exchange resins and	cleaned RO membrane	s for water treatmen	t units.			
	Raw Material(s): HCl, H2SO4, NaOł ionic surfactant, An	H, CO2, H2O, NaCl, Na tifoam, Glycerin, Anion	OCI, CO2.Sodium Metab resin, Cation resin, Activ	oisulfite, Citric Acid, vated Carbon. RO cl	Soda Ash, Propyle eaning chemicals.	ene Glycol, non		
20.3	Flow Rate							
	a. PROCESS WASTEWATER FLOV collection system in gallons per 130,000 gpd Cor SEE ATTACHED	V RATE. Indicate the day, or gpd, and whe ntinuous	e average daily volume ther the discharge is o Intermittent	e of process waste continuous or inte	ewater discharg rmittent.	ed into the		
	b. NON-PROCESS WASTEWATER the collection system in gallons 0 gpd Cor	FLOW RATE. Indica per day, or gpd, and ntinuous	ate the average daily whether the discharge	volume of non-pro e is continuous or	cess wastewate intermittent.	r discharged into		
20.4	Pretreatment Standards. Indicate w	nether the SIU is sub	ject to the following:					
	a. Local Limits	🗹 Yes	🗖 No					
	b. Categorical Pretreatment Stand	ards 🔽 Yes	🗖 No					
	If subject to categorical pretreatment	standards, which ca	tegory and subcatego	ry?				
00.5	40 CFR 437 A	ibuted to weate diash	arged by the SILL U	e the SILL caused	or contributed t	o any problems		
20.5	(e.g., upsets, interference) at the treatment works attr (Problems at the treatment works attr (e.g., upsets, interference) at the treatment works attr	atment works in the p	arged by the SIO. He past three years?		or contributed t			
	If Yes, describe each episode							
L	1805 (09-16)					Page 15		

## Spencer Creek WWTP MO0030970 Outfall 001

# PART F - INDUSTRIAL USER DISCHRGES AND RCRA/CERCLA WASTES

# SUEZ WTS SERVICES USA, INC. con't.

This facility has two permits. One as an SIU for the non-categorical process to treat resin regeneration and RO membrane cleaning waste. The other for the categorical waste from the Centralized Waste Treatment process for waste acids and bases with or without metals.

**20.1** Describe all the industrial processes that affect or contribute to the SIU's discharge.

- Cation Resin Regeneration
- Anion Resin Regeneration
- Metals removal by WAC (weak acid cation exchange)

This regeneration process produces acidic and basic wastewater containing the anions and cations removed and possibly metals. Metal wastes are further treated by weak acid cation exchange for metal removal.

### 20.3 Flow Rate

a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent.

The total average daily discharge for 2018 was 130,000 gpd. Discharge is intermittent. The discharge from the CWT process is intermittent and sporadic. When the CWT waste is discharged to the City of St. Peters, it is comingled with other regulated process wastewater that are not considered CWT waste. The permitted average daily flow for CWT subcategory A waste is 2,500 gpd. A majority of the CWT wastewater is hauled off site.

<u></u>	TY NAME	PERMIT NO.	OUTFALL NO.				
		MO					
PAR	T F – INDUSTRIAL USER DISCHARC	SES AND RCRA/CERCLA WASTES					
22.	RCRA HAZARDOUS WASTE RECE	IVED BY TRUCK, RAIL, OR DEDICATED	PIPELINE				
22.1	Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe?						
22.2       Method by which RCRA waste is received. (Check all that apply)							
22.3	Waste Description						
	EPA Hazardous Waste Number	Amount (volume or mass)	Units				
23.	CERCLA (SUPERFUND) WASTEWA REMEDIAL ACTIVITY WASTEWAT	ATER, RCRA REMEDIATION/CORRECTIN	/E ACTION WASTEWATER, AND OTHER				
23.1	.1 Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities? ☐ Yes ☐ No						
Provide a list of sites and the requested information for each current and future site.							
23.3	known. (Attach additional sheets if r	are received (or are expected to be received iecessary)					
23.4	Waste Treatment						
23.4	Waste Treatment a. Is this waste treated (or will it be tr Yes	eated) prior to entering the treatment works	s?				
23.4	Waste Treatment a. Is this waste treated (or will it be tr Yes If Yes, describe the treatment (p	reated) prior to entering the treatment works ☐ No rovide information about the removal efficie	s? ency):				
23.4	Waste Treatment a. Is this waste treated (or will it be tr Yes If Yes, describe the treatment (p b. Is the discharge (or will the discharge)	reated) prior to entering the treatment works No provide information about the removal efficient rge be) continuous or intermittent?	s? ancy):				
23.4	Waste Treatment a. Is this waste treated (or will it be tr Yes If Yes, describe the treatment (p b. Is the discharge (or will the discha Continuous If intermittent, describe the disch	reated) prior to entering the treatment works No provide information about the removal efficient rge be) continuous or intermittent? Intermittent harge schedule:	s? ency):				
23.4	Waste Treatment a. Is this waste treated (or will it be tr Yes If Yes, describe the treatment (p b. Is the discharge (or will the discha Continuous If intermittent, describe the disch	reated) prior to entering the treatment works No provide information about the removal efficient rge be) continuous or intermittent? Intermittent harge schedule:	s? ency):				

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL										
FACILIT	YNAME	PERMIT NO.		C	DUTFALL NO.					
PART G - COMBINED SEWER SYSTEMS										
Refer to the APPLICATION OVERVIEW to determine whether Part G applies to the treatment works.										
24.	24. GENERAL INFORMATION									
24.1	<ol> <li>System Map. Provide a map indicating the following: (May be included with basic application information.)</li> <li>A. All CSO Discharges.</li> <li>B. Sensitive Use Areas Potentially Affected by CSOs. (e.g., beaches, drinking water supplies, shellfish beds, sensitive aquatic ecosystems and Outstanding Natural Resource Waters.)</li> <li>C. Waters that Support Threatened and Endangered Species Potentially Affected by CSOs.</li> </ol>									
24.2	<ul> <li>4.2 System Diagram. Provide a diagram, either in the map provided above or on a separate drawing, of the Combined Sewer Collection System that includes the following information: <ul> <li>A. Locations of Major Sewer Trunk Lines, Both Combined and Separate Sanitary.</li> <li>B. Locations of Points where Separate Sanitary Sewers Feed into the Combined Sewer System.</li> <li>C. Locations of In-Line or Off-Line Storage Structures.</li> <li>D. Locations of Flow-Regulating Devices.</li> <li>E. Locations of Pump Stations.</li> </ul> </li> </ul>									
24.3	Percent of collection system that is cor	mbined sewer								
24.4	Population served by combined sewer	collection sys	stem							
24.5	Name of any satellite community with	combined sev	ver collection system	)						
25.	CSO OUTFALLS. COMPLETE THE F	OLLOWING	ONCE FOR EACH	CSO DISCHAR						
25.1	<ul> <li>Description of Outfall</li> <li>a. Outfall Number</li> <li>b. Location</li> <li>c. Distance from Shore (if applicable)</li> </ul>	ft								
	c. Distance from Shore (if applicable) it									
	e. Which of the following were monitor Rainfall CSO Flow Volume f. How many storm events were monit	ed during the ] CSO Polluta ] Receiving W tored last year	last year for this CS nt Concentrations /ater Quality ·?	o? □cso						
25.2	CSO Events									
	a. Give the Number of CSO Events in	the Last Year	Events	Actual	Approximate					
	b. Give the Average Duration Per CSC	) Event	Hours	Actual	Approximate					
	c. Give the Average Volume Per CSO	Event	Million Gallons	Actual	Approximate					
	d. Give the minimum rainfall that cause	ed a CSO eve	nt in the last year	inches	of rainfall					
25.3	Description of Receiving Waters									
	a. Name of Receiving Water									
	b. Name of Watershed/River/Stream S	System								
	c. U.S. Soil Conservation Service 14-Digit Watershed Code (If Known)									
	d. Name of State Management/River E	sasin Iralagia Catala	aina Unit Codo /If K	nown)						
e. U.S. Geological Survey 8- Digit Hydrologic Cataloging Unit Code (If Known)										
Describe any known water quality impacts on the receiving water caused by this CSO (e.g., permanent or intermittent beach closings, permanent or intermittent shellfish bed closings, fish kills, fish advisories, other recreational loss, or violation of any applicable state water quality standard.)										
DEC	END OF PART G REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE									
REFE	IN TO THE APPLICATION OVERVIEW			IN FAILIS UP I	ON BETOD WOOT COMPLETE.					

MO 780-1805 (02-19)