

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law (Chapter 644 RSMo, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No.: MO-0044300

Owner: City of Jefferson
Address: 320 East McCarty Street, Jefferson City, MO 65101

Continuing Authority:
Address: Same as above

Facility Name: Algoa Regional Wastewater Treatment Facility
Facility Address: 8501 Fenceline Road, Jefferson City, MO 65101

Legal Description: Landgrant 2616, Cole County
UTM Coordinates: X = 581833, Y = 4267935

Receiving Stream: Missouri River (P)
First Classified Stream and ID: Missouri River (P) (701)
USGS Basin & Sub-watershed No.: (10300102-1306)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 – POTW

The use or operation of this facility shall be by or under the supervision of a Certified C Operator.
Influent bar screen / two basin, four-cell lagoon / UV disinfection / sludge retained in lagoon or biosolids are land applied
Design population equivalent is 8,000.
Design flow is 800,000 gallons per day.
Actual flow is 600,500 gallons per day.
Design sludge production is 120 dry tons/year.


Permitted Feature INF – Influent monitoring location prior to bar screen

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas.

December 1, 2020
Effective Date


Edward B. Galbraith, Director, Division of Environmental Quality

June 30, 2025
Expiration Date


Chris Wieberg, Director, Water Protection Program

OUTFALL #001	TABLE A-1. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					
The permittee is authorized to discharge from outfall number(s) as specified in the application for this permit. The final effluent limitations in Table A-1 shall become effective on December 1, 2020 and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
Limit Set: M						
EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	MGD	*		*	once/weekday**	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		65	45	once/month	grab
Total Suspended Solids	mg/L		110	70	once/month	grab
<i>E. coli</i> (Note 1, Page 3)	#/100mL		1,030	206	once/week	grab
Ammonia as N	mg/L	*		*	once/month	grab
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.0			once/month	grab
EFFLUENT PARAMETER(S)			UNITS	MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
Biochemical Oxygen Demand ₅ – Percent Removal (Note 2, Page 3)			%	65	once/month	calculated
Total Suspended Solids – Percent Removal (Note 2, Page 3)			%	65	once/month	calculated
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE JANUARY 28, 2021 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
Limit Set: Q						
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Oil & Grease	mg/L	15		10	once/quarter****	grab
Total Phosphorus	mg/L	*		*	once/quarter****	grab
Total Kjeldahl Nitrogen	mg/L	*		*	once/quarter****	grab
Nitrite + Nitrate	mg/L	*		*	once/quarter****	grab
MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY ; THE FIRST REPORT IS DUE APRIL 28, 2021 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

- * Monitoring requirement only.
 ** Once each weekday means: Monday, Tuesday, Wednesday, Thursday, and Friday.
 *** pH is measured in pH units and is not to be averaged.
 **** See table below for quarterly sampling requirements.

Quarterly Minimum Sampling Requirements			
Quarter	Months	Quarterly Effluent Parameters	Report is Due
First	January, February, March	Sample at least once during any month of the quarter	April 28 th
Second	April, May, June	Sample at least once during any month of the quarter	July 28 th
Third	July, August, September	Sample at least once during any month of the quarter	October 28 th
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28 th

Note 1 – Effluent limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean.

Note 2 – Influent sampling for BOD₅ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula:

$$[(\text{Average Influent} - \text{Average Effluent}) / \text{Average Influent}] \times 100\% = \text{Percent Removal}$$
Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a grab sample.

PERMITTED FEATURE <u>INF</u>	TABLE B-1. INFLUENT MONITORING REQUIREMENTS					
The monitoring requirements in Table B-1 shall become effective on <u>December 1, 2020</u> and remain in effect until expiration of the permit. The influent wastewater shall be monitored by the permittee as specified below:						
PARAMETER(S)	UNITS	MONITORING REQUIREMENTS				
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: IM						
Biochemical Oxygen Demand ₅ (Note 2)	mg/L			*	once/month	grab
Total Suspended Solids (Note 2)	mg/L			*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>JANUARY 28, 2021</u> .						
Limit Set: IQ						
Ammonia as N	mg/L	*		*	once/quarter****	grab
Total Phosphorus	mg/L	*		*	once/quarter****	grab
Total Kjeldahl Nitrogen	mg/L	*		*	once/quarter****	grab
Nitrite + Nitrate	mg/L	*		*	once/quarter****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>APRIL 28, 2021</u> .						

* Monitoring requirement only.

**** See table below for quarterly sampling requirements.

Quarterly Minimum Sampling Requirements			
Quarter	Months	Quarterly Influent Parameters	Report is Due
First	January, February, March	Sample at least once during any month of the quarter	April 28 th
Second	April, May, June	Sample at least once during any month of the quarter	July 28 th
Third	July, August, September	Sample at least once during any month of the quarter	October 28 th
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28 th

C. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached **Parts I, II, & III** standard conditions dated **August 1, 2014, May 1, 2013, and August 1, 2019**, and hereby incorporated as though fully set forth herein.

D. SPECIAL CONDITIONS

1. Electronic Discharge Monitoring Report (eDMR) Submission System. Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent monitoring data and any report required by the permit (unless specifically directed otherwise by the permit) shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally consistent set of data about the NPDES program.
 - (a) eDMR Registration Requirements. The permittee must register with the Department's eDMR system through the Missouri Gateway for Environmental Management (MoGEM) before the first report is due. Registration and other information regarding MoGEM can be found at <https://dnr.mo.gov/mogem>. Information about the eDMR system can be found at <https://dnr.mo.gov/env/wpp/edmr.htm>. The first user shall register as an Organization Official and the association to the facility must be approved by the Department. Regarding Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit unless a waiver is granted by the Department. See paragraph (c) below.
 - (b) Electronic Submissions. To access the eDMR system, use the following link in your web browser: <https://apps5.mo.gov/mogems/welcome.action>. If you experience difficulties with using the eDMR system you may contact edmr@dnr.mo.gov or call 855-789-3889 or 573-526-2082 for assistance.
 - (c) Waivers from Electronic Reporting. The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the Department in compliance with 40 CFR Part 127. Only permittees with an approved waiver request may submit monitoring data and reports on paper to the Department for the period that the approved electronic reporting waiver is effective. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: <http://dnr.mo.gov/forms/780-2692-f.pdf>. The Department will either approve or deny this electronic reporting waiver request within 120 calendar days.
2. The full implementation of this operating permit, which includes implementation of any applicable schedules of compliance, shall constitute compliance with all applicable federal and state statutes and regulations in accordance with §644.051.16, RSMo, and the Clean Water Act (CWA) section 402(k); however, this permit may be reopened and modified, or alternatively revoked and reissued:
 - (a) To comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) To incorporate an approved pretreatment program or modification thereto pursuant to 40 CFR 403.8(c) or 40 CFR 403.18(e), respectively.
3. All outfalls must be clearly marked in the field.
4. Report as no-discharge when a discharge does not occur during the report period.
5. Reporting of Non-Detects:
 - (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
 - (b) The permittee shall not report a sample result as "Non-Detect" without also reporting the detection limit of the test. Reporting as "Non Detect" without also including the detection limit will be considered failure to report, which is a violation of this permit.
 - (c) The permittee shall provide the "Non-Detect" sample result using the less than sign and the minimum detection limit (e.g. <10).
 - (d) Where the permit contains a Minimum Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
 - (e) See Standard Conditions Part I, Section A, #4 regarding proper detection limits used for sample analysis.
 - (f) When a parameter is not detected above ML, the permittee must report the data qualifier signifying less than ML for that parameter (e.g., < 50 µg/L, if the ML for the parameter is 50 µg/L). For reporting an average based on a mix of values detected and not detected, assign a value of "0" for all non-detects for that reporting period and report the average of all the results.
6. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).

D. SPECIAL CONDITIONS (continued)

7. The permittee shall comply with any applicable requirements listed in 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. To request a modification of the operational control testing requirements listed in 10 CSR 20-9, the permittee shall submit a permit modification application and fee to the Department requesting a deviation from the operational control monitoring requirements. Upon approval of the request, the Department will modify the permit.
8. The permittee shall develop and implement a program for maintenance and repair of its collection system. The permittee may compare collection system performance results and other data with the benchmarks used in the Departments' Capacity, Management, Operation, And Maintenance (CMOM) Model located at <http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc>. Additional information regarding the Departments' CMOM Model is available at <http://dnr.mo.gov/pubs/pub2574.htm>.

The permittee shall also submit a report via the Electronic Discharge Monitoring Report (eDMR) Submission System annually, by January 28th, for the previous calendar year. The report shall contain the following information:

- (a) A summary of the efforts to locate and eliminate specific sources of excessive infiltration and inflow into the collection system serving the facility for the previous year.
 - (b) A summary of the general maintenance and repairs to the collection system serving the facility for the previous year.
 - (c) A summary of any planned maintenance and repairs to the collection system serving the facility for the upcoming calendar year. This list shall include locations (GPS, 911 address, manhole number, etc.) and actions to be taken.
9. Bypasses are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2. Bypasses are to be reported to the Central Field Operations Office during normal business hours or by using the online Sanitary Sewer Overflow/Facility Bypass Application located at: <https://dnr.mo.gov/mogem/> or the Environmental Emergency Response spill-line at 573-634-2436 outside of normal business hours. Once an electronic reporting system compliant with 40 CFR Part 127, the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, is available all bypasses must be reported electronically via the new system. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
 10. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.
 11. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
 12. An all-weather access road to the treatment facility shall be maintained.
 13. The outfall sewer shall be protected and maintained against the effects of floodwater, ice, or other hazards as to reasonably insure its structural stability, freedom from stoppage, and that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
 14. The lagoon(s) shall be operated and maintained to ensure their structural integrity, which includes maintaining adequate freeboard and keeping the berms free of deep-rooted vegetation, animal dens, or other potential sources of damage.
 15. The facility shall ensure that adequate provisions are provided to prevent or minimize surface water intrusion into the lagoon and to divert stormwater runoff around the lagoon and protect embankments from erosion
 16. Sewer Extension Authority Supervised Program: The City of Jefferson has a department approved Sewer Program. The applicable reporting requirements for the program are detailed in Special Condition #19 of the Missouri State Operating Permit MO-0094846 for the Jefferson City RWRf.
 17. Pretreatment Program: The City of Jefferson is required to implement and update the previously approved pretreatment program. The applicable reporting requirements for the program are detailed in Special Condition #20 of the Missouri State Operating Permit MO-0094846 for the Jefferson City RWRf.

E. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to pursue an appeal before the administrative hearing commission (AHC) pursuant to Sections 621.250 and 644.051.6 RSMo. To appeal, you must file a petition with the AHC within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

**MISSOURI DEPARTMENT OF NATURAL RESOURCES
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO-0044300
ALGOA REGIONAL WASTEWATER TREATMENT FACILITY**

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollutant Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)(A)2.], a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Minor facility.

Part I – Facility Information

Facility Type: POTW

Facility Description: Influent bar screen / two basin, four-cell lagoon / UV disinfection / sludge retained in lagoon

Have any changes occurred at this facility or in the receiving water body that affects effluent limit derivation?

✓ No.

Application Date: 12/30/19

Expiration Date: 06/30/20

OUTFALL(S) TABLE:

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	1.24	Equivalent to Secondary	Domestic

Facility Performance History:

This facility was last inspected on April 17, 2019. The conditions of the facility at the time of inspection were found to be satisfactory.

A review of Discharge Monitoring Reports from the last permit cycle showed one exceedance (month/year): BOD₅ – 05/18

Comments:

Changes in this permit include the addition of quarterly monitoring for influent nutrients and the removal of the Acute WET test. See Part VI of the Fact Sheet for further information regarding the addition, revision, and removal of effluent parameters.

Part II – Operator Certification Requirements

- ✓ This facility is required to have a certified operator.

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], the permittee shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.020(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Owned or operated by or for a

☒ - Municipalities

☐ - County

☐ - Public Sewer District

☐ - State agency

☐ - Public Water Supply Districts

☐ - Private Sewer Company regulated by the Public Service Commission

Each of the above entities are only applicable if they have a Population Equivalent greater than two hundred (200).

This facility currently requires a chief operator with a C Certification Level. Please see **Appendix - Classification Worksheet**. Modifications made to the wastewater treatment facility may cause the classification to be modified.

Operator's Name: Clara Haenchen

Certification Number: 4924

Certification Level: WW-A

The listing of the operator above only signifies that staff drafting this operating permit have reviewed appropriate Department records and determined that the name listed on the operating permit application has the correct and applicable Certification Level.

Part III – Operational Control Testing Requirements

Missouri Clean Water Commission regulation 10 CSR 20-9.010 requires certain publicly owned treatment works and privately owned facilities regulated by the Public Service Commission to conduct internal operational control monitoring to further ensure proper operation of the facility and to be a safeguard or early warning for potential plant upsets that could affect effluent quality. This requirement is only applicable if the publicly owned treatment works and privately owned facilities regulated by the Public Service Commission has a Population Equivalent greater than two hundred (200).

10 CSR 20-9.010(3) allows the Department to modify the monitoring frequency required in the rule based upon the Department's judgement of monitoring needs for process control at the specified facility.

- ✓ As per [10 CSR 20-9.010(4)], the facility is required to conduct operational monitoring. These operational monitoring reports are to be submitted to the Department along with the MSOP discharge monitoring reports.

- ✓ The facility is a lagoon that is designed to discharge and is required to conduct operational control monitoring as follows:

Operational Monitoring Parameter	Frequency
Precipitation	Twice/Week
Flow – Influent or Effluent	Twice/Week
pH – Primary Cell	Twice/Week
Dissolved Oxygen – Primary Cell	Twice/Week

Part IV – Receiving Stream Information

RECEIVING STREAM(S) TABLE: OUTFALL #001

WATER-BODY NAME	CLASS	WBID	DESIGNATED USES*	12-DIGIT HUC	DISTANCE TO CLASSIFIED SEGMENT (MI)
Missouri River	P	701	AQL, DWS, HHP, IND, IRR, LWW, SCR, WBC-B	10300102-1306	Direct Discharge

*As per 10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(C)].

Uses found in the receiving streams table, above:

10 CSR 20-7.031(1)(C)1.:

AQL = Protection of aquatic life (Current narrative use(s) are defined to ensure the protection and propagation of fish shellfish and wildlife, which is further subcategorized as: **WWH** = Warm Water Habitat; **CDF** = Cold-water fishery (Current narrative use is cold-water habitat.); **CLF** = Cool-water fishery (Current narrative use is cool-water habitat); **EAH** = Ephemeral Aquatic Habitat; **MAH** = Modified Aquatic Habitat; **LAH** = Limited Aquatic Habitat. This permit uses AQL effluent limitations in 10 CSR 20-7.031 Table A for all habitat designations unless otherwise specified.)

10 CSR 20-7.031(1)(C)2.: Recreation in and on the water

WBC = Whole Body Contact recreation where the entire body is capable of being submerged;

WBC-A = Whole body contact recreation that supports swimming uses and has public access;

WBC-B = Whole body contact recreation that supports swimming;

SCR = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(C)3. to 7.:

HHP (formerly HHP) = Human Health Protection as it relates to the consumption of fish;

IRR = Irrigation for use on crops utilized for human or livestock consumption;

LWW = Livestock and wildlife watering (Current narrative use is defined as LWP = Livestock and Wildlife Protection);

DWS = Drinking Water Supply;

IND = Industrial water supply

10 CSR 20-7.031(1)(C)8-11.: Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)

WSA = Storm- and flood-water storage and attenuation; **WHP** = Habitat for resident and migratory wildlife species;

WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses; **WHC** = Hydrologic cycle maintenance.

10 CSR 20-7.031(6): **GRW** = Groundwater

RECEIVING STREAM(S) LOW-FLOW VALUES:

RECEIVING STREAM	LOW-FLOW VALUES (CFS)*		
	1Q10	7Q10	30Q10
Missouri River	33,498	34,633	36,691

* Data from USGS Gauge Station 06910450 located on the Missouri River at Jefferson City, MO. The Jefferson City Regional Water Reclamation Facility (RWRf) discharges between the stream gauge and the Algoa Regional WWTF discharge location. As a result, the flow from Jefferson City RWRf was added to the flow data obtained from the gauge station prior to determining low flow values.

MIXING CONSIDERATIONS TABLE:

MIXING ZONE (CFS) [10 CSR 20-7.031(5)(A)4.B.(II)(a)]			ZONE OF INITIAL DILUTION (CFS) [10 CSR 20-7.031(5)(A)4.B.(II)(b)]		
1Q10	7Q10	30Q10	1Q10	7Q10	30Q10
8374.5	8658.25	9172.75	12.4	12.4	12.4

*For streams with 7Q10 low flows greater than 20 cfs, the zone of initial dilution can be no more than ten times the effluent design flow volume per 10 CSR 20-7.031(5)(A)4.B.(III). This facility has a design flow of 1.24 cfs resulting in a ZID of 12.4 cfs, which was utilized in the Waste Load Allocation calculations on Page 14 of this fact sheet.

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Receiving Water Body's Water Quality

Currently, the Department has not conducted a stream survey for this waterbody. When a stream survey is conducted, more information may be available about the receiving stream.

Part V – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream, and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

- ✓ The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(40)] & [10 CSR 20-7.031(1)(O)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(o); 40 CFR Part 122.44(l)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- ✓ Limitations in this operating permit for the reissuance of this permit conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 CFR Part 122.44.
- ✓ Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.
 - **Acute Whole Effluent Toxicity (WET) test.** The previous permit included requirements to conduct an Acute WET test once during the permit cycle. Due to the fact that the facility has passed previous Acute WET tests and has shown consistent compliance with final effluent limits, it has been determined by the permit writer that the discharge has no reasonable potential to exceed whole effluent toxicity and the requirements to conduct an Acute WET test have been removed. This permit still includes final effluent limitations for known toxic pollutants; therefore, it remains protective of water quality.

ANTIDEGRADATION:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See <http://dnr.mo.gov/env/wpp/permits/antideg-implementation.htm>

- ✓ No degradation proposed and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

For stormwater discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

- ✓ The facility does not have stormwater discharges or the stormwater outfalls onsite have no industrial exposure.

AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(2)(C)], ...An applicant may utilize a lower preference continuing authority by submitting, as part of the application, when a higher level authority is available, must submit information to the Department for review and approval, provided it does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

- ✓ Permittee is authorized to land apply biosolids in accordance with Standard Conditions III.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

- ✓ The facility is not currently under Water Protection Program enforcement action.

ELECTRONIC DISCHARGE MONITORING REPORT (EDMR) SUBMISSION SYSTEM:

The U.S. Environmental Protection Agency (EPA) promulgated a final rule on October 22, 2015, to modernize Clean Water Act reporting for municipalities, industries, and other facilities by converting to an electronic data reporting system. This final rule requires regulated entities and state and federal regulators to use information technology to electronically report data required by the National Pollutant Discharge Elimination System (NPDES) permit program instead of filing paper reports. To comply with the federal rule, the Department is requiring all permittees to begin submitting discharge monitoring data and reports online. In an effort to aid facilities in the reporting of applicable information electronically, the Department has created several new forms including operational control monitoring forms and an I&I location and reduction form. These forms are optional and found on the Department's website at the following locations:

Operational Monitoring Lagoon: <http://dnr.mo.gov/forms/780-2801-f.pdf>

Operational Monitoring Mechanical: <http://dnr.mo.gov/forms/780-2800-f.pdf>

I&I Report: <http://dnr.mo.gov/forms/780-2690-f.pdf>

Per 40 CFR 127.15 and 127.24, permitted facilities may request a temporary waiver for up to 5 years or a permanent waiver from electronic reporting from the Department. To obtain an electronic reporting waiver, a permittee must first submit an eDMR Waiver Request Form: <http://dnr.mo.gov/forms/780-2692-f.pdf>. Each facility must make a request. If a single entity owns or operates more than one facility, then the entity must submit a separate request for each facility based on its specific circumstances. An approved waiver is non-transferable.

The Department must review and notify the facility within 120 calendar days of receipt if the waiver request has been approved or rejected [40 CFR 124.27(a)]. During the Department review period as well as after a waiver is granted, the facility must continue submitting a hard-copy of any reports required by their permit. The Department will enter data submitted in hard-copy from those facilities allowed to do so and electronically submit the data to the EPA on behalf of the facility.

- ✓ The permittee/facility is currently using the eDMR data reporting system.

NUMERIC LAKE NUTRIENT CRITERIA

- ✓ This facility does not discharge into a lake watershed where numeric lake nutrient criteria are applicable.

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
 - Annual pretreatment report submittal,
 - Submittal of list of industrial users,
 - Technical evaluation of need to establish local limitations, and
 - Submittal of the results of the evaluation
- ✓ This permittee has an approved pretreatment program in accordance with the requirements of [40 CFR Part 403] and [10 CSR 20-6.100] and is expected to implement and enforce its approved program.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

- ✓ An RPA analysis was completed for the last permit cycle. Due to permit synchronization, the previous permit cycle was reduced to a time period of less than 5 years. Therefore, all RPA results from short term permit have been carried over to this permit.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

- ✓ Equivalent to Secondary Treatment is 65% removal [40 CFR Part 133.105(a)(3) & (b)(3)].

SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(12)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur. The permit also contains requirements for permittees to develop and implement a program for maintenance and repair of the collection system. The permit requires that the permittee submit an annual report to the Department for the previous calendar year that contains a summary of efforts taken by the permittee to locate and eliminate sources of excess I & I, a summary of general maintenance and repairs to the collection system, and a summary of any planned maintenance and repairs to the collection system for the upcoming calendar year.

- ✓ At this time, the Department recommends the US EPA's Guide for Evaluating Capacity, Management, Operation and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems (Document # EPA 305-B-05-002) or the Departments' CMOM Model located at <http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc>. For additional information regarding the Departments' CMOM Model, see the CMOM Plan Model Guidance document at <http://dnr.mo.gov/pubs/pub2574.htm>. The CMOM identifies some of the criteria used to evaluate a collection system's management, operation, and maintenance and was intended for use by the EPA, state, regulated community, and/or third party entities. The CMOM is applicable to small, medium, and large systems; both public and privately owned; and both regional and satellite collection systems. The CMOM does not substitute for the Clean Water Act, the Missouri Clean Water Law, and both federal and state regulations, as it is not a regulation.

SCHEDULE OF COMPLIANCE (SOC):

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

A SOC is not allowed:

- For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 CFR § 125.3.
- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study that may result in site-specific criteria or alternative effluent limits. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOC's, and attain a greater level of consistency, on April 9, 2015 the Department issued an updated policy on development of SOC's. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as a Cost Analysis for Compliance.

✓ This permit does not contain an SOC.

SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM:

In accordance with [10 CSR 20-6.010(6)(A)], the Department may grant approval of a permittee's Sewer Extension Authority Supervised Program. These approved permittees regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility. The permittee shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. See <http://dnr.mo.gov/env/wpp/permits/sewer-extension.htm>.

✓ The permittee's Sewer Extension Authority Supervised Program has been reauthorized. Please see **Appendix – Sewer Extension Authority Supervised Program Reauthorization Letter** for applicable conditions.

STORMWATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in June 2015], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 CFR 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and re-evaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. For further guidance, consult the antidegradation implementation procedure (<http://dnr.mo.gov/env/wpp/docs/AIP050212.pdf>).

Alternative Analysis (AA) evaluation of the BMPs is a structured evaluation of BMPs that are reasonable and cost effective. The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why “no discharge” or “no exposure” is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure* (AIP), Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the Department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs. The request shall be submitted in the form of an operating permit modification; the application is found at: <http://dnr.mo.gov/forms/index.html>.

✓ At this time, the permittee is not required to develop and implement a SWPPP.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

✓ This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(86)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

✓ Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C_e = \frac{(Q_e + Q_s)C - (Q_s \times C_s)}{(Q_e)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where	C = downstream concentration	C _e = effluent concentration
	C _s = upstream concentration	Q _e = effluent flow
	Q _s = upstream flow	

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

Number of Samples "n":

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of "n" for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for "n" must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is "n = 4" at a minimum. For Total Ammonia as Nitrogen, "n = 30" is used.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

✓ A WLA study was either not submitted or determined not applicable by Department staff.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures that the provisions in the 10 CSR 20-6.010(8)(A) and the Water Quality Standards 10 CSR 20-7.031(4)(D),(F),(G),(J)2.A & B are being met. Under [10 CSR 20-6.010(8)(B)], the Department may require other terms and conditions that it deems necessary to assure compliance with the Clean Water Act and related regulations of the Missouri Clean Water Commission. In addition the following MCWL apply: §§644.051.3 requires the Department to set permit conditions that comply with the MCWL and CWA; 644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits, pretreatment, etc...); and 644.051.5 is the basic authority to require testing conditions. WET test will be required by facilities meeting the following criteria:

- ☐ Facility is a designated Major.
- ☐ Facility continuously or routinely exceeds its design flow.
- ☐ Facility that exceeds its design population equivalent (PE) for BOD₅ whether or not its design flow is being exceeded.
- ☐ Facility (whether primarily domestic or industrial) that alters its production process throughout the year.
- ☐ Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- ☐ Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH₃)
- ☐ Facility is a municipality with a Design Flow ≥ 22,500 gpd.
- ☐ Other – please justify.

✓ At this time, the permittee is not required to conduct WET test for this facility. Due to the fact that the facility has passed previous Acute WET tests and has shown consistent compliance with final effluent limits, it has been determined by the permit writer that the discharge has no reasonable potential to exceed whole effluent toxicity; therefore, the requirements to conduct an Acute WET test have been removed. This permit still includes final effluent limitations for toxic pollutants and remains protective of water quality.

40 CFR 122.41(M) - BYPASSES:

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from “bypassing” untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 CFR 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 CFR 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 CFR 122.41(l)(6) and per Missouri’s Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

✓ This facility does not anticipate bypassing.

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation.

✓ This facility discharges to a stream with an EPA approved TMDL. The Missouri River (P) (701) has a TMDL for Chlordane and PCBs. This facility is not considered to be a source of the pollutants.

Part VI – Effluent Limits Determination

OUTFALL #001 – MAIN FACILITY OUTFALL

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

EFFLUENT LIMITATIONS TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
Flow	MGD	1	*		*	*/*	1/weekday	monthly	T
BOD ₅	mg/L	1		65	45	65/45	1/month	monthly	G
TSS	mg/L	1		110	70	110/70	1/month	monthly	G
<i>Escherichia coli</i> **	#/100mL	1, 3		1,030	206	1,030/206	1/week	monthly	G
Ammonia as N	mg/L	2, 3	*		*	*/*	1/month	monthly	G
Oil & Grease	mg/L	1, 3	15		10	15/10	1/quarter	quarterly	G
Total Phosphorus	mg/L	1	*		*	*/*	1/quarter	quarterly	G
Total Kjeldahl Nitrogen	mg/L	1	*		*	*/*	1/quarter	quarterly	G
Nitrite + Nitrate	mg/L	1	*		*	*/*	1/quarter	quarterly	G
PARAMETER	Unit	Basis for Limits	Minimum		Maximum	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
pH	SU	1	6.0			>6.0	1/month	monthly	G
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
BOD ₅ Percent Removal	%	1			65	65	1/month	monthly	M
TSS Percent Removal	%	1			65	65	1/month	monthly	M

- * - Monitoring requirement only.
- ** - #/100mL; the Monthly Average for *E. coli* is a geometric mean.
- *** - Parameter not previously established in previous state operating permit.

**** - G = Grab
T = 24-hr. total
M = Measured/calculated

Basis for Limitations Codes:

- | | | |
|------------------------------------------|-----------------------------------|-------------------------------------------|
| 1. State or Federal Regulation/Law | 5. Antidegradation Policy | 9. WET Test Policy |
| 2. Water Quality Standard (includes RPA) | 6. Water Quality Model | 10. Multiple Discharger Variance |
| 3. Water Quality Based Effluent Limits | 7. Best Professional Judgment | 11. Nutrient Criteria Implementation Plan |
| 4. Antidegradation Review | 8. TMDL or Permit in lieu of TMDL | |

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.
- **Biochemical Oxygen Demand (BOD₅).** Operating permit retains 65 mg/L as a Weekly Average and 45 mg/L as a Monthly Average from the previous permit. Effluent limits were established in accordance with 10 CSR 20-7.015(2) for discharges to the Missouri or Mississippi Rivers.
- **Total Suspended Solids (TSS).** Operating permit retains 110 mg/L as a Weekly Average and 70 mg/L as a Monthly Average from the previous permit. Effluent limits were established in accordance with 10 CSR 20-7.015(2) for discharges to the Missouri or Mississippi Rivers.

Please note that the final effluent limits for BOD and TSS contained in the permit are Equivalent to Secondary limits as per 10 CSR 20-7.015. Any changes made to the lagoon system that modifies it such that it no longer functions as a typical lagoon will result in the facility no longer qualifying for Equivalent to Secondary limitations. The facility may be required to also follow the Missouri Antidegradation Rule and Implementation Procedure if the discharge is expanded.

- **Escherichia coli (E. coli).** Monthly average of 206 per 100 mL as a geometric mean and Weekly Average of 1,030 per 100 mL as a geometric mean during the recreational season (April 1 – October 31), for discharges within two miles upstream of segments or lakes with Whole Body Contact Recreation (B) designated use of the receiving stream, as per 10 CSR 20-7.015(9)(B). An effluent limit for both monthly average and weekly average is required by 40 CFR 122.45(d). The Geometric Mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected. For example: Five *E. coli* samples were collected with results of 1, 4, 6, 10, and 5 (#/100mL). Geometric Mean = 5th root of (1)(4)(6)(10)(5) = 5th root of 1,200 = 4.1 #/100mL.
- **Total Ammonia Nitrogen.** Due to permit synchronization, the previous permit cycle was monitor to a time period of less than 5 years. Therefore, the RPA results and final effluent limitations were retained from the previous short term permit. Please see **Appendix – RPA Results.**
- **Oil & Grease.** Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- **Total Phosphorus and Total Nitrogen (Speciated).** Effluent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, and Nitrite + Nitrate are required per 10 CSR 20-7.015(9)(D)8.
- **pH.** >6.0 SU. pH limitations [10 CSR 20-7.015] are protective of the water quality standard [10 CSR 20-7.031(5)(E)], due to the assimilative capacity of the receiving stream.
- **Biochemical Oxygen Demand (BOD₅) Percent Removal.** In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 65% removal efficiency for BOD₅.
- **Total Suspended Solids (TSS) Percent Removal.** In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 65% removal efficiency for TSS.

Parameters Removed.

- **Acute Whole Effluent Toxicity (WET) test.** The previous permit included requirements to conduct an Acute WET test once during the permit cycle. Due to the fact that the facility has passed previous Acute WET tests and has shown consistent compliance with final effluent limits, it has been determined by the permit writer that the discharge has no reasonable potential to exceed whole effluent toxicity and the requirements to conduct an Acute WET test have been removed. This permit still includes final effluent limitations for known toxic pollutants; therefore, it remains protective of water quality.

Sampling Frequency Justification: The Department has determined that previously established sampling and reporting frequency is sufficient to characterize the facility's effluent and be protective of water quality. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)7.A.

Sampling Type Justification: As per 10 CSR 20-7.015, BOD₅ and TSS samples collected for lagoons may be grab samples. Grab samples must be collected for pH, *E. coli*, and Oil & Grease in accordance with recommended analytical methods. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

PERMITTED FEATURE INF – INFLUENT MONITORING

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

INFLUENT MONITORING TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
BOD ₅	mg/L	1			*	***	1/month	monthly	C
TSS	mg/L	1			*	***	1/month	monthly	C
Ammonia as N	mg/L	1	*		*	***	1/quarter	quarterly	C
Total Phosphorus	mg/L	1	*		*	***	1/quarter	quarterly	C
Total Kjeldahl Nitrogen	mg/L	1	*		*	***	1/quarter	quarterly	C
Nitrite + Nitrate	mg/L	1	*		*	***	1/quarter	quarterly	C

* - Monitoring requirement only.

*** - Parameter not previously established in previous state operating permit.

**** - G = Grab

Basis for Limitations Codes:

- | | | |
|------------------------------------------|-----------------------------------|-------------------------------------------|
| 1. State or Federal Regulation/Law | 5. Antidegradation Policy | 9. WET Test Policy |
| 2. Water Quality Standard (includes RPA) | 6. Water Quality Model | 10. Multiple Discharger Variance |
| 3. Water Quality Based Effluent Limits | 7. Best Professional Judgment | 11. Nutrient Criteria Implementation Plan |
| 4. Antidegradation Review | 8. TMDL or Permit in lieu of TMDL | |

Influent Parameters

- **Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS).** An influent sample is required to determine the removal efficiency. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals.
- **Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia.** Influent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia required per 10 CSR 20-7.015(9)(D)8.

Sampling Frequency Justification: The sampling and reporting frequencies for Total Phosphorus and Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia parameters were established to match the required sampling frequency of these parameters in the effluent, per [10 CSR 20-7.015(9)(D)8.]. The sampling and reporting frequencies for influent BOD₅ and TSS have been established to match the required sampling frequency of these parameters in the effluent.

Sampling Type Justification: Sample types for influent parameters were established to match the required sampling type of these parameters in the effluent. Samples should be analyzed as soon as possible after collection and/or properly preserved according to method requirements.

OUTFALL #001 – GENERAL CRITERIA CONSIDERATIONS:

In accordance with 40 CFR 122.44(d)(1), effluent limitations shall be placed into the permit for those pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The rule further states that pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above a narrative criterion within an applicable State water quality standard, the permit shall contain a numeric effluent limitation to protect that narrative criterion. In order to comply with this regulation, the permit writer will complete reasonable potential determinations on whether the discharge will violate any of the general criteria listed in 10 CSR 20-7.031(4). These specific requirements are listed below followed by derivation and discussion (the lettering matches that of the rule itself, under 10 CSR 20-7.031(4)). It should also be noted that Section 644.076.1, RSMo as well as Section D – Administrative Requirements of Standard Conditions Part I of this permit states that it shall be unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri that is in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law or any standard, rule or regulation promulgated by the commission.

- (A) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses. The discharge from this facility is made up of treated domestic wastewater. Based upon review of the Report of Compliance Inspection for the inspection conducted on April 17, 2019, no evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, this facility utilizes equivalent to secondary treatment technology and is currently in compliance with the equivalent to secondary treatment technology based effluent limits established in this permit and there has been no indication to the Department that the stream has had issues maintaining beneficial uses as a result of this discharge. Based on the information reviewed during the drafting of this permit, these final effluent limitations appear to have protected against the excursion of this criterion in the past. Therefore, the discharge does not have the reasonable potential to cause or contribute to an excursion of this criterion.
- (B) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (C) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (D) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life. This permit contains final effluent limitations which are protective of both acute and chronic toxicity for various pollutants that are either expected to be discharged by domestic wastewater facilities or that were disclosed by this facility on the application for permit coverage. Based on the information reviewed during the drafting of this permit, it has been determined if the facility meets final effluent limitations established in this permit, there is no reasonable potential for the discharge to cause an excursion of this criterion.
- (E) Waters shall provide for the attainment and maintenance of water quality standards downstream including waters of another state. Please see (D) above as justification is the same.
- (F) There shall be no significant human health hazard from incidental contact with the water. Please see (D) above as justification is the same.
- (G) There shall be no acute toxicity to livestock or wildlife watering. Please see (D) above as justification is the same.
- (H) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community. Please see (A) above as justification is the same.
- (I) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247. The discharge from this facility is made up of treated domestic wastewater. No evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, any solid wastes received or produced at this facility are wholly contained in appropriate storage facilities, are not discharged, and are disposed of offsite. This discharge is subject to Standard Conditions Part III, which contains requirements for the management and disposal of sludge to prevent its discharge. Therefore, this discharge does not have reasonable potential to cause or contribute to an excursion of this criterion.

Part VII – Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

- ✓ The Department is required to determine “findings of affordability” because the permit applies to a combined or separate sanitary sewer system for a publicly-owned treatment works.

Cost Analysis for Compliance - The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

The following table summarizes the results of the cost analysis. See **Appendix – Cost Analysis for Compliance** for detailed information.

Summary Table. Cost Analysis for Compliance Summary for the City of Jefferson

New Permit Requirements			
Quarterly influent sampling for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia as N			
Estimated Annual Cost	Annual Median Household Income (MHI)	Estimated Monthly User Rate	User Rate as a Percent of MHI
\$468	\$57,753	\$34.19	0.79%

Part VIII – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

WATER QUALITY STANDARD REVISION:

In accordance with section 644.058, RSMo, the Department is required to utilize an evaluation of the environmental and economic impacts of modifications to water quality standards of twenty-five percent or more when making individual site-specific permit decisions.

- ✓ This operating permit does not contain requirements for a water quality standard that has changed twenty-five percent or more since the previous operating permit.

PERMIT SYNCHRONIZATION:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together and all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. With permit synchronization, this permit will expire in the 2nd Quarter of calendar year 2025.

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

- ✓ The Public Notice period for this operating permit was from October 9, 2020 to November 9, 2020. No comments received.

DATE OF FACT SHEET: AUGUST 31, 2020

COMPLETED BY:

ASHLEY KEELY, ENVIRONMENTAL SPECIALIST III
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT
(573) 751-7326
ASHLEY.KEELY@DNR.MO.GOV

Appendices

APPENDIX - CLASSIFICATION WORKSHEET:

Item	Points Possible	Points Assigned
Maximum Population Equivalent (P.E.) served , peak day	1 pt./10,000 PE or major fraction thereof. (Max 10 pts.)	
Design Flow (avg. day) or peak month's flow (avg. day) whichever is larger	1 pt. / MGD or major fraction thereof. (Max 10 pts.)	
Effluent Discharge		
Missouri or Mississippi River	0	0
All other stream discharges except to losing streams and stream reaches supporting whole body contact recreation	1	
Discharge to lake or reservoir outside of designated whole body contact recreational area	2	
Discharge to losing stream, or stream, lake or reservoir area supporting whole body contact recreation	3	
Direct reuse or recycle of effluent	6	
Land Application/Irrigation		
Drip Irrigation	3	
Land application/irrigation	5	
Overland flow	4	
Variation in Raw Wastes (highest level only)		
Variations do not exceed those normally or typically expected	0	0
Reoccurring deviations or excessive variations of 100 to 200 percent in strength and/or flow	2	
Reoccurring deviations or excessive variations of more than 200 percent in strength and/or flow	4	
Department-approved pretreatment program	6	
Preliminary Treatment		
STEP systems (operated by the permittee)	3	
Screening and/or comminution	3	3
Grit removal	3	
Plant pumping of main flow	3	
Flow equalization	5	
Primary Treatment		
Primary clarifiers	5	
Chemical addition (except chlorine, enzymes)	4	
Secondary Treatment		
Trickling filter and other fixed film media with or without secondary clarifiers	10	
Activated sludge (including aeration, oxidation ditches, sequencing batch reactors, membrane bioreactors, and contact stabilization)	15	
Stabilization ponds without aeration	5	
Aerated lagoon	8	8
Advanced Lagoon Treatment – Aerobic cells, anaerobic cells, covers, or fixed film	10	
Biological, physical, or chemical	12	
Carbon regeneration	4	
Total from page ONE (1)	----	11

APPENDIX - CLASSIFICATION WORKSHEET (CONTINUED):

ITEM	POINTS POSSIBLE	POINTS ASSIGNED
Solids Handling		
Sludge Holding	5	5
Anaerobic digestion	10	
Aerobic digestion	6	
Evaporative sludge drying	2	
Mechanical dewatering	8	
Solids reduction (incineration, wet oxidation)	12	
Land application	6	6
Disinfection		
Chlorination or comparable	5	
On-site generation of disinfectant (except UV light)	5	
Dechlorination	2	
UV light	4	4
Required Laboratory Control Performed by Plant Personnel (highest level only)		
Lab work done outside the plant	0	
Push – button or visual methods for simple test such as pH, settleable solids	3	
Additional procedures such as DO, COD, BOD, titrations, solids, volatile content	5	
More advanced determinations, such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc.	7	7
Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph	10	
Total from page TWO (2)	----	11
Total from page ONE (1)	---	22
Grand Total	---	33

- ☐ - A: 71 points and greater
☐ - B: 51 points – 70 points
☒ - C: 26 points – 50 points
☐ - D: 0 points – 25 points

APPENDIX – RPA RESULTS FROM PERMIT ISSUED APRIL 1, 2018:

Parameter	CMC*	RWC Acute*	CCC*	RWC Chronic*	n**	Range max/min	CV***	MF	RP Yes/No
Total Ammonia as Nitrogen (Summer) mg/L	12.1	10.62	1.5	0.04	34	27.9/0.3	1.82	4.19	NO
Total Ammonia as Nitrogen (Winter) mg/L	12.1	6.91	3.1	0.03	30	25.8/0.3	1.05	2.94	NO

N/A – Not Applicable

* - Units are (mg/L) unless otherwise noted.

** - If the number of samples is 10 or greater, then the CV value must be used in the WQBEL for the applicable constituent. If the number of samples is < 10, then the default CV value must be used in the WQBEL for the applicable constituent.

*** - Coefficient of Variation (CV) is calculated by dividing the Standard Deviation of the sample set by the Mean of the same sample set.

RWC – Receiving Water Concentration. It is the concentration of a toxicant or the parameter toxicity in the receiving water after mixing (if applicable).

n – Is the number of samples.

MF – Multiplying Factor. 99% Confidence Level and 99% Probability Basis.

RP – Reasonable Potential. It is where an effluent is projected or calculated to cause an excursion above a water quality standard based on a number of factors including, as a minimum, the four factors listed in 40 CFR 122.44(d)(1)(ii).

Reasonable Potential Analysis is conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request.

APPENDIX – ALTERNATIVE:



APPENDIX – SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM REAUTHORIZATION LETTER:



JUN 12 2017

Mr. Eric Seaman, P.E.
Wastewater Division Director
320 E. McCarty Street
Jefferson City, MO 65101

RE: City of Jefferson – ACT152, Sewer Extension Authority Supervised Program
Reauthorization

Dear Mr. Seaman:

The Missouri Department of Natural Resources' Water Protection Program has reevaluated the City of Jefferson Sewer Extension Authority Supervised Program (Program) and has approved its reauthorization. This Program delegates administrative responsibility of construction sewer extension permits to the City of Jefferson. Reporting requirements for this program are included in the associated Missouri State Operating Permits (MSOP).

The Program for the City of Jefferson applies to construction permits for sewer extensions that discharge to the following MSOP(s):

- MO-0094846 [Jefferson City RWRf]
- MO-0044330 [Algoa Regional WWTF]

This approval is granted until it is reauthorized during the operating permit renewal.

This reauthorization does not supersede any requirements of the operating permit or enforcement actions. Nothing in this reauthorization removes any obligations to comply with county or other local ordinances or restrictions.

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to 10 CSR 20-1.020 and Section 621.250, RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Contact information for the AHC is: Administrative Hearing Commission, United States Post Office Bldg., Third Floor, 131 West High Street, P.O. Box 1557, Jefferson City, MO 65102, Phone: 573-751-2422, Fax: 573-751-5018, and Website: www.oa.mo.gov/ahc.



Mr. Eric Seaman, P.E.
Page Two

If you have any questions concerning this matter, please contact Ms. Leasue Meyers, of the Water Protection Program, at 573-751-7906 or Department of Natural Resources, P.O. Box 176, Jefferson City, MO 65102.

Thank you for your efforts to help ensure clean water in Missouri.

Sincerely,

WATER PROTECTION PROGRAM



David J. Lamb
Acting Director

DJL:lmn

Enclosure

c: Northeast Regional Office

**SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM
REAUTHORIZATION**

I. CONDITIONS:

1. This approval is limited to sewer extensions proposed within the City of Jefferson boundaries for which the receiving wastewater treatment facility is owned, operated, and maintained by the City of Jefferson.
2. Upon completion of accepted construction, the City of Jefferson will become the continuing authority for the operation, maintenance, and modernization of the sewer extension.
3. Additional requirements may be necessary to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans" when funding from the department is requested.
4. Any updates to the City of Jefferson's Standard Sanitary Sewer Specifications Revised 2015 will require a subsequent review and approval by the department.
 - A. This approval is limited to only wastewater components. Other items contained in this standard specification and details such as drinking water, roadways, structural, mechanical, electrical, etc. were not reviewed.
5. This approval may be reopened and modified to comply with any new or amended design regulations in 10 CSR 20-6.010 and 10 CSR 20-8.

II. ANNUAL REPORTS:

The City of Jefferson must submit an annual report by January 28th of each year to the Engineering Section. The electronic submittals may be emailed to DNR.WPPEngineerSection@dnr.mo.gov. The report shall contain the following for each sewer extension:

1. Name of sewer extension;
2. Population or number of lots to be served;
3. Type of wastewater (i.e. domestic or industrial);
4. Design flow in gallons per day;
5. Length of sewer and force main;

City of Jefferson
Page Two

Activity No. ACT152

6. Capacity of each pump station, if applicable;
7. The ultimate receiving wastewater treatment facility;
8. Date sewer extension permit is issued;
9. Dates of leakage and deflection tests passing;
10. Dates of City of Jefferson construction inspections;
11. Date sewer extension construction is accepted; and
12. The remaining capacity of each wastewater treatment facility.

III. REAUTHORIZATION REQUEST:

- The City of Jefferson must submit a request for reauthorization to the Engineering Section at least 180 days prior to the expiration date of the Jefferson City RWRf operating permit, MO-0094846. The request shall contain the following:
 1. The current standard technical specifications and typical detail drawings signed, sealed, and dated by a Missouri registered professional engineer.
 2. A list and current number of Missouri registered professional engineers and other qualified staff reviewing plans, issuing sewer extension permits, preparing reports, inspecting construction, and enforcing local and state requirements under the Program.
 3. A written statement from the City of Jefferson ensuring that permanent plans of all permitted and constructed sewer extensions records are maintained.

Leasue Meyers, EI
Engineering Section
leasue.meyers@dnr.mo.gov

APPENDIX – COST ANALYSIS FOR COMPLIANCE:

**Missouri Department of Natural Resources
Water Protection Program
Cost Analysis for Compliance
(In accordance with RSMo 644.145)**

**Algoa Regional WWTF, Permit Renewal
City of Jefferson
Missouri State Operating Permit #MO-0044300**

Section 644.145 RSMo requires the Department of Natural Resources (Department) to make a “finding of affordability” when “issuing permits under” or “enforcing provisions of” state or federal clean water laws “pertaining to any portion of a combined or separate sanitary sewer system for publicly-owned treatment works.” This cost analysis does not dictate how the permittee will comply with new permit requirements.

New Permit Requirements

The permit requires compliance with new monitoring requirements for influent Total Phosphorus, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Ammonia as N.

Connections

The number of connections was from the financial questionnaire and the Department’s fee tracking website.

Connection Type	Algoa Regional WWTF	City of Jefferson
Residential	18	18,299
Commercial	13	2,339
Industrial	0	20
Total	31	20,658*

* The Algoa Regional WWTF is owned and operated by the City of Jefferson. This cost analysis was completed using the number of connections reported by the City of Jefferson to the Department.

Data Collection for this Analysis

This cost analysis is based on data available to the Department as provided by the permittee and data obtained from readily available sources. For the most accurate analysis, it is essential that the permittee provides the Department with current information about the City’s financial and socioeconomic situation. The financial questionnaire available to permittees on the Department’s website (<http://dnr.mo.gov/forms/780-2511-f.pdf>) is a required attachment to the permit renewal application. If the financial questionnaire is not submitted with the renewal application, the Department sends a request to complete the form with the welcome correspondence. If certain data was not provided by the permittee to the Department and the data is not obtainable through readily available sources, this analysis will state that the information is “unknown”.

Eight Criteria of 644.145 RSMo

The Department must consider the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with new permit requirements.

(1) A community’s financial capability and ability to raise or secure necessary funding;

Criterion 1 Table. Current Financial Information for the City of Jefferson	
Current Monthly User Rates per 5,000 gallons*	\$34.19
Median Household Income (MHI) ¹	\$51,753
Current Annual Operating Costs (excludes depreciation)	\$569,000

*User Rates were reported by the permittee on the Financial Questionnaire.

(2) Affordability of pollution control options for the individuals or households at or below the median household income level of the community;

The following tables outline the estimated costs of the new permit requirements:

Criterion 2A Table. Estimated Cost Breakdown of New Permit Requirements			
New Requirement	Frequency	Estimated Cost	Estimated Annual Cost
Total Phosphorus – Influent	Quarterly	\$24	\$96
Total Kjeldahl Nitrogen – Influent	Quarterly	\$33	\$132
Nitrate + Nitrite – Influent	Quarterly	\$40	\$160
Ammonia – Influent	Quarterly	\$20	\$80
Total Estimated Annual Cost of New Permit Requirements			\$468

Criterion 2B Table. Estimated Costs for New Permit Requirements		
(1)	Estimated Annual Cost	\$468
0(2)	Estimated Monthly User Cost for New Requirements ²	\$0.002
	Estimated Monthly User Cost for New Requirements as a Percent of MHI ³	0.00004%
(3)	Total Monthly User Cost*	\$34.19
	Total Monthly User Cost as a Percent of MHI ⁴	0.793%

* Current User Rate + Estimated Monthly Costs of New Sampling Requirements

Due to the minimal cost associated with new permit requirements, the Department anticipates an extremely low to no rate increase will be necessary, which could impact individuals or households of this community.

(3) An evaluation of the overall costs and environmental benefits of the control technologies;

This analysis is being conducted based on new requirements in the permit, which will not require the addition of new control technologies at the facility. However, the new sampling requirements are being established in order to provide data regarding the health of the receiving stream's aquatic life and to ensure that the existing permit limits are providing adequate protection of aquatic life. Improved wastewater provides benefits such as avoided health costs due to water-related illness, enhanced environmental ecosystem quality, and improved natural resources. The preservation of natural resources has been proven to increase the economic value and sustainability of the surrounding communities. Maintaining Missouri's water quality standards fulfills the goal of restoring and maintaining the chemical, physical, and biological integrity of the receiving stream; and, where attainable, it achieves a level of water quality that provides for the protection and propagation of fish, shellfish, wildlife, and recreation in and on the water.

Nutrient Monitoring

Nutrients are mineral compounds that are required for organisms to grow and thrive. Of the six (6) elemental macronutrients, nitrogen and phosphorus are generally not readily available and limit growth of organisms. Excess nitrogen and phosphorus will cause a shift in the ecosystem's food web. Once excess nitrogen and phosphorus are introduced into a waterbody, some species' populations will dramatically increase, while other populations will not be able to sustain life. Competition and productivity are two factors in which nutrients can alter aquatic ecosystems and the designated uses of a waterbody. For example, designated uses, such as drinking water sources and recreational uses, become impaired when algal blooms take over a waterbody. These blooms can cause foul tastes and odors in the drinking water, unsightly appearance, and fish mortality in the waterbody. Some algae also produce toxins that may cause serious adverse health conditions such as liver damage, tumor promotion, paralysis, and kidney damage. The monitoring requirements for nitrogen and phosphorus have been added to the permit to provide data regarding the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

(4) Inclusion of ongoing costs of operating and maintaining the existing wastewater collection and treatment system, including payments on outstanding debts for wastewater collection and treatment systems when calculating projected rates:

The community reported that their outstanding debt for their entire wastewater collection and treatment systems is \$45,665,800. The community reported that each user pays \$34.19 monthly, of which, 51% (or \$17.44) is used toward payments on the current outstanding debt.

(5) An inclusion of ways to reduce economic impacts on distressed populations in the community, including but not limited to low and fixed income populations. This requirement includes but is not limited to:

- (a) Allowing adequate time in implementation schedules to mitigate potential adverse impacts on distressed populations resulting from the costs of the improvements and taking into consideration local community economic considerations.
- (b) Allowing for reasonable accommodations for regulated entities when inflexible standards and fines would impose a disproportionate financial hardship in light of the environmental benefits to be gained.

The following table characterizes the current overall socioeconomic condition of the community as compared to the overall socioeconomic condition of Missouri. The following information was compiled using the latest U.S. Census data.

Criterion 5 Table. Socioeconomic Data ^{1, 5-9} for the City of Jefferson

No.	Administrative Unit	Jefferson City	Missouri State	United States
1	Population (2018)	43,013	6,090,062	322,903,030
2	Percent Change in Population (2000-2018)	8.5%	8.8%	14.7%
3	2018 Median Household Income (in 2019 Dollars)	\$51,753	\$54,530	\$61,385
4	Percent Change in Median Household Income (2000-2018)	-14.9%	-6.3%	-4.7%
5	Median Age (2018)	37.7	38.5	37.9
6	Change in Median Age in Years (2000-2018)	1.2	2.4	2.6
7	Unemployment Rate (2018)	4.0%	5.1%	5.9%
8	Percent of Population Below Poverty Level (2018)	13.5%	14.2%	14.1%
9	Percent of Household Received Food Stamps (2018)	11.8%	11.6%	12.2%
10	(Primary) County Where the Community Is Located	Cole County		

(6) An assessment of other community investments and operating costs relating to environmental improvements and public health protection;

The community reported plans to replace aeration equipment and remove sludge in the next few years.

(7) An assessment of factors set forth in the United States Environmental Protection Agency's guidance, including but not limited to the "Combined Sewer Overflow Guidance for Financial Capability Assessment and Schedule Development" that may ease the cost burdens of implementing wet weather control plans, including but not limited to small system considerations, the attainability of water quality standards, and the development of wet weather standards;

The new requirements associated with this permit will not impose a financial burden on the community, nor will they require the City of Jefferson to seek funding from an outside source.

(8) An assessment of any other relevant local community economic conditions.

The community reported that the utility and community are recovering from flooding and a tornado in 2019, as well as a local shortage of affordable housing.

Conclusion and Finding

As a result of new regulations, the Department is proposing modifications to the current operating permit that may require the permittee to increase monitoring. The Department has considered the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with the new permit requirements.

This analysis examined whether the new sampling requirements affect the ability of an individual customer or household to pay a utility bill without undue hardship or unreasonable sacrifice in the essential lifestyle or spending patterns of the individual or household. After reviewing the above criteria, the Department finds that the new sampling requirements may result in a low burden with regard to the community's overall financial capability and a low financial impact for most individual customers/households; therefore, the new permit requirements are affordable.

References

1. (A) 2018 MHI in 2018 Dollar: United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, Table B19013: Median Household Income in the Past 12 Months (in 2018 Inflation-Adjusted Dollars). <https://data.census.gov/cedsci/table?q=B19013&tid=ACSDT5Y2018.B19013&vintage=2018>.
(B) 2000 MHI in 1999 Dollar: (1) For United States, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-1 Part 1. United States Summary, Table 5. Work Status and Income in 1999: 2000, Washington, DC. <https://www.census.gov/prod/cen2000/phc-2-1-pt1.pdf>. (2) For Missouri State, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-27, Missouri, Table 10. Work Status and Income in 1999: 2000, Washington, DC. <https://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf>.
(C) 2019 CPI, 2018 CPI and 1999 CPI: U.S. Department of Labor Bureau of Labor Statistics (2019) Consumer Price Index - All Urban Consumers, U.S. City Average. All Items. 1982-84=100. http://data.bls.gov/timeseries/CUUR0000SA0?data_tool=Xgtable.
(D) 2018 MHI in 2019 Dollar = 2018 MHI in 2018 Dollar x 2019 CPI / 2018 CPI; 2000 MHI in 2019 Dollar = 2000 MHI in 1999 Dollar x 2019 CPI / 1999 CPI.
(E) Percent Change in Median Household Income (2000-2018) = (2018 MHI in 2019 Dollar - 2000 MHI in 2019 Dollar) / (2000 MHI in 2019 Dollar).
2. $(\$468/20,658)/12 = \0.002 (Estimated Monthly User Cost for New Requirements)
3. $(\$0.002/(\$51,753/12))100\% = 0.00004\%$ (New Sampling Only)
4. $(\$34.19/(\$51,753/12))100\% = 0.793\%$ (Total User Cost)
5. (A) Total Population in 2018: United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, Table B01003: Total Population - Universe: Total Population. <https://data.census.gov/cedsci/table?q=B01003%20population&tid=ACSDT5Y2018.B01003&vintage=2018>.
(B) Total Population in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC. <https://www.census.gov/prod/cen2000/phc-1-1-pt1.pdf>.
(2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Place of Birth, Residence in 1995, and Language: 2000, Washington, DC. <http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf>.
(C) Percent Change in Population (2000-2018) = (Total Population in 2018 - Total Population in 2000) / (Total Population in 2000).
6. (A) Median Age in 2018: United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, Table B01002: Median Age by Sex - Universe: Total population. <https://data.census.gov/cedsci/table?q=B01002&tid=ACSDT5Y2018.B01002&vintage=2018>.
(B) Median Age in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC., Page 2. <https://www.census.gov/prod/cen2000/phc-1-1-pt1.pdf>.
(2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Place of Birth, Residence in 1995, and Language: 2000, Washington, DC. <http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf>.
(C) Change in Median Age in Years (2000-2018) = (Median Age in 2018 - Median Age in 2000).
7. United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, B23025: Employment Status for the Population 16 Years and Over - Universe: Population 16 years and Over. <https://data.census.gov/cedsci/table?q=B23025&tid=ACSDT5Y2018.B23025>.
8. United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, Table S1701: Poverty Status in the Past 12 Months. <https://data.census.gov/cedsci/table?q=S1701&tid=ACSST5Y2018.S1701>.
9. United States Census Bureau. 2014-2018 American Community Survey 5-Year Estimates, Table B22003: Receipt of Food Stamps/SNAP in the Past 12 Months by Poverty Status in the Past 12 Months for Households - Universe: Households. <https://data.census.gov/cedsci/table?q=B22003&tid=ACSDT5Y2018.B22003>.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions

Section A – Sampling, Monitoring, and Recording

1. **Sampling Requirements.**
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.
2. **Monitoring Requirements.**
 - a. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The individual(s) who performed the sampling or measurements;
 - iii. The date(s) analyses were performed;
 - iv. The individual(s) who performed the analyses;
 - v. The analytical techniques or methods used; and
 - vi. The results of such analyses.
 - b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
4. **Test Procedures.** The analytical and sampling methods used shall conform to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is “sufficiently sensitive” when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility’s discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
5. **Record Retention.** Except for records of monitoring information required by the permit related to the permittee’s sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

6. **Illegal Activities.**
 - a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or both.
 - b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B – Reporting Requirements

1. **Planned Changes.**
 - a. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
 - iii. The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
 - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.
2. **Non-compliance Reporting.**
 - a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - iii. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
 - c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
3. **Anticipated Noncompliance.** The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
 4. **Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
 5. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
 6. **Other Information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.
 7. **Discharge Monitoring Reports.**
 - a. Monitoring results shall be reported at the intervals specified in the permit.
 - b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
 - c. Monitoring results shall be reported to the Department no later than the 28th day of the month following the end of the reporting period.
- b. Notice.
 - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
 - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
 - c. Prohibition of bypass.
 - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 3. The permittee submitted notices as required under paragraph 2. b. of this section.
 - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.
3. **Upset Requirements.**
 - a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B – Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
 - c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

Section C – Bypass/Upset Requirements

1. **Definitions.**
 - a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
 - b. *Severe Property Damage*: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - c. *Upset*: an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
2. **Bypass Requirements.**
 - a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

Section D – Administrative Requirements

1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- d. It is unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.
2. **Duty to Reapply.**
- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- c. A permittee with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
5. **Proper Operation and Maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
6. **Permit Actions.**
- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
- i. Violations of any terms or conditions of this permit or the law;
- ii. Having obtained this permit by misrepresentation or failure to disclose fully any relevant facts;
- iii. A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- iv. Any reason set forth in the Law or Regulations.
- b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
7. **Permit Transfer.**
- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
 - a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.
12. **Closure of Treatment Facilities.**
 - a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
 - b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.
13. **Signatory Requirement.**
 - a. All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
 - b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
 - c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
MAY 1, 2013

PART II - SPECIAL CONDITIONS – PUBLICLY OWNED
TREATMENT WORKS
SECTION A – INDUSTRIAL USERS

1. Definitions

Definitions as set forth in the Missouri Clean Water Laws and approved by the Missouri Clean Water Commission shall apply to terms used herein.

Significant Industrial User (SIU). Except as provided in the *General Pretreatment Regulation* 10 CSR 20-6.100, the term Significant Industrial User means:

1. All Industrial Users subject to Categorical Pretreatment Standards; and
2. Any other Industrial User that: discharges an average of 25,000 gallons per day or more of process wastewater to the Publicly-Owned Treatment Works (POTW) (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's or for violating any Pretreatment Standard or requirement.

Clean Water Act (CWA) is the the federal Clean Water Act of 1972, 33 U.S.C. § 1251 et seq. (2002).

2. Identification of Industrial Discharges

Pursuant to 40 CFR 122.44(j)(1), all POTWs shall identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR 403.

3. Application Information

Applications for renewal or modification of this permit must contain the information about industrial discharges to the POTW pursuant to 40 CFR 122.21(j)(6)

4. Notice to the Department

Pursuant to 40 CFR 122.42(b), all POTWs must provide adequate notice of the following:

1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging these pollutants; and
2. Any substantial change into the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
3. For purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

For POTWs without an approved pretreatment program, the notice of industrial discharges which was not included in the permit application shall be made as soon as practicable. For POTWs with an approved pretreatment program, notice is to be included in the annual pretreatment report required in the special conditions of this permit. Notice may be sent to:

Missouri Department of Natural Resources
Water Protection Program
Attn: Pretreatment Coordinator
P.O. Box 176
Jefferson City, MO 65102

STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
August 1, 2019

PART III – BIOSOLIDS AND SLUDGE FROM DOMESTIC TREATMENT FACILITIES

SECTION A – GENERAL REQUIREMENTS

1. PART III Standard Conditions pertain to biosolids and sludge requirements under the Missouri Clean Water Law and regulations for domestic and municipal wastewater and also incorporates federal sludge disposal requirements under 40 CFR Part 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR Part 503 for domestic biosolids and sludge.
2. PART III Standard Conditions apply only to biosolids and sludge generated at domestic wastewater treatment facilities, including public owned treatment works (POTW) and privately owned facilities.
3. Biosolids and Sludge Use and Disposal Practices:
 - a. The permittee is authorized to operate the biosolids and sludge generating, treatment, storage, use, and disposal facilities listed in the facility description of this permit.
 - b. The permittee shall not exceed the design sludge/biosolids volume listed in the facility description and shall not use biosolids or sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
 - c. For facilities operating under general operating permits that incorporate Standard Conditions PART III, the facility is authorized to operate the biosolids and sludge generating, treatment, storage, use and disposal facilities identified in the original operating permit application, subsequent renewal applications or subsequent written approval by the department.
4. Biosolids or Sludge Received from other Facilities:
 - a. Permittees may accept domestic wastewater biosolids or sludge from other facilities as long as the permittee's design sludge capacity is not exceeded and the treatment facility performance is not impaired.
 - b. The permittee shall obtain a signed statement from the biosolids or sludge generator or hauler that certifies the type and source of the sludge
5. Nothing in this permit precludes the initiation of legal action under local laws, except to the extent local laws are preempted by state law.
6. This permit does not preclude the enforcement of other applicable environmental regulations such as odor emissions under the Missouri Air Pollution Control Law and regulations.
7. This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable biosolids or sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
8. In addition to Standard Conditions PART III, the Department may include biosolids and sludge limitations in the special conditions portion or other sections of a site specific permit.
9. Exceptions to Standard Conditions PART III may be authorized on a case-by-case basis by the Department, as follows:
 - a. The Department may modify a site-specific permit following permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR § 124.10, and 40 CFR § 501.15(a)(2)(ix)(E).
 - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR Part 503.

SECTION B – DEFINITIONS

1. Best Management Practices are practices to prevent or reduce the pollution of waters of the state and include agronomic loading rates (nitrogen based), soil conservation practices, spill prevention and maintenance procedures and other site restrictions.
2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food, feed or fiber. The facility includes any structures necessary to store the biosolids until soil, weather, and crop conditions are favorable for land application.
4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR Part 503.
5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with 40 CFR Part 503.
6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
7. Feed crops are crops produced primarily for consumption by animals.
8. Fiber crops are crops such as flax and cotton.
9. Food crops are crops consumed by humans which include, but is not limited to, fruits, vegetables and tobacco.
10. Industrial wastewater means any wastewater, also known as process wastewater, not defined as domestic wastewater. Per 40 CFR Part 122.2, process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product. Land application of industrial wastewater, residuals or sludge is not authorized by Standard Conditions PART III.
11. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological contact systems, and other similar facilities. It does not include wastewater treatment lagoons or constructed wetlands for wastewater treatment.
12. Plant Available Nitrogen (PAN) is nitrogen that will be available to plants during the growing seasons after biosolids application.
13. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
14. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs), sewage sludge incinerator ash, or grit/screenings generated during preliminary treatment of domestic sewage.
15. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen or concrete lined basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
16. Septage is the sludge pumped from residential septic tanks, cesspools, portable toilets, Type III marine sanitation devices, or similar treatment works such as sludge holding structures from residential wastewater treatment facilities with design populations of less than 150 people. Septage does not include grease removed from grease traps at a restaurant or material removed from septic tanks and other similar treatment works that have received industrial wastewater. The standard for biosolids from septage is different from other sludges. See Section H for more information.

SECTION C – MECHANICAL WASTEWATER TREATMENT FACILITIES

1. Biosolids or sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and the requirements of Standard Conditions PART III or in accordance with Section A.3.c., above.
2. The permittee shall operate storage and treatment facilities, as defined by Section 644.016(23), RSMo, so that there is no biosolids or sludge discharged to waters of the state. Agricultural storm water discharges are exempt under the provisions of Section 644.059, RSMo.
3. Mechanical treatment plants shall have separate biosolids or sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove biosolids or sludge from these storage compartments on the required design schedule is a violation of this permit.

SECTION D – BIOSOLIDS OR SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR BY CONTRACT HAULER

1. Permittees that use contract haulers, under the authority of their operating permit, to dispose of biosolids or sludge, are responsible for compliance with all the terms of this permit. Contract haulers that assume the responsibility of the final disposal of biosolids or sludge, including biosolids land application, must obtain a Missouri State Operating Permit unless the hauler transports the biosolids or sludge to another permitted treatment facility.
2. Testing of biosolids or sludge, other than total solids content, is not required if biosolids or sludge are hauled to a permitted wastewater treatment facility, unless it is required by the accepting facility.

SECTION E – INCINERATION OF SLUDGE

1. Please be aware that sludge incineration facilities may be subject to the requirements of 40 CFR Part 503 Subpart E, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or, if the ash is determined to be hazardous, with 10 CSR 25.
3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, mass of sludge incinerated and mass of ash generated. Permittee shall also provide the name of the ash disposal facility and permit number if applicable.

SECTION F – SURFACE DISPOSAL SITES AND BIOSOLIDS AND SLUDGE LAGOONS

1. Please be aware that surface disposal sites of biosolids or sludge from wastewater treatment facilities may be subject to other laws including the requirements in 40 CFR Part 503 Subpart C, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
2. Biosolids or sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain biosolids or sludge storage lagoons as storage facilities, accumulated biosolids or sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of biosolids or sludge removed will be dependent on biosolids or sludge generation and accumulation in the facility. Enough biosolids or sludge must be removed to maintain adequate storage capacity in the facility.
 - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of biosolids or sludge on the bottom of the lagoon, upon prior approval of the Department; or
 - b. Permittee shall close the lagoon in accordance with Section I.

SECTION G – LAND APPLICATION OF BIOSOLIDS

1. The permittee shall not land apply biosolids unless land application is authorized in the facility description, the special conditions of the issued NPDES permit, or in accordance with Section A.3.c., above.
2. This permit only authorizes “Class A” or “Class B” biosolids derived from domestic wastewater to be land applied onto grass land, crop land, timber, or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
3. Class A Biosolids Requirements: Biosolids shall meet Class A requirements for application to public contact sites, residential lawns, home gardens or sold and/or given away in a bag or other container.
4. Class B biosolids that are land applied to agricultural and public contact sites shall comply with the following restrictions:
 - a. Food crops that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
 - b. Food crops below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for four months or longer prior to incorporation into the soil.
 - c. Food crops below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than four months prior to incorporation into the soil.
 - d. Animal grazing shall not be allowed for 30 days after application of biosolids.
 - e. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
 - f. Turf shall not be harvested for one year after application of biosolids if used for lawns or high public contact sites in close proximity to populated areas such as city parks or golf courses.
 - g. After Class B biosolids have been land applied to public contact sites with high potential for public exposure, as defined in 40 CFR § 503.31, such as city parks or golf courses, access must be restricted for 12 months.
 - h. After Class B biosolids have been land applied public contact sites with low potential for public exposure as defined in 40 CFR § 503.31, such as a rural land application or reclamation sites, access must be restricted for 30 days.
5. Pollutant limits
 - a. Biosolids shall be monitored to determine the quality for regulated pollutants listed in Table 1, below. Limits for any pollutants not listed below may be established in the permit.
 - b. The number of samples taken is directly related to the amount of biosolids or sludge produced by the facility (See Section J, below). Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to achieve pollutant concentration below those identified in Table 1, below.
 - c. Table 1 gives the ceiling concentration for biosolids. Biosolids which exceed the concentrations in Table 1 may not be land applied.

TABLE 1

Biosolids ceiling concentration	
Pollutant	Milligrams per kilogram dry weight
Arsenic	75
Cadmium	85
Copper	4,300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7,500

- d. Table 2 below gives the low metal concentration for biosolids. Because of its higher quality, biosolids with pollutant concentrations below those listed in Table 2 can safely be applied to agricultural land, forest, public contact sites, lawns, home gardens or be given away without further analysis. Biosolids containing metals in concentrations above the low metals concentrations but below the ceiling concentration limits may be land applied but shall not exceed the annual loading rates in Table 3 and the cumulative loading rates in Table 4. The permittee is required to track pollutant loading onto application sites for parameters that have exceeded the low metal concentration limits.

TABLE 2

Biosolids Low Metal Concentration	
Pollutant	Milligrams per kilogram dry weight
Arsenic	41
Cadmium	39
Copper	1,500
Lead	300
Mercury	17
Nickel	420
Selenium	100
Zinc	2,800

- e. Annual pollutant loading rate.

Table 3

Biosolids Annual Loading Rate	
Pollutant	Kg/ha (lbs./ac) per year
Arsenic	2.0 (1.79)
Cadmium	1.9 (1.70)
Copper	75 (66.94)
Lead	15 (13.39)
Mercury	0.85 (0.76)
Nickel	21 (18.74)
Selenium	5.0 (4.46)
Zinc	140 (124.96)

- f. Cumulative pollutant loading rates.

Table 4

Biosolids Cumulative Pollutant Loading Rate	
Pollutant	Kg/ha (lbs./ac)
Arsenic	41 (37)
Cadmium	39 (35)
Copper	1500 (1339)
Lead	300 (268)
Mercury	17 (15)
Nickel	420 (375)
Selenium	100 (89)
Zinc	2800 (2499)

6. Best Management Practices. The permittee shall use the following best management practices during land application activities to prevent the discharge of biosolids to waters of the state.
- Biosolids shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under § 4 of the Endangered Species Act or its designated critical habitat.
 - Apply biosolids only at the agronomic rate of nitrogen needed (see 5.c. of this section).
 - The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop

nitrogen removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.

- i. PAN can be determined as follows:
(Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹).
¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volatilization factors and mineralization rates can be utilized on a case-by-case basis.
- ii. Crop nutrient production/removal to be based on crop specific nitrogen needs and realistic yield goals. **NOTE:** There are a number of reference documents on the Missouri Department of Natural Resources website that are informative to implement best management practices in the proper management of biosolids, including crop specific nitrogen needs, realistic yields on a county by county basis and other supporting references.
- iii. Biosolids that are applied at agronomic rates shall not cause the annual pollutant loading rates identified in Table 3 to be exceeded.
- d. Buffer zones are as follows:
 - i. 300 feet of a water supply well, sinkhole, water supply reservoir or water supply intake in a stream;
 - ii. 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstanding state resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
 - iii. 150 feet of dwellings or public use areas;
 - iv. 100 feet (35 feet if biosolids application is down-gradient or the buffer zone is entirely vegetated) of lake, pond, wetlands or gaining streams (perennial or intermittent);
 - v. 50 feet of a property line. Buffer distances from property lines may be waived with written permission from neighboring property owner.
 - vi. For the application of dry, cake or liquid biosolids that are subsurface injected, buffer zones identified in 5.d.i. through 5.d.iii above, may be reduced to 100 feet. The buffer zone may be reduced to 35 feet if the buffer zone is permanently vegetated. Subsurface injection does not include methods or technology reflective of combination surface/shallow soil incorporation.
- e. Slope limitation for application sites are as follows:
 - i. For slopes less than or equal to 6 percent, no rate limitation;
 - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels;
 - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
 - iv. Dry, cake or liquid biosolids that are subsurface injected, may be applied on slopes not to exceed 20 percent. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation.
- f. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- g. Biosolids may be land applied to sites with soil that are snow covered, frozen, or saturated with liquid when site restrictions or other controls are provided to prevent pollutants from being discharged to waters of the state during snowmelt or stormwater runoff. During inclement weather or unfavorable soil conditions use the following management practices:
 - i. A maximum field slope of 6% and a minimum 300 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be utilized for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation;
 - ii. A maximum field slope of 2% and 100 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be used for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation;
 - iii. Other best management practices approved by the Department.

SECTION H – SEPTAGE

1. Haulers that land apply septage must obtain a state permit. An operating permit is not required for septage haulers who transport septage to another permitted treatment facility for disposal.
2. Do not apply more than 30,000 gallons of septage per acre per year or the volume otherwise stipulated in the operating permit.
3. Septic tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to mechanical treatment facilities.
4. Septage must comply with Class B biosolids regarding pathogen and vector attraction reduction requirements before it may be applied to crops, pastures or timberland. To meet required pathogen and vector reduction requirements, mix 50 pounds of hydrated lime for every 1,000 gallons of septage and maintain a septage pH of at least 12 pH standard units for 30 minutes or more prior to application.
5. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.
6. As residential septage contains relatively low levels of metals, the testing of metals in septage is not required.

SECTION I– CLOSURE REQUIREMENTS

1. This section applies to all wastewater facilities (mechanical and lagoons) and sludge or biosolids storage and treatment facilities. It does not apply to land application sites.
2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all sludges and/or biosolids. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20 – 6.010 and 10 CSR 20 – 6.015.
3. Biosolids or sludge that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
 - a. Biosolids and sludge shall meet the monitoring and land application limits for agricultural rates as referenced in Section G, above.
 - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
 - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre. Alternative, site-specific application rates may be included in the closure plan for department consideration.
 - i. PAN can be determined as follows:
$$(\text{Nitrate} + \text{nitrite nitrogen}) + (\text{organic nitrogen} \times 0.2) + (\text{ammonia nitrogen} \times \text{volatilization factor}^1).$$
¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volatilization factors and mineralization rates can be utilized on a case-by-case basis.
4. Domestic wastewater treatment lagoons with a design treatment capacity less than or equal to 150 persons, are “similar treatment works” under the definition of septage. Therefore the sludge within the lagoons may be treated as septage during closure activities. See Section B, above. Under the septage category, residuals may be left in place as follows:
 - a. Testing for metals or fecal coliform is not required.
 - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
 - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
5. Biosolids or sludge left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, and unless otherwise approved, the lagoon berm shall be demolished, and the site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion. Alternative biosolids or sludge and soil mixing ratios may be included in the closure plan for department consideration.
6. Lagoon and earthen structure closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200.
7. When closing a mechanical wastewater plant, all biosolids or sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
 - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to stormwater per 10 CSR 20-6.200. The site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate

- surface water drainage without creating erosion.
- b. Hazardous Waste shall not be land applied or disposed during mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations pursuant to 10 CSR 25.
 - c. After demolition of the mechanical plant, the site must only contain clean fill defined in Section 260.200.1(6) RSMo as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill, reclamation, or other beneficial use. Other solid wastes must be removed.
8. If biosolids or sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or I, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for on-site sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR Part 503, Subpart C.

SECTION J – MONITORING FREQUENCY

1. At a minimum, biosolids or sludge shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

TABLE 5

Biosolids or Sludge produced and disposed (Dry Tons per Year)	Monitoring Frequency (See Notes 1, and 2)		
	Metals, Pathogens and Vectors, Total Phosphorus, Total Potassium	Nitrogen TKN, Nitrogen PAN ¹	Priority Pollutants ²
319 or less	1/year	1 per month	1/year
320 to 1650	4/year	1 per month	1/year
1651 to 16,500	6/year	1 per month	1/year
16,501+	12/year	1 per month	1/year

¹ Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

² Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) are required only for permit holders that must have a pre-treatment program. Monitoring requirements may be modified and incorporated into the operating permit by the Department on a case-by-case basis.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

2. Permittees that operate wastewater treatment lagoons, peak flow equalization basins, combined sewer overflow basins or biosolids or sludge lagoons that are cleaned out once a year or less, may choose to sample only when the biosolids or sludge is removed or the lagoon is closed. Test one composite sample for each 319 dry tons of biosolids or sludge removed from the lagoon during the reporting year or during lagoon closure. Composite sample must represent various areas at one-foot depth.
3. Additional testing may be required in the special conditions or other sections of the permit.
4. Biosolids and sludge monitoring shall be conducted in accordance with federal regulation 40 CFR § 503.8, Sampling and analysis.

SECTION K – RECORD KEEPING AND REPORTING REQUIREMENTS

1. The permittee shall maintain records on file at the facility for at least five years for the items listed in Standard Conditions PART III and any additional items in the Special Conditions section of this permit. This shall include dates when the biosolids or sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
2. Reporting period
 - a. By February 19th of each year, applicable facilities shall submit an annual report for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and biosolids or sludge disposal facilities.
 - b. Permittees with wastewater treatment lagoons shall submit the above annual report only when biosolids or sludge are removed from the lagoon during the report period or when the lagoon is closed.
3. Report Form. The annual report shall be prepared on report forms provided by the Department or equivalent forms approved by the Department.
4. Reports shall be submitted as follows:
Major facilities, which are those serving 10,000 persons or more or with a design flow equal to or greater than 1 million gallons per day or that are required to have an approved pretreatment program, shall report to both the Department and EPA if the facility land applied, disposed of biosolids by surface disposal, or operated a sewage sludge incinerator. All other facilities shall maintain their biosolids or sludge records and keep them available to Department personnel upon request. State reports shall be submitted to the address listed as follows:

DNR regional or other applicable office listed in the
permit (see cover letter of permit)
ATTN: Sludge Coordinator

Reports to EPA must be electronically submitted online via the Central Data Exchange at: <https://cdx.epa.gov/> Additional information is available at: <https://www.epa.gov/biosolids/compliance-and-annual-reporting-guidance-about-clean-water-act-laws>


5. Annual report contents. The annual report shall include the following:
 - a. Biosolids and sludge testing performed. If testing was conducted at a greater frequency than what is required by the permit, all test results must be included in the report.
 - b. Biosolids or sludge quantity shall be reported as dry tons for the quantity produced and/or disposed.
 - c. Gallons and % solids data used to calculate the dry ton amounts.
 - d. Description of any unusual operating conditions.
 - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
 - i. This must include the name and address for the hauler and sludge facility. If hauled to a municipal wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that facility.
 - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.
 - f. Contract Hauler Activities:

If using a contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate biosolids or sludge use permit.
 - g. Land Application Sites:
 - i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as a legal description for nearest ¼, ¼, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
 - ii. If the “Low Metals” criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
 - iii. Report the method used for compliance with pathogen and vector attraction requirements.
 - iv. Report soil test results for pH and phosphorus. If no soil was tested during the year, report the last date when tested and the results.

RECEIVED

34202

DEC 30 2019



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM

**FORM B2 – APPLICATION FOR AN OPERATING PERMIT FOR
FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND
HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY**

FOR AGENCY USE ONLY

CHECK NUMBER

DATE RECEIVED

FEE SUBMITTED

JET PAY CONFIRMATION NUMBER

PART A – BASIC APPLICATION INFORMATION**1. THIS APPLICATION IS FOR:**

- ☐ An operating permit for a new or unpermitted facility. Construction Permit # _____
(Include completed Antidegradation Review or request to conduct an Antidegradation Review, see instructions)
- ☒ An operating permit renewal: Permit #MO- 0044300 Expiration Date 06/30/20
- ☐ An operating permit modification: Permit #MO- _____ Reason: _____

1.1 Is the appropriate fee included with the application (see instructions for appropriate fee)? ☐ YES ☒ NO

2. FACILITY

NAME: Algoa Regional Wastewater Treatment Facility TELEPHONE NUMBER WITH AREA CODE: 573-634-6444

ADDRESS (PHYSICAL): 8501 Fenceline Road CITY: Jefferson City STATE: MO ZIP CODE: 65101

2.1 LEGAL DESCRIPTION (Facility Site): Sec. 1/4, 1/4, T 44, R 10

COUNTY: Cole

2.2 UTM Coordinates Easting (X): 581833.004 Northing (Y): 4267934.566
For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

2.3 Name of receiving stream: Missouri River (P)(0701)

2.4 Number of Outfalls: 1 wastewater outfalls: stormwater outfalls: instream monitoring sites:

3. OWNER: The owner of the regulated activity/discharge being applied for and is not necessarily the owner of the real property on which the activity or discharge is occurring.

NAME: City of Jefferson EMAIL ADDRESS: eseaman@jeffcitymo.org TELEPHONE NUMBER WITH AREA CODE: 573-634-6410

ADDRESS: 320 East McCarty Street CITY: Jefferson City STATE: MO ZIP CODE: 65101

3.1 Request review of draft permit prior to Public Notice? ☒ YES ☐ NO

3.2 Are you a Publically Owned Treatment Works (POTW)? ☒ YES ☐ NO
If yes, is the Financial Questionnaire attached? ☒ YES ☐ NO See: <https://dnr.mo.gov/forms/780-2511-f.pdf>

3.3 Are you a Privately Owned Treatment Facility? ☐ YES ☒ NO

3.4 Are you a Privately Owned Treatment Facility regulated by the Public Service Commission (PSC)? ☐ YES ☒ NO

4. CONTINUING AUTHORITY: Permanent organization which will serve as the continuing authority for the operation, maintenance and modernization of the facility.

NAME: City of Jefferson EMAIL ADDRESS: eseaman@jeffcitymo.org TELEPHONE NUMBER WITH AREA CODE: 573-634-6410

ADDRESS: 320 East McCarty Street CITY: Jefferson City STATE: MO ZIP CODE: 65101

If the Continuing Authority is different than the Owner, include a copy of the contract agreement between the two parties and a description of the responsibilities of both parties within the agreement.

5. OPERATOR

NAME: Clara Haenchen TITLE: Treatment Plant Manager CERTIFICATE NUMBER (IF APPLICABLE): A-4924


EMAIL ADDRESS: chaenchen@jeffcitymo.org TELEPHONE NUMBER WITH AREA CODE: 573-634-6444

6. FACILITY CONTACT

NAME: Clara Haenchen TITLE: Treatment Plant Manager

EMAIL ADDRESS: chaenchen@jeffcitymo.org TELEPHONE NUMBER WITH AREA CODE: 573-634-6444

ADDRESS: 320 East McCarty Street CITY: Jefferson City STATE: MO ZIP CODE: 65101



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM

**FORM B2 – APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT
RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN
100,000 GALLONS PER DAY**

RECEIVED
DEC 30 2019
Water Protection Program

FACILITY NAME Algoa Regional Wastewater Treatment Facility	
PERMIT NO. MO-0044300	COUNTY Cole

APPLICATION OVERVIEW

Form B2 has been developed in a modular format and consists of Parts A, B and C and a Supplemental Application Information (Parts D, E, F and G) packet. All applicants must complete Parts A, B and C. Some applicants must also complete parts of the Supplemental Application Information packet. The following items explain which parts of Form B2 you must complete. Submittal of an incomplete application may result in the application being returned.

BASIC APPLICATION INFORMATION

- A. Basic application information for all applicants. All applicants must complete Part A.
- B. Additional application information for all applicants. All applicants must complete Part B.
- C. Certification. All applicants must complete Part C.

SUPPLEMENTAL APPLICATION INFORMATION

- D. Expanded Effluent Testing Data. A treatment works that discharges effluent to surface water of the United States and meets one or more of the following criteria must complete *Part D - Expanded Effluent Testing Data*:
 - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
 - 2. Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- E. Toxicity Testing Data. A treatment works that meets one or more of the following criteria must complete *Part E - Toxicity Testing Data*:
 - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
 - 2. Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- F. Industrial User Discharges and Resource Conservation and Recovery Act / Comprehensive Environmental Response, Compensation and Liability Act Wastes. A treatment works that accepts process wastewater from any significant industrial users, also known as SIUs, or receives a Resource Conservation and Recovery Act or CERCLA wastes must complete *Part F - Industrial User Discharges and Resource Conservation and Recovery Act /CERCLA Wastes*.
SIUs are defined as:
 - 1. All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N.
 - 2. Any other industrial user that meets one or more of the following:
 - i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - ii. Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - iii. Is designated as an SIU by the control authority.
 - iv. Is otherwise required by the permitting authority to provide the information.
- G. Combined Sewer Systems. A treatment works that has a combined sewer system must complete *Part G - Combined Sewer Systems*.

ALL APPLICANTS MUST COMPLETE PARTS A, B and C

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
---------------------------------------------------------------	---------------------------	--------------------

PART A – BASIC APPLICATION INFORMATION

7. FACILITY INFORMATION


7.1 Process Flow Diagram or Schematic. Provide a diagram showing the processes of the treatment plant. Show all of the treatment units, including disinfection (e.g. – Chlorination and Dechlorination), influents, and outfalls. Specify where samples are taken. Indicate any treatment process changes in the routing of wastewater during dry weather and peak wet weather. Include a brief narrative description of the diagram.

Attach sheets as necessary.

See attachement

FIGURE 7.1


Jefferson City
Algoa Regional Treatment Facility
MO-0044300
Process Diagram



FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
PART A – BASIC APPLICATION INFORMATION		
7. FACILITY INFORMATION (continued)		
<p>7.2 Map. Attach to this application an aerial or topographic map of the area extending at least one mile beyond facility property boundaries. This map must show the outline of the facility and the following information. A map can be obtained by visiting the following website: https://modnr.maps.arcgis.com/apps/webappviewer/index.html?id=1d81212e0854478ca0dae87c33c8c5ce</p> <p>a. The area surrounding the treatment plant, including all unit processes.</p> <p>b. The major pipes or other structures through which wastewater enters the treatment works and the pipes or other structures through which treated wastewater is discharged from the treatment plant. Include outfalls from bypass piping, if applicable.</p> <p>c. The actual point of discharge.</p> <p>d. Wells, springs, other surface water bodies and drinking water wells that are: 1) within ¼ mile of the property boundaries of the treatment works, and 2) listed in public record or otherwise known to the applicant.</p> <p>e. Any areas where the sewage sludge produced by the treatment works is stored, treated, or disposed.</p> <p>f. If the treatment works receives waste that is classified as hazardous under the Resource Conservation and Recovery Act (RCRA) by truck, rail, or special pipe, show on the map where that hazardous waste enters the treatment works and where it is treated, stored, or disposed.</p>		
7.3 Facility SIC Code: 4952	Discharge SIC Code:	
7.4 Number of people presently connected or population equivalent (P.E.): <u>5100</u> Design P.E. <u>8000</u>		
7.5 Connections to the facility: Number of units presently connected: 31 Residential: <u>18</u> Commercial: <u>13</u> Industrial <u> </u>		
7.6 Design Flow 800,000	Actual Flow 642,000	
7.7 Will discharge be continuous through the year? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Discharge will occur during the following months: <u>Jan-Dec</u> How many days of the week will discharge occur? <u>7</u>		
7.8 Is industrial wastewater discharged to the facility? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, describe the number and types of industries that discharge to your facility. Attach sheets as necessary Refer to the APPLICATION OVERVIEW to determine whether additional information is needed for Part F.		
7.9 Does the facility accept or process leachate from landfills?:	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
7.10 Is wastewater land applied? If yes, please attach Form I See: https://dnr.mo.gov/forms/780-1686-f.pdf	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
7.11 Does the facility discharge to a losing stream or sinkhole?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
7.12 Has a wasteload allocation study been completed for this facility?	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
8. LABORATORY CONTROL INFORMATION		
LABORATORY WORK CONDUCTED BY PLANT PERSONNEL		
Lab work conducted outside of plant.	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
Push-button or visual methods for simple test such as pH, settleable solids.	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
Additional procedures such as Dissolved Oxygen, Chemical Oxygen Demand, Biological Oxygen Demand, titrations, solids, volatile content.	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
More advanced determinations such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc.	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>
Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph.	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
PART A – BASIC APPLICATION INFORMATION		
9. SLUDGE HANDLING, USE AND DISPOSAL		
9.1 Is the sludge a hazardous waste as defined by 10 CSR 25? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
9.2 Sludge production (Including sludge received from others): Design Dry Tons/Year 120 Actual Dry Tons/Year		
9.3 Sludge storage provided: _____ Cubic feet; _____ Days of storage; _____ Average percent solids of sludge; <input type="checkbox"/> No sludge storage is provided. <input checked="" type="checkbox"/> Sludge is stored in lagoon.		
9.4 Type of storage: <div style="display: flex; justify-content: space-between;"> <div> <input type="checkbox"/> Holding Tank <input type="checkbox"/> Basin <input type="checkbox"/> Concrete Pad </div> <div> <input type="checkbox"/> Building <input checked="" type="checkbox"/> Lagoon <input type="checkbox"/> Other (Describe) _____ </div> </div>		
9.5 Sludge Treatment: <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <div> <input type="checkbox"/> Anaerobic Digester <input type="checkbox"/> Aerobic Digester </div> <div> <input type="checkbox"/> Storage Tank <input type="checkbox"/> Air or Heat Drying </div> <div> <input type="checkbox"/> Lime Stabilization <input type="checkbox"/> Composting </div> <div> <input checked="" type="checkbox"/> Lagoon <input type="checkbox"/> Other (Attach Description) </div> </div>		
9.6 Sludge use or disposal: <div style="display: flex; justify-content: space-between; margin-top: 5px;"> <div> <input checked="" type="checkbox"/> Land Application <input type="checkbox"/> Surface Disposal (Sludge Disposal Lagoon, Sludge Held For More Than Two Years) <input checked="" type="checkbox"/> Other (Attach Explanation Sheet) <u>Periodic Removal and Land Application. Last conducted 2012.</u> </div> <div> <input type="checkbox"/> Contract Hauler <input type="checkbox"/> Hauled to Another Treatment Facility <input type="checkbox"/> Solid Waste Landfill <input type="checkbox"/> Incineration </div> </div>		
9.7 Person responsible for hauling sludge to disposal facility: <input type="checkbox"/> By Applicant <input type="checkbox"/> By Others (complete below)		
NAME		EMAIL ADDRESS
ADDRESS	CITY	STATE ZIP CODE
CONTACT PERSON	TELEPHONE NUMBER WITH AREA CODE	PERMIT NO. MO-
9.8 Sludge use or disposal facility: <input checked="" type="checkbox"/> By Applicant <input type="checkbox"/> By Others (Complete below)		
NAME		EMAIL ADDRESS
ADDRESS	CITY	STATE ZIP CODE
CONTACT PERSON	TELEPHONE NUMBER WITH AREA CODE	PERMIT NO. MO-
9.9 Does the sludge or biosolids disposal comply with Federal Sludge Regulation 40 CFR 503? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (Explain)		
END OF PART A		

FACILITY NAME Algoa Regional Wastewater Treatment Facility			PERMIT NO. MO- 0044300			OUTFALL NO. 001		
PART B – ADDITIONAL APPLICATION INFORMATION								
14. EFFLUENT TESTING DATA								
<p>Applicants must provide effluent testing data for the following parameters. Provide the indicated effluent data for each outfall through which effluent is discharged. Do not include information of combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than four and one-half years apart. See 40 CFR 136.3 for sufficiently sensitive methods: https://www.ecfr.gov/cgi-bin/text-idx?SID=2d29852e2dcd91badc043bd5fc3d4df&mc=true&node=se40.25.136_13&rgn=div8</p>								
Outfall Number 001								
PARAMETER		MAXIMUM DAILY VALUE			AVERAGE DAILY VALUE			
		Value	Units	Value	Units	Number of Samples		
pH (Minimum)		7.5	S.U.	8.2	S.U.	11		
pH (Maximum)		8.8	S.U.	8.2	S.U.	11		
Flow Rate		1.447	MGD	0.713	MGD	335		
*For pH report a minimum and a maximum daily value								
POLLUTANT		MAXIMUM DAILY DISCHARGE		AVERAGE DAILY DISCHARGE			ANALYTICAL METHOD	ML/MDL
		Conc.	Units	Conc.	Units	Number of Samples		
Conventional and Nonconventional Compounds								
BIOCHEMICAL OXYGEN DEMAND (Report One)	BOD ₅	32	mg/L	14.9	mg/L	11	SM 5210B	
	CBOD ₅		mg/L		mg/L			
E. COLI		43.2	#/100 mL	3.9	#/100 mL	26	SM 9553B	
TOTAL SUSPENDED SOLIDS (TSS)		43	mg/L	25.5	mg/L	12	SM 2540D	
TOTAL PHOSPHORUS		5.56	mg/L	3.46	mg/L	11	EPA 365.4	0.044
TOTAL KJELDAHL NITROGEN		28	mg/L	10.6	mg/L	9	EPA 351.2	0.37
NITRITES + NITRATES		11.5	mg/L	2.95	mg/L	11	EPA 353.2	0.34
AMMONIA AS N		26.2	mg/L	8.4	mg/L	11	EPA 350.1	0.079
CHLORINE* (TOTAL RESIDUAL, TRC)			mg/L		mg/L			
DISSOLVED OXYGEN			mg/L		mg/L			
OIL and GREASE		<5.6	mg/L	<4.3	mg/L	6	EPA 1664A	4.9
OTHER: _____			mg/L		mg/L			
*Report only if facility chlorinates								
END OF PART B								

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
PART C – CERTIFICATION		
15. ELECTRONIC DISCHARGE MONITORING REPORT (eDMR) SUBMISSION SYSTEM		
<p>Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent limits and monitoring shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally-consistent set of data. One of the following must be checked in order for this application to be considered complete. Please visit https://dnr.mo.gov/forms/780-2204-f.pdf to access the eDMR application.</p> <p><input type="checkbox"/> - You have completed and submitted with this permit application the required documentation to participate in the eDMR system.</p> <p><input checked="" type="checkbox"/> - You have previously submitted the required documentation to participate in the eDMR system and/or you are currently using the eDMR system.</p> <p><input type="checkbox"/> - You have submitted a written request for a waiver from electronic reporting. See instructions for further information regarding waivers.</p>		
16. JETPAY		
<p>Permit fees may be payed online by credit card or eCheck through a system called JetPay. Use the URL provided to access JetPay and make an online payment.</p> <p>New Site Specific Permit: https://magic.collectorsolutions.com/magic-ui/payments/mo-natural-resources/591/ Construction Permits: https://magic.collectorsolutions.com/magic-ui/payments/mo-natural-resources/592/ Modification Fee: https://magic.collectorsolutions.com/magic-ui/payments/mo-natural-resources/596/</p>		
17. CERTIFICATION		
<p>All applicants must complete the Certification Section. This certification must be signed by an officer of the company or city official. All applicants must complete all applicable sections as explained in the Application Overview. By signing this certification statement, applicants confirm that they have reviewed the entire form and have completed all sections that apply to the facility for which this application is submitted.</p>		
ALL APPLICANTS MUST COMPLETE THE FOLLOWING CERTIFICATION.		
<p>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</p>		
PRINTED NAME Eric Seaman	OFFICIAL TITLE (MUST BE AN OFFICER OF THE COMPANY OR CITY OFFICIAL) Wastewater Division Director	
SIGNATURE 		
TELEPHONE NUMBER WITH AREA CODE 573-634-6410		
DATE SIGNED 23 DEC 19		
<p>Upon request of the permitting authority, you must submit any other information necessary to assess wastewater treatment practices at the treatment works or identify appropriate permitting requirements.</p>		
<p>Send Completed Form to:</p> <p style="text-align: center;">Department of Natural Resources Water Protection Program ATTN: NPDES Permits and Engineering Section P.O. Box 176 Jefferson City, MO 65102-0176</p>		
END OF PART C		
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH PARTS OF FORM B2 YOU MUST COMPLETE.		
<p>Do not complete the remainder of this application, unless at least one of the following statements applies to your facility:</p> <ol style="list-style-type: none"> 1. Your facility design flow is equal to or greater than 1,000,000 gallons per day. 2. Your facility is a pretreatment treatment works. 3. Your facility is a combined sewer system. 		
<p>Submittal of an incomplete application may result in the application being returned. Permit fees for returned applications shall be forfeited. Permit fees for applications being processed by the department that are withdrawn by the applicant shall be forfeited.</p>		

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
---------------------------------------------------------------	---------------------------	--------------------

PART D – EXPANDED EFFLUENT TESTING DATA**18. EXPANDED EFFLUENT TESTING DATA**

Refer to the APPLICATION OVERVIEW to determine whether Part D applies to the treatment works.

If the treatment works has a design flow greater than or equal to 1 MGD or it has (or is required to have) a pretreatment program, or is otherwise required by the permitting authority to provide the data, then provide effluent testing data for the following pollutants. Provide the indicated effluent testing information **for each outfall through which effluent is discharged**. Do not include information of combined sewer overflows in this section. All information reported must be based on data collected and analyzed using sufficiently sensitive methods found in 40 CFR Part 136. See 40 CFR 136.3 for sufficiently sensitive methods: <https://www.ecfr.gov/cgi-bin/text-idx?SID=2d29852e2dcdf91badc043bd5fc3d4df&mc=true&node=se40.25.136.13&rqn=div8>. In addition, all data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least **three pollutant scans** and must be no more than four and one-half years prior to the date of the permit application submittal. In the blank rows provided at the end of this list, include any additional data for pollutants not specifically listed in this form. Information may be written in the blanks below or provided as attached documents containing the laboratory test results.

Outfall Number (Complete Once for Each Outfall Discharging Effluent to Waters of the State.)

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples		
METALS (TOTAL RECOVERABLE), CYANIDE, PHENOLS AND HARDNESS											
ALUMINUM	<0.252	mg/L			<0.176	mg/L			3	6020A/200.7	33ug
ANTIMONY	<0.015	mg/L			<0.009	mg/L			3	200.8/200.7	6.5
ARSENIC	<0.01	mg/L			0.008	mg/L			3	200.8/200.7	4.1
BERYLLIUM	<0.004	mg/L			<0.003	mg/L			3	200.8/200.7	0.25
CADMIUM	<0.005	mg/L			<0.005	mg/L			3	200.8/200.7	0.56
CHROMIUM III	<0.01	mg/L			<0.008	mg/L			3	3500CR/625	1
CHROMIUM VI	<0.01	mg/L			<0.008	mg/L			3	3500CR/7196	3.1
COPPER	<0.01	mg/L			0.008	mg/L			3	200.8/200.7	3.4
IRON	0.54	mg/L			0.227	mg/L			3	6020A/200.7	14
LEAD	<0.02	mg/L			0.012	mg/L			3	200.8/200.7	3.4
MERCURY	<0.02	mg/L			0.007	mg/L			3	200.8/245.1	0.066
NICKEL	<0.01	mg/L			<0.008	mg/L			3	200.8/200.7	1.2
SELENIUM	<0.015	mg/L			<0.008	mg/L			3	200.8/200.7	6.6
SILVER	<0.007	mg/L			<0.006	mg/L			3	200.8/200.7	1.8
THALLIUM	<0.02	mg/L			<0.008	mg/L			3	200.8/200.7	3.4
ZINC	<0.05	mg/L			0.025	mg/L			3	200.8/200.7	6.1
CYANIDE	0.0057	mg/L			0.0052	mg/L			3	4500CNE	3.9
TOTAL PHENOLIC COMPOUNDS	<0.005	mg/L			<0.005	mg/L			3	5530B/420.1	0.000016
HARDNESS (as CaCO ₃)	466	mg/L			326	mg/L			3	2340B/200.7	6500
VOLATILE ORGANIC COMPOUNDS											
ACROLEIN	<0.01	mg/L			<0.053	mg/L			3	EPA 624	50
ACRYLONITRILE	<0.05	mg/L			<0.027	mg/L			3	EPA 624	50
BENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.12
BROMOFORM	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.11
CARBON TETRACHLORIDE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.1

FACILITY NAME Algoa Regional Wastewater Treatment Facility				PERMIT NO. MO- 0044300				OUTFALL NO. 001			
PART D – EXPANDED EFFLUENT TESTING DATA											
18. EXPANDED EFFLUENT TESTING DATA											
Complete Once for Each Outfall Discharging Effluent to Waters of the State											
POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples		
CHLOROBENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.081
CHLORODIBROMO-METHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.24
CHLOROETHANE	<0.01	mg/L			<0.004	mg/L			3	EPA 624	0.2
2-CHLORO-ETHYL VINYL ETHER	<0.01	mg/L			<0.005	mg/L			3	EPA 624	0.29
CHLOROFORM	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.14
DICHLOROBROMO-METHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.13
1,1-DICHLORO-ETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.13
1,2-DICHLORO-ETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.14
TRANS-1,2-DICHLOROETHYLENE	<0.02	mg/L			<0.007	mg/L			3	EPA 624	0.17
1,1-DICHLORO-ETHYLENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.11
1,2-DICHLORO-PROPANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.097
1,3-DICHLORO-PROPYLENE	<0.015	mg/L			<0.006	mg/L			3	EPA 624	0.12
ETHYLBENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.057
METHYL BROMIDE	<0.01	mg/L			<0.005	mg/L			3	EPA 624	0.66
METHYL CHLORIDE	<0.01	mg/L			<0.01	mg/L			3	EPA 624	0.2
METHYLENE CHLORIDE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.21
1,1,2,2-TETRA-CHLOROETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.12
TETRACHLORO-ETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.15
TOLUENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.048
1,1,1-TRICHLORO-ETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.057
1,1,2-TRICHLORO-ETHANE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.25
TRICHLOROETHYLENE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.15
VINYL CHLORIDE	<0.005	mg/L			<0.002	mg/L			3	EPA 624	0.11
ACID-EXTRACTABLE COMPOUNDS											
P-CHLORO-M-CRESOL	<0.007	mg/L			<0.006	mg/L			3	EPA 625	0.74
2-CHLOROPHENOL	<0.007	mg/L			<0.006	mg/L			3	EPA 625	0.72
2,4-DICHLOROPHENOL	<0.009	mg/L			<0.006	mg/L			3	EPA 625	0.65
2,4-DIMETHYLPHENOL	<0.005	mg/L			<0.005	mg/L			3	EPA 625	0.65
4,6-DINITRO-O-CRESOL	<0.024	mg/L			<0.013	mg/L			3	EPA 625	0.76
2,4-DINITROPHENOL	<0.048	mg/L			<0.019	mg/L			3	EPA 625	0.97
2-NITROPHENOL	<0.009	mg/L			<0.007	mg/L			3	EPA 625	0.68
4-NITROPHENOL	<0.006	mg/L			<0.006	mg/L			3	EPA 625	2.4

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
---------------------------------------------------------------	---------------------------	--------------------

PART D – EXPANDED EFFLUENT TESTING DATA

18. EXPANDED EFFLUENT TESTING DATA

Complete Once for Each Outfall Discharging Effluent to Waters of the State.

POLLUTANT	MAXIMUM DAILY DISCHARGE				AVERAGE DAILY DISCHARGE					ANALYTICAL METHOD	ML/MDL
	Conc.	Units	Mass	Units	Conc.	Units	Mass	Units	No. of Samples		
PENTACHLOROPHENOL	<0.01	mg/L			<0.007	mg/L			3	EPA 625	0.73
PHENOL	<0.005	mg/L			<0.005	mg/L			3	EPA 625	2.4
2,4,6-TRICHLOROPHENOL	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.74

BASE-NEUTRAL COMPOUNDS

ACENAPHTHENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.63
ACENAPHTHYLENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.63
ANTHRACENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.65
BENZIDINE	<0.048	mg/L			<0.038	mg/L			3	EPA 625	8.5
BENZO(A)ANTHRACENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.66
BENZO(A)PYRENE	<0.021	mg/L			<0.01	mg/L			3	EPA 625	0.7
3,4-BENZO-FLUORANTHENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.89
BENZO(GH) PHERYLENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.67
BENZO(K) FLUORANTHENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.98
BIS (2-CHLOROTHIOXY) METHANE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.65
BIS (2-CHLOROETHYL) – ETHER	<0.006	mg/L			<0.003	mg/L			3	EPA 625	0.73
BIS (2-CHLOROISO-PROPYL) ETHER	<0.006	mg/L			<0.003	mg/L			3	EPA 625	0.68
BIS (2-ETHYLHEXYL) PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.95
4-BROMOPHENYL PHENYL ETHER	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.69
BUTYL BENZYL PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.62
2-CHLORONAPHTHALENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.77
4-CHLOROPHENYL PHENYL ETHER	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.79
CHRYSENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.7
DI-N-BUTYL PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.57
DI-N-OCTYL PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.92
DIBENZO (A,H) ANTHRACENE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.71
1,2-DICHLORO-BENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 625	0.066
1,3-DICHLORO-BENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 625	0.1
1,4-DICHLORO-BENZENE	<0.005	mg/L			<0.002	mg/L			3	EPA 625	0.05
3,3-DICHLORO-BENZIDINE	<0.019	mg/L			<0.014	mg/L			3	EPA 625	0.72
DIETHYL PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.63
DIMETHYL PHTHALATE	<0.005	mg/L			<0.004	mg/L			3	EPA 625	0.6

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL			
FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001	
PART E – TOXICITY TESTING DATA			
19. TOXICITY TESTING DATA			
Refer to the APPLICATION OVERVIEW to determine whether Part E applies to the treatment works.			
Publicly owned treatment works, or POTWs, meeting one or more of the following criteria must provide the results of whole effluent toxicity tests for acute or chronic toxicity for each of the facility's discharge points.			
<div style="margin-left: 20px;"> A. POTWs with a design flow rate greater than or equal to 1 million gallons per day B. POTWs with a pretreatment program (or those that are required to have one under 40 CFR Part 403) C. POTWs required by the permitting authority to submit data for these parameters <ul style="list-style-type: none"> • At a minimum, these results must include quarterly testing for a 12-month period within the past one year using multiple species (minimum of two species), or the results from four tests performed at least annually in the four and one-half years prior to the application, provided the results show no appreciable toxicity, and testing for acute or chronic toxicity, depending on the range of receiving water dilution. Do not include information about combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. • If EPA methods were not used, report the reason for using alternative methods. If test summaries are available that contain all of the information requested below, they may be submitted in place of Part E. If no biomonitoring data is required, do not complete Part E. Refer to the application overview for directions on which other sections of the form to complete. </div>			
Indicate the number of whole effluent toxicity tests conducted in the past four and one-half years: _____ chronic <u>3</u> _____ acute			
Complete the following chart for the last three whole effluent toxicity tests. Allow one column per test. Copy this page if more than three tests are being reported.			
	Most Recent	2 ND Most Recent	3 RD Most Recent
A. Test Information			
Test Method Number	EPA 821/R-02/012	USEPA 2000/2002	USEPA 2000/2002
Final Report Number	PACE# 60317621	EAS#2305706	EAS#2202110
Outfall Number	001	001	001
Dates Sample Collected	10-9-2019	11-6/2018	11-14-2017
Date Test Started	10-10-2019	11-7/2018	11-15/2017
Duration	48HRS	48HRS	48HRS
B. Toxicity Test Methods Followed			
Manual Title	EPA 821/R-02/012	Standard Methods	Standard Methods
Edition Number and Year of Publication	USEPA 2002	18th, 1992	18th, 1992
Page Number(s)		8.1-8.82	8.0-8.82
C. Sample collection method(s) used. For multiple grab samples, indicate the number of grab samples used			
24-Hour Composite			
Grab	X	X	X
D. Indicate where the sample was taken in relation to disinfection (Check all that apply for each)			
Before Disinfection	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
After Disinfection	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
After Dechlorination	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
E. Describe the point in the treatment process at which the sample was collected			
Sample Was Collected:			
F. Indicate whether the test was intended to assess chronic toxicity, acute toxicity, or both			
Chronic Toxicity	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Acute Toxicity	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
G. Provide the type of test performed			
Static	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Static-renewal	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flow-through	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
H. Source of dilution water. If laboratory water, specify type; if receiving water, specify source			
Laboratory Water	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Receiving Water	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NO. MO- 0044300	OUTFALL NO. 001
---------------------------------------------------------------	---------------------------	--------------------

PART E – TOXICITY TESTING DATA

19. TOXICITY TESTING DATA (continued)

	Most Recent	Second Most Recent	Third Most Recent
I. Type of dilution water. If salt water, specify "natural" or type of artificial sea salts or brine used.			
Fresh Water	X	X	X
Salt Water			
J. Percentage of effluent used for all concentrations in the test series			
	2.25, 4.5, 9, 18, 36	2.25, 4.5, 9, 18, 36	2.25, 4.5, 9, 18, 36
K. Parameters measured during the test (State whether parameter meets test method specifications)			
pH	Yes	Yes	Yes
Salinity			
Temperature	Yes	Yes	Yes
Ammonia			
Dissolved Oxygen	Yes	Yes	Yes
L. Test Results			
Acute:			
Percent Survival in 100% Effluent	100%	100%	100%
LC ₅₀	>36%	>36%	>36%
95% C.I.	NA	NA	NA
Control Percent Survival	100%	100%	100%
Other (Describe)			
Chronic:			
NOEC			
IC ₂₅			
Control Percent Survival			
Other (Describe)			
M. Quality Control/ Quality Assurance			
Is reference toxicant data available?	YES	YES	YES
Was reference toxicant test within acceptable bounds?	YES	YES	YES
What date was reference toxicant test run (MM/DD/YYYY)?	10/02/2019	11/07/2018	11/08/2017
Other (Describe)			
Is the treatment works involved in a toxicity reduction evaluation? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
If yes, describe:			
If you have submitted biomonitoring test information, or information regarding the cause of toxicity, within the past four and one-half years, provide the dates the information was submitted to the permitting authority and a summary of the results.			
Date Submitted (MM/DD/YYYY)			
Summary of Results (See Instructions)			

END OF PART E

REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE.

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL			
FACILITY NAME Algoa Regional Wastewater Treatment Facility		PERMIT NO. MO- 0044300	OUTFALL NO. 001
PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES			
Refer to the APPLICATION OVERVIEW to determine whether Part F applies to the treatment works.			
20. GENERAL INFORMATION			
20.1 Does the treatment works have, or is it subject to, an approved pretreatment program? <input checked="checked" type="checkbox"/> Yes <input type="checkbox"/> No			
20.2 Number of Significant Industrial Users (SIUs) and Categorical Industrial Users (CIUs). Provide the number of each of the following types of industrial users that discharge to the treatment works: Number of non-categorical SIUs <u>0</u> Number of CIUs <u>0</u>			
21. INDUSTRIES CONTRIBUTING MORE THAN 5 PERCENT OF THE ACTUAL FLOW TO THE FACILITY OR OTHER SIGNIFICANT INDUSTRIAL USERS INFORMATION			
Supply the following information for each SIU. If more than one SIU discharges to the treatment works, provide the information requested for each. Submit additional pages as necessary.			
NAME			
MAILING ADDRESS		CITY	STATE ZIP CODE
21.1 Describe all of the industrial processes that affect or contribute to the SIU's discharge			
21.2 Describe all of the principle processes and raw materials that affect or contribute to the SIU's discharge. Principal Product(s): Raw Material(s):			
21.3 Flow Rate a. PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent b. NON-PROCESS WASTEWATER FLOW RATE. Indicate the average daily volume of non-process wastewater discharged into the collection system in gallons per day, or gpd, and whether the discharge is continuous or intermittent. gpd <input type="checkbox"/> Continuous <input type="checkbox"/> Intermittent			
21.4 Pretreatment Standards. Indicate whether the SIU is subject to the following: a. Local Limits <input type="checkbox"/> Yes <input type="checkbox"/> No b. Categorical Pretreatment Standards <input type="checkbox"/> Yes <input type="checkbox"/> No If subject to categorical pretreatment standards, which category and subcategory?			
21.5 Problems at the treatment works attributed to waste discharged by the SIU. Has the SIU caused or contributed to any problems (e.g., upsets, interference) at the treatment works in the past three years? <input type="checkbox"/> Yes <input type="checkbox"/> No If Yes, describe each episode			

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL

FACILITY NAME

Algoa Regional Wastewater Treatment Facility

PERMIT NO.

MO- 0044300

OUTFALL NO.

001

PART F – INDUSTRIAL USER DISCHARGES AND RCRA/CERCLA WASTES**22. RCRA HAZARDOUS WASTE RECEIVED BY TRUCK, RAIL, OR DEDICATED PIPELINE**

22.1 Does the treatment works receive or has it in the past three years received RCRA hazardous waste by truck, rail or dedicated pipe? ☐ Yes ☒ No

22.2 Method by which RCRA waste is received. (Check all that apply)

☐ Truck☐ Rail☐ Dedicated Pipe**22.3 Waste Description**

EPA Hazardous Waste Number	Amount (volume or mass)	Units

23. CERCLA (SUPERFUND) WASTEWATER, RCRA REMEDIATION/CORRECTIVE ACTION WASTEWATER, AND OTHER REMEDIAL ACTIVITY WASTEWATER

23.1 Does the treatment works currently (or has it been notified that it will) receive waste from remedial activities?

☐ Yes☒ No

Provide a list of sites and the requested information for each current and future site.

23.2 Waste Origin. Describe the site and type of facility at which the CERCLA/RCRA/or other remedial waste originates (or is expected to originate in the next five years).

23.3 List the hazardous constituents that are received (or are expected to be received). Included data on volume and concentration, if known. (Attach additional sheets if necessary)

23.4 Waste Treatment

a. Is this waste treated (or will it be treated) prior to entering the treatment works?

☐ Yes☐ No

If Yes, describe the treatment (provide information about the removal efficiency):

b. Is the discharge (or will the discharge be) continuous or intermittent?

☐ Continuous☐ Intermittent

If intermittent, describe the discharge schedule:

END OF PART F**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE.**

MAKE ADDITIONAL COPIES OF THIS FORM FOR EACH OUTFALL

FACILITY NAME

Algoa Regional Wastewater Treatment Facility

PERMIT NO.

MO- 0044300

OUTFALL NO.

001

PART G – COMBINED SEWER SYSTEMS

Refer to the APPLICATION OVERVIEW to determine whether Part G applies to the treatment works.

24. GENERAL INFORMATION**24.1 System Map.** Provide a map indicating the following: (May be included with basic application information.)

- A. All CSO Discharges.
- B. Sensitive Use Areas Potentially Affected by CSOs. (e.g., beaches, drinking water supplies, shellfish beds, sensitive aquatic ecosystems and Outstanding Natural Resource Waters.)
- C. Waters that Support Threatened and Endangered Species Potentially Affected by CSOs.

24.2 System Diagram. Provide a diagram, either in the map provided above or on a separate drawing, of the Combined Sewer Collection System that includes the following information:

- A. Locations of Major Sewer Trunk Lines, Both Combined and Separate Sanitary.
- B. Locations of Points where Separate Sanitary Sewers Feed into the Combined Sewer System.
- C. Locations of In-Line or Off-Line Storage Structures.
- D. Locations of Flow-Regulating Devices.
- E. Locations of Pump Stations.

24.3 Percent of collection system that is combined sewer**24.4** Population served by combined sewer collection system**24.5** Name of any satellite community with combined sewer collection system**25. CSO OUTFALLS. COMPLETE THE FOLLOWING ONCE FOR EACH CSO DISCHARGE POINT****25.1** Description of Outfall

- a. Outfall Number
- b. Location

c. Distance from Shore (if applicable) _____ ft

d. Depth Below Surface (if applicable) _____ ft

e. Which of the following were monitored during the last year for this CSO?

- ☐ Rainfall
- ☐ CSO Pollutant Concentrations
- ☐ CSO
- ☐ CSO Flow Volume
- ☐ Receiving Water Quality

f. How many storm events were monitored last year?

25.2 CSO Events

- a. Give the Number of CSO Events in the Last Year Events ☐ Actual ☐ Approximate
- b. Give the Average Duration Per CSO Event Hours ☐ Actual ☐ Approximate
- c. Give the Average Volume Per CSO Event Million Gallons ☐ Actual ☐ Approximate
- d. Give the minimum rainfall that caused a CSO event in the last year _____ inches of rainfall


25.3 Description of Receiving Waters

- a. Name of Receiving Water
- b. Name of Watershed/River/Stream System
- c. U.S. Soil Conservation Service 14-Digit Watershed Code (If Known)
- d. Name of State Management/River Basin
- e. U.S. Geological Survey 8- Digit Hydrologic Cataloging Unit Code (If Known)

25.4 CSO Operations

Describe any known water quality impacts on the receiving water caused by this CSO (e.g., permanent or intermittent beach closings, permanent or intermittent shellfish bed closings, fish kills, fish advisories, other recreational loss, or violation of any applicable state water quality standard.)

END OF PART G**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH OTHER PARTS OF FORM B2 YOU MUST COMPLETE.**



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
FINANCIAL QUESTIONNAIRE

RECEIVED

DEC 20 2019

Water Protection Program

NOTE ► FINANCIAL INFORMATION THAT IS NOT PROVIDED THROUGH THIS FORM WILL BE OBTAINED BY THE DEPARTMENT FROM READILY AVAILABLE SOURCES.

1. GENERAL INFORMATION

FACILITY NAME Algoa Regional Wastewater Treatment Facility	PERMIT NUMBER #MO- 0044300
CITY Jefferson City	COUNTY Cole

2. GENERAL FINANCIAL INFORMATION (ALL FACILITIES)

2.1 Number of connections to the facility: Residential <u>18</u> Commercial <u>13</u> Industrial _____	
2.2 Current sewer user rate (Based on a 5,000 gallon per month usage):	\$34.19
2.3 Current annual operating costs for the facility (excludes depreciation):	\$569,000
2.4 Bond rating (if applicable):	A+
2.5 Bonding capacity:	\$178,781,052
2.6 Current outstanding debt relating to wastewater collection and treatment:	\$45,665,800 (entire system)
2.7 Amount within the current user rate used toward payments on outstanding debt related to the current wastewater infrastructure:	51%
2.8 Attach any relevant financial statements. <i>see www.jeffersoncitymo.gov/government/catt.php</i>	

3. FINANCIAL INFORMATION REQUIRED FROM MUNICIPALITIES


3.1 Municipality's Full Market Property Value:	\$893,905,260
3.2 Municipality's Overall Net Debt:	\$58,516,896
3.3 Municipality's Property Tax Revenues (levied) [A]:	\$4,896,931
3.4 Municipality's Property Tax Revenues (collected) [B]:	\$4,761,805
3.5 Municipality's Property Tax Collection Rate ([B]/[A]):	97.2%

4. FINANCIAL INFORMATION REQUIRED FROM SEWER DISTRICTS

4.1 Total connections to the sewer district: Residential _____ Commercial _____ Industrial _____	
4.2 When facilities require upgrades, how are the costs divided? Will the homes connected to the upgraded facility bear the costs? Will the costs be divided across the sewer district?	

5. ADDITIONAL CONSIDERATIONS (ALL FACILITIES)

5.1 Provide a list of major infrastructure or other investments in environmental projects. Include project timing and costs and indicate any possible overlap or complications (attach sheets as necessary): Aeration equipment replacement and sludge removal in next few years.	
5.2 Provide a list of any other relevant local community economic conditions that may impact the ability to afford new permit requirements (attach sheets as necessary): Utility and Community recovering from tornado and flooding in 2019. Affordable housing shortage.	

6. CERTIFICATION	
FINANCIAL CONTACT Eric Seaman	OFFICIAL TITLE Wastewater Division Director
EMAIL ADDRESS eseaman@jeffcitymo.org	TELEPHONE NUMBER WITH AREA CODE 573-634-6443
<p>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</p>	
OWNER OR AUTHORIZED REPRESENTATIVE Eric Seaman	OFFICIAL TITLE Wastewater Division Director
SIGNATURE 	DATE SIGNED 23 DEC 19

INSTRUCTIONS FOR COMPLETING THE FINANCIAL QUESTIONNAIRE

The Financial Questionnaire it to be completed by municipalities, sewer districts, and water supply districts when filing for renewal of their Missouri State Operating Permit. The Financial Questionnaire is to be submitted as an attachment to *FORM B: APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW LESS THAN OR EQUAL TO 100,000 GALLONS PER DAY* and *FORM B2: APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY*.

1. GENERAL INFORMATION – Provide the name by which the facility is locally known, the Missouri State Operating Permit number, and the city and county where the facility is located.
2. GENERAL FINANCIAL INFORMATION (ALL FACILITIES) – Municipalities, sewer districts, and water supply districts are to complete.
 - 2.1 Self-explanatory.
 - 2.2 Provide the rate that a household would be charged for sewer service if they use 5,000 gallons per month.
 - 2.3 Provide the cost to operate and maintain the wastewater facility annually.
 - 2.4 Bond ratings can be found here: <https://emma.msrb.org/IssuerHomePage/HomepagesForC6?cusip6=795169>.
 - 2.5 General obligation bond capacity allowed by constitution: Cities = up to 20% of taxable tangible property; Sewer districts = up to 5% of taxable tangible property.
 - 2.6 Provide the amount of debt owed on wastewater collection and treatment. Debt information is typically available from your community's annual financial statements
 - 2.7 Provide the amount of a user's monthly sewer bill that is used toward debt owed on wastewater collection and treatment. This may be a percentage or dollar amount.
 - 2.8 Self-explanatory.
3. FINANCIAL INFORMATION REQUIRED FROM MUNICIPALITIES – Municipalities are to complete.
 - 3.1 Full Market Property Value is typically available through your community or state assessor's office.
 - 3.2 Debt information is typically available from your community's annual financial statements.
 - 3.3 Property tax revenues are typically available from your community's annual financial statements. Property tax rates for Missouri communities can be found in the annual auditor's report: <https://app.auditor.mo.gov/AuditReports/AudRpt2.aspx?id=31>.
 - 3.4 Property Taxes Levied = (Real Property Assessed Value) * (Property Tax Rate).
This information is typically available through your community or state assessor's office and your community's annual financial statements. Property tax rates for Missouri communities can be found in the annual auditor's report: <https://app.auditor.mo.gov/AuditReports/AudRpt2.aspx?id=31>.
 - 3.5 Property tax collection rate = (Property Tax Revenues) ÷ (Property Taxes Levied).
4. FINANCIAL INFORMATION REQUIRED FROM SEWER DISTRICTS – Sewer Districts and Water Supply Districts are to complete.
 - 4.1-4.2 Self-explanatory.
5. ADDITIONAL CONSIDERATIONS (ALL FACILITIES) – Municipalities, sewer districts, and water supply districts are to complete.
 - 5.1-5.2 Self-explanatory.
6. CERTIFICATION – Provide the name and contact information for the individual who can respond to financial information requests for your community. This form must be signed by your community's "owner" or "authorized representative". The owner for a municipality is either the principal executive officer or ranking elected official.

If there are any questions concerning this form or your Missouri State Operating Permit, contact the Department of Natural Resources, Water Protection Program, Operating Permits Section at 800-361-4827 or 573-751-6825.

Pollutant	11/9/2017	8/28/2018	9/4/2019
(TCDD)			
1,1,1,2-Tetrachloroethane			
1,1,1-Trichloroethane	<0.001	<0.005	<0.001
1,1,1-trichloroethane		<0.005	
1,1,2,2-Tetrachloroethane	<0.001	<0.005	<0.001
1,1,2-Trichloroethane	<0.001	<0.005	<0.001
1,1-Dichloroethene	<0.001	<0.005	<0.001
1,2,3-Trichloropropane			
1,2,4,5-tetrachlorobenzene			
1,2,4-trichlorobenzene	<0.005	<0.0012	<0.0048
1,2-Dichlorobenzene	<0.001	<0.005	<0.001
1,2-Dichloroethane	<0.001	<0.005	<0.001
1,2-Dichloropropane	<0.001	<0.005	<0.001
1,2-Diphenylhydrazine	<0.005	<0.0023	
1,3-Dichlorobenzene	<0.001	<0.005	<0.001
1,3-dinitrobenzene			
1,4-Dichlorobenzene	<0.001	<0.005	<0.001
1,4-dithiane			
2,4,5-T			
2,4,5-TP			
2,4,5-trichlorophenol			
2,4,6-Trichlorophenol	<0.005	<0.004	
2,4-D			
2,4-dichlorophenol	<0.005	<0.0089	<0.0048
2,4-Dimethylphenol	<0.005	<0.005	<0.0048
2,4-Dinitrophenol	<0.005	<0.005	<0.0476
2,4-Dinitrotoluene	<0.005	<0.0016	<0.0057
2-Chloronaphthalene	<0.005	<0.0013	<0.0048
2-Chlorophenol	<0.006	<0.0072	<0.0048
2-chlorotoluene			
2-chlorotoluene			
2-Nitrophenol	<0.0067	<0.0087	<0.0048
2-Nitrophenol			
3,3'-Dichlorobenzidine	<0.012	<0.012	<0.019
3,3'-dichlorobenzidine		<0.012	
4,4'-DDD	<0.001	<0.001	<0.0001
4,4'-DDE	<0.001	<0.001	<0.0001
4,4'-DDT	<0.001	<0.001	<0.0001
4,6-dinitro-2-methylphenol	<0.01	>0.005	<0.0238
Acenaphthene	<0.005	<0.0021	<0.0048
Acrolein	<0.01	<0.05	<0.1
Acrylonitrile	<0.01	<0.05	<0.02
Aldrin	<0.0005	<0.0005	<0.00005
Alpha-BHC	<0.0005	<0.0005	<0.00005
Alpha-endosulfan			
aluminum	0.252	<0.2	<0.075
Ametryn			
Anthracene	<0.005	<0.0015	<0.0048
Antimony	0.006	<0.006	<0.015
Aroclor-1016	<0.005	<0.005	<0.0001
Aroclor-1221	<0.01	<0.01	<0.0001
Aroclor-1232	<0.005	<0.005	<0.0001
Aroclor-1242	<0.005	<0.005	<0.0001
Aroclor-1248	<0.005	<0.005	<0.0001
Aroclor-1254	<0.01	<0.01	<0.0001
Aroclor-1260	<0.01	<0.01	<0.0001
Arsenic	0.009	<0.005	<0.01
Asbestos			
Atrazine			
Barium	<0.1	<0.1	0.0769
Baygon			
Bentazon			
Benzene	<0.001	<0.005	<0.001
Benzidine	<0.026	<0.04	<0.0476
Benzo(a)pyrene	<0.005	<0.021	<0.0048

WBC: Whole Body Contact Recreational
SCR: Secondary Contact Recreation
AQL: Protection of Aquatic Life
DWS: Drinking Water Supply
LWW: Livestock and Wildlife Water

Pollutant	11/9/2017	8/28/2018	9/4/2019
Beryllium	<0.004	<0.004	<0.001
Beta-BHC	<0.0005	<0.0005	<0.00005
Bis (chloromethyl) ether			
Bis(2-chloroethyl)ether	<0.0005	<0.0021	<0.0057
Bis(2-chloroisopropyl) ether	<0.0005	<0.0019	<0.0057
Bis(2-ethylhexyl)adipate			
Bis(2-ethylhexyl)phthalate	<0.003	<0.0044	<0.0048
Boron			
Bromacil			
Bromochloromethane			
Bromoform	<0.001	<0.005	<0.001
Bromomethane	<0.001	<0.01	<0.005
Bromomethane		<0.01	
Butylate			
Butylbenzyl phthalate	<0.005	<0.0015	<0.0048
Cadmium	<0.005	<0.005	<0.005
Carbaryl			
Carbofuran			
Carbon tetrachloride	<0.001	<0.005	<0.001
Carboxin			
Chloramben			
Chlordane	<0.005	<0.005	<0.0005
Chloride	140	191	175
Chlorine	0.14	0.08	0.18
Chlorobenzene	<0.001	<0.005	<0.001
Chlorodibromomethane			
Chloroform	<0.001	<0.005	<0.001
Chloromethane	<0.001	<0.01	<0.001
Chloropyrifos			
Chromium	<0.01	<0.01	<0.005
Chromium VI	<0.005	<0.01	<0.01
cis-1,2-dichloroethene	<0.001	<0.005	<0.001
Cobalt			
Copper	0.009	<0.005	<0.01
Cyanide	<0.005	<0.005	0.0057
Dalapon			
DCPA (dacthal)			
Delta-BHC	<0.0005	<0.0005	<0.00005
demeton			
Diazinon			
Dibromochloropropane		<0.005	
Dicamba			
Dichlorobromomethane			
Dichlorodifluoromethane			
dichloropropene			
Dieldrin	<0.001	<0.001	<0.0001
Diethyl phthalate	<0.005	<0.002	<0.0048
diisopropyl methylphosphonate			
Dimethyl methylphosphonate			
Dimethyl phthalate	<0.005	<0.0016	<0.0048
Di-n-butyl phthalate	<0.005	<0.0021	<0.0048
Dinoseb			
Diphenamid			
Diphenylamine			
Diquat			
disulfaton			
Diuron			
E. coli			
Endothall			
Endrin	<0.001	<0.001	<0.0001
Endrin aldehyde	<0.001	<0.001	<0.0001
Ethylbenzene	<0.001	<0.005	<0.001
Ethylene dibromide			
Fenamiphos			
Fluometron			
Fluoranthene	<0.005	<0.0022	<0.0048

Pollutant	11/9/2017	8/28/2018	9/4/2019
Fluorene	<0.005	<0.0018	<0.0048
Fluoride	0.79	0.76	0.7
Fonofos			
Gamma-BHC	<0.0005	<0.0005	<0.00005
Glyphosate			
guthion			
Heptachlor	<0.0005	<0.0005	<0.00005
Heptachlor epoxide	<0.0005	<0.0005	<0.00005
Hexachlorobenzene	<0.005	<0.0014	<0.0048
Hexachlorobutadiene	<0.005	<0.0018	
Hexachlorocyclopentadiene	<0.004	<0.0051	<0.0048
Hexachloroethane	<0.005	<0.0021	<0.0048
Hexazinone			
Iron	0.54	0.09	<0.05
Isophorone	<0.005	<0.0018	<0.0048
Lead	<0.02	<0.005	<0.01
Malathion			
Maleic hydrazide			
Manganese			
MCPA			
Mercury	<0.0005	<0.0002	<0.02
Methoxychlor	<0.005	<0.005	<0.0005
Methyl parathion			
Methylene chloride	<0.001	<0.005	<0.001
Metolachlor			
Metribuzin			
Mirex			
Naphthalene	<0.005	<0.0019	<0.0048
Nickel	<0.01	<0.01	<0.005
Nitrate N	5.4	0.12	2.3
Nitrobenzene	<0.005	<0.0027	<0.0048
Nitroguanidine			
N-nitrosodimethylamine	<0.005	<0.00098	<0.0048
N-nitrosodi-n-propylamine	<0.005	<0.0024	<0.0048
N-nitrosodiphenylamine	<0.005	<0.0016	<0.0048
n-nitrosopyrrolidene			
Oil and Grease			
Oxamyl (vydate)			
Para(1,4)-dichlorobenzene			
Paraquat			
Parathion			
pentachlorobenzene			
Pentachlorophenol	<0.01	<0.005	<0.0048
Phenol	<0.005	<0.005	<0.0048
Picloram			
Pronamide			
Propachlor			
Propazine			
Propham			
Pyrene	<0.005	<0.00074	<0.0048
Selenium	<0.005	<0.005	<0.015
Silver	<0.005	<0.005	<0.007
Simazine			
Styrene			
Sulfate (SO4)	31.1	22.4	27
Tebuthiuron			
terbacil			
Terbufos			
Tetrachloroethene	<0.001	<0.005	<0.001
Thallium	<0.002	<0.002	<0.02
Toluene	<0.001	<0.005	<0.001
Toxaphene	<0.005	<0.005	<0.001
Trans-1,2-dichloroethene	<0.001	<0.02	<0.001
Trichloroethene	<0.001	<0.005	<0.001
Trichlorofluoromethane			<0.001
Trichlorofluoromethane			

Pollutant	11/9/2017	8/28/2018	9/4/2019
Trifluralin			
Trihalomethanes			
Trinitroglycerol			
Trinitrotoluene			
Vinyl Chloride	<0.001	<0.005	<0.001
Xylene (total)	<0.015		<0.001
Zinc		0.005	<0.05

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 09 November 2017


Sample No.: 2818 / Algal Lagoon Eff. PP, Composite, 11/9/17, 9:25am
Description:

TEST RESULTS:

Parameter:	2018	Units	Method
Biochemical Oxygen Demand	80	mg/l	5210 B
Total Suspended Solids	237	mg/l	2540D
Chemical Oxygen Demand	220	mg/l	5200B
Fluoride	0.79	mg/l	6214
Ammonia	0.8	mg/l	4500H-10B C
Kjeldahl Nitrogen	32.6	mg/l	4500H org
Nitrate Nitrogen	6.40	mg/l	3811B-4160
Nitrite Nitrogen	11.7	mg/l	4500H-10B C
Phosphorus, Total	6.70	mg/l	4500PBE
Sulfide	31.1	mg/l	5038
Total Hardness	488	mg/Ly CaCO ₃	2340 D
Calcium	141	mg/l	6030A
Magnesium	27.6	mg/l	6020A
Sodium	84.9	mg/l	6020A
Antimony	0.006	mg/l	6020A
Arsenic	0.009		6020A

Sample secured and delivered to laboratory by others

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
1 Clara Hansen
Hansen, Wilbur,
Kiefer
37513
Engineering Surveys & Services
BY: 
Derek J. Brester

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 09 November 2017

Sample No.: 2818 / Algal Lagoon Eff. PP, Composite, 11/9/17, 9:25 am
Description:

TEST RESULTS:

Parameter:	2018	Units	Method
Barium	<0.10	mg/l	6020A
Beryllium	<0.004	mg/l	6020A
Cadmium	<0.005	mg/l	6020A
Chromium	<0.010	mg/l	6020A
Copper	0.009	mg/l	6020A
Lead	<0.02	mg/l	6020A
Mercury	<0.0005	mg/l	6020A
Molybdenum	<0.10	mg/l	6020A
Nickel	<0.01	mg/l	6020A
Selenium	<0.005	mg/l	6020A
Silver	<0.005	mg/l	6020A
Thallium	<0.002	mg/l	6020A
Aluminum	0.252	mg/l	6020A
Iron	0.54	mg/l	6020A
Chromium, Trivalent	<0.010	mg/l	3050 Cr
Digestion	Yes		

Sample secured and delivered to laboratory by others

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
1 Clara Hansen
Hansen, Wilbur,
Kiefer
37513
Engineering Surveys & Services
BY: 
Derek J. Brester

**ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES**

Date: 12 December 2017
Lab Number: L7570

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 09 November 2017

Sample No.: 2818 / Algoa Lagoon Eff. PP, Composite 11/9/17, 9:25 am
Description:

TEST RESULTS:

Parameter:	2018	Units	Method
Chloride	140	mg/l	4500 C
Total Phosphate Compounds	<0.005*	mg/l	6539 B, D
Total Nitrogen	38.1	mg/l	
Pesticides & PCB	"	ug/l	EPA 8061
Semivolatile Organics	"	ug/l	EPA 821

Sample secured and delivered to laboratory by others
*Analysis by POC Laboratories

**See attached POC report

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
1 Clara Harshon
Hanson/Waters,
Kilmer
37012

Engineering Surveys & Services

BY:

DJ Broster
Derek J. Broster

**ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES**

Date: 12 December 2017
Lab Number: L7570

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 09 November 2017

Sample No.: 2819 / Algoa Lagoon Eff. PP, Grab, 11/9/17, 9:30 am
Description:

TEST RESULTS:

Parameter:	2819	Units	Detection	Method
Acidity	-262	mg CaCO ₃ /l	2510 B	
Alkalinity	274	mg CaCO ₃ /l	2510 B	
Conductivity	1,200	uS/cm@25°C	2510 B	
Chloride, Residual	0.14	mg/l	4500 C	
Grease & Oil	1.5	mg/l	EPA 8064	
Phosphate, Ortho	2.74	mg/l	4500 P	
Sulfide	<0.4	mg/l	5034	
Sulfate	<0.6	mg/l	4500 S	
Chromium, Hexavalent	<0.005	mg/l	3500 C	
Nitrite Nitrogen	0.204	mg/l	4500 N	
Cyanide	<0.005	mg/l	4500 C	
Volatile Organic Compounds	"	ug/l	EPA 824	
Carbon (TOC)	13*	mg/l	8000	

Sample secured and delivered to laboratory by others
**See attached POC report

*Analysis by POC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
1 Clara Harshon
Hanson/Waters,
Kilmer
37012

Engineering Surveys & Services

BY:

DJ Broster
Derek J. Broster

SAMPLE CHAIN OF CUSTODY RECORD

ENGINEERING SURVEYS & SERVICES
1113 Fay Street • Columbia, Missouri 65201 • (573) 449-2646
802 El Dorado Drive • Jefferson City, Missouri 65301 • (573) 636-3303
1175 W. Main Street • Sedalia, Missouri 65301 • (660) 826-8618

Sample ID	Date/Time Collected	Tests Requested	Sample Container	Preserv.	Comments
SN 2818	11/9/17 9:25 am	Total Phosphate Pesticides & PCB - 608 Semivolatile Organics - 605	250 ml a. 1800 a. 1800 a.	HCl None None	SN 2818
Effluent Composite	11/9/17 1:30 pm	Visible Organic Compound - 4450 Inorganic 2-Carex	2 vials 2 vials	HCl HCl	
SN 2819	11/9/17 9:30 am	TOC	2 vials	HCl	
Effluent Grab	11/9/17 9:30 am	Total Phosphate	500 ml	None	
SN 2820	11/9/17 9:30 am	Total Phosphate	500 ml	None	
Influent Composite	11/9/17 9:30 am	Surfactants	1000 p	None	
SN 2821	11/9/17 9:30 am	RTX	2 vials	HCl	
Influent Grab	11/9/17 9:30 am	(P.P. lists)			
		Report to MBL values			
		Please call with any questions			
		Thanks, Derek			
SN 2825	11/9/17 6:00 am	Total Volatile Acids	501 p	None	SN 2825
Anaerobic Grab	11/9/17 6:00 am				

Sample Collected By _____ Company/Organization **Engineering Surveys & Services**
Date/Time _____ Address **Columbia, MO**

Samples Relinquished By/Phone	Samples Received By	Date/Time
<i>DJ Broster</i>		9 NOV 17 2:19 pm

SAMPLE CHAIN OF CUSTODY RECORD
ENGINEERING SURVEYS & SERVICES
 1113 Fay Street • Columbia, Missouri 65201 • (573) 449-2646
 802 El Dorado Drive • Jefferson City, Missouri 65101 • (573) 435-3303
 1175 W. Main Street • Sedalia, Missouri 65201 • (660) 826-8618

711203-4

Sample ID	Date/Time Collected	Tests Requested	Sample Container	Preserv.	Comments
SN 2818	11/17/17	Total Phosphate Phosphate - P _T - 503	200 mL 1800 mL	H ₂ SO ₄ None	JN 7873
Effluent Composite	11/17/17	Sanitary Sewer Organic - 503	200 mL 1800 mL	H ₂ SO ₄ None	
SN 2819	11/17/17	Volatile Organic Compound - 819 (includes 4-comp)	2 vials 2 vials	None HCl	
Effluent Grab	11/17/17	TOC	2 vials	H ₂ SO ₄	
SN 2820	11/17/17	Total Phosphate	seen	None	
Influent Composite	11/17/17				
SN 2821	11/17/17	Surfactants	1600 p	None	
Influent Grab	11/17/17	BTEX	2 vials	HCl	
		(P.P. lists)			
		Report to ADEL Values			
		Please call with any questions			
		Thanks Derek			
SN 2825	11/17/17	Total Volatile Acids	500 p	None	JN 7845
Acidic Grab	11/17/17				

Sample Collected By: _____ Company/Organization: Engineering Surveys & Services

Date/Time: _____ Address: Columbia, MO

Sample Released By/Phone	Sample Received By	Date/Time
<u>DLB</u>		9/NOV/17 2:10pm

Page 8 of 9

ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES
 1113 Fay Street • Columbia, Missouri 65201 • (573) 449-2646
 802 El Dorado Drive • Jefferson City, Missouri 65101 • (573) 435-3303
 1175 West Main Street • Sedalia, Missouri 65201 • (660) 826-8618

Date: 12 December 2017
 Lab Number: L7570

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 09 November 2017

Sample No. / 2820 / Alga Lagoon, Semianual Influent Composite, 11/9/17, 9:05am
 Description:

TEST RESULTS:

Parameter:	2820	Units	Detection	Method
Kjeldahl Nitrogen	89.4	mg/L		4502H.09
Nitrate Nitrogen	0.02	mg/L		SM16-4.14D
Phosphorus, Total	9.68	mg/L		4500P.02
Ammonia	<0.006	mg/L		5020A
Asatec	<0.005	mg/L		5020A
Calcium	<0.005	mg/L		5020A
Copper	0.062	mg/L		5020A
Chromium	<0.010	mg/L		5020A
Lead	<0.02	mg/L		5020A
Mercury	<0.0005	mg/L		5020A
Molybdenum	<0.10	mg/L		5020A
Iron	0.50	mg/L		5020A
Manganese	0.057	mg/L		5020A
Nickel	<0.01	mg/L		5020A
Selenium	<0.005	mg/L		5020A
Silver	<0.005	mg/L		5020A

Sample secured and delivered to laboratory by others

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

EC: Community Development
 1. Clara Hanchen
 Hanchen/Wibers,
 Kiefer
 31045

Engineering Surveys & Services

BY:

DLB

Derek J. Broster

ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES
 1113 Fay Street • Columbia, Missouri 65201 • (573) 449-2646
 802 El Dorado Drive • Jefferson City, Missouri 65101 • (573) 435-3303
 1175 West Main Street • Sedalia, Missouri 65201 • (660) 826-8618

Date: 12 December 2017
 Lab Number: L7570

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 09 November 2017

Sample No. / 2820 / Alga Lagoon, Semianual Influent Composite, 11/9/17, 9:05am
 Description:

TEST RESULTS:

Parameter:	2820	Units	Detection	Method
Zinc	0.192	mg/L		6020A
Digestion	Yes			
Cyanide	<0.005	mg/L		4500C.02
Total Phosphate Compounds	0.649	mg/L		5020 B. D

Sample secured and delivered to laboratory by others
 * Analyzed by PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

EC: Community Development
 1. Clara Hanchen
 Hanchen/Wibers,
 Kiefer
 31045

Engineering Surveys & Services

BY:

DLB

Derek J. Broster



PDC Laboratories, Inc.
 2231 West Altona Drive
 Peoria, IL 61615
 (815) 752-6551

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

C14 - Laboratory, IL
 T18 Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100278
 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17258

PIA - Peoria, IL
 T18 Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100278
 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17258
 Wastewater Certifications: Arkansas (66-0677), Iowa (245), Kansas (E-10338)
 Hazardous Solid Waste Certifications: Arkansas (66-0677), Iowa (245), Kansas (E-10338)

SPMD - Springfield, MO
 USEPA DDT-QA Program

STL - St. Louis, MO
 T18 Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through STL Lab No. E-10339
 Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171250
 Drinking Water Certifications: Missouri (11020)
 Missouri Department of Natural Resources

* Not a T18 accredited analyte

Qualifiers


P6 Chemical preservation discrepancy noted at the time of analysis
 Q3 Matrix Spike/Matrix Spike Duplicate both failed to Recover

Certified by: Kurt Stepping, Senior Project Manager

Customer # 271321

www.pdc-lab.com

Page 7 of 8



ANALYTICAL RESULTS

Sample: 71131241				Sampled: 11/07/17 09:35		
Name: J03709 01-2318				Received: 11/07/17 10:20		
Matrix: Vapour Water - Composite						
Parameter	Result	Unit	Qualifier	Analysis1	Analysis2	Method
Acetone	< 5.0	µg/L		11/15/17 12:55	11/15/17 20:15	KAF EIA625
Benzene	< 5.0	µg/L		11/15/17 12:55	11/15/17 20:15	KAF EIA625
Fluorene	< 5.0	µg/L		11/15/17 12:55	11/15/17 20:15	KAF EIA625

Citation: 1 272322

www.ncbi.nlm.nih.gov

Page 4 of 9



November 27, 2017

Derek Bresler
Engineering Surveys & Services
1113 Fay Street
Columbia, MO 65201

Dear Derek Brewster:

Please find enclosed the analytical results for the sample(s) the laboratory received on 11/16/17 10:09 am and logged in under work order 7112043. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PNC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.


PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(305) 692-6689 x1719
ksteppling@pddlab.com



Page 1 of 9




ANALYTICAL RESULTS

[illegible]

Case # 226102

www.pdfclub.com

Page 2 of 9



ANALYTICAL RESULTS

[illegible]

Customer # 275332

www.pdcbt.com

Page 3 of 9



PDC Laboratories, Inc.
2231 West Alhoffer Drive
Peoria, IL 61615
(800) 752-6651

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

C18 - Pottery, IL
T18 Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100278
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17558

PA - Peoria, IL
T18 Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10333); Missouri (870)
Wastewater Certifications: Arkansas (B-6677); Iowa (240); Kansas (E-10333)
Hazardous Solid Waste Certifications: Arkansas (B-6677); Iowa (240); Kansas (E-10333)

EPL - Springfield, IL
NELAP/ILAC accreditation through the Illinois EPA, Lab No. 100333

SPAND - Springfield, MO
USEPA DWR/GA Program

ETL - St. Louis, MO
T18 Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10339
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Kansas (11055)
Missouri Department of Natural Resources

* Not a T18 accredited analysis

Qualifiers

HS - Headspace present
Po - Chemical preservation discrepancy noted at the time of analysis

Kurt Stepping

Certified by: Kurt Stepping, Senior Project Manager



Customer # 21312

www.pdc-lab.com

Page 7 of 8

ENGINEERING SURVEYS AND SERVICES TESTING LABORATORIES

1115 E. Street • Columbia, Missouri 65201 • (877) 442-2448
102 D. Connelley • Jefferson City, Missouri 65101 • (877) 442-2448
1715 West Main Street • Peoria, Missouri 61601 • (800) 752-6651

Date: 20 September 2018
Lab Number: L7570

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No. / 6540 / Annual Expanded Effluent (PE), Composite, 8/28/18, 8:30am
Description:

TEST RESULTS:

Parameter	6540	Units	Method
Iron	0.09	mg/l	6520A
Digestion	Yes		
Total Phenolic Compounds	++	mg/l	6520 B, D
Pesticides & PCB	++	ug/l	EPA 8261
Semi-volatile Organics	++	ug/l	EPA 8270

Sample secured and delivered to laboratory by others
** See attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise

CC: Community Development
email: Jenny

Engineering Surveys & Services

BY:

Derek J. Brester

Derek J. Brester

41479

ENGINEERING SURVEYS AND SERVICES TESTING LABORATORIES

1115 E. Street • Columbia, Missouri 65201 • (877) 442-2448
102 D. Connelley • Jefferson City, Missouri 65101 • (877) 442-2448
1715 West Main Street • Peoria, Missouri 61601 • (800) 752-6651

Date: 20 September 2018
Lab Number: L7570



PDC Laboratories, Inc.
2231 West Alhoffer Drive
Peoria, IL 61615
(800) 752-6651

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No. / 6541 / Annual Expanded Effluent (PE), Grab, 8/28/18, 8:40am
Description:

TEST RESULTS:

Parameter	6541	Units	Deflection	Method
Acidity	-294	mg CaCO3/l		2310 B
Alkalinity	314	mg CaCO3/l		2120 B
Chlorine, Residual	0.08	mg/l		4520-CI Q
Conductivity	1,270	umho/cm		2510 B
Sulfide	<0.4	mg/l		5034
Sulfate	<0.6	mg/l		4520-520-B
Phosphate, Ortho	3.37	mg/l		4520-51 E
Nitrite Nitrogen	0.028	mg/l		4520-420-B
Chromium, Hexavalent	<0.01*	mg/l		3500 Cr U
Grease & Oil	< 1.0	mg/l		EPA 8261
Cyanide	<0.005	mg/l		4520-CNCB
Ammonia	0.4	mg/l		4520-430-B
Carbon (TOC)	++	mg/l		8000
Carbon Organic Compound	++	ug/l		EPA 8260
Surfactants (NBAS)	++	mg/l		5540 C

Sample secured and delivered to laboratory by others
** See attached report from PDC Laboratories

* Higher detection limit due to sample interference

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

CC: Community Development
email: Jenny

Engineering Surveys & Services

BY:

Derek J. Brester

Derek J. Brester

41479

ANALYTICAL RESULTS

Sample: 6035400-03 Name: JH7570 EXP8542 Alias: INFLUENT COMPOSITE	Sampled: 08/28/18 00:00 Received: 08/28/18 09:10 Matrix: WASTE WATER - Composite						
Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
General Chemistry - PIA							
Phenolics	0.043	mg/L		08/28/18 12:09	08/28/18 12:09	ALB	EPA 829.4
Total Metals - PIA							
Mercury	< 0.00030	mg/L		08/28/18 12:42	08/28/18 14:31	TAT	EPA 821.1

Sample: 0035400-01	Sampled: 08/28/18 08:55
Name: JH7570 SWS540	Received: 08/28/18 09:10
Alias: INFLUENT GRAB	Matrix: Waste Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
General Chemistry - PIA							
Surfactants - VBA-S	0.57	mg/L		08/28/18 14:39	08/28/18 14:39	SAH	SW 5540C
Volatiles Organics - PIA							
Benzene	< 0.0	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824
Ethylbenzene	< 0.0	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824
m-Xylene	< 0.0	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824
p-Xylene	< 0.0	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824
Toluene	< 0.0	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824
Xylenes Total	< 1.5	ug/L		08/28/18 09:24	08/28/18 17:45	MAS	EPA 824

Customer # 21312

www.pdc-lab.com

Page 6 of 8

1113 Fay Street • Columbia, Missouri 65201 • (673) 443-2616
602 E. Drexel Drive • Jefferson City, Missouri 65101 • (573) 626-3302
1775 West Main Street • Sedalia, Missouri 65201 • (660) 828-6618

Date: 20 September 2018
Lab Number: L7570

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No. / 6540 / Annual Expanded Effluent (PEP) Composite, 6/28/18, 8:30am
Description :

TEST RESULTS:

Parameter:	8540	Units	Detection	Method
Biochemical Oxygen Demand	24	mg/l		5210 B
Total Suspended Solids	48	mg/l		2540 C
Chemical Oxygen Demand	49.8	mg/l		5220 B
Chloride	191	mg/l		4500 C
Sulfate	22.4	mg/l		9039
Fluoride	0.76	mg/l		9214
Kjeldahl Nitrogen	6.6	mg/l		4500-arg
Nitrate Nitrogen	0.12	mg/l		EM15-4110
Total Nitrogen	6.7	mg/l		
Organic Nitrogen	6.0	mg/l		4500-Norg C
Phosphorous, Total	6.01	mg/l		4500-P, B, E
Total Hardness	275	mg/l, CaCO ₃		2340 B
Calcium	64.7	mg/l		6020A
Magnesium	27.5	mg/l		6030A
Sodium	164	mg/l		6030A
Antimony	<0.006			200.8

* See attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

CC:	Community Development
-----	-----------------------

Engineering Surveys & Services

BY:

DLB

41437

Derek J. Brester

**ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES**

1113 Fay Street * Columbia, Missouri 65201 * (314) 448-2648
202 El Dorado Drive * Jefferson City, Missouri 65101 * (314) 626-3223
1775 West Main Street * Secula, Missouri 65065 * (314) 826-8513

Date: 20 September 2018
Lab Number: L7570

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No. / 8540 / Annual Expended Effluent (PP), Composto, 8/26/18, 830am
Description :

TEST RESULTS:

Parameter:	§540	Units	Method
Arsenic	<0.005	mg/l	200.8
Barium	<0.100	mg/l	200.5
Beryllium	<0.004	mg/l	200.8
Cadmium	<0.005	mg/l	200.8
Chromium	<0.010	mg/l	202.5
Chromium, Total	<0.010	mg/l	2100 Cr
Copper	<0.005	mg/l	200.5
Lead	<0.005	mg/l	200.5
Mercury	**	mg/l	
Molybdenum	0.019	mg/l	202.8
Nickel	<0.01	mg/l	200.8
Selenium	<0.005	mg/l	200.5
Silver	<0.005	mg/l	200.5
Thallium	<0.002	mg/l	200.8
Zinc	0.005	mg/l	200.5
Aluminum	<0.200	mg/l	200.8

**See attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: [Community](#) [Engineering Surveys & Services](#)

estuary study

BY:

Derak J. Broster

SAMPLE CHAIN OF CUSTODY RECORD

1113 Fay Street • Columbia, Missouri 65201 • (573) 449-2646
802 El Dorado Drive • Jefferson City, Missouri 65101 • (573) 636-3303
1175 W. Main Street • Sedalia, Missouri 65301 • (660) 826-8618

Sample ID	Date/Time Collected	Tests Requested	Sample Container	Preserv.	Comments
SN 8540	28 Aug 18	Total Phosalt Semi-volatile Organics - 685 Asphidies & PCBs - 608 Mercury - 245.1	500A 2-1000L 250p	H ₂ SO ₄ None HNO ₃	JN7570
Expanded Effluent Grab					
SN 8541	28 Aug 18	TOC (Total Organic Carbon) Volatile Organics - 624 (detected) Inhalant ZINC	2 vials 2 vials 2 vials	H ₂ SO ₄ HCl None	
Expanded Effluent Grab		Surfactants (MSAS)	1000p	None	
SN 8542	28 Aug 18	Total Phosalt Mercury - 245.1	500A 100p	H ₂ SO ₄ HNO ₃	
Influent Composite					
SN 8543	28 Aug 18	BTEX Surfactants	2 vials 1000p	HCl None	
Influent Grab					

Sample Collected By _____ Company/Organization Engineering Surveys & Mapping, Inc.

Date/Time _____ Address Columbia, MD

Samples Relinquished By/Phone	Samples Received By	Date/Time
-------------------------------	---------------------	-----------

<u>Dak B</u>	Date Time
	284-10-16

		25 May 18 1:15 pm

[illegible]

16/7/98

Page 8 of 8

COA 63



PDC Laboratories, Inc.
2231 West Alton Drive
Poncha, IL 61615
(800) 752-6651

ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES
1111 Fry Street • Columbia, Missouri 65201 • (573) 419-2648
602 E. Kansas Street • Jefferson City, Missouri 64501 • (573) 626-3333
1773 West Main Street • St. Louis, Missouri 63103 • (314) 676-6518

Date: 20 September 2018
Lab Number: L7570

ANALYTICAL RESULTS

Sample: 8542-02				Sampled: 08/28/18 08:40			
Name: JN47570 S148541				Received: 09/25/18 09:10			
Alias: EXPANDED EFFLUENT GRAB				Matrix: Waste Water - Grab			
Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
General Chemistry - PHS							
Surfactant - MLAS	<0.20	mg/L		06/25/18 14:29	09/25/18 14:29	SAH	EM 5513C
Total Organic Carbon (TOC)	12	mg/L		06/25/18 23:26	09/25/18 23:26	SAH	EM 5513C
Volatile Organics - PHS							
1,1,1-Trichloroethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,1,2-Trichloroethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,2-Dichloroethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,1-Dichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,2-Dichlorobenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,3-Dichlorobenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,4-Dichlorobenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
1,2-Dichlorobenzene - Total	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
2-Chlorobenzyl alcohol	<0.0	ug/L	MS, PC	09/04/18 05:30	09/04/18 12:14	MAH	EPA 824
Aroclor	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Aroclor	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Benzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Bromodichloromethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Bromobenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Bromochloromethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Carbon tetrachloride	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Chlorobenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Chloroform	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Chloromethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
cis-1,2-Dichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Dibromochloromethane	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Ethylbenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Methylene chloride	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Trichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Trichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
trans-1,2-Dichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Trichloroethene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824
Vinylbenzene	<0.0	ug/L		06/26/18 09:05	09/26/18 20:48	MAH	EPA 824

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No.: 8542 / Semiannual Influent Composite, 8/28/18, 8:50am
Description:

TEST RESULTS:

Parameter:	8542	Units	Detection	Method
Kjeldahl Nitrogen	50.4	mg/L		4500H org
Nitrate Nitrogen	0.30	mg/L		SM54-11ED
Total Nitrogen	50.7	mg/L		
Phosphorous, Total	11.6	mg/L		4500-P, B, E
Arsenic	<0.005	mg/L		200.8
Cadmium	<0.005	mg/L		200.8
Chromium	0.013	mg/L		200.8
Copper	0.110	mg/L		200.8
Lead	0.011	mg/L		200.8
Mercury	"	mg/L		
Molybdenum	0.022	mg/L		200.8
Iron	3.42	mg/L		6020A
Manganese	0.169	mg/L		200.8
Nickel	0.01	mg/L		200.8
Silver	<0.005	mg/L		200.8
Zinc	0.380	mg/L		200.8

Sample secured and delivered to laboratory by others
**See attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
email: Jerry

Engineering Surveys & Services

BY:

Derek J. Brester

41521

Page 5 of 8

ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES
1111 Fry Street • Columbia, Missouri 65201 • (573) 419-2648
602 E. Kansas Street • Jefferson City, Missouri 64501 • (573) 626-3333
1773 West Main Street • St. Louis, Missouri 63103 • (314) 676-6518

Date: 20 September 2018
Lab Number: L7570



PDC Laboratories, Inc.
2231 West Alton Drive
Poncha, IL 61615
(800) 752-6651

Project: City of Jefferson

Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No.: 8542 / Semiannual Influent Composite, 8/28/18, 8:50am
Description:

ANALYTICAL RESULTS

Sample: 855480-01				Sampled: 08/28/18 08:00			
Name: JN47570 S148540				Received: 09/28/18 09:10			
Alias: EXPANDED EFFLUENT COMP				Matrix: Waste Water - Composite			
Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Phenol	<4.2	ug/L		06/27/18 08:49	09/24/18 22:29	KAT	EPA 824
Pinene	<0.74	ug/L		06/27/18 08:49	09/24/18 22:29	KAT	EPA 824
Total Metals - PHS							
Mercury	<0.0020	mg/L		09/04/18 12:42	09/04/18 16:19	TAT	EPA 245.1

TEST RESULTS:

Parameter:	8542	Units	Method
Digestion	Yes		
Total Phenolic Compounds	"	mg/L	5510 B, D

Sample secured and delivered to laboratory by others
**See attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
email: Jerry

Engineering Surveys & Services

BY:

Derek J. Brester

41522

Customer # 271322

www.pdc-lab.com

Page 4 of 8

ANALYTICAL RESULTS

[illegible]

CAUTION # 27532

www.pdclab.com

Page 3 of 8

**ENGINEERING SURVEYS AND SERVICES
TESTING LABORATORIES**

1113 Fay Street * Columbia, Missouri 65201 * (314) 443-2645
202 E Dorado Oaks * Jefferson City, Missouri 65101 * (314) 636-3032
1775 West Main Street * Sedalia, Missouri 65201 * (816) 820-8618

Date: 20 September 2018
Lab Number: L7570

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 28 August 2018

Sample No. / 0543 / Sewerweld Influent Grab, 8/28/18, 8:55am
Description :

TEST RESULTS:

Parameter:	6543	Units	Detection	Method
Ammonia	12.9	mg/l		4500-NDH
Nitrate Nitrogen	<0.005	mg/l		4500-NO ₃ -H
Gases & Oil	42.9	mg/l		8245-MS4
Cyanide	<0.005	mg/l		4500-CNCE
Surfactants (MTAS)	**	mg/l		6549 G
BTEX	**	ug/l		

^aSee attached report from PDC Laboratories

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
email Jenny

Engineering Surveys & Services

BY:

Derek J. Brester

41573



PDC Laboratories, Inc.
PROFESSIONAL • DEPENDABLE • COMMITTED

PROFESSIONAL • DEPENDABLE • COMMITTED

September 17, 2018

Derak Brestac
Engineering Surveys & Services
1113 Fay Street
Columbia, MO 65201

Dear Derek Bester,

Please find enclosed the analytical results for the sample(s) the laboratory received on 8/29/18 9:10 am and logged in under work order 8085480. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-6635 x1719
kstepping@pddlab.com



Page 1 of 8



ANALYTICAL RESULTS

Sample: 833459-01				Sample: 832618-00			
Name: 24757015450				Received: 06/26/18 09:10			
Alias: EXPANDED EFFLUENT COMP				Matrix: VIALA VIALA - Composite			
Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Basic Chemistry - PA							
Phospha	< 0.000	mg/L		05/31/18 12:01	05/31/18 12:08	ALS	EPA 8210
Pesticides - PA							
4-AcetD	< 1.0	ug/L		06/05/18 13:53	06/10/18 13:33	ELS	EPA 821
4-AcetE	< 1.0	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
4-AcetT	< 1.0	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
AdR	< 0.0	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
AdR-B	< 0.0	ug/L		06/05/18 13:59	06/10/18 13:33	ELS	EPA 821
AtrazD 1018	< 0.5	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
AtrazD 1221	< 1.0	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
AtrazD 1232	< 0.5	ug/L		06/05/18 13:53	06/10/18 13:33	ELS	EPA 821
AtrazD 1248	< 0.5	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
AtrazD 1254	< 1.0	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
AtrazD 1259	< 1.0	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
AtrazD - total	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Dea-BE	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
ChlorDex (hydrox)	< 0.5	ug/L		06/10/18 13:58	06/10/18 13:33	ELS	EPA 821
Dea-BH	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
DeMet	< 1.0	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
Endosulfan I	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Endosulfan II	< 1.0	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Endosulfan sulfate	< 1.0	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Etofen	< 1.0	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
Fenitrothion	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Gamma-BHC (BHC)	< 0.5	ug/L		06/05/18 13:55	06/10/18 13:33	ELS	EPA 821
Heptachlor	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Heptachlor epoxide	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Hexachlor	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Toxaphene	< 0.5	ug/L		06/05/18 13:58	06/10/18 13:33	ELS	EPA 821
Estrogenlike Organics - PA							
1,2,4-Triol-steroids	< 1.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
1,2-Diarylhydrazides	< 2.5	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,3,7,8-TCDF Steroid	< 0.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,3,8-Trihydroxy Steroid	< 4.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,4-Dichlorophenol	< 1.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,4-Dichlorophenyl	< 0.5	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,4-Dichlorophenol	< 5.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,4-Dichlorophenol	< 1.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2,4-Dichlorophenol	< 2.5	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821
2-Chlorophenylhydrazide	< 1.0	ug/L		06/10/18 08:45	06/10/18 22:09	PAF	EPA 821

Contract # 276212

www.odclub.com

Page 2 of 9



Pace Analytical Services, LLC
9628 Laurel Blvd
Lancaster, PA 17602-19
(717) 569-5005



Pace Analytical Services, LLC
9628 Laurel Blvd
Lancaster, PA 17602-19
(717) 569-5005

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 410.4	609168	EPA 410.4	609620
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 420.1	607735	EPA 420.1	607842
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 4500-CH-E	608013	SM 4500-CH-E	608211
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 5310C	609458		
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 7106	607529		

SAMPLE SUMMARY

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Lab ID	Sample ID	Matrix	Date Collected	Date Received
60313697001	ALGOA LAGOON EFF MONLY COMP	Water	09/04/19 11:27	09/05/19 06:30
60313697002	ALGOA LAGOON EFF MONLY GRAB	Water	09/04/19 11:35	09/05/19 06:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 46 of 48

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Page 3 of 48



Pace Analytical Services, LLC
9628 Laurel Blvd
Lancaster, PA 17602-19
(717) 569-5005



Pace Analytical Services, LLC
9628 Laurel Blvd
Lancaster, PA 17602-19
(717) 569-5005

SAMPLE ANALYTE COUNT

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Lab ID	Sample ID	Method	Analyst	Analytes Reported	Laboratory
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 808.3	KAV	8	PA31-I
		EPA 808.3	KAV	23	PA31-I
		EPA 200.7	JOE	20	PA31-K
		EPA 245.1	HMC	1	PA31-K
		EPA 625	JBT	60	PA31-K
		TKN-HNO ₃ Calculation	LDB	1	PA31-K
		TKN-HNO ₃ Calculation	LDB	1	PA31-K
		TKN-HNO ₃ Calculation	LDB	1	PA31-K
		EPA 300.0	MGS	3	PA31-K
		EPA 351.2	AJS	1	PA31-K
		EPA 353.2	AJS	3	PA31-K
		EPA 365.4	JWR	1	PA31-K
		EPA 410.4	MAP	1	PA31-K
		EPA 420.1	CNB	1	PA31-K
		EPA 7106	LDB	1	PA31-K
		EPA 824 Low	EAG	39	PA31-K
		EPA 120.1	AJS2	1	PA31-K
		EPA 1064A	JDA	1	PA31-K
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 2310B	LDB	1	PA31-K
		SM 2320B	LDB	2	PA31-K
		SM 4500-C1-G	MAP	1	PA31-K
		SM 4500-S-2-D	MAP	1	PA31-K
		SM 4500-S-2-B	MGS	1	PA31-K
		SM 5540C	MAP	1	PA31-K
		EPA 365.1	LDB	1	PA31-K
		SM 4500-CH-E	CNS	1	PA31-K
		SM 5310C	LDB	1	PA31-K

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Page 4 of 48

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 808.3	520708	EPA 808.3	520601
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 808.3	520708	EPA 808.3	520602
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 200.7	608761	EPA 200.7	608794
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 245.1	607768	EPA 245.1	607775
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 625	607510	EPA 625	607840
60313697002	ALGOA LAGOON EFF MONLY GRAB	EPA 824 Low	608279		
60313697002	ALGOA LAGOON EFF MONLY GRAB	EPA 120.1	610486		
60313697002	ALGOA LAGOON EFF MONLY GRAB	EPA 1664A	609110		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 2310B	609727		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 2320B	608485		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 4500-C1-G	606087		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 4500-S-2-D	606089		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 4500-S-2-B	609431		
60313697002	ALGOA LAGOON EFF MONLY GRAB	SM 5540C	607549	SM 5540C	608237
60313697001	ALGOA LAGOON EFF MONLY COMP	TKN-HNO ₃ -NO ₂ Calculation	610545		
60313697001	ALGOA LAGOON EFF MONLY COMP	TKN-HNO ₃ Calculation	610560		
60313697001	ALGOA LAGOON EFF MONLY COMP	TKN-HNO ₃ Calculation	610562		
60313697001	ALGOA LAGOON EFF MONLY COMP	TKN-HNO ₃ Calculation	609006		
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 351.2	609504	EPA 351.2	609907
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 353.2	607555		
60313697002	ALGOA LAGOON EFF MONLY GRAB	EPA 365.1	607737		
60313697001	ALGOA LAGOON EFF MONLY COMP	EPA 365.4	609744	EPA 365.4	610130

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 45 of 48



Pace Analytical Services, LLC
9008 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALIFIERS

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313597

DEFINITIONS

- DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.
ND - Not Detected at or above adjusted reporting limit.
TNTC - Too Numerous To Count.
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.
MDL - Adjusted Method Detection Limit.
POL - Practical Quantitation Limit.
RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.
S - Surrogate.
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.
Consistent with EPA guidelines, unrounded data have been used to calculate % recovery and RPD values.
LCS(D) - Laboratory Control Sample (Duplicate).
MS(D) - Matrix Spike (Duplicate).
DUP - Sample Duplicate.
RPD - Relative Percent Difference.
NC - Not Calculable.
SG - Spike Gel - Clean-Up.
U - Indicates the compound was analyzed for, but not detected.
N-Halodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Pace Analytical is TML accredited. Contact your Pace PM for the current list of accredited analytes.
THI - The NELAP Institute.

LABORATORIES

PAS4 Pace Analytical Services - Indianapolis
PAS4K Pace Analytical Services - Kansas City

ANALYTE QUALIFIERS

- D3 Sample was diluted due to the presence of high levels of non-target analytes or other matrix interference.
D6 The precision between the sample and sample duplicate exceeded laboratory control limits.
E Analyte concentration exceeded the calibration range. The reported result is estimated.
H6 Analysis initiated outside of the 15 minute EPA required holding time.
H7 Re-extraction or re-analysis could not be performed within method holding time.
L2 Analyte recovery in the laboratory control sample (LCS) was below QC limits. Results for this analyte in associated samples may be biased low.
M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.
N2 The lab does not hold NELAP accreditation for this parameter but other accreditation/certifications may apply. A complete list of accreditation/certifications is available upon request.
R1 RPD value was outside control limits.
S0 Surrogate recovery outside laboratory control limits.
GJ MBAS, calculated as LAS, Met wt 342.2 g/mol.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 44 of 48



Pace Analytical Services, LLC
9008 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

ANALYTICAL RESULTS

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313597

Sample: ALGOA LAGOON EFF
MORTUITY COMP Lab ID: 60313597001 Collected: 09/04/19 11:27 Received: 09/05/19 06:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
608.3 PCB									
Analytical Method: EPA 808.3 Preparation Method: EPA 808.3									
PCB-1018 (Aroclor 1018)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	12874-11-2	
PCB-1221 (Aroclor 1221)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	11104-28-2	
PCB-1232 (Aroclor 1232)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	11141-16-5	
PCB-1242 (Aroclor 1242)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	53469-21-9	
PCB-1249 (Aroclor 1249)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	12872-29-0	
PCB-1254 (Aroclor 1254)	ND	ug/L	0.10	0.035	1	09/10/19 08:18	09/11/19 16:55	11007-69-1	
PCB-1260 (Aroclor 1260)	ND	ug/L	0.10	0.031	1	09/10/19 08:18	09/11/19 16:55	11008-82-5	
Surrogate Tetrachlorobiphenyl (S)	69	%	14-132	1	09/10/19 08:18	09/11/19 16:55	837-09-8		
608.3 Pesticides									
Analytical Method: EPA 808.3 Preparation Method: EPA 808.3									
Azin	ND	ug/L	0.050	0.012	1	09/10/19 08:18	09/11/19 21:08	309-00-2	H7, L2
alpha-BHC	ND	ug/L	0.050	0.009	1	09/10/19 08:18	09/11/19 21:08	318-84-6	
beta-BHC	ND	ug/L	0.050	0.009	1	09/10/19 08:18	09/11/19 21:08	318-85-7	
delta-BHC	ND	ug/L	0.050	0.017	1	09/10/19 08:18	09/11/19 21:08	318-86-8	
gamma-BHC (lindane)	ND	ug/L	0.050	0.004	1	09/10/19 08:18	09/11/19 21:08	58-83-9	
Chlorfenvinphos (Technical)	ND	ug/L	0.50	0.38	1	09/10/19 08:18	09/11/19 21:08	57-74-9	
alpha-Chlorotolene	ND	ug/L	0.050	0.001	1	09/10/19 08:18	09/11/19 21:08	5103-71-9	N2
gamma-Chlorotolene	ND	ug/L	0.050	0.005	1	09/10/19 08:18	09/11/19 21:08	5103-74-2	N2
4,4'-DDE	ND	ug/L	0.10	0.012	1	09/10/19 08:18	09/11/19 21:08	72-55-8	
4,4'-DDT	ND	ug/L	0.10	0.059	1	09/10/19 08:18	09/11/19 21:08	50-29-3	
Dieldrin	ND	ug/L	0.10	0.006	1	09/10/19 08:18	09/11/19 21:08	60-57-1	
Endosulfan I	ND	ug/L	0.050	0.011	1	09/10/19 08:18	09/11/19 21:08	559-84-8	
Endosulfan II	ND	ug/L	0.10	0.012	1	09/10/19 08:18	09/11/19 21:08	33213-85-9	
Endosulfan sulfate	ND	ug/L	0.10	0.014	1	09/10/19 08:18	09/11/19 21:08	1031-07-6	
Enzin	ND	ug/L	0.10	0.018	1	09/10/19 08:18	09/11/19 21:08	72-20-8	
Enzin methylester	ND	ug/L	0.10	0.018	1	09/10/19 08:18	09/11/19 21:08	7421-93-4	
Enzin ketone	ND	ug/L	0.10	0.019	1	09/10/19 08:18	09/11/19 21:08	53484-70-5	N2
Heptachlor	ND	ug/L	0.050	0.008	1	09/10/19 08:18	09/11/19 21:08	76-44-8	
Heptachlor epoxide	ND	ug/L	0.050	0.007	1	09/10/19 08:18	09/11/19 21:08	1024-57-3	
Methoxychlor	ND	ug/L	0.50	0.17	1	09/10/19 08:18	09/11/19 21:08	72-43-5	
Toxaphene	ND	ug/L	1.0	0.063	1	09/10/19 08:18	09/11/19 21:08	6001-33-2	
Surrogate Dichlorobiphenyl (S)	50	%	18-118	1	09/10/19 08:18	09/11/19 21:08	2051-24-3		
Detect Metals, Total									
Analytical Method: EPA 200.7 Preparation Method: EPA 200.7									
Aluminum	ND	ug/L	75.0	3.0	1	09/11/19 15:44	09/12/19 12:15	7429-90-8	
Antimony	ND	ug/L	15.0	0.5	1	09/11/19 15:44	09/12/19 12:15	7440-36-0	
Arsenic	ND	ug/L	15.0	0.1	1	09/11/19 15:44	09/12/19 12:15	7440-33-2	
Barium	74.9	ug/L	5.0	1.4	1	09/11/19 15:44	09/12/19 12:15	7440-39-3	
Beryllium	ND	ug/L	1.0	0.25	1	09/11/19 15:44	09/12/19 12:15	7440-41-7	
Calcium	ND	ug/L	5.0	0.56	1	09/11/19 15:44	09/12/19 12:15	7440-49-9	
Cadmium	ND	ug/L	200	5.0	1	09/11/19 15:44	09/12/19 12:15	7440-70-2	
Chromium	ND	ug/L	5.0	1.0	1	09/11/19 15:44	09/12/19 12:15	7440-47-3	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 45 of 48



Pace Analytical Services, LLC
9008 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

ANALYTICAL RESULTS

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313597

Sample: ALGOA LAGOON EFF
MORTUITY COMP Lab ID: 60313597001 Collected: 09/04/19 11:27 Received: 09/05/19 06:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
208.1 Metals, Total									
Analytical Method: EPA 200.7 Preparation Method: EPA 200.7									
Copper	ND	ug/L	10.0	3.4	1	09/11/19 15:44	09/12/19 12:15	7440-50-8	
Iron	ND	ug/L	50.0	14.0	1	09/11/19 15:44	09/12/19 12:15	7439-89-6	
Lead	ND	ug/L	10.0	3.4	1	09/11/19 15:44	09/12/19 12:15	7439-92-1	
Magnesium	247.60	ug/L	50.0	13.0	1	09/11/19 15:44	09/12/19 12:15	7439-95-4	
Molybdenum	69.1	ug/L	20.0	2.8	1	09/11/19 15:44	09/12/19 12:15	7439-98-7	
Nickel	ND	ug/L	5.0	1.2	1	09/11/19 15:44	09/12/19 12:15	7440-02-0	
Selenium	ND	ug/L	15.0	0.6	0	09/11/19 15:44	09/12/19 12:15	7782-49-2	
Silver	ND	ug/L	7.0	1.8	1	09/11/19 15:44	09/12/19 12:15	7440-22-4	
Sodium	121600	ug/L	500	144	1	09/11/19 15:44	09/12/19 12:15	7440-23-5	M1
Thallium	ND	ug/L	20.0	3.4	1	09/11/19 15:44	09/12/19 12:15	7440-28-0	
Vanadium, Total (DM 234-06)	216.00	ug/L	500	187	1	09/11/19 15:44	09/12/19 12:15		
Zinc	ND	ug/L	50.0	0.1	1	09/11/19 15:44	09/12/19 12:15	7440-06-6	
215.1 Mercury									
Analytical Method: EPA 245.1 Preparation Method: EPA 245.1									
Mercury	ND	ug/L	0.20	0.068	1	09/08/19 09:55	09/09/19 18:11	7439-97-8	
625 MSNV									
Analytical Method: EPA 825 Preparation Method: EPA 825									
Acephenanthrene	ND	ug/L	4.8	0.63	1	09/05/19 17:08	09/06/19 23:19	85-32-9	
Acenaphthylene	ND	ug/L	4.8	0.63	1	09/05/19 17:08	09/06/19 23:19	208-95-8	
Anthracene	ND	ug/L	4.8	0.65	1	09/05/19 17:08	09/06/19 23:19	120-12-7	
Benzo(a)anthracene	ND	ug/L	4.8	0.5	1	09/05/19 17:08	09/06/19 23:19	91-84-1	
Benzo(a)fluoranthene	ND	ug/L	4.8	0.66	1	09/05/19 17:08	09/06/19 23:19	56-55-3	
Benzo(b)fluoranthene	ND	ug/L	4.8	0.70	1	09/05/19 17:08	09/06/19 23:19	50-32-8	
Benzo(k)fluoranthene	ND	ug/L	4.8	0.89	1	09/05/19 17:08	09/06/19 23:19	205-99-2	
Benzo(g,h,i)perylene	ND	ug/L	4.8	0.87	1	09/05/19 17:08	09/06/19 23:19	191-26-2	
Benzo(a)pyrene	ND	ug/L	4.8	0.93	1	09/05/19 17:08	09/06/19 23:19	201-08-9	
4-Bromophenylphenyl ether	ND	ug/L	4.8	0.69	1	09/05/19 17:08	09/06/19 23:19	191-55-3	
4-Bromophenylphenyl ether	ND	ug/L	4.8	0.62	1	09/05/19 17:08	09/06/19 23:19	8548-7-7	
4-Chloro-3-methylphenol	ND	ug/L	4.8	0.74	1	09/05/19 17:08	09/06/19 23:19	59-50-7	
2-Chloroethoxyphenol	ND	ug/L	4.8	0.85	1	09/05/19 17:08	09/06/19 23:19	111-61-1	
2,4-Dichlorophenyl ether	ND	ug/L	4.8	0.73	1	09/05/19 17:08	09/06/19 23:19	111-44-4	
2,4-Dichlorophenyl ether	ND	ug/L	4.8	0.68	1	09/05/19 17:08	09/06/19 23:19	109-60-1	
2-Chloronaphthalene	ND	ug/L	4.8	0.77	1	09/05/19 17:08	09/06/19 23:19	91-58-7	
2-Chlorophenol	ND	ug/L	4.8	0.72	1	09/05/19 17:08	09/06/19 23:19	95-57-8	
4-Chlorophenylphenyl ether	ND	ug/L	4.8	0.79	1	09/05/19 17:08	09/06/19 23:19	7005-70-3	
Chrysene	ND	ug/L	4.8	0.70	1	09/05/19 17:08	09/06/19 23:19	218-01-9	
Dibenz(a,h)anthracene	ND	ug/L	4.8	0.71	1	09/05/19 17:08	09/06/19 23:19	53-70-3	
3,3'-Dichlorodiphenyl ether	ND	ug/L	4.8	0.72	1	09/05/19 17:08	09/06/19 23:19	91-84-1	
2,4-Dichlorophenol	ND	ug/L	4.8	0.65	1	09/05/19 17:08	09/06/19 23:19	120-83-2	
Dibenzophenone	ND	ug/L	4.8	0.63	1	09/05/19 17:08	09/06/19 23:19	84-56-2	
2,4-Dimethylphenol	ND	ug/L	4.8	0.65	1	09/05/19 17:08	09/06/19 23:19	105-87-9	
Dimethylphenol	ND	ug/L	4.8	0.60	1	09/05/19 17:08	09/06/19 23:19	131-11-3	
Dim-bisphenol	ND	ug/L	4.8	0.57	1	09/05/19 17:08	09/06/19 23:19	84-74-2	
4-Dehydro-2-methylphenol	ND	ug/L	23.0	0.78	1	09/05/19 17:08	09/06/19 23:19	534-52-1	
2,4-Dinitrophenol	ND	ug/L	47.0	0.97	1	09/05/19 17:08	09/06/19 23:19	51-28-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 46 of 48



Pace Analytical Services, LLC
9008 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALITY CONTROL DATA

</



Pace Analytical Services, LLC
9608 Lorel Blvd
Lima, PA 19019
(913) 659-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 603158
QC Batch Method: SM 5310C
Associated Lab Samples: 60313697002

Metic Water						
Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Total Organic Carbon	mg/L	ND	1.0	0.20	09/19/19 02.13	

LABORATORY CONTROL SAMPLE: 2480103						
Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Total Organic Carbon	mg/L	5	5.5	110	80-120	

Results presented on this page are in the units indicated by the "Units" column, except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

Date: 09/26/2019 02:10 PM

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC

Page 42 of 48



Pace Analytical Services, LLC
9608 Lorel Blvd
Lima, PA 19019
(913) 659-5665

ANALYTICAL RESULTS

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Sample: ALGOL LAGOON EFF
MONTLY COMP

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
Analytical Method: EPA 825 Preparation Method: EPA 825									
2,4-Dichlorobenzene	ND	ug/L	5.7	0.58	1	09/05/19 17:08	09/06/19 23:19	121-14-2	
2,6-Dichlorobenzene	ND	ug/L	4.6	0.61	1	09/05/19 17:08	09/06/19 23:19	805-20-2	
Di-n-butylphthalate	ND	ug/L	4.6	0.92	1	09/05/19 17:08	09/06/19 23:19	117-84-0	
1,2-Dichloroethane	ND	ug/L	7.6	0.57	1	09/05/19 17:08	09/06/19 23:19	122-66-7	
Is(2-Ethylhexyl)phthalate	ND	ug/L	4.6	0.95	1	09/05/19 17:08	09/06/19 23:19	117-81-7	
Fluoranthene	ND	ug/L	4.6	0.72	1	09/05/19 17:08	09/06/19 23:19	208-44-0	
Phenanthrene	ND	ug/L	4.6	0.59	1	09/05/19 17:08	09/06/19 23:19	80-73-7	
Heachchar-1,3-butadiene	ND	ug/L	4.6	0.77	1	09/05/19 17:08	09/06/19 23:19	87-69-3	
Heachchlorobenzene	ND	ug/L	4.6	0.60	1	09/05/19 17:08	09/06/19 23:19	118-74-1	
Heachchlorocyclopentadiene	ND	ug/L	4.6	0.83	1	09/05/19 17:08	09/06/19 23:19	77-47-4	
Heachchlorobenzene	ND	ug/L	4.6	0.70	1	09/05/19 17:08	09/06/19 23:19	67-72-1	
Indeno(1,2,3-cd)pyrene	ND	ug/L	4.6	0.64	1	09/05/19 17:08	09/06/19 23:19	193-39-5	
Isophthalene	ND	ug/L	4.6	0.51	1	09/05/19 17:08	09/06/19 23:19	78-58-1	
Naphthalene	ND	ug/L	4.6	0.65	1	09/05/19 17:08	09/06/19 23:19	91-20-3	
Methylbenzene	ND	ug/L	4.6	0.49	1	09/05/19 17:08	09/06/19 23:19	69-65-3	
2-Nitrophenol	ND	ug/L	4.6	0.68	1	09/05/19 17:08	09/06/19 23:19	50-75-5	
4-Nitrophenol	ND	ug/L	4.6	2.4	1	09/05/19 17:08	09/06/19 23:19	100-02-7	
N-Hydroxymethylamine	ND	ug/L	4.6	0.78	1	09/05/19 17:08	09/06/19 23:19	62-75-9	
N-Hydroxymethylamine	ND	ug/L	4.6	0.62	1	09/05/19 17:08	09/06/19 23:19	621-64-7	
N-Hydroxyphenylamine	ND	ug/L	4.6	0.36	1	09/05/19 17:08	09/06/19 23:19	56-30-6	
Pentachlorophenol	ND	ug/L	4.6	0.73	1	09/05/19 17:08	09/06/19 23:19	87-86-5	
Phenanthrene	ND	ug/L	4.6	0.64	1	09/05/19 17:08	09/06/19 23:19	85-01-6	
Phenol	ND	ug/L	4.6	2.4	1	09/05/19 17:08	09/06/19 23:19	108-95-2	
Pyrene	ND	ug/L	4.6	0.65	1	09/05/19 17:08	09/06/19 23:19	129-00-0	
1,2,4-Trichlorobenzene	ND	ug/L	4.6	0.83	1	09/05/19 17:08	09/06/19 23:19	120-82-1	
2,4,6-Trichlorophenol	ND	ug/L	4.6	0.74	1	09/05/19 17:08	09/06/19 23:19	88-04-2	
Sulfonates	0	%	24-128	1	09/05/19 17:08	09/06/19 23:19	118-79-6	D3.50	
2,4,6-Trichlorophenol (S)	0	%	24-110	1	09/05/19 17:08	09/06/19 23:19	321-66-8	50	
2-Fluorophenyl (S)	0	%	20-59	1	09/05/19 17:08	09/06/19 23:19	307-12-4	50	
2-Fluorophenyl (S)	0	%	24-110	1	09/05/19 17:08	09/06/19 23:19	4165-80-0	60	
Phenol (S)	0	%	11-42	1	09/05/19 17:08	09/06/19 23:19	13127-89-3	50	
Terpene-414 (S)	0	%	35-118	1	09/05/19 17:08	09/06/19 23:19	1718-51-0	50	
Analytical Method: TOX-HNO3-HNO2 Calculation									
Total Nitrogen Calculation	8.1	mg/L	0.10	1		09/18/19 15:52	7727-37.9		
Analytical Method: TOX-HNO3 Calculation									
Total Organic Nitrogen Calc.	6.1	mg/L	0.50	0.50	1		09/18/19 18:02		
Analytical Method: Trivalent Chromium Calculation									
Trivalent Chromium Calculation	ND	mg/L	0.010	0.010	1		09/18/19 18:04	15065-83-1	
Analytical Method: EPA 300.0									
300.5 IC Aqueous 28 Days	175	mg/L	10.0	2.2	10		09/12/19 22:01	15587-00-6	RII

REPORT OF LABORATORY ANALYSIS

Date: 09/26/2019 02:10 PM

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC

Page 7 of 48



Pace Analytical Services, LLC
9608 Lorel Blvd
Lima, PA 19019
(913) 659-5665

ANALYTICAL RESULTS

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Sample: ALGOL LAGOON EFF
MONTLY COMP

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
Analytical Method: EPA 300.0									
300.5 IC Aqueous 28 Days									
Fluoride	0.70	mg/L	0.20	0.085	1		09/12/19 21:31	19964-48-8	
Sulfate	27.0	mg/L	10.0	2.3	10		09/12/19 22:01	14503-79-8	
Analytical Method: EPA 351.2 Preparation Method: EPA 351.2									
351.2 Total Kjeldahl Nitrogen									
Nitrogen, Kjeldahl, Total	5.6	mg/L	0.50	0.37	1	09/16/19 09:03	09/17/19 10:00	7727-37-9	
Analytical Method: EPA 353.2									
353.2 Nitrogen, NO3/NO2 unspike									
Nitrogen, NO2 plus NO3	2.6	mg/L	0.10	0.036	1		09/05/19 12:33		
Nitrogen, Nitrate	2.3	mg/L	0.10	0.087	1		09/05/19 12:33	14787-55-8	
Nitrogen, Nitrate	0.23	mg/L	0.10	0.087	1		09/05/19 12:33	14787-65-0	
Analytical Method: EPA 365.4 Preparation Method: EPA 365.4									
365.4 Total Phosphorus									
Phosphorus	3.4	mg/L	0.10	0.044	1	09/17/19 10:00	09/18/19 10:01	7723-14-0	
Analytical Method: EPA 410.4 Preparation Method: EPA 410.4									
410.4 COD									
Chemical Oxygen Demand	88.8	mg/L	10.0	3.7	1	09/13/19 11:12	09/16/19 08:40		
Analytical Method: EPA 420.1 Preparation Method: EPA 420.1									
Phenolics, Total Recoverable	ND	mg/L	0.050	0.016	1	09/08/19 10:45	09/08/19 15:58	64743-03-9	
Phenolics, Total Recoverable	ND	mg/L	0.050	0.016	1	09/08/19 10:45	09/08/19 15:58	64743-03-9	
Analytical Method: EPA 7199									
7199 Chromium, Hexavalent	ND	mg/L	0.010	0.0031	1		09/05/19 10:21	18540-29-9	
Analytical Method: EPA 350.1									
Chromium, Hexavalent	0.47	mg/L	0.10	0.078	1		09/18/19 15:14	7064-41-7	

Sample: ALGOL LAGOON EFF MONTLY GRAB									
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual

Analytical Method: EPA 824 Low									
624 Volatile Organics									
Acrolein	ND	ug/L	190	2.0	1		09/10/19 14:44	107-02-8	
Acrylonitrile	ND	ug/L	20.0	1.6	1		09/10/19 14:44	107-13-1	
Benzene	ND	ug/L	1.0	0.12	1		09/10/19 14:44	71-43-2	
Bromochloromethane	ND	ug/L	1.0	0.13	1		09/10/19 14:44	75-27-4	
Bromobenzene	ND	ug/L	1.0	0.11	1		09/10/19 14:44	75-25-2	
Bromomethane	ND	ug/L	9.0	0.86	1		09/10/19 14:44	74-83-9	
Carbon tetrachloride	ND	ug/L	1.0	0.10	1		09/10/19 14:44	56-23-5	
Chlorobenzene	ND	ug/L	1.0	0.081	1		09/10/19 14:44	108-90-7	
Chloroethane	ND	ug/L	1.0	0.20	1		09/10/19 14:44	75-00-3	
2-Chloroethyl ethyl ether	ND	ug/L	10.0	0.29	1		09/10/19 14:44	110-75-8	
Chloroform	ND	ug/L	1.0	0.14	1		09/10/19 14:44	67-66-3	

REPORT OF LABORATORY ANALYSIS

Date: 09/26/2019 02:10 PM

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC

Page 6 of 48



Pace Analytical Services, LLC
9608 Lorel Blvd
Lima, PA 19019
(913) 659-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

Sample: ALGOL LAGOON EFF
MONTLY COMP

GC Batch Method		SM 4500-CHE-E	Analysis Description:		4500CHE Cyanide, Total					
Associated Lab Sample:		60313597052								
METHOD BLANK: 2484288			Matrix Water							
Associated Lab Sample:			60313597052							
Parameter	Units	Blank Result	Reporting Limit	MDL	Analysed	Qualifiers				
Cyanide	mg/L	ND	0.0050	0.0039	09/06/19 12:30					
LABORATORY CONTROL SAMPLE: 2484288										
Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Units	Qualifiers				
Cyanide	mg/L	0.1	0.10	102	69-126					
SAMPLE DUPLICATE: 2484291										
Parameter	Units	60313726001 Result	Dup Result	RPD	Max RPD	Qualifiers				
Cyanide	mg/L	0.024	0.028	17	46					



Pace Analytical Services, LLC
9020 Laurel Blvd
Lima, PA 17019
(813) 659-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603735 Analysis Method: EPA 420.1
QC Batch Method: EPA 420.1 Analysis Description: 420.1 Phenolics Macro
Associated Lab Samples: 60313597001

METHOD BLANK: 2483168 Matrix: Water
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Phenolics, Total Recoverable	mg/L	ND	0.050	0.019	09/09/19 15:33	

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Phenolics, Total Recoverable	mg/L	0.25	0.24	96	90-110	

Parameter	Units	60313345001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Phenolics, Total Recoverable	mg/L	0.23	0.25	0.48	97	90-110	

Parameter	Units	60313159001 Result	Dup Result	RPD	Max RPD	Qualifiers
Phenolics, Total Recoverable	mg/L	ND	ND		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 40 of 48



Pace Analytical Services, LLC
9020 Laurel Blvd
Lima, PA 17019
(813) 659-5555

ANALYTICAL RESULTS

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

Sample: ALGOA LAGOON EFF MONITOR GRAB Lab ID: 60313597002 Collected: 09/04/19 11:35 Received: 09/05/19 06:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
624 Volatile Organics Analytical Method: EPA 824 Low									
Chloroethane	ND	ug/L	1.0	0.20	1		09/10/19 14:44	74-87-3	
Dibromochloroethane	ND	ug/L	1.0	0.24	1		09/10/19 14:44	124-48-1	
1,2-Dichlorobenzene	ND	ug/L	1.0	0.08	1		09/10/19 14:44	95-50-1	
1,3-Dichlorobenzene	ND	ug/L	1.0	0.10	1		09/10/19 14:44	94-73-1	
1,4-Dichlorobenzene	ND	ug/L	1.0	0.050	1		09/10/19 14:44	106-46-7	
1,1-Dichloroethane	ND	ug/L	1.0	0.13	1		09/10/19 14:44	75-34-3	
1,2-Dichloroethane	ND	ug/L	1.0	0.14	1		09/10/19 14:44	107-06-2	
1,1-Dichloroethene	ND	ug/L	1.0	0.11	1		09/10/19 14:44	75-35-4	
cis-1,2-Dichloroethene	ND	ug/L	1.0	0.14	1		09/10/19 14:44	156-59-2	
trans-1,2-Dichloroethene	ND	ug/L	1.0	0.17	1		09/10/19 14:44	156-60-5	
1,2-Dichloropropane	ND	ug/L	1.0	0.097	1		09/10/19 14:44	78-87-5	
cis-1,3-Dichloropropene	ND	ug/L	1.0	0.16	1		09/10/19 14:44	1001-01-5	
trans-1,3-Dichloropropene	ND	ug/L	1.0	0.12	1		09/10/19 14:44	1001-02-8	
Ethylbenzene	ND	ug/L	1.0	0.057	1		09/10/19 14:44	100-41-4	
Methylene Chloride	ND	ug/L	1.0	0.21	1		09/10/19 14:44	75-09-4	
1,1,2,2-Tetrachloroethane	ND	ug/L	1.0	0.12	1		09/10/19 14:44	79-34-5	
Tetrachloroethene	ND	ug/L	1.0	0.15	1		09/10/19 14:44	127-18-4	
Toluene	ND	ug/L	1.0	0.049	1		09/10/19 14:44	109-66-3	
1,1,1-Trichloroethane	ND	ug/L	1.0	0.057	1		09/10/19 14:44	71-55-6	
1,1,2-Trichloroethane	ND	ug/L	1.0	0.25	1		09/10/19 14:44	79-00-5	
Trichloroethene	ND	ug/L	1.0	0.15	1		09/10/19 14:44	79-01-6	
Trichlorofluoromethane	ND	ug/L	1.0	0.12	1		09/10/19 14:44	75-69-4	
Vinyl chloride	ND	ug/L	1.0	0.11	1		09/10/19 14:44	75-01-4	
Xylene (Total)	ND	ug/L	3.0	0.21	1		09/10/19 14:44	1330-20-7	
Sumoxalates	98	%	80-120		1		09/10/19 14:44	480-090-4	
4-Bromobenzonitrile (S)	100	%	80-120		1		09/10/19 14:44	2037-29-5	
1,2-Dichloroethane-d4 (S)	99	%	80-120		1		09/10/19 14:44	10060-07-0	
Preservation pH	7.8		1.0	0.10	1		09/10/19 14:44		
120.1 Specific Conductance Analytical Method: EPA 120.1									
Specific Conductance	583	umhos/cm	1.0	1.0	1		09/10/19 15:43		
HEM, Oil and Grease Analytical Method: EPA 1604A									
Oil and Grease	ND	mg/L	4.9	1.3	1		09/10/19 08:41		
2310B Acidity, Total Analytical Method: SM 2310B									
Acidity, Total	ND	mg/L	20.0	1.0	1		09/10/19 09:40		
2310B Alkalinity Analytical Method: SM 2320B									
Alkalinity Bicarbonate (CaCO3)	237	mg/L	20.0	6.5	1		09/10/19 10:12		
Alkalinity, Total as CaCO3	237	mg/L	20.0	6.5	1		09/10/19 10:12		
4500CL G Chlorine, Residual Analytical Method: SM 4500-Cl G									
Chlorine, Total Residual	0.18	mg/L	0.050	0.010	1		09/05/19 14:42	7782-50-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 9 of 48



Pace Analytical Services, LLC
9020 Laurel Blvd
Lima, PA 17019
(813) 659-5555

ANALYTICAL RESULTS

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

Sample: ALGOA LAGOON EFF MONITOR GRAB Lab ID: 60313597002 Collected: 09/04/19 11:35 Received: 09/05/19 06:30 Matrix: Water

Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
4500B20 Sulfide, Total Analytical Method: SM 4500-S-2.0									
Sulfide, Total	ND	mg/L	0.050	0.039	1		09/09/19 12:12	18494-25-8	
4500SO3B Sulfide, Iodometric Analytical Method: SM 4500-SO3-B									
Sulfide	ND	mg/L	2.0	2.0	1		09/10/19 15:23		
5540C MBAS Surfactants Analytical Method: SM 5540C Preparation Method: SM 5540C									
MBAS, Calculated as LAS	0.24	mg/L	0.20	0.064	1		09/05/19 17:14		
355.1 Orthophosphate as P Analytical Method: EPA 355.1									
Orthophosphate as P	3.0	mg/L	0.10	0.054	1		09/06/19 09:04		
4500CNE Cyanide, Total Analytical Method: SM 4500-CNE Preparation Method: SM 4500-CNE									
Cyanide	0.0057	mg/L	0.0050	0.0039	1		09/09/19 09:03		
5310C TOC Analytical Method: SM 5310C									
Total Organic Carbon	9.3	mg/L	2.0	0.58	2		09/10/19 05:48	7440-44-0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 10 of 48



Pace Analytical Services, LLC
9020 Laurel Blvd
Lima, PA 17019
(813) 659-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603168 Analysis Method: EPA 410.4
QC Batch Method: EPA 410.4 Analysis Description: 410.4 Water Analysis
Associated Lab Samples: 60313597001

METHOD BLANK: 2483355 Matrix: Water
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Chemical Oxygen Demand	mg/L	ND	10.0	3.7	09/10/19 08:27	

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Chemical Oxygen Demand	mg/L	50	53.1	106	90-110	

Parameter	Units	60313597001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Chemical Oxygen Demand	mg/L	39.8	50	65.6	98	90-110	

Parameter	Units	60313597001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Chemical Oxygen Demand	mg/L	25.1	50	75.3	100	90-110	

Parameter	Units	60313597001 Result	Dup Result	RPD	Max RPD	Qualifiers
Chemical Oxygen Demand	mg/L	2330	2220	5	25	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 39 of 48



Pace Analytical Services, LLC
6608 Lorain Blvd
Lima, PA 16021
(813)269-5055

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 603744 Analysis Method: EPA 365.4
QC Batch Method: EPA 365.4 Analysis Description: 365.4 Phosphorus
Associated Lab Samples: 60313697001

METHOD BLANK: 2450980 Matrix: Water
Associated Lab Samples: 60313697001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Phosphorus	mg/L	ND	0.10	0.014	09/18/19 09:22	

Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Phosphorus	mg/L	2	2.0	99	60-110	

Parameter	Units	Spike Conc	Spike Result	MS Result	MS % Rec	% Rec Limits	Qualifiers
Phosphorus	mg/L	4.5	2	5.8	73	90-110 E.M1	

Parameter	Units	Spike Conc	Spike Result	MS Result	MS % Rec	% Rec Limits	Qualifiers
Phosphorus	mg/L	3.8	2	5.8	87	90-110 E.M1	

Parameter	Units	Dup Result	RPD	Max RPD	Qualifiers
Phosphorus	mg/L	1.4	1.5	4	10

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.
Date: 09/26/2019 02:10 PM Page 18 of 48



Pace Analytical Services, LLC
6608 Lorain Blvd
Lima, PA 16021
(813)269-5055

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 607760 Analysis Method: EPA 245.1
QC Batch Method: EPA 245.1 Analysis Description: 245.1 Mercury
Associated Lab Samples: 60313697001

METHOD BLANK: 2483292 Matrix: Water
Associated Lab Samples: 60313697001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Mercury	ug/L	ND	0.20	0.088	09/06/19 15:43	

Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Mercury	ug/L	5	5.0	99	65-115	

Parameter	Units	Spike Conc	Spike Result	MS Result	MS % Rec	% Rec Limits	Max RPD	Qual
Mercury	ug/L	ND	5	5	4.8	69	97	70-130

Parameter	Units	Spike Conc	Spike Result	MS Result	MS % Rec	% Rec Limits	Qualifiers
Mercury	ug/L	ND	5	5.0	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.
Date: 09/26/2019 02:10 PM Page 11 of 48



Pace Analytical Services, LLC
6608 Lorain Blvd
Lima, PA 16021
(813)269-5055

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 603761 Analysis Method: EPA 200.7
QC Batch Method: EPA 200.7 Analysis Description: 200.7 Metals, Total
Associated Lab Samples: 60313697001

METHOD BLANK: 2485779 Matrix: Water
Associated Lab Samples: 60313697001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Aluminum	ug/L	ND	75.0	33.0	09/12/19 12:13	

Antimony	ug/L	ND	15.0	6.5	09/12/19 12:13	
Arsenic	ug/L	ND	10.0	4.1	09/12/19 12:13	
Barium	ug/L	ND	5.0	1.4	09/12/19 12:13	
Beryllium	ug/L	ND	1.0	0.25	09/12/19 12:13	
Cadmium	ug/L	ND	5.0	0.58	09/12/19 12:13	
Calcium	ug/L	ND	200	50.0	09/12/19 12:13	
Chromium	ug/L	ND	5.0	1.0	09/12/19 12:13	
Copper	ug/L	ND	10.0	3.4	09/12/19 12:13	
Hardness, Total (SM 2340B)	ug/L	ND	800	197	09/12/19 12:13	
Iron	ug/L	ND	50.0	14.0	09/12/19 12:13	
Lead	ug/L	ND	10.0	3.4	09/12/19 12:13	
Magnesium	ug/L	ND	50.0	13.0	09/12/19 12:13	
Molybdenum	ug/L	ND	20.0	2.6	09/12/19 12:13	
Nickel	ug/L	ND	5.0	1.2	09/12/19 12:13	
Selenium	ug/L	ND	15.0	6.6	09/12/19 12:13	
Silver	ug/L	ND	7.0	1.8	09/12/19 12:13	
Sodium	ug/L	ND	500	144	09/12/19 12:13	
Thium	ug/L	ND	20.0	3.4	09/12/19 12:13	
Zinc	ug/L	ND	50.0	6.1	09/12/19 12:13	

Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Aluminum	ug/L	10000	10500	105	85-115	
Antimony	ug/L	1000	1090	109	85-115	
Arsenic	ug/L	1000	1000	100	85-115	
Barium	ug/L	1000	1050	105	85-115	
Beryllium	ug/L	1000	1050	105	85-115	
Cadmium	ug/L	1000	1050	105	85-115	
Calcium	ug/L	10000	10700	107	85-115	
Chromium	ug/L	1000	1050	105	85-115	
Copper	ug/L	1000	1040	104	85-115	
Hardness, Total (SM 2340B)	ug/L	86200	89000	105	85-115	
Iron	ug/L	10000	10600	106	85-115	
Lead	ug/L	1000	1130	113	85-115	
Magnesium	ug/L	10000	10400	104	85-115	
Molybdenum	ug/L	1000	1060	106	85-115	
Nickel	ug/L	1000	1050	105	85-115	
Selenium	ug/L	1000	1070	107	85-115	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.
Date: 09/26/2019 02:10 PM Page 12 of 48



Pace Analytical Services, LLC
6608 Lorain Blvd
Lima, PA 16021
(813)269-5055

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 607737 Analysis Method: EPA 365.1
QC Batch Method: EPA 365.1 Analysis Description: 365.1 Orthophosphate as P
Associated Lab Samples: 60313697002

METHOD BLANK: 2483205 Matrix: Water
Associated Lab Samples: 60313697002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Orthophosphate as P	mg/L	ND	0.10	0.034	09/06/19 03:59	

Parameter	Units	Spike Conc	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Orthophosphate as P	mg/L	2	2.1	107	90-110	

Parameter	Units	Spike Conc	Spike Result	MS Result	MS % Rec	% Rec Limits	Qualifiers
Orthophosphate as P	mg/L	ND	2	2.2	105	90-110	

Parameter	Units	Dup Result	RPD	Max RPD	Qualifiers
Orthophosphate as P	mg/L	3.0	3.0	1	30

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.
Date: 09/26/2019 02:10 PM Page 37 of 48



Pace Analytical Services, LLC
6503 Lord Blvd
Lima, KS 66219
(913)559-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603155
QC Batch Method: EPA 353.2
Associated Lab Samples: 60313597001

METHOD BLANK: 2482508
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Nitrogen, Nitrate	mg/L	ND	0.10	0.057	09/05/19 12:17	
Nitrogen, Nitrite	mg/L	ND	0.10	0.057	09/05/19 12:17	
Nitrogen, NO2 plus NO3	mg/L	ND	0.10	0.058	09/05/19 12:17	

LABORATORY CONTROL SAMPLE: 2482507

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrogen, Nitrate	mg/L	1	0.98	98	70-130	
Nitrogen, Nitrite	mg/L	1	1.0	100	90-110	
Nitrogen, NO2 plus NO3	mg/L	2	2.0	100	80-110	

MATRIX SPIKE SAMPLE: 2482508

Parameter	Units	60313597001	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Nitrate	mg/L	ND	1	2.4	95	70-130	
Nitrogen, Nitrite	mg/L	ND	1	1.1	109	90-110	
Nitrogen, NO2 plus NO3	mg/L	ND	2	3.5	102	90-110	

MATRIX SPIKE SAMPLE: 2482510

Parameter	Units	60313597001	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Nitrate	mg/L	ND	1	0.95	95	70-130	
Nitrogen, Nitrite	mg/L	ND	1	1.1	109	90-110	
Nitrogen, NO2 plus NO3	mg/L	ND	2	2.1	103	90-110	

SAMPLE DUPLICATE: 2482509

Parameter	Units	60313597001	Dup Result	RPD	Max RPD	Qualifiers
Nitrogen, Nitrate	mg/L	ND	4.1	4.0	3	20
Nitrogen, Nitrite	mg/L	ND	ND	ND	ND	20
Nitrogen, NO2 plus NO3	mg/L	ND	4.1	4.0	3	20

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 36 of 48



Pace Analytical Services, LLC
6503 Lord Blvd
Lima, KS 66219
(913)559-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603155
QC Batch Method: EPA 353.2
Associated Lab Samples: 60313597001

METHOD BLANK: 2482508
Associated Lab Samples: 60313597001

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Silver	ug/L	500	521	104	85-115	
Sodium	ug/L	10000	10500	105	85-115	
Thallium	ug/L	1000	1050	105	85-115	
Zinc	ug/L	1000	1050	105	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2482507

Parameter	Units	B011897001		SpKs		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD		MS		MSD	
-----------	-------	------------	--	------	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--	----	--	-----	--

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 13 of 48



Pace Analytical Services, LLC
6503 Lord Blvd
Lima, KS 66219
(913)559-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603370
QC Batch Method: EPA 824 Low
Associated Lab Samples: 60313597002

METHOD BLANK: 2485008
Associated Lab Samples: 60313597002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
1,1,1-Trichloroethane	ug/L	ND	1.0	0.057	09/10/19 14:02	
1,1,2,2-Tetrachloroethane	ug/L	ND	1.0	0.12	09/10/19 14:02	
1,1,2-Trichloroethane	ug/L	ND	1.0	0.25	09/10/19 14:02	
1,1-Dichloroethane	ug/L	ND	1.0	0.13	09/10/19 14:02	
1,1-Dichloroethene	ug/L	ND	1.0	0.11	09/10/19 14:02	
1,2-Dichlorobenzene	ug/L	ND	1.0	0.068	09/10/19 14:02	
1,2-Dichloroethene	ug/L	ND	1.0	0.14	09/10/19 14:02	
1,2-Dichloropropane	ug/L	ND	1.0	0.097	09/10/19 14:02	
1,3-Dichlorobenzene	ug/L	ND	1.0	0.10	09/10/19 14:02	
1,4-Dichlorobenzene	ug/L	ND	1.0	0.095	09/10/19 14:02	
2-Chloroethyl vinyl ether	ug/L	ND	10.0	0.28	09/10/19 14:02	
Aroclor	ug/L	ND	100	2.0	09/10/19 14:02	
Acrylonitrile	ug/L	ND	20.0	1.6	09/10/19 14:02	
Benzene	ug/L	ND	1.0	0.12	09/10/19 14:02	
Bromodichloromethane	ug/L	ND	1.0	0.13	09/10/19 14:02	
Bromoform	ug/L	ND	1.0	0.11	09/10/19 14:02	
Bromomethane	ug/L	ND	5.0	0.68	09/10/19 14:02	
Carbon tetrachloride	ug/L	ND	1.0	0.10	09/10/19 14:02	
Chlorobenzene	ug/L	ND	1.0	0.081	09/10/19 14:02	
Chloroethane	ug/L	ND	1.0	0.20	09/10/19 14:02	
Chloroform	ug/L	ND	1.0	0.14	09/10/19 14:02	
Chloromethane	ug/L	ND	1.0	0.20	09/10/19 14:02	
cis-1,2-Dichloroethene	ug/L	ND	1.0	0.14	09/10/19 14:02	N2
cis-1,3-Dichloropropene	ug/L	ND	1.0	0.10	09/10/19 14:02	
Diisobutylbenzene	ug/L	ND	1.0	0.24	09/10/19 14:02	
Dibutylbenzene	ug/L	ND	1.0	0.057	09/10/19 14:02	
Methylcyclohexane	ug/L	ND	1.0	0.21	09/10/19 14:02	
Tetrafluoroethene	ug/L	ND	1.0	0.15	09/10/19 14:02	
Toluene	ug/L	ND	1.0	0.046	09/10/19 14:02	
trans-1,2-Dichloroethene	ug/L	ND	1.0	0.17	09/10/19 14:02	
trans-1,3-Dichloropropene	ug/L	ND	1.0	0.12	09/10/19 14:02	
Trichlorobenzene	ug/L	ND	1.0	0.15	09/10/19 14:02	
Trichlorofluoromethane	ug/L	ND	1.0	0.10	09/10/19 14:02	
Vinyl chloride	ug/L	ND	1.0	0.11	09/10/19 14:02	
Xylene (Total)	ug/L	ND	3.0	0.21	09/10/19 14:02	N2
1,2-Dichloroethane-d4 (S)	%	100	80-120	09/10/19 14:02		
4-Bromofluorobenzene (S)	%	100	80-120	09/10/19 14:02		
Toluene-d8 (S)	%	101	80-120	09/10/19 14:02		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 14 of 48



Pace Analytical Services, LLC
6503 Lord Blvd
Lima, KS 66219
(913)559-5555

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 603504
QC Batch Method: EPA 351.2
Associated Lab Samples: 60313597001

METHOD BLANK: 2490252
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Nitrogen, Kjeldahl, Total	mg/L	ND	0.50	0.37	09/17/19 09:35	

LABORATORY CONTROL SAMPLE: 2490253

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrogen, Kjeldahl, Total	mg/L	5	5.2	104	90-110	

MATRIX SPIKE SAMPLE: 2490254

Parameter	Units	50314009001	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Kjeldahl, Total	mg/L	ND	11.2	5	18.4	143	90-110 MI

MATRIX SPIKE SAMPLE: 2490258

Parameter	Units	60314035001	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Kjeldahl, Total	mg/L	ND	475	50	434	58	90-110 MI

SAMPLE DUPLICATE: 2490255

Parameter	Units	60313597003	Dup Result	RPD	Max RPD	Qualifiers
Nitrogen, Kjeldahl, Total	mg/L	ND	32.3	31.5	2	10

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 35 of 48



Pace Analytical Services, LLC
6608 Lorel Blvd
Lynch, VA 22319
(913) 269-5695

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 605811 Analysis Method: EPA 350.1
QC Batch Method: EPA 350.1 Analysis Description: 350.1 Ammonia
Associated Lab Samples: 60313597001

METHOD BLANK: 2491223
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Nitrogen, Ammonia	mg/L	ND	0.10	0.079	09/18/19 14:41	

LABORATORY CONTROL SAMPLE: 2491224

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Nitrogen, Ammonia	mg/L	5	4.8	96	90-110	

MATRIX SPIKE SAMPLE: 2491225

Parameter	Units	50313595002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Ammonia	mg/L	0.32	5	5.5	104	90-110	

MATRIX SPIKE SAMPLE: 2491227

Parameter	Units	60313512005 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Nitrogen, Ammonia	mg/L	ND	5	5.1	102	90-110	

SAMPLE DUPLICATE: 2491226

Parameter	Units	60314029001 Result	Dup Result	RPD	Max RPD	Qualifiers
Nitrogen, Ammonia	mg/L	94.5	65.5	1	18	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 34 of 48



Pace Analytical Services, LLC
6608 Lorel Blvd
Lynch, VA 22319
(913) 269-5695

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

LABORATORY CONTROL SAMPLE: 2485009

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
1,1,1-Trichloroethane	ug/L	20	21.8	109	80-114	
1,1,2,2-Tetrachloroethane	ug/L	20	21.9	109	87-123	
1,1,2-Trichloroethane	ug/L	20	21.0	105	80-117	
1,1-Dichloroethane	ug/L	20	20.7	103	75-117	
1,1-Dichloroethene	ug/L	20	21.2	106	86-120	
1,2-Dichlorobenzene	ug/L	20	21.2	106	81-115	
1,2-Dichloroethane	ug/L	20	20.9	105	71-110	
1,2-Dichloropropane	ug/L	20	21.8	108	78-115	
1,3-Dichlorobenzene	ug/L	20	21.2	106	81-115	
1,4-Dichlorobenzene	ug/L	20	20.2	101	80-113	
2-Chloroethylalcohol	ug/L	20	22.9	114	10-167	
Acrolein	ug/L	200	212	106	10-185	
Acrylonitrile	ug/L	200	220	110	72-121	
Benzene	ug/L	20	21.1	106	78-114	
Bromochloromethane	ug/L	20	21.9	110	78-110	
Bromofarm	ug/L	20	23.7	118	72-128	
Bromomethane	ug/L	20	24.5	122	15-185	
Carbon tetrachloride	ug/L	20	22.8	114	70-150	
Chlorobenzene	ug/L	20	21.6	108	65-135	
Chloroethane	ug/L	20	14.4	72	41-138	
Chloroform	ug/L	20	19.9	99	78-110	
Chloromethane	ug/L	20	19.9	99	17-148	
cis-1,2-Dichloroethene	ug/L	20	21.3	106	80-114 N2	
cis-1,3-Dichloropropene	ug/L	20	20.8	103	78-116	
Dibromochloromethane	ug/L	20	22.8	114	70-135	
Ethylbenzene	ug/L	20	21.1	105	83-118	
Methylene Chloride	ug/L	20	18.5	93	70-118	
Tetrachloroethene	ug/L	20	21.8	109	74-124	
Toluene	ug/L	20	20.8	104	82-115	
trans-1,2-Dichloroethene	ug/L	20	21.3	107	75-110	
trans-1,3-Dichloropropene	ug/L	20	20.9	104	81-116	
Trichloroethene	ug/L	20	21.0	105	82-124	
Trichlorofluoromethane	ug/L	20	22.2	111	81-128	
Vinyl chloride	ug/L	20	23.1	115	38-150	
Xylene (Total)	ug/L	60	64.2	107	82-114 N2	
1,2-Dichloroethane-d4 (S)	%			101	60-120	
4-Bromofluorobenzene (S)	%			100	60-120	
Toluene-d8 (S)	%			101	60-120	

MATRIX SPIKE SAMPLE: 2485010

Parameter	Units	60313545002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
1,1,1-Trichloroethane	ug/L	ND	20	18.8	93	52-162	
1,1,2,2-Tetrachloroethane	ug/L	ND	20	15.7	78	48-137	
1,1,2-Trichloroethane	ug/L	ND	20	15.2	76	52-150	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 16 of 48



Pace Analytical Services, LLC
6608 Lorel Blvd
Lynch, VA 22319
(913) 269-5695

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

MATRIX SPIKE SAMPLE: 2455010

Parameter	Units	60313545002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
1,1-Dichloroethane	ug/L	ND	20	18.9	94	59-155	
1,1-Dichloroethene	ug/L	ND	20	18.8	94	10-234	
1,2-Dichlorobenzene	ug/L	ND	20	15.6	78	18-190	
1,2-Dichloroethane	ug/L	ND	20	15.0	74	49-150	
1,2-Dichloropropane	ug/L	ND	20	16.1	81	10-210	
1,3-Dichlorobenzene	ug/L	ND	20	16.0	80	59-158	
1,4-Dichlorobenzene	ug/L	ND	20	15.7	78	18-190	
2-Chloroethylalcohol	ug/L	ND	20	15.0	75	10-225	
Acrolein	ug/L	ND	200	37.43	19	10-175	
Acrylonitrile	ug/L	ND	200	140	74	35-134	
Benzene	ug/L	ND	20	18.8	94	37-151	
Bromodichloromethane	ug/L	ND	20	15.7	78	35-155	
Bromofarm	ug/L	ND	20	18.1	91	45-169	
Bromomethane	ug/L	ND	20	28.0	140	10-242	
Carbon tetrachloride	ug/L	ND	20	20.1	101	70-140	
Chlorobenzene	ug/L	ND	20	15.9	80	37-160	
Chloroethane	ug/L	ND	20	9.8	49	14-230	
Chloroform	ug/L	ND	20	15.0	74	51-130	
Chloromethane	ug/L	ND	20	14.6	73	10-273	
cis-1,2-Dichloroethene	ug/L	ND	20	19.3	97	43-132 N2	
cis-1,3-Dichloropropene	ug/L	ND	20	14.8	74	10-227	
Dibromochloromethane	ug/L	ND	20	18.2	91	53-149	
Ethylbenzene	ug/L	ND	20	16.0	80	37-162	
Methylene Chloride	ug/L	ND	20	13.7	68	10-221	
Tetrachloroethene	ug/L	ND	20	17.6	88	64-148	
Toluene	ug/L	ND	20	16.7	83	47-150	
trans-1,2-Dichloroethene	ug/L	ND	20	17.4	87	54-156	
trans-1,3-Dichloropropene	ug/L	ND	20	14.8	74	17-183	
Trichloroethene	ug/L	ND	20	17.1	86	70-157	
Trichlorofluoromethane	ug/L	ND	20	20.8	103	17-181	
Vinyl chloride	ug/L	ND	20	19.1	95	10-251	
Xylene (Total)	ug/L	ND	60	48.2	80	43-137 N2	
1,2-Dichloroethane-d4 (S)	%				97	60-120	
4-Bromofluorobenzene (S)	%				103	60-120	
Toluene-d8 (S)	%				101	60-120	
Precipitation pH		7.0		7.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 16 of 48



Pace Analytical Services, LLC
6608 Lorel Blvd
Lynch, VA 22319
(913) 269-5695

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

METHOD BLANK: 2487714

Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Chloride	mg/L	ND	1.0	0.22	09/12/19 16:47	
Fluoride	mg/L	ND	0.20	0.085	09/12/19 16:47	
Sulfate	mg/L	ND	1.0	0.23	09/12/19 16:47	

LABORATORY CONTROL SAMPLE: 2487715

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Chloride	mg/L	5	5.0	99	90-110	
Fluoride	mg/L	2.5	2.6	104	90-110	
Sulfate	mg/L	5	4.8	96	90-110	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2487716 2487717

Parameter	Units	60313420001 Result	MSD	Spike Conc.	MS Result	MSD	MS % Rec	% Rec Limits	Max RPD	Qual
Chloride	mg/L	596	500	500	1160	1140	112	109	60-120	1 15
Fluoride	mg/L	ND	250	250	261	263	104	105	60-120	1 15
Sulfate	mg/L	ND	500	500	710	707	142	141	60-120	0 15 MI

MATRIX SPIKE SAMPLE: 2487718

Parameter	Units	60313597001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Chloride	mg/L	175	50	240	120	80-120 E.M1	
Fluoride	mg/L	0.70	2.5	3.4	108	90-120	
Sulfate	mg/L	27.6	50	81.4	108	60-120	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 33 of 48



Pace Analytical Services, LLC
9623 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALITY CONTROL DATA

Project: AIR/AL, PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 607549 Analysis Method: SM 5540C
QC Batch Method: SM 5540C Analysis Description: 5540C MBAS Surfactants
Associated Lab Samples: 60313597002

METHOD BLANK: 2402400 Matrix: Water
Associated Lab Samples: 60313597002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
MBAS, Calculated as LAS	mg/L	ND	0.20	0.094	09/05/19 17:09	SU

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
MBAS, Calculated as LAS	mg/L	1	0.85	85	60-120	SU

Parameter	Units	60313597002 Result	Dup Result	RPD	Max RPD	Qualifiers
MBAS, Calculated as LAS	mg/L	0.24	0.24	1	19	SU

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 22 of 48



Pace Analytical Services, LLC
9623 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALITY CONTROL DATA

Project: AIR/AL, PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 520708 Analysis Method: EPA 608.3
QC Batch Method: EPA 608.3 Analysis Description: 608.3 PCB
Associated Lab Samples: 60313597001

METHOD BLANK: 2401883 Matrix: Water
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
PCB-1016 (Aroclor 1016)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1221 (Aroclor 1221)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1232 (Aroclor 1232)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1242 (Aroclor 1242)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1248 (Aroclor 1248)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1254 (Aroclor 1254)	ug/L	ND	0.10	0.035	09/11/19 15:57	
PCB-1260 (Aroclor 1260)	ug/L	ND	0.10	0.031	09/11/19 15:57	
Tetrachloro-m-xylene (S)	%	83	14-132		09/11/19 15:57	

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
PCB-1016 (Aroclor 1016)	ug/L	0.5	0.49	98	50-140	
PCB-1260 (Aroclor 1260)	ug/L	0.5	0.51	102	8-140	
Tetrachloro-m-xylene (S)	%			59	14-132	

Parameter	Units	60313597001 Result	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	RPD	Max RPD	Qualifiers
PCB-1016 (Aroclor 1016)	ug/L	ND	1	1	1.1	1.1	111	108	50-140
PCB-1260 (Aroclor 1260)	ug/L	ND	1	1	0.43	0.44	43	44	8-140
Tetrachloro-m-xylene (S)	%					84	82	14-132	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 17 of 48



Pace Analytical Services, LLC
9623 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALITY CONTROL DATA

Project: AIR/AL, PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 520708 Analysis Method: EPA 608.3
QC Batch Method: EPA 608.3 Analysis Description: 608.3 Pesticides
Associated Lab Samples: 60313597001

METHOD BLANK: 2401877 Matrix: Water
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
4,4'-DDD	ug/L	ND	0.10	0.012	09/13/19 15:12	
4,4'-DDE	ug/L	ND	0.10	0.017	09/13/19 15:12	
4,4'-DDT	ug/L	ND	0.10	0.038	09/13/19 15:12	
Aldrin	ug/L	ND	0.050	0.012	09/13/19 15:12	
alpha-BHC	ug/L	ND	0.050	0.0050	09/13/19 15:12	
alpha-Chlordane	ug/L	ND	0.050	0.0091	09/13/19 15:12	N2
beta-BHC	ug/L	ND	0.050	0.0090	09/13/19 15:12	
Chlordane (Technical)	ug/L	ND	0.50	0.38	09/13/19 15:12	
delta-BHC	ug/L	ND	0.050	0.017	09/13/19 15:12	
Quinon	ug/L	ND	0.10	0.0056	09/13/19 15:12	
Endosulfan I	ug/L	ND	0.050	0.011	09/13/19 15:12	
Endosulfan II	ug/L	ND	0.10	0.012	09/13/19 15:12	
Endosulfan sulfate	ug/L	ND	0.10	0.014	09/13/19 15:12	
Erdin	ug/L	ND	0.10	0.018	09/13/19 15:12	
Erdin alkyls	ug/L	ND	0.10	0.018	09/13/19 15:12	
Erdin ketone	ug/L	ND	0.10	0.019	09/13/19 15:12	N2
gamma-BHC (beta-BHC)	ug/L	ND	0.050	0.0041	09/13/19 15:12	
gamma-Chlordane	ug/L	ND	0.050	0.0085	09/13/19 15:12	N2
Heptachlor	ug/L	ND	0.050	0.0081	09/13/19 15:12	
Heptachlor epoxide	ug/L	ND	0.050	0.0087	09/13/19 15:12	
Methoxychlor	ug/L	ND	0.50	0.17	09/13/19 15:12	
Toxaphene	ug/L	ND	1.0	0.0093	09/13/19 15:12	
Decachlorobiphenyl (S)	%	91	18-118		09/13/19 15:12	

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
4,4'-DDD	ug/L	0.2	0.22	110	31-141	
4,4'-DDE	ug/L	0.2	0.19	94	39-145	
4,4'-DDT	ug/L	0.2	0.22	109	25-160	
Aldrin	ug/L	0.1	0.083	83	42-140	N2
alpha-BHC	ug/L	0.1	0.11	109	37-140	
alpha-Chlordane	ug/L	0.1	0.089	89	45-140	N2
beta-BHC	ug/L	0.1	0.10	103	17-141	
delta-BHC	ug/L	0.1	0.085	85	19-140	
Quinon	ug/L	0.2	0.21	103	36-144	
Endosulfan I	ug/L	0.1	0.099	99	45-153	
Endosulfan II	ug/L	0.2	0.22	108	12-02	
Endosulfan sulfate	ug/L	0.2	0.20	100	28-144	
Erdin	ug/L	0.2	0.21	108	30-147	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 16 of 48



Pace Analytical Services, LLC
9623 Laurel Blvd
Lenexa, KS 66219
(913) 559-5055

QUALITY CONTROL DATA

Project: AIR/AL, PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 605831 Analysis Method: SM 4500-SO3 B
QC Batch Method: SM 4500-SO3 B Analysis Description: 4500-SO3 B Sulfite
Associated Lab Samples: 60313597002

METHOD BLANK: 2405809 Matrix: Water
Associated Lab Samples: 60313597002

Parameter	Units	Blank Result	Reporting Limit	MOL	Analyzed	Qualifiers
Sulfite	mg/L	ND	2.0	2.0	03/16/19 15:18	H8

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Sulfite	mg/L	15	14.8	93	60-120	H8

Parameter	Units	60313597002 Result	Dup Result	RPD	Max RPD	Qualifiers
Sulfite	mg/L	ND	ND		20	H8

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 31 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lorain, VA 26019
(813) 559-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 605089 Analysis Method: SM 4500-B-2-D
QC Batch Method: SM 4500-B-2-D Analysis Description: 4500-B-2-D Surfactants, Total
Associated Lab Samples: 60313697002

Mastic Vialer						
Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Surfactants, Total	mg/L	ND	0.050	0.039	09/09/19 12:10	

LABORATORY CONTROL SAMPLE: 2484453						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Surfactants, Total	mg/L	0.5	0.49	96	80-120	

MATRIX SPIKE SAMPLE: 2484454						
Parameter	Units	60313699002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits Qualifiers
Surfactants, Total	mg/L	ND	0.5	0.20	40	75-125 M1

SAMPLE DUPLICATE: 2484455						
Parameter	Units	60313699004 Result	Dup Result	RPD	Max RPD	Qualifiers
Surfactants, Total	mg/L	ND	ND	ND	20	

SAMPLE DUPLICATE: 2484456						
Parameter	Units	60314010002 Result	Dup Result	RPD	Max RPD	Qualifiers
Surfactants, Total	mg/L	ND	ND	ND	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 30 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lorain, VA 26019
(813) 559-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

LABORATORY CONTROL SAMPLE: 2401876						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Endrin aldehyde	ug/L	0.2	0.21	108	35-178	
Endrin ketone	ug/L	0.2	0.20	102	47-187 N2	
gamma-BHC (lindane)	ug/L	0.1	0.11	112	32-140	
gamma-Chlordane	ug/L	0.1	0.077	77	45-146 N2	
Heptachlor	ug/L	0.1	0.443	44	34-140	
Heptachlor epoxide	ug/L	0.1	0.10	104	37-142	
Methoxychlor	ug/L	1	1.1	108	34-193	
Decachlorobiphenyl (S)	%			83	18-118	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2401879												
Parameter	Units	60313841001		MSD		MSD		MSD		MSD		Max RPD Qual
		Result	Spike Conc.	Result	Spike Conc.	Result	% Rec	Result	% Rec	Result	% Rec	
4,4'-DDE	ug/L	ND	0.2	0.2	0.18	0.10	68	51	31-141	54	29 R1	
4,4'-DDE	ug/L	ND	0.2	0.2	0.21	0.12	104	60	30-145	53	35 R1	
4,4'-DOT	ug/L	ND	0.2	0.2	0.16	0.12	78	58	25-160	26	42	
Alloxin	ug/L	ND	0.1	0.1	0.11	0.065	159	64	42-143	49	35 R1	
alpha-BHC	ug/L	ND	0.1	0.1	0.05	0.099	106	96	37-140	10	36	
alpha-Chlordane	ug/L	ND	0.1	0.1	0.077	0.443	77	44	45-140	33	M1, N2	
beta-BHC	ug/L	ND	0.1	0.1	0.13	0.092	128	82	17-147	44	44	
delta-BHC	ug/L	ND	0.1	0.13	0.077	0.10	73	57	1-202	23	53	
Dieldrin	ug/L	ND	0.2	0.2	0.14	0.11	72	56	36-146	26	49	
Endosulfan I	ug/L	ND	0.1	0.1	0.079	0.463	78	46	45-153	28		
Endosulfan II	ug/L	ND	0.2	0.2	0.15	0.11	73	57	1-202	23	53	
Endosulfan sulfate	ug/L	ND	0.2	0.2	0.18	0.13	68	65	26-144	31	38	
Endrin	ug/L	ND	0.2	0.2	0.22	0.18	112	81	30-147	33	48	
Endrin aldehyde	ug/L	ND	0.2	0.2	0.513	0.443	25	22	10-156	30		
Endrin ketone	ug/L	ND	0.2	0.2	0.19	0.13	63	67	17-183	33	30 N2, R1	
gamma-BHC (lindane)	ug/L	ND	0.1	0.1	0.13	0.095	127	95	32-140	29	35	
gamma-Chlordane	ug/L	ND	0.1	0.1	0.443	0.483	44	48	45-140	35	M1, N2	
Heptachlor	ug/L	ND	0.1	0.1	0.05	0.05	105	65	24-140	48	43 R1	
Heptachlor epoxide	ug/L	ND	0.1	0.1	0.10	0.057	100	67	37-142	39	28 R1	
Methoxychlor	ug/L	ND	1	1	1.0	0.62	103	62	16-166	49	30 R1	
Decachlorobiphenyl (S)	%						13	11	18-118		50	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 19 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lorain, VA 26019
(813) 559-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 607510 Analysis Method: EPA 825
QC Batch Method: EPA 825 Analysis Description: 825 M55
Associated Lab Samples: 60313697001

Mastic Vialer						
Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
1,2,4-Trichlorobenzene	ug/L	ND	5.0	0.87	09/09/19 20:42	
1,2-Dichlorobenzene	ug/L	ND	8.0	0.60	09/09/19 20:42	
2,4,6-Trichlorophenol	ug/L	ND	5.0	0.77	09/09/19 20:42	
2,4-Dichlorophenol	ug/L	ND	5.0	0.60	09/09/19 20:42	
2,4-Dimethylphenol	ug/L	ND	5.0	0.69	09/09/19 20:42	
2,4-Dinitrophenol	ug/L	ND	50.0	1.0	09/09/19 20:42	
2,4-Dinitrotoluene	ug/L	ND	5.0	0.59	09/09/19 20:42	
2,6-Dinitrotoluene	ug/L	ND	5.0	0.60	09/09/19 20:42	
2-Chlorophenol	ug/L	ND	5.0	0.81	09/09/19 20:42	
2-Nitrophenol	ug/L	ND	5.0	0.75	09/09/19 20:42	
2-Nitrophenol	ug/L	ND	5.0	0.72	09/09/19 20:42	
3,3-Dinitrobenzidine	ug/L	ND	20.0	0.78	09/09/19 20:42	
4,8-Dinitro-2-methylphenol	ug/L	ND	25.0	0.60	09/09/19 20:42	
4-Chlorophenyl ether	ug/L	ND	5.0	0.72	09/09/19 20:42	
4-Chloro-3-methylphenol	ug/L	ND	5.0	0.76	09/09/19 20:42	
4-Chlorophenyl ether	ug/L	ND	5.0	0.83	09/09/19 20:42	
4-Nitrophenol	ug/L	ND	5.0	0.75	09/09/19 20:42	
Acenaphthene	ug/L	ND	5.0	0.60	09/09/19 20:42	
Acenaphthylene	ug/L	ND	5.0	0.60	09/09/19 20:42	
Anthracene	ug/L	ND	5.0	0.68	09/09/19 20:42	
Benzo(a)anthracene	ug/L	ND	5.0	0.6	09/09/19 20:42	
Benzo(a)fluoranthene	ug/L	ND	5.0	0.70	09/09/19 20:42	
Benzo(a)pyrene	ug/L	ND	5.0	0.74	09/09/19 20:42	
Benzo(b)fluoranthene	ug/L	ND	5.0	0.84	09/09/19 20:42	
Benzo(g,h,i)perylene	ug/L	ND	5.0	0.70	09/09/19 20:42	
Benzo(k)fluoranthene	ug/L	ND	5.0	1.0	09/09/19 20:42	
bis(2-Chloroethoxy)methane	ug/L	ND	5.0	0.68	09/09/19 20:42	
bis(2-Chloroethyl) ether	ug/L	ND	5.0	0.76	09/09/19 20:42	
bis(2-Chloroisopropyl) ether	ug/L	ND	5.0	0.72	09/09/19 20:42	
bis(2-Ethoxyethyl)phthalate	ug/L	ND	5.0	1.0	09/09/19 20:42	
Butylbenzylphthalate	ug/L	ND	5.0	0.95	09/09/19 20:42	
Cyclohexane	ug/L	ND	5.0	0.74	09/09/19 20:42	
D-n-butylphthalate	ug/L	ND	5.0	0.80	09/09/19 20:42	
D-n-butylphthalate	ug/L	ND	5.0	0.97	09/09/19 20:42	
Dibenz(a,h)anthracene	ug/L	ND	5.0	0.74	09/09/19 20:42	
Dibenz(b,h)anthracene	ug/L	ND	5.0	0.68	09/09/19 20:42	
Dimethylphthalate	ug/L	ND	5.0	0.83	09/09/19 20:42	
Fluorene	ug/L	ND	5.0	0.75	09/09/19 20:42	
Fluorene	ug/L	ND	5.0	0.62	09/09/19 20:42	
Hexachloro-1,3-butadiene	ug/L	ND	5.0	0.81	09/09/19 20:42	
Hexachlorobenzene	ug/L	ND	5.0	0.95	09/09/19 20:42	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 20 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lorain, VA 26019
(813) 559-5665

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313697

QC Batch: 606087 Analysis Method: SM 4500-C1-G
QC Batch Method: SM 4500-C1-G Analysis Description: 4500-C1-G Chlorine, Total Residual
Associated Lab Samples: 60313697002

Mastic Vialer						
Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Chlorine, Total Residual	mg/L	ND	0.050	0.010	09/09/19 15:41	H8

LABORATORY CONTROL SAMPLE: 2484449						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Chlorine, Total Residual	mg/L	1	1.1	107	60-120 H8	

SAMPLE DUPLICATE: 2484450						
Parameter	Units	60313409001 Result	Dup Result	RPD	Max RPD	Qualifiers
Chlorine, Total Residual	mg/L	ND	ND	ND	10 H8	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 29 of 48



Pace Analytical Services, LLC
9538 Laurel Blvd
Lancaster, KS 66219
(913) 269-5065

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 605185 Analysis Method: SM 2120B
QC Batch Method: SM 2120B Analysis Description: 2120B Aesthetics
Associated Lab Samples: 60313597002

METHOD BLANK: 2485708 Matrix: Water
Associated Lab Samples: 60313597002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Arsenic, Total as CaCO ₃	mg/L	ND	20.0	6.5	09/10/19 16:00	
Arsenic/Bicarbonate (CaCO ₃)	mg/L	ND	20.0	6.5	09/10/19 16:00	

LABORATORY CONTROL SAMPLE: 2485707

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Arsenic, Total as CaCO ₃	mg/L	500	514	103	90-110	

SAMPLE DUPLICATE: 2485708

Parameter	Units	60313597002 Result	Dup Result	RPD	Max RPD	Qualifiers
Arsenic, Total as CaCO ₃	mg/L	287	281	1	10	
Arsenic/Bicarbonate (CaCO ₃)	mg/L	287	281	1	10	

SAMPLE DUPLICATE: 2485709

Parameter	Units	60314020005 Result	Dup Result	RPD	Max RPD	Qualifiers
Arsenic, Total as CaCO ₃	mg/L	181	187	4	10	
Arsenic/Bicarbonate (CaCO ₃)	mg/L	181	187	4	10	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 28 of 49



Pace Analytical Services, LLC
9538 Laurel Blvd
Lancaster, KS 66219
(913) 269-5065

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

METHOD BLANK: 2482278 Matrix: Water
Associated Lab Samples: 60313597001

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Hexachlorocyclopentadiene	ug/L	ND	5.0	0.68	09/09/19 20:42	
Hexachlorobenzene	ug/L	ND	5.0	0.74	09/09/19 20:42	
Indeno(1,2,3-cd)pyrene	ug/L	ND	5.0	0.87	09/09/19 20:42	
Isophorone	ug/L	ND	5.0	0.54	09/09/19 20:42	
N-Hydroxy-N-propylamine	ug/L	ND	5.0	0.88	09/09/19 20:42	
N-Hydroxy-N-methylamine	ug/L	ND	5.0	0.63	09/09/19 20:42	
N-Hydroxyphenylamine	ug/L	ND	5.0	0.40	09/09/19 20:42	
Naphthalene	ug/L	ND	5.0	0.68	09/09/19 20:42	
Nitrobenzene	ug/L	ND	5.0	0.51	09/09/19 20:42	
Perfluorobenzene	ug/L	ND	5.0	0.70	09/09/19 20:42	
Phenanthrene	ug/L	ND	5.0	0.87	09/09/19 20:42	
Phenol	ug/L	ND	5.0	2.6	09/09/19 20:42	
Pyrene	ug/L	ND	5.0	0.68	09/09/19 20:42	
2,4,6-Trichlorophenol (S)	%	60	24-126		09/09/19 20:42	
2-Fluorophenyl (S)	%	55	24-110		09/09/19 20:42	
2-Fluorophenol (S)	%	38	20-59		09/09/19 20:42	
Nitrobenzene-d5 (S)	%	66	24-110		09/09/19 20:42	
Phenol-d6 (S)	%	25	11-42		09/09/19 20:42	
Terphenyl-014 (S)	%	63	35-118		09/09/19 20:42	

LABORATORY CONTROL SAMPLE: 2482279

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
1,2,4-Trichlorobenzene	ug/L	50	29.0	58	64-93	
1,2-Dichlorobenzene	ug/L	50	38.8	78	62-105	
2,4,6-Trichlorophenol	ug/L	50	34.0	68	63-100	
2,4-Dichlorophenol	ug/L	50	33.0	66	58-95	
2,4-Dimethylphenol	ug/L	50	39.2	80	55-92	
2,4-Dichlorophenol	ug/L	50	33.2	66	36-137	
2,4-Dichlorophenol	ug/L	50	33.5	75	65-113	
2,6-Dichlorophenol	ug/L	50	35.2	70	65-108	
2-Chloronaphthalene	ug/L	50	33.4	67	60-98	
2-Chlorophenol	ug/L	50	32.8	66	51-89	
2-Nitrophenol	ug/L	50	34.4	69	54-110	
3,3'-Dichlorobenzidine	ug/L	50	43.6	87	64-163	
4,8-Dinitro-2-methylphenol	ug/L	50	39.0	78	58-125	
4-Bromophenylphenyl ether	ug/L	50	33.5	67	61-107	
4-Chloro-3-methylphenol	ug/L	50	35.6	71	62-98	
4-Chlorophenylphenyl ether	ug/L	50	33.4	67	63-102	
4-Nitrophenol	ug/L	50	35.5	71	60-98	
Acenaphthene	ug/L	50	34.3	69	62-101	
Acenaphthylene	ug/L	50	33.9	68	62-100	
Anthrone	ug/L	50	36.2	72	63-105	
Benidine	ug/L	50	ND	11	10-123	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 21 of 49



Pace Analytical Services, LLC
9538 Laurel Blvd
Lancaster, KS 66219
(913) 269-5065

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

LABORATORY CONTROL SAMPLE: 2482279

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Benz(a)anthracene	ug/L	50	35.6	71	65-105	
Benz(a)pyrene	ug/L	50	35.7	71	60-114	
Benz(b)fluoranthene	ug/L	50	35.5	71	60-114	
Benz(g,h,i)perylene	ug/L	50	35.9	72	66-110	
Benzophenanthrene	ug/L	50	35.7	71	59-110	
bp(2-Chlorobenzoyl)methane	ug/L	50	36.0	72	63-97	
bp(2-Chlorobenzoyl) ether	ug/L	50	36.2	72	53-97	
bp(2-Chlorobenzoyl) ether	ug/L	50	37.3	75	54-98	
bp(2-Ethylbenzoyl)phthalates	ug/L	50	35.8	79	61-121	
Butylbenzophthalates	ug/L	50	38.1	78	59-125	
Chrysene	ug/L	50	34.7	69	63-108	
Dibenz(a,h)anthracene	ug/L	50	38.8	78	65-112	
Dibenz(a,h)anthracene	ug/L	50	40.9	82	66-127	
Dibenz(a,h)anthracene	ug/L	50	35.9	72	60-111	
Dibenz(a,h)anthracene	ug/L	50	36.8	74	65-103	
Dibenz(a,h)anthracene	ug/L	50	35.9	72	64-103	
Fluorene	ug/L	50	37.3	75	64-108	
Fluorene	ug/L	50	35.0	70	65-101	
Hexachloro-1,3-butadiene	ug/L	50	28.4	57	45-94	
Hexachlorobenzene	ug/L	50	31.7	63	55-106	
Hexachlorocyclopentadiene	ug/L	50	18.8	38	18-50	
Hexachloroethane	ug/L	50	26.0	52	47-90	
Indeno(1,2,3-cd)pyrene	ug/L	50	35.5	71	60-110	
Isophorone	ug/L	50	39.0	78	62-97	
N-Hydroxy-N-propylamine	ug/L	50	38.9	78	59-100	
N-Hydroxy-N-methylamine	ug/L	50	29.2	58	20-87	
N-Hydroxyphenylamine	ug/L	50	34.3	69	61-102	
Naphthalene	ug/L	50	33.2	66	55-94	
Nitrobenzene	ug/L	50	36.5	73	59-95	
Perfluorobenzene	ug/L	50	31.2	62	54-121	
Phenanthrene	ug/L	50	35.8	72	63-105	
Phenol	ug/L	50	16.0	32	17-44	
Pyrene	ug/L	50	35.8	71	63-108	
2,4,6-Trichlorophenol (S)	%	61	24-126			
2-Fluorophenyl (S)	%	62	24-110			
2-Fluorophenol (S)	%	37	20-59			
Nitrobenzene-d5 (S)	%	70	24-110			
Phenol-d6 (S)	%	25	11-42			
Terphenyl-014 (S)	%	65	35-118			

MATRIX SPIKE SAMPLE: 2482280

Parameter	Units	60313841001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
1,2,4-Trichlorobenzene	ug/L	ND	200	84.3	42	44-109	M1
1,2-Dichlorobenzene	ug/L	ND	200	113	57	16-120	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 22 of 49



Pace Analytical Services, LLC
9538 Laurel Blvd
Lancaster, KS 66219
(913) 269-5065

QUALITY CONTROL DATA

Project: ANNUAL PP AND DNR POLLUTANT
Pace Project No.: 60313597

QC Batch: 605727 Analysis Method: SM 2110B
QC Batch Method: SM 2110B Analysis Description: 2110B Acidity, Total
Associated Lab Samples: 60313597002

METHOD BLANK: 2469344 Matrix: Water
Associated Lab Samples: 60313597002

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Acidity, Total	mg/L	ND	20.0	1.0	09/17/19 09:40	

LABORATORY CONTROL SAMPLE: 2469345

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Acidity, Total	mg/L	400	508	104	90-110	

SAMPLE DUPLICATE: 2469346

Parameter	Units	60313597002 Result	Dup Result	RPD	Max RPD	Qualifiers
Acidity, Total	mg/L	ND	ND		13	

SAMPLE DUPLICATE: 2469347

Parameter	Units	60314020003 Result	Dup Result	RPD	Max RPD	Qualifiers
Acidity, Total	mg/L	ND	ND		13	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 09/26/2019 02:10 PM

Page 27 of 49



Pace Analytical Services, LLC
9608 Laurel Blvd
Lancaster, PA 17601
(717) 569-5955

QUALITY CONTROL DATA

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313697

QC Batch: 603118
QC Batch Method: EPA 1664A
Associated Lab Samples: 60313697002
Analysis Method: EPA 1664A
Analysis Description: 1664 HEM, Oil and Grease

METHOD BLANK: 2485011
Associated Lab Samples: 60313697002
Matrix: Water

Parameter Units Blank Result Reporting Limit MDL Analyzed Qualifiers

Oil and Grease mg/L ND 5.0 13 09/13/19 08:38

LABORATORY CONTROL SAMPLE: 2485012

Parameter Units Spike Conc LCS Result LCS % Rec % Rec Limits Qualifiers

Oil and Grease mg/L 40 39.8 100 78-114

MATRIX SPIKE SAMPLE: 2485013

Parameter Units 60314479002 Spike Conc MS Result MS % Rec % Rec Limits Qualifiers

Oil and Grease mg/L 10.0 95 114 93 78-114

SAMPLE DUPLICATE: 2485014

Parameter Units 60314479003 Dup Result RPD Max RPD Qualifiers

Oil and Grease mg/L 10.0 37.7 78 18 D9

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 26 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lancaster, PA 17601
(717) 569-5955

QUALITY CONTROL DATA

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313697

MATRIX SPIKE SAMPLE: 2482260

Parameter Units 60313841001 Spike Conc MS Result MS % Rec % Rec Limits Qualifiers

2,4-Dichlorophenol ug/L ND 200 119 59 37-123

2,4-Dichlorophenol ug/L ND 200 114 57 39-115

2,4-Dichlorophenol ug/L ND 200 119 59 32-116

2,4-Dichlorophenol ug/L ND 200 129 65 10-154

2,4-Dichlorophenol ug/L ND 200 114 57 39-122

2,4-Dichlorophenol ug/L ND 200 128 64 50-119

2,4-Dichlorophenol ug/L ND 200 93 49 90-98 M1

2-Chlorophenol ug/L ND 200 103 52 35-81

2-Naphthol ug/L ND 200 110 55 29-132

3,3-Dichlorobenzene ug/L ND 200 14.5 7 10-156 M1

4-Bromobenzene ug/L ND 200 116 59 10-155

4-Bromobenzene ug/L ND 200 113 56 53-115

4-Chlorobenzene ug/L ND 200 145 73 39-105

4-Chlorobenzene ug/L ND 200 109 53 29-111

4-Nitrophenol ug/L ND 200 75 38 17-49

Azobenzene ug/L ND 200 105 53 47-110

Azobenzene ug/L ND 200 102 51 33-110

Azobenzene ug/L ND 200 111 55 27-114

Benzene ug/L ND 200 ND 0 10-18 M1

Benzene ug/L ND 200 113 57 33-113

Benzene ug/L ND 200 115 57 28-116

Benzene ug/L ND 200 122 61 28-121

Benzene ug/L ND 200 104 52 24-118

Benzene ug/L ND 200 106 53 28-116

Benzene ug/L ND 200 116 58 33-109

Benzene ug/L ND 200 107 57 27-109 M1

Benzene ug/L ND 200 112 56 26-113

Benzene ug/L ND 200 141 65 33-128

Benzene ug/L ND 200 129 64 32-131

Benzene ug/L ND 200 106 54 30-116

Benzene ug/L ND 200 124 62 31-120

Benzene ug/L ND 200 137 68 27-142

Benzene ug/L ND 200 107 53 25-119

Benzene ug/L ND 200 115 57 30-112

Benzene ug/L ND 200 109 55 29-111

Benzene ug/L ND 200 113 57 28-115

Benzene ug/L ND 200 107 54 29-111 M1

Benzene ug/L ND 200 98 49 23-107

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 23 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lancaster, PA 17601
(717) 569-5955

QUALITY CONTROL DATA

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313697

MATRIX SPIKE SAMPLE: 2482260

Parameter Units 60313841001 Spike Conc MS Result MS % Rec % Rec Limits Qualifiers

Nitrobenzene ug/L ND 200 108 54 35-118

Nitrobenzene ug/L ND 200 127 64 14-147

Nitrobenzene ug/L ND 200 109 54 54-113

Nitrobenzene ug/L ND 200 112 56 18-42

Nitrobenzene ug/L ND 200 117 59 52-115

Nitrobenzene (S) % 52 24-128

Nitrobenzene (S) % 48 24-110

Nitrobenzene (S) % 52 20-59

Nitrobenzene (S) % 56 24-110

Nitrobenzene (S) % 22 11-42

Nitrobenzene (S) % 55 55-118

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 24 of 48



Pace Analytical Services, LLC
9608 Laurel Blvd
Lancaster, PA 17601
(717) 569-5955

QUALITY CONTROL DATA

Project: ANNUAL PP AND DMR POLLUTANT
Pace Project No.: 60313697

QC Batch: 610408
QC Batch Method: EPA 120.1
Associated Lab Samples: 60313697002
Analysis Method: EPA 120.1
Analysis Description: 120.1 Specific Conductance

METHOD BLANK: 2493803
Associated Lab Samples: 60313697002
Matrix: Water

Parameter Units Blank Result Reporting Limit MDL Analyzed Qualifiers

Specific Conductance umhos/cm ND 1.0 1.0 09/19/19 15:42

SAMPLE DUPLICATE: 2493804

Parameter Units 60313697002 Dup Result RPD Max RPD Qualifiers

Specific Conductance umhos/cm 993 893 0 20

SAMPLE DUPLICATE: 2493805

Parameter Units 60314203004 Dup Result RPD Max RPD Qualifiers

Specific Conductance umhos/cm 993 893 1 20


Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Date: 09/26/2019 02:10 PM

Page 25 of 48



October 22, 2019

Clara Haenchen
City of Jefferson City Wastewater Treatment
Plant
401 Old Mokane Rd
Jefferson City, MO 65101

RE: Project: ACUTE WET TEST ALGOA
Pace Project No.: 60317621

Enclosed are the analytical results for sample(s) received by the laboratory on October 10, 2019. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/ELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Nolie Wood
nolie.wood@pacelabs.com
1(913)563-1401
Project Manager

Enclosures

cc: Bradley Kieflner, City of Jefferson WWTP
Jacob Schroeder, City of Jefferson City, MO Wastewater
Treatment Plant
Emily Valbers, City of Jefferson City WWTP

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Page 1 of 19



Pace Analytical Services, LLC
9603 Lantry Blvd
Lenexa, KS 66219
(913) 259-6595

CERTIFICATIONS

Project: ACUTE WET TEST ALGOA
Pace Project No: 60317621

Southeast Kansas Certification IDs
803 West McKay, Frontenac, KS 66783
Arkansas Certification #: 18-018-0
Iowa Certification #: 118
Kansas/NELAP Certification #: E-10428

Louisiana Certification #: 03055
Oklahoma Certification #: 9935
Texas Certification #: T104704407
Utah Certification #: KS00021

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC

Page 2 of 18

Form 10-100 (Rev. 1-77)

U.S. DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain of Custody is a LEGAL DOCUMENT. All Entries Must Be Completed Accurately.

Section B
Case Information

Case No. 100-443887
 Sub Case No. 100-443887-1
 Date of Report 10-1-78
 Date of Collection 9-27-78
 Date of Analysis 10-1-78
 Name of Laboratory FBI Lab

Section C
Specimen Information

Specimen No. 100-443887-1-1
 Name of Specimen 100-443887-1-1
 Date of Collection 9-27-78
 Date of Analysis 10-1-78
 Name of Laboratory FBI Lab

Section D
Requesting Agency

Requesting Agency FBI Lab
 Address 2500 16th St NW
 City Washington, DC
 State DC
 Zip 20037

Section E
Chain of Custody

No.	Name	Signature	Date
1	John Doe	<i>[Signature]</i>	9-27-78
2	Jane Smith	<i>[Signature]</i>	9-28-78
3	Bob Johnson	<i>[Signature]</i>	9-29-78
4	Alice Brown	<i>[Signature]</i>	9-30-78
5	Charlie White	<i>[Signature]</i>	10-1-78

Section F
Analysis Results

Item #	Description	Analysis Results
1	Sample 1	Analysis Results
2	Sample 2	Analysis Results
3	Sample 3	Analysis Results
4	Sample 4	Analysis Results
5	Sample 5	Analysis Results

Section G
Remarks

[Handwritten Remarks]

Section H
Signatures

Analyst [Signature]
 Supervisor [Signature]
 Date 10-1-78

Page 19 of 19

PACE # 60317621



Pace Analytical Services, LLC
9608 Loriet Blvd
Lenexa, KS 66219
(813) 609-5555

QUALITY ASSURANCE:

The absence of control mortality during this test indicated the health of the organisms and indicated that any significant mortality in the test concentrations is not due to contaminants or variations in test conditions. Reference toxicity tests are routinely performed by staff members of our Toxicology Department.

REFERENCE TOXICANT (NaCl)

CONC OF TOXICANT	TEST INITIATION	24 HOUR EXPOSURE	48 HOUR EXPOSURE
3.0 g/l	20	2	0
2.5 g/l	20	15	8
2.0 g/l	20	19	18
1.5 g/l	20	20	20
1.0 g/l	20	20	20

LC50 = 2.33 g/l NaCl

REFERENCE TOXICANT (NaCl)

CONC OF TOXICANT	TEST INITIATION	24 HOUR EXPOSURE	48 HOUR EXPOSURE
10.0 g/l	40	6	0
8.0 g/l	40	38	25
6.0 g/l	40	39	38
4.0 g/l	40	40	40
2.0 g/l	40	40	40

LC50 = 8.27 g/l NaCl

Submitted By: *Tim Harrell*
Timothy Harrell
Technical Director

SAMPLE SUMMARY

Project: ACUTE WET TEST ALGOA
Pace Project No.: 60317621

Lab ID	Sample ID	Matrix	Date Collected	Date Received
60317621001	ALGOA LAGOON	Water	10/09/19 14:20	10/10/19 08:00

Page 9 of 9

Page 18 of 19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC

Page 3 of 19



Pace Analytical Services, LLC
9608 Loriet Blvd
Lenexa, KS 66219
(813) 609-5555

PACE # 60317621

SAMPLE ANALYTE COUNT

Project: ACUTE WET TEST ALGOA
Pace Project No.: 60317621

Lab ID	Sample ID	Method	Analyst	Analyses Reported	Laboratory
60317621001	ALGOA LAGOON	EPA 82141-02/012	MEB	1	PAS-SE

INITIAL WATER QUALITY:

Initial Measurements Synthetic Water

pH	D.O. (mg/l)	Cond. (umhos)	Cl2 (mg/l)	Temp (C)	Hard (mg/l)	Alk (mg/l)
7.59	8.10	340	<0.1	25.0	98	64

Initial Measurements of 100% Effluent

pH	D.O. (mg/l)	Cond. (umhos)	Cl2 (mg/l)	Temp (C)	Hard (mg/l)	Alk (mg/l)
8.14	8.20	1269	<0.1	25.0	266	384

TEST WATER QUALITY:

24-hour Water Quality Measurements

EFFLUENT CONC (%)	pH	D.O. (mg/l)	TEMP (C)	COND (umhos)
Synthetic	7.68	7.80	24.9	347
2.5%	7.69	7.80	24.9	349
4.5%	7.71	7.89	24.9	356
9%	7.76	7.89	24.9	371
18%	7.82	7.93	24.9	402
36%	7.91	7.98	24.9	760

48-hour Water Quality Measurements

EFFLUENT CONC (%)	pH	D.O. (mg/l)	TEMP (C)	COND (umhos)
Synthetic	7.74	7.50	25.0	356
2.5%	7.76	7.50	25.0	361
4.5%	7.79	7.60	25.0	374
9%	7.86	7.60	25.0	386
18%	7.94	7.70	25.0	511
36%	8.01	7.89	25.0	769

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC

Page 4 of 19

Page 8 of 9

Page 17 of 19



WATER CHEMISTRY RESULTS:

Total residual chlorine (Cl₂) - The effluent sample from the City of Jefferson City (Algoa Lagoon) discharge had <0.1 mg/l detectable level of total residual chlorine upon receipt in the laboratory.

Dissolved Oxygen (D.O.) - Dissolved oxygen reading of the 100% effluent sample was 8.20 mg/l after being raised to the test temperature of 25° C. At termination D.O. was 7.80 mg/l in the 10% effluent, which falls into acceptable limits. Aeration was not required in this test.

pH - The pH of the 100% effluent was 8.14 upon receipt in the laboratory and the synthetic control had a 7.59. At termination the pH measurement in the 10% effluent sample was 8.61.

Conductance - The conductance of the effluent sample was 1269 umhos and the synthetic control was 340 umhos.

ANALYTICAL RESULTS

Project: ACUTE WET TEST ALGOA		Lab ID: 60317621001		Collected: 10/22/19 14:20		Received: 10/10/19 03:00		Matrix: Water	
Pace Project No.: 60317621		Sample: ALGOA LAGOON		Report Limit: MDL		DF		Prepared	
Parameters	Results	Units	Report Limit	MDL	DF	Prepared	Analyzed	CAS No.	Qual
Acute Toxicity	Analytical Method: EPA 821-R-02-012								
Toxicity Acute	Complete		1.0	1.0	1	10/10/19 14:30			

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC



QUALIFIERS

Project: ACUTE WET TEST ALGOA
Pace Project No.: 60317621

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.
ND - Not Detected at or above adjusted reporting limit.
TNTC - Too Numerous To Count
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.
MDL - Adjusted Method Detection Limit
POL - Practical Quantitation Limit
RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix
S - Surrogate
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.
LCS(D) - Laboratory Control Sample (Duplicate)
MS(D) - Matrix Spike (Duplicate)
DUP - Sample Duplicate
RPD - Relative Percent Difference
NC - Not Calculable
SG - Spill Gel - Clean-Up
U - Indicates the compound was analyzed for, but not detected.
N-Methylsopharylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Pace Analytical is TML accredited. Contact your Pace PM for the current list of accredited analytes.
TNI - The NELAP Institute

LABORATORIES

PAS-SE Pace Analytical Services - SE Kansas

THE Phosphates RESULTS - Minnows exposed to effluent collected at the City of Jefferson City (Algoa Lagoon) effluent discharge exhibited no significant mortality in the 10% effluent concentration during the 48 hr exposure period. The synthetic control showed no significant mortality during the testing period. The LC50 value of the effluent to fathead minnows is estimated to be >10% the TUs <2.78.

CONC.	REPS	0 HOURS	24 HOURS	48 HOURS	% MORTALITY
SYNTHETIC	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0
2.35%	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0
4.55%	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0
5%	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0
18%	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0
36%	1	10	10	10	0
"	2	10	10	10	0
"	3	10	10	10	0
"	4	10	10	10	0

AVG. MORTALITY @ 10% EFFLUENT = 0.0%

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC



QUALITY CONTROL DATA CROSS REFERENCE TABLE

 Project: ACUTE VMT TEST ALGOA
 Pace Project No.: 60317621

Lab ID	Sample ID	QC Batch/Method	QC Batch	Analytical Method	Analytical Batch
60317621001	ALGOA LAGOON	EPA 821-H-02-012	815769		

RESULTS:

THE Ceriodaphnia MORTALITY RESULTS - There was no significant mortality observed of the freshwater invertebrate, Ceriodaphnia dubia during the 48 hour exposure period to the 36% effluent concentrations. There was no significant mortality in the synthetic control. The LC50 value of the sample to Ceriodaphnia is approximately >36% the TUA <2.7A.

Ceriodaphnia MORTALITY DATA

# ALIVE					
CONC.	REP #	0 HOURS	24 HOURS	48 HOURS	% MORT.
SYNTHETIC	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0
2.25%	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0
4.5%	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0
9%	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0
18%	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0
36%	1	5	5	5	0
	2	5	5	5	0
	3	5	5	5	0
	4	5	5	5	0

AVG. MORTALITY @ (36% EFFLUENT) = 0.0%

REPORT OF LABORATORY ANALYSIS

 This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC

Client Name: Jeff City

Courier: FedEx ☐ UPS ☐ VIA ☒ Clay ☐ PEX ☐ ECH ☐ Xroads ☐ Creek ☐ Other ☐

Tracking #: 92743

Custody Seal on Cooler/Box Present: ☒ No ☐ Yes ☐ (If Yes, Initials:)

Packing Material: Ice Packs

Thermometer Used: 1.243

Cooler Temperature (°C): 3.7 As-read 3.9 Cor Factor -0.2 Corrected 3.9

Temperatures should be above freezing to 5°C

Date and initials of person receiving contents: 10/10/19 gwc

Chain of Custody present	<input checked="" type="checkbox"/>	Yes	No	Other
Chain of Custody relinquished	<input checked="" type="checkbox"/>	Yes	No	Other
Temperatures within holding time	<input checked="" type="checkbox"/>	Yes	No	Other
Short Hold Time analysis (<72hr)	<input checked="" type="checkbox"/>	Yes	No	Other
Push Turn Around Time requested	<input checked="" type="checkbox"/>	Yes	No	Other
Sufficient volume	<input checked="" type="checkbox"/>	Yes	No	Other
Correct containers used	<input checked="" type="checkbox"/>	Yes	No	Other
Acc containers used	<input checked="" type="checkbox"/>	Yes	No	Other
Containers sealed	<input checked="" type="checkbox"/>	Yes	No	Other
Preserved 5035A / TX 1055/1000 seals frozen in 48hrs?	<input checked="" type="checkbox"/>	Yes	No	Other
Sealed vials received for dissolving tests?	<input checked="" type="checkbox"/>	Yes	No	Other
Sample labels match COC Data time / HPLC analyses	<input checked="" type="checkbox"/>	Yes	No	Other
Analyses contain multiple phases?	<input checked="" type="checkbox"/>	Yes	No	Other
Containers requiring pH preservation in compliance?	<input checked="" type="checkbox"/>	Yes	No	Other
NO ₃ , NO ₂ , NH ₄ , H ₂ O ₂ , H ₂ SO ₄ , H ₂ PO ₄ , H ₂ CO ₃ (Cyanide)	<input checked="" type="checkbox"/>	Yes	No	Other
Residual VOA, VOA, OAS, OAS, OAS, OAS, OAS	<input checked="" type="checkbox"/>	Yes	No	Other
Residual water sample checks	<input checked="" type="checkbox"/>	Yes	No	Other
Residual ship turn time (if present)	<input checked="" type="checkbox"/>	Yes	No	Other
Residual in VOA vials (>60%)	<input checked="" type="checkbox"/>	Yes	No	Other
Complex from USDA Regulated Area	<input checked="" type="checkbox"/>	Yes	No	Other
Additional labels attached to 5035A: TX 1055/1000 vials in the field	<input checked="" type="checkbox"/>	Yes	No	Other
Residual Notification Resolution	<input checked="" type="checkbox"/>	Yes	No	Other
Residual Contacted	<input checked="" type="checkbox"/>	Yes	No	Other
Residual Resolution	<input checked="" type="checkbox"/>	Yes	No	Other

gsc Manager Review

INTRODUCTION:

The purpose of this test was to determine the acute toxicity of the City of Jefferson City (Alga Lagoon) effluent on the freshwater invertebrate, *Ceriodaphnia dubia* and the fathead minnow, *Pimephales promelas*. These tests were conducted at Pace Analytical Services, Inc., Frontenac, KS.

TEST ORGANISMS:

Ceriodaphnia dubia - The genetic stock of *Ceriodaphnia dubia* used in this acute toxicity test were originally obtained from a private breeder. *Ceriodaphnia* are cultured in house at Pace Analytical Services, Inc. Culture methods of *Ceriodaphnia* were obtained from EPA821-G-02-006, November 2002.

Pimephales promelas - The fathead minnows used in this acute toxicity test were cultured in-house at Pace Analytical Services, Inc., Frontenac, KS and/or were obtained from a private breeder. Fathead minnows are maintained at Pace Analytical Services until use for acute toxicity between the ages of 1 and 14 days. Information for culturing fathead minnows was taken from EPA821-G-02-006, November 2002.

MATERIALS AND METHODS:

Procedures used in the acute toxicity tests are described in Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms (EPA, 2002).

City of Jefferson City (Alga Lagoon) personnel collected the effluent tested from the City of Jefferson City (Alga Lagoon) discharge. Testing was performed using a 30% effluent, a series of dilutions, and a synthetic control. The toxicity test was initiated within 16 hours of sample collection.

Effluent and synthetic control test solutions were not aerated during the testing period.

Ceriodaphnia ACUTE METHODS:

This static test was run using 40 ml glass vials containing 25 ml of test solution. Feed was administered before the test. Five *Ceriodaphnia* neonates (<24 hr old) were randomly selected and placed in each of 4 replicates of test solution. A total of 20 organisms per concentration were tested. Observations of mortality were made at 24 and 48 hours of exposure.

CHAIN-OF-CUSTODY / Analytical Request Document

This Chain of Custody is a LEGAL DOCUMENT. All recorded data must be completed accurately.

Section A: Requester Information		Section B: Sample Information		Section C: Test Information		Section D: Laboratory Information	
Requester Name: City of Jefferson City Requester Address: 401 Old McKane Rd Requester City/State/Zip: Jefferson City, MO 65101 Requester Phone: 573-634-6566 Requester Email: Emily.Wibers@jeffersoncitymo.gov		Sample ID: Alga Lagoon Sample Description: Effluent Sample Date/Time: 10/14/19 14:00 Sample Location: City of Jefferson City (Alga Lagoon)		Test Name: Acute Toxicity Test Date/Time: 10/14/19 14:00 Test Location: Pace Analytical Services, Inc.		Laboratory Name: Pace Analytical Services, Inc. Laboratory Address: 808 West McKay, Frontenac, KS 66763 Laboratory Phone: 781-866-8888 Laboratory Email: info@paceanalytical.com	
Requester Signature: [Signature] Requester Title: Technical Director		Sample Collector: [Signature] Sample Collector Title: [Title]		Test Performer: [Signature] Test Performer Title: [Title]		Laboratory Director: [Signature] Laboratory Director Title: [Title]	
Requester Comments:		Sample Comments:		Test Comments:		Laboratory Comments:	

October 14, 2019

City of Jefferson City (Alga Lagoon)
Emily Wibers
401 Old McKane Rd
Jefferson City, MO 65101

Re: Lab Project Number: 60317621
Client Project ID: Wet Test

Dear:

Enclosed are the analytical results for sample(s) received by the laboratory. The results relate only to the samples included in this report. Results reported herein conform to the most current NELAP standards, where applicable, unless otherwise noted in the body of the report.

If you have any question concerning this report, please feel free to contact me.

Sincerely,

Tim Hamell

Tim Hamell
tim.hamell@paceanalytical.com
Technical Director

Pace Analytical Services, Inc.

808 West McKay, Frontenac, KS 66763

LABORATORY REPORT:

CLIENT: City of Jefferson City (Alga Lagoon)
Attn: Emily Wibers
401 Old McKane Rd.
Jefferson City, MO 65101
573-634-6566

Date Reported: 10-14-19
Date Initiated: 10-10-19
Time Set: 14:00
Date Terminated: 10-12-19

BIOMONITORING STUDY

ACUTE TOXICITY

Permit # MO-0044300

FINDING AND CONCLUSIONS:

Acute toxicity testing was performed on duplicate samples of effluent collected from the City of Jefferson City (Alga Lagoon) effluent discharge. Acute toxicity, as defined by significant mortality for at least one of two aquatic test species during a 48 hour period of exposure, was not detected in *Ceriodaphnia dubia* exposed to the 30% effluent, and was not detected in fathead minnows exposed to the 30% effluent. The LC50 for the *Ceriodaphnia dubia* was >30% and >36% for the *Pimephales*. The test species utilized in this test were the water flea *Ceriodaphnia dubia* and the fathead minnow, *Pimephales promelas*. Detailed results of the toxicity testing are provided in the Acute Toxicity Reports. In addition to the acute toxicity testing, water temperature, pH, dissolved oxygen, total hardness, total alkalinity, conductivity, and chloride determinations were performed on the effluent and control samples.

SAMPLING PROCEDURES:

City of Jefferson City (Alga Lagoon) personnel collected a sample at the City of Jefferson City (Alga Lagoon) effluent discharge. The sample was preserved with ice and transported to Pace Analytical by commercial carrier.

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 08 November 2018

Sample No.: 1042 / Algae Lagoon Effluent, 11-5-18, 9:30 am
Description:

TEST RESULTS:

Parameter:	1042	Units	Detection	Method
Whole Effluent Toxicity	"		n/a	

Sample received and delivered to laboratory by others.
**See attached report from EA South Laboratory

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community
Development
email: jenny

Engineering Surveys & Services

BY:

DJB

43147

Derek J. Bresler

Environmental Analysis South, Inc.

4060 East Jackson Blvd. • Jackson, MO 63105 • 673-204-8817 • Fax 573-204-6916



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001 (grab) AEC = 9%
MO-0044300
EAS LOG# 2305705
November 7, 2018 through November 9, 2018

Tests performed by:

John P. Clippard / Chemical Analyst at Environmental Analysis South (EAS)
Kelly J. Ray / Biologist at Environmental Analysis South (EAS)
Sara C. Shields / Lab Supervisor - Chemist at Environmental Analysis South (EAS)
David F. Warren / Lab Director - Chemist at Environmental Analysis South (EAS)

1. Report Summation
 - 1.1. Data Summation
 - 1.2. Conclusion
2. Method Summation
 - 2.1. Test Conditions and Methods
 - 2.2. Potassium chloride Reference Salt Test
 - 2.2.1. *Pimephales promelas* data
 - 2.2.2. *Caridophila dubia* data
 - 2.3. Literature Cited
3. Raw Data Bench Sheets
 - 3.1. Initial observations (page 1)
 - 3.2. Zero hour Observations (page 1)
 - 3.3. Twenty-four (24) hour Observations (page 1)
 - 3.4. Forty-eight (48) hour Observations (page 1)
 - 3.5. Survival Data Table (page 2)
 - 3.6. Test Comments (page 3)
4. Chain of Custody
5. MO DNR "Whole Effluent Toxicity (WET) Test Report (Form 760-1899)



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001(grab) AEC = 9%
MO-0044300
EAS LOG# 2305706
November 7, 2018 through November 8, 2018

1. REPORT SUMMATION:

1.1. Multiple Dilution Data Summation

Test Solution	<i>Pimephales promelas</i> Acute Toxicity Test 48 Hour Survival	<i>Ceriodaphnia dubia</i> Acute Toxicity Test 48 Hour Survival
Reconstituted Control (RC)	100%	100%
Upstream Control (UC)	N/A	N/A
2.25% Effluent	100%	100%
4.6% Effluent	100%	100%
9% Effluent	100%	100%
18% Effluent	100%	100%
36% Effluent	100%	100%
Estimated 48 Hour LC ₅₀ Value	>36% Effluent	>36% Effluent
TU ₀₁ Value	<2.78	<2.78
Result of Toxicity Test	Monitor	Monitor

* Indicates a significant difference at alpha = 0.5 between effluent and control survival data.

Conclusion:
Fimephales promelas 48 hour WET results:
 LC 50=36% using the Graphical Method
 NOAEC = 36% by Steer's Many-One Rank Test
 TU₀₅=2.78
Ceriodaphnia dubia 48 hour WET results:
 LC 50=35% using the Graphical Method
 NOAEC = 36% by Steer's Many-One Rank Test
 TU₀₅=2.78

Approved by _____

Sara C. Shields, Chemist

Page 2 of 4

Analytical Chemistry • Research • Field Studies

Environmental Analysis South, Inc.
4030 East Jackson Blvd. • Jackson, MO 63755 • 873-204-8617 • Fax 873-204-8818



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001 (grab) AEC = 9%
MO-0044300
EAS LOG# 2305706
November 7, 2018 through November 9, 2018

2. TEST METHOD SUMMARY

2. TEST METHOD SUMMARY

2.1. TEST CONDITIONS AND METHODS:		
	<i>Ceriodaphnia dubia</i> :	<i>Pimephales promelas</i> :
Test duration:	48 hours	48 hours
Temperature:	24 ± 26 degree Celsius	24 - 28 degree Celsius
Light quality:	Ambient laboratory illumination	Ambient laboratory illumination
Photoperiod:	16 hour light, 8 hours dark	16 hour light, 8 hours dark
Control Water:	Moderately Hard Reconstituted Water	Moderately Hard Reconstituted Water
Dilution Water:	Upstream Water - If unavailable or poor, then control water will be used.	Upstream Water - If unavailable or poor, then control water will be used.
Size of test vessel:	80 milliliters	250 milliliters
Volume of test solution:	16 milliliters	200 milliliters
Age of test organisms	<24 hours	1-14 days (all same age)
Number of organisms/test vessel:	6	10
Number of replicates/concentration:	4	2
Number of organisms/concentration	20	40 for a single dilution test and 20 for a multiple dilution test
Feeding regime:	None (fed prior to test)	None (fed prior to test)
Aeration:	None	None
Test acceptability criterion:	90% or greater survival in controls	90% or greater survival in controls

The methodology used for the chemistry data was taken from the *Standard Methods for the Examination of Water and Wastewater*, 16th edition (1992). The exception was hardness, which was determined using a Hach EDTA titration test kit. The toxicity tests follow guidelines laid out in the permittee's NPDES permit and were conducted according to EPA approved methods (USEPA 2002).

All test organisms were cultured according to EPA approved methods (USEPA 2002). The *Ceriodaphnia dubia* and the *Pimephales promelas* were obtained from Environmental Enterprises USA Inc. located in Slidell, Louisiana and shipped overnight for use in the whole effluent toxicity test.

Page 3 of 4

Analytical Chemistry • Research • Fluid Studies

SAMPLE CHAIN OF CUSTODY RECORD

1113 Fay Street * Columbia, Missouri 65201 * (573) 449-2646
802 El Dorado Drive * Jefferson City, Missouri 65101 * (573) 636-3303
1175 W. Main Street * Sedalia, Missouri 65301 * (660) 826-8618

[illegible]

Sample Collected By _____ Company/Organization Engineering Services & Services

Date/Time	Address <u>Columbin, CID</u>		
Samples Relinquished By/Phone	Samples Received By	Date/Time	
<u>[Signature]</u>	<u>[Signature]</u>	<u>FedEx</u>	<u>4 NOV 17 12:00 PM</u>
			<u>11/17/17</u> <u>1055</u>



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001 (grab) AEC = 9%
MO-0044300
EAS LOG# 2305706

2.2. REFERENCE TOXICITY TEST:
Environmental Analysis South performs monthly reference toxicity tests. The most recent reference test was initiated on November 7, 2018 using KCL Lot #41713. Following are the results:

2.2.1. *P. promelas* - 48 hr. Acute Test $LC_{50} = 1.227$ g/L 95%CI (0.929 g/L - 1.525 g/L)
EAS % CV = 12.2%
National Warning Limits (75th percentile) = 19%CV
National Control Limits (90th percentile) = 33%CV

2.2.2. *C. dubia* - 48 hr. Acute Test $LC_{50} = 0.118$ g/L 95%CI (0.178 g/L - 0.851g/L)
EAS % CV = 26.6%
National Warning Limits (75th percentile) = 29%CV
National Control Limits (90th percentile) = 34%CV

2.3. LITERATURE CITED:

1. APHA. 1992. *Standard methods for the examination of water and wastewater*, 18th Ed. American Public Health Association, Washington, D.C.
2. USEPA. 2002. *Methods for measuring the acute toxicity of effluents and receiving waters to freshwater and marine organisms*, 8th Ed. EPA-821-R-02-012.
3. USEPA 2000. *Understanding and Accounting for Model Variability in Whole Effluent Toxicity Applications under the National Pollutant Discharge Elimination System*, (Table H-2). June 2000. EPA 833-R-00-003.

Page 4 of 4

Analytical Chemistry • Research • Field Studies

[illegible]

Date: 11/3/18

Approved by _____

Analyst 1:	DFW
Analyst 2:	KJR
Analyst 3:	SCS

--	--

Time Test Elapsed Time

Nov

[illegible][illegible]

Project: City of Jefferson
Location: Jefferson City, Missouri

Date Received: 14 November 2017

Sample No.: 2923 / Algae Lagoon Effluent, 11/14/17, 8:55am
Description:

TEST RESULTS:

Parameter:	2923	Units	Detection	Method
Whole Effluent Toxicity	**		n/a	

Samples secured by others
**See attached report

Method number from "Standard Methods for the Examination of Water & Wastewater", current edition, unless noted otherwise.

cc: Community Development
1. Clara Henderson
Hannchen/Wilkins,
Kiefer
20149

Engineering Surveys & Services

BY:

Derek J. Broster

Environmental Analysis South, Inc.

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-264-8917 • Fax 573-264-8918



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001 (grab) AEC = 5%
MO-0044300
EAS LOG# 2202110
November 15, 2017 through November 17, 2017

Tests performed by:

John P. Cippard / Chemical Analyst at Environmental Analysis South (EAS)
Kelly J. Ray / Biologist at Environmental Analysis South (EAS)
Sara C. Shields / Lab Supervisor - Chemist at Environmental Analysis South (EAS)
David F. Warren / Lab Director - Chemist at Environmental Analysis South (EAS)

- Report Summation
 - 1.1. Data Summation
 - 1.2. Conclusion
- Method Summation
 - 2.1. Test Conditions and Methods
 - 2.2. Potassium chloride Reference Salt Test
 - 2.2.1. *Pimephales promelas* data
 - 2.2.2. *Ceriodaphnia dubia* data
 - 2.3. Literature Cited
- Raw Data Bench Sheets
 - 3.1. Initial observations (page 1)
 - 3.2. Zero hour Observations (page 1)
 - 3.3. Twenty-four (24) hour Observations (page 1)
 - 3.4. Forty-eight (48) hour Observations (page 1)
 - 3.5. Survival Data Table (page 2)
 - 3.6. Test Comments (page 3)
- Chain of Custody
- MO DNR "Whole Effluent Toxicity (WET) Test Report (Form 780-1899)

WHOLE EFFLUENT TOXICITY (WET) TEST REPORT (TO BE ATTACHED TO WET TESTS FOR SUBMISSION TO THE REGULATORY AUTHORITY)

MINIMUM REQUIRED ANALYTICAL RESULTS FOR THE 100% UPSTREAM SAMPLE			
PARAMETER	RESULT	METHOD	WHEN ANALYZED
Temperature °C	21	SM16 2650B stored at 4 degree C until test setup	11/14/17 1345 hrs
pH Standard Units	8.43	SM16 4500-H B	11/14/17 1345 hrs
Conductance μmhos	249	SM16 2510B	11/14/17 1345 hrs
Dissolved Oxygen mg/L	9.28.7	SM16 4500-O G	11/14/17 1345 hrs
Total Residual Chlorine mg/L	<0.04	SM16 4500-Cl G	11/14/17 1345 hrs
Un-ionized Ammonia mg/L	<0.05x0.12<0.010	SM16 4500-NH3 F @ 25 degree C	11/17/17 1615 hrs
Total Alkalinity mg/L	68.2	SM16 2320B	11/17/17 1300 hrs
Total Hardness mg/L	72.6	SM16 2340 C	11/17/17 1330 hrs

*Recommended by USEPA guidance, not a required analysis.

PRELIMINARY TEST ACCEPTABILITY MATRIX (FOR USE BY PERMITTEE IN DETERMINING TEST VALIDITY)

PERMIT ALLOWABLE EFFLUENT CONCENTRATION (AEC): As indicated on permit. Test is invalid otherwise.
EFFLUENT SAMPLE TYPE: As indicated on permit. Test is invalid otherwise.
TEST TYPE: Acute Static Non-Renewal Test or other as indicated on permit. Test is invalid otherwise.
TEST DURATION: Forty-eight (48) hours or as indicated on permit. Test is invalid otherwise.
TEST ORGANISMS: As indicated on permit. Test is invalid otherwise.
DILUTION WATER USED TO ACHIEVE AEC: Upstream receiving water required if available.
TEST METHOD: The only acceptable method is the most current edition of *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, or other as specifically assigned by EPA for determining TPODES compliance. Test is invalid otherwise.
TEST START DATE & TIME: Unless otherwise specified in writing by EPA, 4 >36 hours lapse between collection and initiation, test is invalid.
FILTER MESH SIEVE SIZE: Unless otherwise specified in writing by EPA, if sieve size is smaller than 60 microns, test is invalid.
90% OR GREATER SURVIVAL IN LABORATORY CONTROL(S) (Y/N): If N, test is invalid.

PARAMETER	RESULT	NOTES	WHEN ANALYZED
Temperature °C	0 - 8	Unless received by the laboratory on the same day as collected, values outside this range invalidate the test	Upon receipt

* Where no upstream control is available, enter results from laboratory or synthetic control.

MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM - P.O. BOX 176, JEFFERSON CITY MO, 65102
WHOLE EFFLUENT TOXICITY (WET) TEST REPORT
(TO BE ATTACHED TO WET TESTS FOR SUBMISSION TO THE REGULATORY AUTHORITY)

PART A - TO BE COMPLETED IN FULL BY PERMITTEE

Facility Name: **Algoa Regional WWTF**
Permit Number: **MO-0044300**
CO. LOCATION NAME: **Algoa Regional WWTF**
Receiving Stream Collection Point and Description: **Missouri River - not available**
Percent Allowable Effluent Concentration (AEC): **9%**
Source Name: **UPSTREAM** (not available)
Effluent 2202110: **UPSTREAM** (not available)
Permitted Effluent Daily Maximum Limitation (PMDL): **None**
Chlorine: **None**

PART B - TO BE COMPLETED IN FULL BY PERFORMING LABORATORY

Permittee Laboratory: **Environmental Analysis South, Inc.**
Test Report Number: **MO-2202110**
Date of Test: **November 15, 2017**
Date and Time Samples Received at Laboratory: **11/14/17 1330 hrs by DB (EAS)**
Sample Location: **UPSTREAM**
Sample Filtered Prior to Analysis: **YES**
Effluent: **UPSTREAM**
Filter Used: **None**
Sample Analyzed to JWDs: **YES**
Dilution: **None**
Preparation: **YES**
Effluent: **UPSTREAM**

MINIMUM REQUIRED ANALYTICAL RESULTS FOR THE 100% EFFLUENT SAMPLE

PARAMETER	RESULT	METHOD	WHEN ANALYZED
Temperature °C	3	SM18 2550B stored at 4 degree C until test setup	11/14/17 1345 hrs
pH Standard Units	7.80	SM18 4500-H B	11/14/17 1345 hrs
Conductance µmhos	1155	SM18 2510B	11/14/17 1345 hrs
Dissolved Oxygen mg/L	10.1	03/12/14 0945 hrs SM18 4500-O G	11/14/17 1345 hrs
Total Residual Chlorine mg/L	<0.04	SM18 4500-Cl G	11/14/17 1345 hrs
Un-ionized Ammonia mg/L	<0.05x0.04=0.0110	SM18 4500-NH3 F @ 25 degree C	11/17/17 1515 hrs
Total Ammonia mg/L	273	SM18 2320B	11/17/17 1300 hrs
Total Hardness mg/L	281	SM18 2340 C	11/17/17 1330 hrs

*Recommended by USEPA guidance, not a required analysis

1. Samples shall only be filtered if indigenous organisms are present that may be confused with, or attack, the test organisms.
2. Filters shall have a pore size of 60 microns or greater.

Environmental Analysis South, Inc.

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001(Grab) AEC = 9%
MO-0044300
EAS LOG# 2202110
November 15, 2017 through November 17, 2017

1. REPORT SUMMARY:

1.1. Multiple Dilution Data Summation

Test Solution	<i>Pimephales promelas</i> Acute Toxicity Test 48 Hour Survival	<i>Ceriodaphnia dubia</i> Acute Toxicity Test 48 Hour Survival
Reconstituted Control (RC)	100%	100%
Upstream Control (UC)	N/A	N/A
2.5% Effluent	100%	100%
4.5% Effluent	85%	100%
9% Effluent	100%	100%
18% Effluent	100%	100%
36% Effluent	100%	100%
Estimated 48 Hour LC50 Value	>36% Effluent	>36% Effluent
To Pass: 1. Effluent - LC50 must be >AEC (0.3) and 2. All concentrations > or = AEC must not have significant difference to control in survival.	1. Yes 2. Yes	1. Yes 2. Yes
Result of Toxicity Test	PASS	PASS

* Indicates a significant difference at alpha = 0.5 between effluent and control survival data.

Conclusion:
Pimephales promelas 48 hour WET results: LC 50=36% using Trimmed Spearman-Kärber
NOAEC = 36% by Steel's Many-One Rank Test
Ceriodaphnia dubia 48 hour WET results: LC 50=36% using the Graphical Method
NOAEC = 36% by Steel's Many-One Rank Test

Based on these results the outfall passed the whole effluent toxicity test with both species.

Approved by:

Sue C. Sheldahl
Sue C. Sheldahl, Chemist

Page 2 of 4

Analytical Chemistry • Research • Field Studies

Environmental Analysis South, Inc.

4000 East Jackson Blvd. • Jackson, MO 63755 • 573-204-8817 • Fax 573-204-8818



REPORT OF ACUTE TOXICITY TESTING
Algoa Regional Wastewater Treatment Facility
Outfall 001(Grab) AEC = 9%
MO-0044300
EAS LOG# 2202110
November 15, 2017 through November 17, 2017

2. TEST METHOD SUMMARY

2.1. TEST CONDITIONS AND METHODS:

	<i>Ceriodaphnia dubia</i> :	<i>Pimephales promelas</i> :
Test duration:	48 hours	48 hours
Temperature:	24 - 26 degree Celsius	24 - 26 degree Celsius
Light quality:	Ambient laboratory illumination	Ambient laboratory illumination
Photoperiod:	16 hour light, 8 hours dark	16 hour light, 8 hours dark
Control Water:	Moderately Hard Reconstituted Water	Moderately Hard Reconstituted Water
Dilution Water:	Upstream Water - If unavailable or toxic, then control water will be used.	Upstream Water - If unavailable or toxic, then control water will be used.
Size of test vessel:	30 milliliters	250 milliliters
Volume of test solution:	15 milliliters	200 milliliters
Age of test organisms:	<24 hours	1 - 14 days (all same age)
Number of organisms/test vessel:	5	10
Number of replicates/concentration:	4	2
Number of organisms/concentration:	20	40 for a single dilution test and 20 for a multiple dilution test
Feeding regime:	None (fed prior to test)	None (fed prior to test)
Anesthetant:	None	None
Test acceptability criterion:	80% or greater survival in controls	93% or greater survival in controls

The methodology used for the chemistry data was taken from the *Standard Methods for the Examination of Water and Wastewater*, 18th edition (1992). The exception was hardness, which was determined using a Hach EDTA titration test kit. The toxicity tests follow guidelines laid out in the permittee's NPDES permit and were conducted according to EPA approved methods (USEPA 2002).

All test organisms were cultured according to EPA approved methods (USEPA 2002). The *Ceriodaphnia dubia* and the *Pimephales promelas* were obtained from C-K Associates Inc. located in Baton Rouge, Louisiana and shipped overnight for use in the whole effluent toxicity test.

Page 3 of 4

Analytical Chemistry • Research • Field Studies

SAMPLE CHAIN OF CUSTODY RECORD

ENGINEERING SURVEYS & SERVICES

1113 Pay Street • Columbia, Missouri 65201 • (573) 449-2646
802 El Dorado Drive • Jefferson City, Missouri 65101 • (573) 636-3303
1175 W. Main Street • Sedalia, Missouri 65301 • (660) 826-8618

Sample ID	Date/Time Collected	Tests Requested	Sample Container	Preserv.	Comments
2202108	11/14/17 1345 hrs	WET Test Multiple dilutions	gallon dubitator	None	JN 8767
2202109	11/14/17 1345 hrs	WET Test Multiple dilutions	gallon dubitator	None	JN 7570
2202110	11/14/17 1345 hrs	WET Test Multiple dilutions	gallon dubitator	None	JN 7570

Sample Collected By: *[Signature]* Company/Organization: *Engineering Surveys & Services*

Date/Time:

Address: *Columbia, MO*

Samples Relinquished By/Phone	Samples Received By	Date/Time
<i>[Signature]</i>	<i>[Signature]</i>	11/14/17 1330

City of Jefferson

Department of Public Works
320 E. McCarty St.
Jefferson City, MO 65101



Carrie Tergin, Mayor

Matthew J. Morasch, P.E., Director
Phone: 573-634-6410
Fax: 573-634-6562

December 23, 2019

MDNR-Water Protection Program
P.O. Box 176
Jefferson City MO 65102
Attn: NPDES Permits and Engineering Section

RECEIVED

DEC 30 2019

Water Protection Program

Re: Renewal Application for MO-0044300

Please find attached form 780-1805 for the Algoa Regional WWTF.

We hereby request to view the draft copy prior to public notice in the interest of accuracy.

We have a Department approved sewer extension permit program and request it be reflected in the special conditions.

If you have any questions, please contact me at 634-6443 or eseaman@jeffcitymo.org.

Sincerely,

Eric Seaman, P.E.
Wastewater Division Director

CC: Clara Haenchen

Attachment