

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: September 1, 2021

Facility Name: Southgate Subdivision WWTP

Permit Number: MO-0094196

County: Pettis

Facility Description: Grinder pump / extended aeration / clarifier / UV disinfection / sludge disposal by contract hauler

Design Flow: 19,760 gpd

Actual Flow: 14,000 gpd

Reason for removal: The Department has terminated Permit # MO-0094196. This facility is now operating under Missouri State Operating Permit # MO-GD00591. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table C** found on Page 6 of 15. This facility is subject to the **WBC-B** limits for *E. coli*.

If you have any questions about this permit please contact Brant Farris at (660)-385-8019 or by email at brant.farris@dnr.mo.gov.