

# Missouri Department of Natural Resources



## NOTIFICATION OF PERMIT REMOVAL

Date removed: November 1, 2021

Facility Name: Lead-M Oakland Woods WWTP

Permit Number: MO-0105546

County: Jefferson

Facility Description: Four-cell lagoon, three cells aerated, sand filter, year round chlorination and dechlorination, sludge retained in lagoon

Design Flow: 0.0345 MGD

Actual Flow: 0.0117 MGD

Reason for removal: The Department has terminated Permit # MO-00105546. This facility is now operating under Missouri State Operating Permit # MO-GD00588. The Master General Permit template can be found on the Department's website at: <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/wastewater/non-publically-owned-treatment-works-potw-discharging-50000-gallons-day-mo-gd00000>.

The applicable table for this facility is **Table E** found on Page 9 of 15. This facility is subject to the **Losing Stream** limits for *E. coli*.

If you have any questions about this permit please contact Steve Hamm at (573)-526-1002 or by email at [steven.hamm@dnr.mo.gov](mailto:steven.hamm@dnr.mo.gov).