STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law (Chapter 644 RSMo, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0106151

Owner: City of Fremont Hills

Address: 1953 Fremont Hills Drive, Nixa, MO 65714

Continuing Authority: Same as above Address: Same as above

Facility Name: Fremont Hills Wastewater Treatment Plant Facility Address: 100 Blue Jay Way, Nixa, MO 65714

Legal Description: Sec. 05, T27N, R21W, Christian County

UTM Coordinates: X = 477223, Y = 4103136

Receiving Stream: Tributary to James River (C)

First Classified Stream and ID: Presumed Use Stream(C) (5070) (losing)

USGS Basin & Sub-watershed No.: (11010002-0304)

authorizes activities pursuant to the terms and conditions of this permit in accordance with the Missouri Clean Water Law and/or the National Pollutant Discharge Elimination System; it does not apply to other regulated activities.

FACILITY DESCRIPTION

Outfall #001 - POTW

The use or operation of this facility shall be by or under the supervision of a Certified "C" Operator.

Bar screen / extended aeration / chemical addition for phosphorus removal / tertiary filtration / UV disinfection / sludge disposal by contract hauler.

Design population equivalent is 1,758.

Design flow is 176,000 gallons per day.

Actual flow is 94,000 gallons per day.

Design sludge production is 35.0 dry tons/year.

Permitted Feature INF – Influent Monitoring Location – Headworks

November 1, 2019
Effective Date

November 1, 2023
Modification Date

October 31, 2024

Expiration Date

John Hoke, Director, Water Protection Program

OUTFALL #001

TABLE A-1. INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified. In accordance with 10 CSR 20-7.031, the final limitations outlined in **Table A-2** must be achieved as soon as possible but no later than **November 1, 2035**. These interim effluent limitations in **Table A-1** are effective beginning **November 1, 2023** and remain in effect through **October 31, 2035** or as soon as possible. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

		FINAL EFF	LUENT LIM	ITATIONS	MONITORING RE	QUIREMENTS
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: M				_		
Flow	MGD	*		*	once/month	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		15	10	once/month	composite**
Total Suspended Solids	mg/L		20	15	once/month	composite**
E. coli (Note 1, Page 3)	#/100mL	126		*	once/week	grab
Ammonia as N (Apr 1 – Sep 30) (Oct 1 – Mar 31)	mg/L	4.3 11.6		1.4 2.6	once/month	composite**
Total Phosphorus	mg/L	*		0.5	once/month	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/week	composite**
Nitrite + Nitrate	mg/L	*		*	once/week	composite**
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.5		9.0	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE NEXT REPORT IS DUE DECEMBER 28, 2023.

EEEE LIENT DA DANGEED (C)	LINUTEG	FINAL EFF	LUENT LIM	ITATIONS	MONITORING REQUIREMENTS					
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: Q										
Oil & Grease	& Grease mg/L 15				once/quarter***	grab				
Aluminum, Total Recoverable (Note 2 , Page 3)	μg/L	*		*	once/quarter***	composite**				
EFFLUENT PARAMET	ER(S)		UNITS	MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Biochemical Oxygen Demand ₅ – Percent Re	%	85	once/quarter***	calculated						
Total Suspended Solids – Percent Removal	%	85	once/quarter***	calculated						

MONITORING REPORTS SHALL BE SUBMITTED $\underline{\mathbf{QUARTERLY}}$; THE NEXT REPORT IS DUE $\underline{\mathbf{JANUARY}}$ 28, 2024.

^{*} Monitoring requirement only.

^{**} A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

^{***} pH is measured in pH units and is not to be averaged.

**** See table on Page 5 for quarterly sampling requirements.

OUTFALL #001

TABLE A-1 (Continued) INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified. In accordance with 10 CSR 20-7.031, the final limitations outlined in **Table A-2** must be achieved as soon as possible but no later than **November 1, 2035**. These interim effluent limitations in **Table A-1** are effective beginning **November 1, 2023** and remain in effect through **October 31, 2035** or as soon as possible. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

EFFLUENCE DAD AMEGED (C)	UNITS	INTERIM I LIMITA	- '	MONITORING REQUIREMENTS					
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE	MONTHLY TOTAL §	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: M									
Total Nitrogen (Note 4)	mg/L	*		once/week	calculated				
Total Nitrogen	lbs.		*	once/week	calculated				
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE DECEMBER 28, 2023.									
EFFLUENT PARAMETER(S)	UNITS	ANNUAL AVERAGE ¥	ANNUAL TOTAL Φ	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: A									
Total Nitrogen	mg/L	*		once/year	calculated				
Total Nitrogen	lbs.		*	once/year	calculated				
MONITORING REPORTS SHALL BE SUBMITTED ANNUALLY ; THE FIRST REPORT IS DUE <u>MARCH 28, 2024</u> .									

- * Monitoring requirement only.
- § The facility shall calculate pounds per month by using the monthly average concentration in mg/L multiplied by 8.34 and multiplied by the total monthly flow in MG.
- Φ Annual Total is calculated as the sum of the 12 calendar months (January 1st through December 31st) of monthly samples in pounds (lbs.).
- ¥ Annual Average is calculated as the average of the 12 calendar months (January 1st through December 31st) of weekly samples in mg/L.
- **Note 1** Effluent limits of 126 #/100 mL daily maximum and monitoring only for monthly average for *E. coli* are applicable year round due to losing stream designation. No more than 10% of samples over the course of a calendar year shall exceed the 126 #/100 mL daily maximum.
- **Note 2** If no Aluminum or Iron was used in a given sampling period, an actual analysis is not necessary. Simply report as "AG Conditional Monitoring Not Required this Period".
- Note 3 Influent sampling for BOD₅ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.
- Note 4 Total Nitrogen consists of Total Kieldahl Nitrogen and Nitrate + Nitrite.

OUTFALL #001

TABLE A-2. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified. The final effluent limitations in **Table A-2** shall become effective on **November 1, 2035** and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

		FINAL EFF	LUENT LIM	ITATIONS	MONITORING RE	QUIREMENTS
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Limit Set: M						1
Flow	MGD	*		*	once/month	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		15	10	once/month	composite**
Total Suspended Solids	mg/L		20	15	once/month	composite**
E. coli (Note 1, Page 3)	#/100mL	126		*	once/week	grab
Ammonia as N (Apr 1 – Sep 30) (Oct 1 – Mar 31)	mg/L	4.3 11.6		1.4 2.6	once/month	composite**
Total Phosphorus	mg/L	*		0.5	once/month	composite**
Total Kjeldahl Nitrogen	mg/L	*		*	once/week	composite**
Nitrite + Nitrate	mg/L	*		*	once/week	composite**
EFFLUENT PARAMETER(S)	UNITS	MINIMUM		MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH – Units***	SU	6.5		9.0	once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED MONTHLY; THE FIRST REPORT IS DUE DECEMBER 28, 2035.

	INTEG	FINAL EFF	LUENT LIM	ITATIONS	MONITORING REQUIREMENTS				
EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE			
Limit Set: Q									
Oil & Grease	15		10	once/quarter***	grab				
Aluminum, Total Recoverable (Note 2 , Page 3)	μg/L	*		*	once/quarter***	composite**			
EFFLUENT PARAMET	ER(S)		UNITS	MONTHLY AVERAGE MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE			
Biochemical Oxygen Demand ₅ – Percent Re	%	85	once/quarter***	calculated					
Total Suspended Solids – Percent Removal	%	85	once/quarter***	calculated					

MONITORING REPORTS SHALL BE SUBMITTED **QUARTERLY**; THE FIRST REPORT IS DUE <u>JANUARY 28, 2036</u>.

^{*} Monitoring requirement only.

^{**} A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

^{***} pH is measured in pH units and is not to be averaged.

^{****} See table on Page 5 for quarterly sampling requirements.

OUTFALL #001

TABLE A-2 (Continued) FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall number(s) as specified. The final effluent limitations in **Table A-2** shall become effective on **November 1, 2035** and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

		FINAL EFFLUEN	T LIMITATIONS	MONITORING R	REQUIREMENTS				
EFFLUENT PARAMETER(S)	UNITS	MONTHLY AVERAGE	MONTHLY TOTAL §	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: M									
Total Nitrogen (Note 4, Page 3)	mg/L	*		once/week	calculated				
Total Nitrogen	lbs.		*	once/week	calculated				
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE <u>DECEMBER 28, 2035</u> .									
EFFLUENT PARAMETER(S)	UNITS	ANNUAL AVERAGE GOAL ¥	ANNUAL TOTAL Φ	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: A									
Total Nitrogen	mg/L	10		once/year	calculated				
Total Nitrogen	lbs.		*	once/year	calculated				
Annual Nitrogen Credit (+ or -) €									
Point Source Credits Nonpoint Source Credits	lbs.		*	once/year once/year	documented documented				
Nitrogen 12-Month Total, after Credit Adjustment X	lbs.		5,357.62	once/year	calculated				

MONITORING REPORTS SHALL BE SUBMITTED **ANNUALLY**; THE FIRST REPORT IS DUE <u>MARCH 28, 2036</u>.

- \S The facility shall calculate pounds per month by using the monthly average concentration in mg/L multiplied by 8.34 and multiplied by the total monthly flow in MG.
- Φ Annual Total is calculated as the sum of the 12 calendar months (January 1st through December 31st) of monthly samples in pounds (lbs.).
- ¥ Annual Average is calculated as the average of the 12 calendar months (January 1st through December 31st) of weekly samples in mg/L.
- €- See Special Condition 2. The annual nitrogen credit will document a permittee's credit sales and purchases.
- **X** The Nitrogen 12-Month Total, After Credit Adjustment (ACA) value is calculated by increasing or decreasing the facility's actual annual effluent nitrogen load for the previous 12 calendar months (January 1st through December 31st) by the documented point and/or nonpoint nutrient annual credits (sold or purchased). The ACA is the value evaluated for compliance.

	Quarterly Minimum Sampling Requirements								
Quarter	Months	Months Quarterly Effluent Parameters							
First	January, February, March	Sample at least once during any month of the quarter	April 28 th						
Second	April, May, June	Sample at least once during any month of the quarter	July 28 th						
Third	July, August, September	Sample at least once during any month of the quarter	October 28th						
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th						

^{*} Monitoring requirement only.

PERMITTED FEATURE INF

TABLE B-1. INFLUENT MONITORING REQUIREMENTS

The monitoring requirements in **Table B-1** shall become effective on <u>November 1, 2019</u> and remain in effect until expiration of the permit. The influent wastewater shall be monitored by the permittee as specified below:

			MONITORING REQUIREMENTS							
PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE				
Limit Set: IQ										
Biochemical Oxygen Demand ₅ (Note 3)	mg/L			*	once/quarter***	composite**				
Total Suspended Solids (Note 3)	mg/L			*	once/quarter***	composite**				
Ammonia as N	mg/L	*		*	once/quarter***	composite**				
Total Phosphorus	mg/L	*		*	once/quarter***	composite**				
Total Kjeldahl Nitrogen	mg/L	*		*	once/quarter***	composite**				
Nitrite + Nitrate	mg/L	*		*	once/quarter***	composite**				
MONITORING REPORTS SHALL BE SUBMI	TOTAL	DOEDI V. m	IE EIDGE DED	ODE IG DIE IA	ANITADIZ OO OOO					

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY; THE FIRST REPORT IS DUE JANUARY 28, 2020.

- * Monitoring requirement only.
- ** A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.
- *** See table below for quarterly sampling requirements.

Note 3 – Influent sampling for BOD₅ and TSS is not required when the facility does not discharge effluent during the reporting period. Samples are to be collected prior to any treatment process. Calculate Percent Removal by using the following formula: [(Average Influent –Average Effluent) / Average Influent] x 100% = Percent Removal. Influent and effluent samples are to be taken during the same month. The Average Influent and Average Effluent values are to be calculated by adding the respective values together and dividing by the number of samples taken during the month. Influent samples are to be collected as a 24-hour composite sample, composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.

	Quarterly Minimum Sampling Requirements								
Quarter	Months	Months Quarterly Influent Parameters							
First	January, February, March	Sample at least once during any month of the quarter	April 28 th						
Second	April, May, June	Sample at least once during any month of the quarter	July 28 th						
Third	July, August, September	Sample at least once during any month of the quarter	October 28th						
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28th						

C. SCHEDULE OF COMPLIANCE

The facility shall attain compliance with final effluent limitations as soon as possible but in no case later than **twelve** (12) **years** of the effective date of this permit.

- 1. Within six months of the effective date of this permit, the permittee shall report progress made in attaining compliance with the final effluent limits for Total Nitrogen.
- 2. The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limits every 12 months from the effective date of this permit.

The **November 1, 2028** annual report shall detail the permittee's compliance approach to meet final limits (i.e. installation of technology, purchase TN credits, or hybrid including installation of technology and purchase of TN credits).

3. Within **twelve** (12) **years** of the effective date of this permit, the permittee shall attain compliance with the final effluent limits for Total Nitrogen.

Please submit progress reports to the Missouri Department of Natural Resources via the Electronic Discharge Monitoring Report (eDMR) Submission System.

D. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached Parts I, II, & III standard conditions dated August 1, 2014, May 1, 2013, and August 1, 2019, and hereby incorporated as though fully set forth herein. Annual reports required per Standard Conditions Part III Section K shall be submitted online to the Department via the Department's eDMR system as an attachment. This supersedes Standard Conditions Part III Section K #4. EPA reports shall continue to be submitted online via the Central Data Exchange system.

E. SPECIAL CONDITIONS

- 1. Electronic Discharge Monitoring Report (eDMR) Submission System. Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent monitoring data and any report required by the permit (unless specifically directed otherwise by the permit) shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally consistent set of data about the NPDES program. All reports uploaded into the system shall be reasonably named so they are easily identifiable, such as "WET Test Chronic Outfall 002 Jan 2023," or "Outfall 004 Daily Data Mar 2025."
 - (a) eDMR Registration Requirements. The permittee must register with the Department's eDMR system through the Missouri Gateway for Environmental Management (MoGEM) before the first report is due. Registration and other information regarding MoGEM can be found at https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem. Information about the eDMR system can be found at https://dnr.mo.gov/water/business-industry-other-entities/reporting/electronic-discharge-monitoring-reporting-system-edmr. The first user shall register as an Organization Official and the association to the facility must be approved by the Department. Regarding Standard Conditions Part I, Section B, #7, the eDMR system is currently the only Department approved reporting method for this permit unless a waiver is granted by the Department. See paragraph (c) below.
 - (b) Electronic Submissions. To access the eDMR system, use the following link in your web browser: https://apps5.mo.gov/mogems/welcome.action. If you experience difficulties with using the eDMR system you may contact edmr@dnr.mo.gov or call 855-789-3889 or 573-526-2082 for assistance.
 - (c) Waivers from Electronic Reporting. The permittee must electronically submit compliance monitoring data and reports unless a waiver is granted by the Department in compliance with 40 CFR Part 127. The permittee may obtain an electronic reporting waiver by first submitting an eDMR Waiver Request Form: https://dnr.mo.gov/document-search/electronic-discharge-monitoring-report-waiver-request-form-mo-780-2692. The Department will either approve or deny this electronic reporting waiver request within 120 calendar days.
- 2. The full implementation of this operating permit, which includes implementation of any applicable schedules of compliance, shall constitute compliance with all applicable federal and state statutes and regulations in accordance with §644.051.16, RSMo, and the Clean Water Act (CWA) section 402(k); however, this permit may be reopened and modified, or alternatively revoked and reissued:
 - (a) To comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) To incorporate an approved pretreatment program or modification thereto pursuant to 40 CFR 403.8(c) or 40 CFR 403.18(e), respectively.
- 3. All outfalls must be clearly marked in the field.
- 4. Report as no-discharge when a discharge does not occur during the report period.
- 5. Reporting of Non-Detects:
 - (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.

- (b) See sufficiently sensitive test method requirements in Standard Conditions Part I, Section A, No. 4 regarding proper testing and method minimum levels used for sample analysis.
- (c) The permittee shall not report a sample result as "Non-Detect" without also reporting the method minimum level of the test. Reporting as "Non Detect" without also including the method minimum level, will be considered failure to report, which is a violation of this permit.
- (d) The permittee shall provide the "Non-Detect" sample result using the less than symbol and the method minimum level (e.g., $<50 \mu g/L$), if the method minimum level for the parameter is $50 \mu g/L$).
- (e) Where the permit contains a Department determined Minimum Quantification Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
- (f) For the daily maximum, the facility shall report the highest value. If the highest value was a non-detect, use the less than "<" symbol and the laboratory's highest method minimum level.
- (g) For reporting an average based on all non-detected values, remove the "<" sign from the values, average the values, and then add the "<" symbol back to the resulting average.
- (h) For reporting an average based on a mix of detected and non-detected values (not including *E. coli*), assign a value of "0" for all non-detects for that reporting period and report the average of all the results.
- (i) When *E. coli* is not detected above the method minimum level, the permittee must report the data qualifier signifying less than detection limit for that parameter (e.g., <1 #/100mL, if the method minimum level is 1 #/100mL). For reporting a geometric mean based on a mix of detected and non-detected values, use one-half of the detection limit (instead of zero) for non-detects when calculating geometric means.
- (j) See the Fact Sheet Appendix Non-Detect Example Calculations for further guidance.
- 6. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).
- 7. The permittee shall comply with any applicable requirements listed in 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. To request a modification of the operational control testing requirements listed in 10 CSR 20-9, the permittee shall submit a permit modification application and fee to the Department requesting a deviation from the operational control monitoring requirements. Upon approval of the request, the Department will modify the permit.
- 8. The permittee shall develop and implement a program for maintenance and repair of its collection system. The permittee may compare collection system performance results and other data with the benchmarks used in the Departments' Capacity, Management, Operation, And Maintenance (CMOM) Model, located at https://dnr.mo.gov/document-search/capacity-management-operations-maintenance-plan-editable-template. Additional information regarding the Departments' CMOM Model is available at https://dnr.mo.gov/print/document-search/pub2574.
- 9. The permittee shall also submit a report via the Electronic Discharge Monitoring Report (eDMR) Submission System annually, by January 28th, for the previous calendar year. The report shall contain the following information:
 - (a) A summary of the efforts to locate and eliminate specific sources of excessive infiltration and inflow into the collection system serving the facility for the previous year.
 - (b) A summary of the general maintenance and repairs to the collection system serving the facility for the previous year.
 - (c) A summary of any planned maintenance and repairs to the collection system serving the facility for the upcoming calendar year. This list shall include locations (GPS, 911 address, manhole number, etc.) and actions to be taken.
- 10. Bypasses are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2. Bypasses are to be reported to the Southwest Regional Office during normal business hours or by using the online Sanitary Sewer Overflow/Facility Bypass Application located at: https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem or the Environmental Emergency Response spill-line at 573-634-2436 outside of normal business hours. Once an electronic reporting system compliant with 40 CFR Part 127, the National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, is available all bypasses must be reported electronically via the new system. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
- 11. The facility must be sufficiently secured to restrict entry by children, livestock and unauthorized persons as well as to protect the facility from vandalism.

- 12. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.
- 13. An all-weather access road to the treatment facility shall be maintained.
- 14. The outfall sewer shall be protected and maintained against the effects of floodwater, ice, or other hazards as to reasonably ensure its structural stability, freedom from stoppage, and that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
- 15. Sludge/biosolids treatment, storage and disposal practices shall be conducted in accordance with Standard Conditions Part III.
- 16. The media in the filter beds shall be properly maintained to prevent surface pooling, vegetative growth, and accumulation of leaf litter.
- 17. This facility does not currently retain an operator with the correct level of certification required to operate the wastewater treatment plant. The City is required to retain an operator with an "A" level of wastewater certification to operate the wastewater treatment plant. Missouri Clean Water Law and its implementing regulation 10 CSR 20-9.020(2)(F) allows the Department to develop a schedule of activities including the date by which compliance with this requirement shall be obtained. The City of Fremont Hills shall submit a written report to the Southwest Regional Office within six (6) months from the effective date of this operating permit. The report shall contain:
 - (a) The Certified Operators' name,
 - (b) The Certified Operators' wastewater certification number,
 - (c) The Certified Operators' level of certification for wastewater,
 - (d) A copy of the contract between the City and the Certified Operator; and/or
 - (e) A written correspondence from the City indicating that they have hired the services of the Certified Operator.
- 18. <u>Nutrient Removal</u>: The permittee should strive to operate the treatment facility to maximize the level of nutrient removal to achieve the following target goals and limits:

```
Total Nitrogen (as TKN and Nitrate + Nitrite) \leq 5,357.62 lbs./year as a 12-month total limit Total Nitrogen (as TKN and Nitrate + Nitrite) \leq 10 mg/L as an annual average goal
```

The target goals for concentration (mg/L) are not to be considered as effluent limits for this permit. However, the Total Nitrogen mass loading limits (lbs./year) are enforceable. The Department reserves the right to reopen this permit to impose limits for nutrients pursuant to Missouri Law after such criteria or a TMDL limiting nutrients is adopted.

A TMDL for Total Phosphorus and Total Nitrogen in the James River Watershed has been adopted, and the value for Total Nitrogen mass (lbs/year) is a limit to be imposed through the Special Condition and Schedule of Compliance of this permit.

- 19. <u>Trading</u>. The watershed permittees are authorized to participate in nutrient trading for the purpose of complying with the TN allocations listed in Appendix B of the Fact Sheet. Additionally, the James River TMDL authorizes nutrient trading as a means of achieving the cumulative TN wasteload allocations established by the TMDL.
- 20. Watershed Compliance. Through treatment, other pollutant reductions at the facility, or point and/or nonpoint source nutrient trading, the individual watershed permittees must meet mass-based loads for TN as stated in Appendix B. If trading is the chosen method, the permittee must purchase point source credits from authorized sellers and/or obtain nonpoint source nutrient credits within the watershed in an amount sufficient to compensate for the discharge of TN that is in excess of TN allocations stated in the watershed permittee list. Nonpoint pollutant reduction credits are available as specified in the Nonpoint Source Offset Implementation Plan or approved amendments thereof.

The Nitrogen 12-Month Total, After Credit Adjustment (ACA) value is calculated by increasing or decreasing the facility's actual annual effluent nitrogen load for the previous 12 calendar months (January 1st through December 31st) by the documented point and/or nonpoint nutrient annual credits (sold or purchased) from the previous year. The ACA is the value evaluated for compliance.

(a) For any calendar year in which a watershed permittee exceeds its TN Limitation and/or fails to obtain sufficient credits, shall be in violation of this permit, and the Department may take appropriate enforcement action against the watershed permittee for such exceedance.

- (b) Termination, regionalization, consolidation of dischargers, purchases, sales, trades, leases, and the transaction(s) affecting the TN allocations shall not limit the Department's authority to enforce the terms and conditions of this permit nor shall it relieve the watershed permittees of their responsibility to comply with any other applicable federal, state, or local law, rule, standard, ordinance, order, judgment, or decree.
- 21. <u>Nonpoint Source Credit Generation Plan</u>. Prior to initiating credit offset projects, watershed permittees shall develop a project implementation plan for Department review, approval, and incorporation into the operating permit. Implementation plans must at a minimum include the following information:
 - (a) Overview of the offset project, including specific BMPs to be implemented;
 - (b) Projected Total Nitrogen credits that will be generated;
 - (c) Proposed Trading ratio(s) calculations;
 - (d) Implementation and credit tracking plans (i.e. legal agreements, credit tracking, annual review process, process for mitigating failing BMPs);
 - (e) Relevant financial analyses (i.e. implementation cost, external funding opportunities)
 - (f) Project implementation schedule; and
 - (g) Inspection and on-going maintenance requirements of nonpoint source BMPs

Only those pollutant reduction credits established in the project implementation plan approved by the Department may be used by the permittee to demonstrate compliance with the total nitrogen limits. The plan may be amended, however, Department approval must be obtained prior to initiating work associated with the change.

- 22. <u>Aggregated Assessment</u>. An owner or continuing authority of two or more facilities with a total nitrogen wasteload allocation (WLA) or derived from the James River TMDL required by 10 CSR 20-7.015(3)(F) may apply for and receive an aggregated assessment reflecting the total WLA for such facilities.
 - (a) The permittee (and all individual facilities covered under the aggregated limit) shall be deemed in compliance when the aggregate mass load discharged by the facilities is less than the aggregate load limit.
 - (b) If aggregated mass load limit is exceeded, facilities that achieve individual WLA load limits in Appendix B shall be deemed in compliance.
 - (c) The permittee will be eligible to generate credits only if the aggregate mass load discharged by the facilities is less than the total of the WLA assigned to any of the affected facilities.
 - (d) Point and/or nonpoint source nutrient trading may be used to meet the aggregated mass load limit.
 - (e) The aggregation of mass load limits shall not affect any requirement to comply with local water quality-based limitations.
- Required Elements and Reporting Requirements. Any permittee seeking to meet their mass-based permitted effluent limit for TN
 is required to submit to the Department the following information along with a completed permit application.

Permittees planning to acquire credits through more than one of these three options must submit completed plans for each option.

All annual reporting documents are due on March 28th. In addition, new trading plans or modifications of existing trading plans for the upcoming calendar year must be submitted for Department review and approval by March 28th.

(a) For Point Source to Point Source Trading Plans:

- (1) Completed Point Source to Point Source Trading Plan listing all permitted point sources within the trading zone that the permittee would consider as potential credit suppliers. The plan should list potential contingencies for compliance if sufficient credits are unavailable.
 - List of Facility Names and Permit Numbers.
- (2) Annual Reporting Requirements:
 - Completed Annual Trade Accounting Worksheet
 - Completed Private Agreements, or evidence thereof, whether in the form of a Legal Contract to Trade executed by Buyer and Seller, or receipt of sale, for all credit purchases.

(b) For Point Source to Point Source Aggregated Assessment Plans:

- (1) Spreadsheet displaying all facilities within the designated trading zone owned by the permittee that are to operate under this individual Aggregated Assessment Plan.
 - List of Facility Names and Permit Numbers.
 - Each participating facility's annual mass-based limits for the pollutant(s) to be traded.
 - Each participating facility's actual annual discharge in pounds for the most recent January 1 December 31 period.
 - Display of credits generated or needed from each facility.

- Total aggregated sums of point B through D above.
- (2) Annual Reporting Requirements:
 - Completed Annual Trade Accounting Worksheet

(c) Point Source to Nonpoint Source Trades:

- (1) Nonpoint Source Credit Generation Plan that includes the following:
 - Overview of the offset project;
 - Projected credits that will be generated;
 - Proposed trade ratio(s) and calculations;
 - Implementation and offset tracking plans (i.e. legal agreements, tracking offsets and credits, annual review process, process for mitigating failing BMPs);
 - Relevant financial analyses (i.e. implementation cost, external funding opportunities)
 - Project implementation schedule; and
 - Inspection and on-going maintenance requirements of nonpoint source BMPs
- (2) Annual Reporting Requirements:
 - Completed Annual Trade Accounting Worksheet;
 - Completed Private Agreements, or evidence thereof, whether in the form of a Legal Contract to Trade executed by Buyer and Seller, or receipt of sale, for all credit purchases Verification and evidence of completed and installed practice;
 - Evidence of existing Maintenance Agreements for existing Nonpoint Source Best Management Practices

F. REOPEN, MODIFY, OR REVOKE PROVISION

The Department may, for any reason provided by law, by summary proceedings or otherwise, revoke or suspend this permit or reopen and modify it to establish any appropriate conditions, schedules of compliance, or other provisions which may be necessary to protect human health or the environment or to implement the James River TMDL. In addition, the Department may modify or revoke and reissue the permit if the limits for Total Nitrogen no longer attain and maintain applicable water quality standards. The Department may also reopen and modify the permit to suspend the ability to trade credits to comply with the TN Allocations of this permit.

G. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to pursue an appeal before the administrative hearing commission (AHC) pursuant to Sections 621.250 and 644.051.6 RSMo. To appeal, you must file a petition with the AHC within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission U.S. Post Office Building, Third Floor 131 West High Street, P.O. Box 1557 Jefferson City, MO 65102-1557 Phone: 573-751-2422

Fax: 573-751-5018 Website: https://ahc.mo.gov

MISSOURI DEPARTMENT OF NATURAL RESOURCES STATEMENT OF BASIS MO-0106151 FREMONT HILLS WWTP

This Statement of Basis (Statement) gives pertinent information regarding modifications to the above listed operating permit. A Statement is not an enforceable part of a Missouri State Operating Permit.

Part I – Modification Rationale

This operating permit is hereby modified to reflect new requirements for Total Nitrogen as a result of the James River Total Maximum Daily Load (TMDL) for nutrients. New Total Nitrogen sampling and reporting requirements are listed in Tables A-1 and A-2 which implement a twelve (12) year schedule of compliance to meet new effluent limitations for Total Nitrogen. Additionally, in Table A-1 Nitrite + Nitrate, and Total Kjeldahl Nitrogen were increased to weekly sampling and monthly reporting to ensure compliance with TMDL requirements.

Other changes in this modification include updates on the certificate page to the authorization language and the receiving and first classified stream names and waterbody IDs which were updated to reflect the most current naming convention and numbering system; however, the actual receiving stream has not changed nor have its designated uses. Language in Table A-1 was removed regarding the prohibition of trace amounts of foam and floating solids as such general criteria should be met if permitted limits are met, this change is reflected in the Anti-backsliding section of the fact sheet, along with language regarding Continuing Authority. Information regarding annual reports as required by Standard Conditions Part III was added. Changes to special conditions include the revision of eDMR and reporting of non-detects, updated web links where applicable, and the addition of special conditions 18-23 for the James River TMDL and new Total Nitrogen requirements including nutrient removal, trading, watershed compliance, nonpoint source credit generation plan, aggregated assessment, and required elements and reporting requirements. Additionally, a clause allowing the Department to reopen, modify, or revoke this permit was included to ensure the requirements of the TMDL are met, see Part F of the permit.

No other changes were made at this time.

Part II - Facility Information

Facility Type and Description-- POTW Bar screen / extended aeration / chemical addition for phosphorus removal / tertiary filtration / UV disinfection / sludge disposal by contract hauler.

DEFINITIONS

After Credit Adjustment (ACA) Value: Is calculated by increasing or decreasing the facility's actual annual effluent nitrogen load for the previous 12 months by the documented nutrient annual credit (sold or purchased) from the previous year. The ACA is the value evaluated for compliance.

<u>Allocation (or "TN Allocation")</u>: The mass quantity (as of TN) that a discharger is potentially allowed to release to surface waters in accordance with this permit. TN Allocations may be expressed as active or reserve allocation.

<u>Baselines</u>: The discharge or loading limits expected of the source that would apply in the absence of trading. This applies to both buyers and sellers of credits. An example of a point source baseline is a permitted effluent limit. An example of nonpoint baselines are the nutrient discharge conditions prior to the installation of best management practices.

Best Management Practice (BMP): An action that reduces pollutant discharge to waters of the state. The eligibility and nutrient trading value of any proposed practice will be subject to approval by the Department's Water Protection Program.

Consolidation: The transfer of ownership and/or operational authority of an independent wastewater system to a larger one.

<u>Credit</u>: A credit is a unit of pollutant reduction measured in pounds. Credits can be generated by a point source over-controlling its discharge or by a nonpoint source installing best management practices (BMPs) that are different than or in addition to its baseline.

Discharge TN Allocation: TN Allocation specified as applying at the point of discharge (or "end-of-pipe").

<u>Discharge TN Load</u>: Actual TN Load measured at a watershed permittee member's point of discharge (or "end-of-pipe").

<u>Limitation (or "TN Limitation" or "TN Load Limitation")</u>: The mass quantity of TN specified as the maximum that an individual discharger is authorized to discharge to surface waters.

<u>Load (or "TN Load")</u>: The actual mass quantity (as of TN) that a discharger releases into surface waters of the James River watershed (upstream of the TMDL compliance point at Galena, MO).

Nonpoint Source: Pollutants generally resulting from land runoff, precipitation, atmospheric deposition, drainage, seepage or hydrologic modification. Nonpoint source pollution, unlike pollution from industrial and sewage treatment plants, comes from many diffuse sources.

<u>Point Source</u>: Any discernible, confined, and discrete conveyance, including but not limited to any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, or vessel or other floating craft, from which pollutants are or may be discharged. Point source does not include agricultural storm water discharges and return flows from irrigated agriculture.

Regionalization: When (1) an independent wastewater system directly connects to an existing regional wastewater district or (2) when two or more independent wastewater systems combine to form a single area-wide wastewater district.

<u>Total Maximum Daily Load (TMDL)</u>: is a watershed planning tool that identifies the maximum amount of a pollutant that a water body can receive and still attain applicable water quality standards. This maximum loading is then allocated to the various sources in the watershed, and these allocations serve as targets for restoring water quality. In the context of this permit, refers to Phase III of the Total Maximum Daily Load for TN to the James River watershed, upstream of the TMDL compliance point at Galena, MO.

Total Nitrogen (TN): The sum of the Total Kjeldahl Nitrogen, Nitrite Nitrogen, and Nitrate Nitrogen.

<u>Trading Zone</u>: A defined geographical area (most often a watershed) within which pollutant credits can be bought and sold, and which permittees are authorized to use credits to meet mass-based permitted effluent limits. Trading zones are designated or subject to approval by the Department's Water Protection Program and identified in eligible permits. The trading zone for this framework is identified in the TMDL as the James River Watershed, upstream of Galena, MO.

NUTRIENT TRADING

Trading terms and information are as follows:

(1) Aggregate Assessment Plans for Point Source Continuing Authorities: One flexibility offered to permittees who serve as continuing authorities for multiple permitted facilities is the option to provide an Aggregate Assessment Plan when planning and reporting for point source offsetting and trading between two or more of their facilities. In addition to providing a more streamlined method for reporting annual compliance through multiple trades, the Aggregated Assessment removes the need to provide documented legal agreements, receipts, or other such contracts between facilities owned by the same permittee.

These continuing authorities may submit an Aggregate Assessment in place of a Point Source Trading Plan as part of the permit application process to begin trading. However, if the continuing authority also seeks credits from any other point source to meet a permit obligation for any given permit, they must submit a Point Source Trading Plan for the permits in question. Likewise for nonpoint source trading, all applications for nonpoint source trading must be accompanied by Nonpoint Source Credit Generation Plans. An optional credit accounting worksheet is provided by the Department to assist permittees develop their plans.

Note: Facilities owned by the same continuing authority that wish to participate in trading in order to meet a permit requirement must still be located in the same Trading Zone for the type of credit that is being traded.

- (2) <u>Annual Reconciliation Period</u>: An Annual Reconciliation Period (also known as a "true-up" period) will occur between January 1 and March 28 of every year. Permittees will have until March 28 to use or purchase any necessary credits to meet the annual mass-based effluent limit for the annual compliance period that ended December 31.
 - Permittees also have until March 28 to update or modify Point Source Trading Plans, Aggregate Assessment Plans, or Nonpoint Source Credit Generation Plans that address compliance for the current and upcoming annual compliance periods.
- (3) <u>Attenuation's Influence on Credit Determination</u>: The Department may calculate general estimates of nutrient attenuation in streams using observed rates of nutrient reduction measured during low-flow wasteload allocation studies completed for wastewater treatment facilities located in a representative watershed.


For this approach, the observed percentage of nutrient loss for a given distance measured in the wasteload allocation study is applied for the entire extent from the wastewater treatment facility outfall to the subject water body. This approach assumes that streams having similar hydrology and are located in watersheds having similar land use, climate, and geology have similar kinetic rates related to instream nutrient loss. Due to the inherent uncertainty associated with this approach, additional conservative assumptions (i.e., trade ratios) may be employed to ensure pollutant reduction goals are achieved. Additionally, uncertainty may be reduced through the completion of site-specific low-flow wasteload allocation studies. Such studies should be completed in consultation with the Department and following the Department's quality assurance procedures for data collection.

Attenuation calculations would be employed across all permits within a designation trading zone. The Department will make this determination on a zone by zone basis. When attenuation is used, credits and credit baselines are calculated at the receiving waterbody identified in the attenuation study as opposed to directly at the point source outfall. When employed in this fashion, mass-based load limitations become more equitable across the trading zone and increases the ease of credit tracking from point sources.

For the purposes of the James River Permitting Framework, attenuation has already been considered and utilized during the development of the final permitted limits. Therefore, no further attenuation calculations will be employed for credits generated from nonpoint source BMPs or for the aggregation of mass load limits.

- (4) <u>Centralized Trading Ledger</u>: To facilitate trade negotiations and provide centralized, transparent, and timely information regarding available credits in the trading zone, the Department will establish and maintain a Nutrient Trading Ledger (Ledger) unique to each respective trading zone. The Department will update the Ledger with TN data submitted by each permittee participating in a trading agreement on an annual basis. The Ledger will display each permittee in the trading zone, their permit limitations, their reported pollutant discharge in mass, and a positive or negative "credit balance." The Ledger will be maintained on the Department's website. *Disclaimer: Updates to the ledger are only as accurate and timely as what has been provided to the Department by the permittees pursuant to their reporting requirements.*
- (5) <u>Credit Generation and Sale</u>: Permittees that maintain an annual discharge of TN below their permitted mass-based effluent limit for that respective pollutant are authorized to sell those pollutant reductions as "credits" to authorized credit buyers within their designated trading zone. One credit is equal to one pound of pollutant reduction. The designated trading zone is subject to approval by the Water Protection Program and will be identified in the permit.
- (6) <u>Credit Generation and Sale (without permitted limits)</u>: Facilities without permitted nutrient effluent limitations are also offered the opportunity to generate nutrient reduction credits. Facilities without limits established in their permits may elect to submit 5 years of representative effluent data in order to determine the facility's effluent baseline conditions. Therefore, any nutrient reductions below these baseline conditions are authorized to sell as credits. Facilities that choose to participate in trading in this way will be required to conduct weekly effluent monitoring. If the participating facility's permit does not already include weekly monitoring for nutrients, the permit must be modified in order to incorporate weekly monitoring for the parameter(s) that are to be traded. The modification must be approved and issued before credits can be sold.
- (7) <u>Credit Use and Purchasing:</u> Permittees may purchase available credits from other permittees within the designated trading zone to meet the mass-based TN and/or TP limits within their permit. TN credits can only be used to meet mass-based TN limits.
- (8) Nonpoint Source Load Allocation: "Where a TMDL has been approved or established by EPA, the applicable point source waste load allocation or nonpoint source load allocation would establish the baselines for generating credits" (EPA, 2003). Therefore, all nonpoint source practices, or combinations thereof, must first achieve the nonpoint source load allocations according to their respective land use category before generating credits within a TMDL zone. The ability of established nonpoint source Best Management Practices (BMPs) to generate nutrient reductions will be determined on a per-treated acre or per field basis, as appropriate. Only nutrient reductions achieved below the nonpoint source load allocation (represented in annual average pounds per acre) will be eligible for trading to a permittee to meet a permitted effluent limit.

Nonpoint source load allocations, determined by the Department, are unique to each TMDL and are consistent with the assumptions and requirements upon which each respective TMDL is established. These load allocations that nonpoint source nutrient reduction practices will have to meet before being allowed to generate nutrient credits will be identified in each respective TMDL.



(9) <u>Trading Permit Goals</u>: The TN goals listed in the permit are not to be considered as effluent limits for this permit, they are incorporated to further encourage reductions in the watershed. Nutrient credits cannot be purchased for meeting goals, however they can be purchased for meeting a permitted limit.

If a facility <100,000 gpd would like to sell credits when meeting a goal, they must submit applicable information explained in the Credit Generation and Sale (without permitted limits) paragraph of this section.

(10) <u>Time Terms for Credits</u>: All credits must be earned/generated before they can be traded or sold. Therefore, any credits purchased or used as offsets directly translate to pollutant reductions that have already occurred in the trading zone. The total loads of each trading zone, along with any reductions, credits, and offsets are verified annually at the end of the Annual Reconciliation Period on March 28th. The Time Terms will be defined in each permit along with the permittee's trading zone.

In trading zones with established Total Maximum Daily Loads (TMDLs) for nutrients or chlorophyll-a, credits have a total of two years to be traded or sold from the date the credit is reported. Once a credit is purchased or traded, the buyer can use the credit as an offset for the reporting period that just ended, or claim the credit as an offset towards their annual load limit for the current reporting period. Nutrient credits generated in trading zones with established nutrient or chlorophyll-a TMDLs cannot be used to offset any load that occurs more than two annual reporting periods from the one in which the credit was generated.

Limitations established by the Department on the Time Terms for Credits are intended to ensure consistency with the assumptions and requirements of any established TMDL wasteload allocation, water quality standard, or nutrient reduction target in the trading zone. Any allowance of credit banking beyond the designated term increases the potential that the purchase and use of banked credits would allow for excursions of collective wasteload allocations, water quality standards, or nutrient reduction targets.

- (11) <u>Trade Negotiations</u>: For all trades, it is the responsibility of the permittee to negotiate trades and obtain executed trade agreements prior to applying to the Department to meet a permit limitation. Trade negotiations and agreements shall take place without the involvement of the Department. Copies of legally binding agreements shall be provided to the Department pursuant to the permit application process for any facility that is seeking to offset any nutrient load through trading.
- (12) <u>Trade Ratios</u>: A mechanism applied to trades to adjust for uncertainty associated with measuring the effectiveness of non-point source nutrient reductions. The trade ratio for point source to point source trades within this trading zone will be 1:1. The trade ratios for nonpoint source trades will be approved on a case by case basis and should be addressed in each approved Nonpoint Source Credit Generation Plan. In order to safeguard the attainment of water quality standards, TMDL requirements, and/or water quality goals, the Department reserves the right to make final determinations on trade ratios associated with any given trade or practice used to meet a permitted effluent limitation.

WATERSHED PERMITTEES AND TN LIMITATIONS

Threshold Applicability. Statewide nutrient monitoring requirements in 10 CSR 20-7.015(9)(D)8. establish a threshold for point sources that have the design capacity of greater than one hundred thousand (100,000) gpd that typically discharge nitrogen and phosphorus. The James River TMDL establishes the TN wasteload allocation to point sources in the James River watershed to be 3,949 pounds per day. The Department has determined that facilities >100,000 gpd in the James River Watershed encompass 99.4% of the watershed TN loading. Upon implementation of the final effluent limits stated in the permit, collectively as a group this will attain the goals of the TMDL. Facilities less than one hundred thousand (100,000) gpd will be required to optimize their treatment facilities to meet a TN goal of 15 mg/L, this action will further the reductions in the watershed beyond the TMDL target. This permit authorizes wastewater discharges of Total Nitrogen from wastewater treatment facilities located in the James River Watershed. Although not all facilities in the watershed will be required to meet final TN effluent limits, three categories of facilities are required to follow conditions of this permit:

- (a) Wastewater treatment facilities authorized to discharge less than 100,000 gallons per day to the James River Watershed. These facilities have already been identified during the development of the James River Watershed TN Permitting Framework; further these facilities have been assigned TN concentration goals, as an annual average in this permit.
- (b) Wastewater treatment facilities authorized to discharge 100,000 gallons or more per day to the James River Watershed. These facilities have already been identified during the development of the James River Watershed TN Permitting Framework; further, these facilities have been assigned waste load allocations for TN, to be regulated as annual total limits in this permit.
- (c) Wastewater treatment facilities that, as a result of new construction or expansion, are proposed to discharge to the James River Watershed, that have not commenced the discharge prior to March 15, 2023. Any discharger with a permitted flow of 100,000 gallons or more per day that proposes an expansion to their facility, TN discharge limits shall not exceed a concentration of 10 mg/L. Any discharger with a permitted flow of less than 100,000 gallons per day that proposes an expansion to their facility, TN discharge limits shall not exceed a concentration of 15 mg/L. These facilities will not receive a waste load allocation for the new or increased discharges and will be required to offset any new TN load.

Nutrient Limit. The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tribal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Due to the long term effects of nutrients on streams, an Annual Total Limit (ATL), an Annual Average Goal, and a Monthly Average and Monthly Total monitoring only requirement is applied. This value is consistent with the assumptions and requirements of the TMDL.

Nutrient monitoring will be conducted on at least a weekly basis, and the monthly mass load will be summarized based on the total flow during the month and reported as a monthly load.

Allocations. Upon timely and proper notification by the watershed permittees, as described elsewhere in this permit, the Department shall revise the watershed permittee list to incorporate changes in participation and/or allowable changes in TN limitations. (a) Changes in participation.

i. Participation. In the event that a new discharger, $\geq 100,000$ gpd, is added in the James River watershed, the Department shall add the discharger and its TN limitations to the watershed permittee list as a watershed permittee. To comply with the James River Total Maximum Daily Load, the new discharge must completely offset its TN load through nutrient trading or a mutually acceptable wasteload allocation transfer between permittees. The addition will not result in an adjustment to the established TN wasteload allocations for the watershed.

- ii. Expansions. In the event that a discharger in the James River watershed expands its design average flow, the expansion will not result in an adjustment to the established TN wasteload allocation in Appendix B. Any additional loading of TN from the expansion must be offset through nutrient trading or a mutually acceptable wasteload allocation transfer between permittees.
- iii. Termination. In the event that a watershed permittee is terminated, the Department shall delete the departing watershed permittee and its TN limitations from the watershed permittee list.
- iv. Regionalization of dischargers. In the event that a watershed permittee with design flows \geq 100,000 gpd regionalizes with another discharging facility with design flows \geq 100,000 gpd in the watershed, the Department shall revise the watershed permittee list to incorporate the TN allocation adjustment to the receiving facility.
- v. Consolidation of dischargers. In the event that a watershed permittee with design flows ≥100,000 gpd consolidates with another discharging facility with design flows ≥100,000 gpd in the watershed, the TN allocation will remain with each facility's discharge location and no adjustment will be made to the TN allocations. However, the consolidated discharges may be permitted under an aggregated mass load limit.
- (b) For the purposes of this permit, allowable reapportions in TN allocations include those resulting from purchase, sale, trade, or lease of allocation among the watershed permittees; and other transactions approved by the Department.

Nonpoint Source Load Allocation. The James River TMDL provides an annual TN loading target of 1,670,682 lbs/year for nonpoint sources. A common approach utilized in TMDLs for allocating loading to specific stormwater driven sources is to use an area-based approach. For nonpoint sources such allocations (i.e., baselines) may be based on land cover. Realizing that more natural areas (i.e. forest) are likely to contribute less nutrients, the department is implementing a more weighted approach in this permitting framework.

The results in the Table below give these values and are based on the proportion of existing overland loading as estimated using the Spreadsheet Tool for Estimating Pollutant Loads (STEPL). Baselines for nonpoint sources not included in Table 1 are based on existing conditions.

Table 1: TN LA by land cover type weighted by proportion of existing loading estimated by STEPL

Type	Sq.	Acres	STEPL estimated	STEPL estimated TN load*	Loading Proportion	LA	LA	
71	Miles		TN load* (lbs/year)	(lbs/acre/year)	(%)	(lbs/year)	(lbs/acre/year)	
Developed	148.19	94,839	430,530	4.5	14.30%	238,945	2.5	
Hay/Pasture	521.14	333,531	2,357,263	7.1	78.31%	1,308,288	3.9	
Forest	328.18	210,033	198,650	0.9	6.60%	110,251	0.5	
Cropland	3.06	1,959	23,779	12.1	0.79%	13,197	6.7	
Totals:	1,000.57	640,362	3,010,222	NA	100%	1,670,682	NA	

^{*} assumes no best management practices

Part III - Effluent Limitations and Monitoring Requirements

OUTFALL #001 - MAIN FACILITY OUTFALL

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

Receiving Water Body's Water Quality

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs. A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation.

- ✓ This facility discharges to a stream with an EPA approved TMDL. The facility discharges into a tributary of the James River. The TMDL for the James River was approved on May 7, 2001. The pollutant of concern in the TMDL is nutrients. The effluent limits in this permit meet the assumptions and requirements of the TMDL.
- ✓ Nutrient levels in the James River are of concern because the James River is a significant source of nutrients for Table Rock Lake. Water clarity in Table Rock Lake has been declining over time, and that trend is related to increasing nutrient levels, particularly phosphorus. In order to help reduce nutrient levels in the lake, a total phosphorus limit of 0.5 mg/L has been imposed on all point sources who discharge to a tributary of Table Rock Lake that have a design discharge greater than or equal to 22,500 gallons per day. This facility discharges to a tributary of Table Rock Lake, therefore the total phosphorus limits applies.

CHANGES TO EFFLUENT LIMITATIONS TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit/ Frequency	Sampling Frequency	Reporting Frequency	Sample Type ***
Total Kjeldahl Nitrogen	mg/L	1, 8	*		*	1/quarter	1/week	monthly	С
Nitrite + Nitrate	mg/L	1, 8	*		*	1/quarter	1/week	monthly	C

PARAMETER	Unit	Basis for Limits	Monthly Average	Monthly Total	Previous Permit Limit/ Frequency	Sampling Frequency	Reporting Frequency	Sample Type ***
Nitrogen, Total	mg/L	8	*		**	1/week	monthly	M
Nitrogen, Total	lbs.	8		*	**	1/week	monthly	M
PARAMETER	Unit	Basis for Limits	Annual Average Goal	Annual Total	Previous Permit Limit/ Frequency	Sampling Frequency	Reporting Frequency	Sample Type ****
Nitrogen, Total (Interim)	mg/L	8	*		**	1/year	1/year	M
Nitrogen, Total (Final)	mg/L	8	10		*	1/year	1/year	M
Nitrogen, Total (Interim)	lbs.	8		*	**	1/year	1/year	M
Annual Nitrogen Credit Point Source (Final)	lbs.	8		*	**	1/year	1/year	D
Annual Nitrogen Credit Nonpoint Source (Final)	lbs.	8		*	**	1/year	1/year	D
Nitrogen 12-month Total after Credit Adjustment (Final)	lbs.	8		5,357.62	**	1/year	1/year	M

^{* -} Monitoring requirement only.

***- C = 24-hour composite

D = Documented

M = Measured/calculated

Basis for Limitations Codes:

- 1. State or Federal Regulation/Law
- Water Quality Standard (includes RPA)
 Water Quality Based Effluent Limits
- 4. Antidegradation Review
- Antidegradation Policy
- 6. Water Quality Model
- 7. Best Professional Judgment
- 8. TMDL or Permit in lieu of TMDL
- WET Test Policy
- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

OUTFALL #001 - DERIVATION AND DISCUSSION OF LIMITS:

<u>Total Kjeldahl Nitrogen & Nitrate + Nitrite</u>. Effluent monitoring for Total Kjeldahl Nitrogen and Nitrate + Nitrite are required per 10 CSR 20-7.015(9)(D)8.

<u>Total Nitrogen (Table A-1)</u>. Effluent monitoring for Total Nitrogen is required per 10 CSR 20-6.010(8)(B).

<u>Total Nitrogen (Table A-2)</u>. The NPDES regulations at 40 CFR 122.45(d) require that all permit limits be expressed, unless impracticable, as both average monthly limits and maximum daily limits for all dischargers other than publicly owned treatment works (POTWs), and as average weekly limits and average monthly limits for POTWs.

In the March 3, 2004 EPA Memorandum with the subject of; Annual Permit Limits for Nitrogen and Phosphorus for Permits Designed to Protect Chesapeake Bay and its tidal tributaries from Excess Nutrient Loading under the National Pollutant Discharge Elimination System, the Office of Wastewater Management cautioned that the steady-state statistical procedures described in EPA's

^{** -} Parameter not previously established in previous state operating permit.

Technical Support Document for Water Quality-based Toxics Control (TSD) were not applicable or appropriate for developing nutrient limits for the main stem of Chesapeake Bay and its tribal tributaries. The memo stated that developing permit limits for nutrients affecting Chesapeake Bay and its tidal tributaries is different from setting limits for toxic pollutants because the exposure period of concern for nutrients is longer than one month, and can be up to a few years, and the average exposure rather than the maximum exposure is of concern. The statistical derivation procedure described in the TSD for acute and chronic aquatic life protection is not applicable to exposure periods more than 30 days (see TSD page 105). The Office of Wastewater Management concluded that due to the characteristics of nutrient loading and its effects on the water quality in Chesapeake Bay and its tidal tributaries and because the derivation of appropriate daily, weekly or monthly limits is not possible for the reasons described above, that it is therefore "impracticable" to express permit effluent limitations as daily maximum, weekly average, or monthly average effluent limitations. Therefore the Department has determined that the WLA provided in the TMDL will be applied as an Average Monthly Limit (AML) in concentration and also as a Maximum Daily Load (MDL) in lbs. Due to the long term effects of nutrients on streams, an Annual Total Limit (ATL), an Annual Average Goal (AAG), and a Monthly Average and Monthly Total monitoring only requirements applied. These values are consistent with the assumptions and requirements of the TMDL.

<u>Total Nitrogen Annual Average Goal</u>: The TN goal listed in the permit is not to be considered as an effluent limit for this permit, it is incorporated to further encourage reductions in the watershed. Nutrient credits cannot be purchased for meeting goals, however they can be purchased for meeting a permitted limit.

```
AAG = WLA = 10 mg/L
ATL = MDL x 365 days
Concentration to Mass formula: Mass (lbs./day) = concentration (mg/L) x Flow (MGD) x Conversion Factor
MDL = 10 mg/L x 0.176 MGD x 8.34 = 14.68 lbs./day
ATL = 14.68 lbs./day x 365 days = 5,357.62 lbs.
```

Annual Nitrogen Point Source Credits: Permittees may purchase available credits from other permittees located within the designated trading zone to meet the mass-based TN and/or TP limits within their permit. Permittees may also sell available credits to other permittees located within the designated trading zone for the other permittees to meet the mass-based TN and/or TP limits within their permit. TN credits can only be used to meet mass-based TN limits.

<u>Sampling Frequency Justification</u>: The Department has determined that previously established sampling and reporting frequency is sufficient to characterize the facility's effluent and be protective of water quality, except for nutrients. Weekly sampling is required for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Total Nitrogen to ensure that adequate data is collected to ensure that the discharge is protective of the TMDL limits.

Sampling Type Justification: Total Nitrogen is calculated as; TN = Total Kjeldahl Nitrogen + (Nitrate + Nitrite).

Part IV – Rationale and Derivation of Effluent Limitations & Permit Conditions

Antidegradation:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See https://dnr.mo.gov/document-search/antidegradation-implementation-procedure.

When new, altered, or expanding discharges to the James River Watershed are proposed, special considerations for antidegradation relative to nutrient trading depend on the tier of protection applied to the waterbody. The James River Watershed is a Tier 1 waterbody. The Department's Antidegradation Implementation Procedure explains that TMDLs developed for Tier 1 protection shall be designed to achieve compliance with the water quality criteria. The procedure further explains the minimum effluent requirements include meeting any limits established by a TMDL or limits established under watershed remediation projects.

✓ No degradation was proposed in this permit action and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

Schedule of Compliance (SOC):

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation.

A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

A SOC is not allowed:

- For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 CFR § 125.3.
- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study that may result in site-specific criteria or alternative effluent limits. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOCs, and attain a greater level of consistency, on April 9, 2015 the Department issued an updated policy on development of SOCs. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as a Cost Analysis for Compliance.

✓ The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(11)]. The facility has been given a schedule of compliance to meet final effluent limits for Total Nitrogen. The twelve (12) year schedule of compliance allowed for this facility should provide adequate time to evaluate operations, obtain an engineering report, hold a bond election, obtain a construction permit and implement upgrades required to meet effluent limits. Due to the high economic burden on this community of the cost of compliance and associated difficulty in raising the necessary funding, the schedule has been established at 12 years in accordance with the Department's "Schedule of Compliance, Policy for Staff Drafting Operating Permits". Please see the Cost Analysis for Compliance attached as an appendix to the permit for further detail on how the socio-economic status of the community has impacted this SOC.

The following suggested milestones can be used by the permittee as a timeline toward compliance with new permit requirements.

Suggested Milestones during the 12 Year Schedule of Compliance

Year	Milestone(s)
1	Hire engineer and conduct rate survey, submit application for Engineering Report Grant for I&I evaluations
2	Implement rate survey recommendations, optimization, I&I work
3	Optimization, I&I work
4	Optimization, I&I work. Annual report shall detail the permittee's compliance approach to meet final limits (i.e. installation of technology, purchase TN credits, or hybrid including installation of technology and purchase of TN credits)
5	Submit renewal application, hold bond election, I&I work
6	Submit funding application, submit facility plan/Antidegradation, develop construction permit application, I&I work
7	Submit construction permit application, operating permit modification application, technical plans and specifications and summary of design
8	Construction permit application review, start construction
9	Construction
10	Construction, submit renewal application
11	Construction
12	Construction complete, submit Statement of Work Complete, meet limits

Part V – Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

✓ The Department is required to determine "findings of affordability" because the permit applies to a combined or separate sanitary sewer system for a publicly-owned treatment works.

Cost Analysis for Compliance:

The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

The following table summarizes the results of the cost analysis. See **Appendix C – Cost Analysis for Compliance** for detailed information.

Summary Table. Cost Analysis for Compliance Summary for the City of Fremont Hills

Annual Median Household Income (MHI)	Estimated Monthly User Rate	Residential Indicator (User Rate as a Percent of MHI)	Financial Capability Indicator	Financial Burden	Schedule of Compliance Length
\$121,310	\$167.71	1.66%	2.8	Medium-Burden	12 years

Pollution Control Option Selected for Analysis: BNR treatment system with UV disinfection and additional sampling costs.

Estimated Present Worth: \$6,991,439

Part VI – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

Permit Synchronization:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. With permit synchronization, the next cycle of this permit will expire in the 3rd Quarter of calendar year 2028.

Public Notice:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

✓ The Public Notice period for this operating permit was May 26, 2023 through June 26, 2023. No comments were received.

DATE OF STATEMENT OF BASIS: APRIL 18, 2023

COMPLETED BY:

NICOLE TERHERST AMEZCUA, ENVIRONMENTAL PROGRAM ANALYST MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT (573) 526-4029 Nicole.TerherstAmezcua@dnr.mo.gov

Appendices

$APPENDIX\ A-JAMES\ RIVER\ WATERSHED\ NUTRIENT\ PERMITTING\ FRAMEWORK\ -\ WATERSHED\ PERMITTEES\ (<0.100\ MGD)$ and TN Wasteload Allocation Goals

Permit No.	Permittee	Facility	Design Flow MGD	Optimization TN Goal mg/L
MO0129828	Village of Diggins	Diggins WWTF	0.045	15.0
MO0107182	City of Galena	Galena WWTF	0.099	15.0
MO0125601	City of Hurley	Hurley WWTF	0.052	15.0
MO0119067	Galena R-II Schools	Galena Abesville School WWTF	0.004	15.0
MO0128163	Harold Oberkrom	Oak Hill MHP	0.019	15.0
MO0100315	James Valley Farm Property Owners Association, Inc.	James Valley Farms Subdivision WWTP	0.009	15.0
MO0116971	Liberty Utilities (Missouri Water) LLC	Valley Woods Water Co. WWTP	0.010	15.0
MO0093556	Missouri Department of Corrections	MDOC, Ozark Correctional Facility	0.092	15.0
MO0106127	North O Real Estate, LLC	Cedar Hill Apartments WWTP	0.007	15.0
MO0114464	River Downs West Homeowners Association Inc.	River Downs West Subdivision WWTF	0.019	15.0
MO0106470	Shirley Smith	South Oaks MHP WWTP	0.013	15.0
MO0121568	Three Stone Properties	Silver Bell Mobile Home & RV Park WWTP	0.023	15.0
MO0119008	Wood Ridge South Property Owners Association, Inc.	Wood Ridge South Subdivision WWTF	0.014	15.0

APPENDIX B - JAMES RIVER WATERSHED NUTRIENT PERMITTING FRAMEWORK - WATERSHED PERMITTEES (\geq 0.100 MGD) and TN Wasteload Allocations:

Permit No.	Permittee	Facility	Design Flow MGD	James River TMDL TN Limitation mg/L	12-Month Mass Load lbs/year
MO0102318	City of Clever	Clever WWTF	0.210	10.0	6,392.61
MO0040835	City of Crane	Crane WWTF	0.300	10.0	9,132.30
MO0099813	City of Fordland	Fordland Municipal WWTF	0.100	10.0	3,044.10
MO0106151	City of Fremont Hills	Fremont Hills WWTF	0.176	10.0	5,357.62
MO0028037	City of Nixa	Nixa WWTF	4.000	10.0	121,764.00
MO0099163	City of Ozark	Ozark WWTF	2.100	10.0	63,926.10
MO0133671	City of Ozark	Elk Valley WWTF	1.000	10.0	30,441.00
MO0102679	City of Rogersville	Rogersville WWTF	0.960	10.0	29,223.36
MO0022985	City of Seymour	Seymour WWTF	0.378	10.0	11,506.70
MO0104027	City of Sparta	Sparta WWTF	0.200	10.0	6,088.20
MO0049522	City of Springfield	Springfield Southwest WWTF	64.000	10.0	1,948,224.00
MO0131172	Tuscany Hills Regional Sewer District, Inc.	Tuscany Hills Subdivision WWTF	0.120	10.0	3,652.92

APPENDIX C – COST ANALYSIS FOR COMPLIANCE:

Missouri Department of Natural Resources Water Protection Program Cost Analysis for Compliance (In accordance with RSMo 644.145)

Fremont Hills WWTP, Permit Modification City of Fremont Hills Missouri State Operating Permit #MO-0106151

Section 644.145 RSMo requires the Department of Natural Resources (Department) to make a "finding of affordability" when "issuing permits under" or "enforcing provisions of" state or federal clean water laws "pertaining to any portion of a combined or separate sanitary sewer system for publicly-owned treatment works." This cost analysis does not dictate that the permittee will upgrade their facility, or how the permittee will comply with new permit requirements. The results of this analysis are used to determine an adequate compliance schedule for the permit that may mitigate the financial burden of new permit requirements.

New Permit Requirements

The permit requires compliance with new effluent limitations for Total Nitrogen, which may require the design, construction, and operation of a different treatment technology. The cost assumptions in this analysis anticipate replacement of the existing treatment facility. For this analysis, the Department has selected a mechanical system that could be the most practical solution to meet the new requirements for the community.

The permit requires compliance with new effluent monitoring requirements for Total Nitrogen. The permit requires compliance with revised effluent monitoring frequencies for Total Kjeldahl Nitrogen and Nitrate + Nitrite.

Flow and Connections

The size of the facility evaluated for upgrades was chosen based on the permitted design flow. If significant population growth is expected in the community, or if a significant portion of the flow is due to inflow and infiltration, then the flows and resulting estimated costs used in a facility plan prepared by a consulting engineer may differ. The number of connections was reported by the permittee on the Financial Questionnaire.

Flow Evaluated: 176,000 gallons per day			
Connection Type	Number		
Residential	547		
Commercial	4		
Industrial	0		
Total	551		

Data Collection for this Analysis

This cost analysis is based on data available to the Department as provided by the permittee and data obtained from readily available sources. For the most accurate analysis, it is essential that the permittee provides the Department with current information about the City's financial and socioeconomic situation. The financial questionnaire available to permittees on the Department's website (https://dnr.mo.gov/document-search/financial-questionnaire-mo-780-2511) is a required attachment to the permit renewal application. If the financial questionnaire is not submitted with the renewal application, the Department sends a request to complete the form with the welcome correspondence. The City submitted a Financial Questionnaire to the Department on April 28, 2023. If certain data was not provided by the permittee to the Department and the data is not obtainable through readily available sources, this analysis will state that the information is "unknown".

The Department estimates the cost for construction of a treatment plant using a software program from Hydromantis¹ titled CapdetWorks. CapdetWorks is a preliminary design and costing software program for wastewater treatment plants utilizing national indices, such as the Marshall and Swift Index and Engineering News Records Cost Index, to price the development of capital, operating, maintenance, material, and energy costs for various treatment technologies. The program works from national indices; therefore, estimated costs will vary from actual costs, as each community is unique in its budget commitments and treatment design. Because the methods used to derive the analysis estimate costs that tend to be greater than actual costs associated with an upgrade, it reflects a conservative estimate anticipated for a community. The overestimation of costs is due to the fact that it is unknown by the

Department what existing equipment and structures will be reused in the upgraded facility before an engineer completes a facility design. For questions associated with CapdetWorks, please contact the Department's Engineering Section at (573) 751-6621.

Eight Criteria of 644.145 RSMo

The Department must consider the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with new permit requirements.

(1) A community's financial capability and ability to raise or secure necessary funding;

Criterion 1 Table. Current Financial Information for the City of Fremont Hills			
Current Monthly User Rates per 5,000 gallons*	\$48.77		
Municipal Bond Rating (if applicable)	N/A		
Bonding Capacity**	\$6,871,969		
Median Household Income (MHI) ²	\$121,310		
Current Annual Operating Costs (excludes depreciation)	\$503,945		
Current Outstanding Debt for the Facility	\$590,000		
Amount within the Current User Rate Used toward Payments on Outstanding Debt Related to the Current Wastewater Infrastructure	\$29.52		

^{*} User Rates were obtained from the City of Fremont Hills Financial Questionnaire and the 2022 Missouri Public Utility Alliance Water and Wastewater Rate Survey.

(2) Affordability of pollution control options for the individuals or households at or below the median household income level of the community;

The cost estimates located within this document are for the construction of a disinfection system that is the most practical to facilitate compliance with new permit requirements.

Cost Estimate Assumptions:

- Total Present Worth includes a five percent interest rate to construct and perform annual operation and maintenance of the new treatment plant over the term of the loan, which is 20 years for the mechanical plant option.
- Capital Cost includes design, construction, inspection, and contingency costs from CapdetWorks.
- Operation and maintenance (O&M) includes operations, maintenance, materials, chemical, and electrical costs for the facility on an annual basis. It includes items that are expected to be replaced during operations, such as pumps and is estimated between 15% and 45% of the user rate.
- Estimated user costs per 5,000 gallons per month are calculated using equations that account for debt retirement and annualized operation and maintenance costs over the life of the treatment facility. Estimated user costs are not added to the community's current user rate because they estimate total replacement of the facility.

The following table outlines the estimated costs of the new permit requirements:

Criterion 2A Table. Estimated Cost Breakdown of New Permit Requirements					
New Requirement	Frequency	Estimated Cost	Estimated Annual Cost		
Total Kjeldahl Nitrogen – Effluent	Weekly §	\$31.50 x 48	\$1,512		
Nitrate + Nitrite - Effluent	Weekly §	\$31.50 x 48	\$1,512		
Total Estimated Annual Cost of New Sampling and Permit Requirements \$3,024					

^{§ -} Previous permit required quarterly frequency

Mechanical Plant Pollution Control Option Cost Estimates:

For the mechanical plant option, the Department has estimated costs for a BNR treatment system with UV disinfection.

^{**} General Obligation Bond capacity allowed by constitution: Cities = up to 20% of taxable tangible property; Sewer districts or villages = up to 5% of taxable tangible property

Sludge handling and sludge treatment are included in the capital, operations, maintenance, and present worth cost estimations. New sampling costs are also included in the following cost estimations.

Crit	Criterion 2B Table. Estimated Costs for Mechanical Plant Pollution Control Option					
(1)	Estimated Total Present Worth	\$6,991,439				
	Estimated Capital Cost	\$3,357,733				
	Estimated Annual Cost of Operation and Maintenance	\$291,578				
	Estimated Monthly Cost Per User	\$137.72				
	Estimated Monthly Costs of New Sampling and Permit Requirements Per User	\$0.47				
(2)	Current Monthly Debt Retirement Amount Per User	\$29.52				
(3)	Total Monthly User Cost*	\$167.71				
	Total Monthly User Cost as a Percent of MHI ⁴	1.66 %				

^{*} Current User Rate + Estimated Monthly Costs + Estimated Monthly Costs of New Sampling and Permit Requirements + Debt Retirement Amount

(3) An evaluation of the overall costs and environmental benefits of the control technologies;

An investment in wastewater treatment will provide several social, environmental, and economic benefits. Improved wastewater provides benefits such as avoided health costs due to water-related illness, enhanced environmental ecosystem quality, and improved natural resources. The preservation of natural resources has been proven to increase the economic value and sustainability of the surrounding communities. Maintaining Missouri's water quality standards fulfills the goal of restoring and maintaining the chemical, physical, and biological integrity of the receiving stream; and, where attainable, it achieves a level of water quality that provides for the protection and propagation of fish, shellfish, wildlife, and recreation in and on the water.

Total Ammonia Nitrogen Treatment

Ammonia can be toxic to aquatic life. Fish may suffer a loss of equilibrium, hyperexcitability, increased respiratory activity and oxygen uptake, and increased heart rate. At extreme ammonia levels, fish may experience convulsions, coma, and death. Native fish and other native aquatic life are extremely important to Missouri's ecosystem. They contribute essential nutrients to the streams, rivers, lakes, pond other waters in which they inhabit. Freshwater ecosystems are important for human survival, in that it provides a majority of people's drinking water. Also, a pristine freshwater ecosystem with an abundance of aquatic life can increase the community's overall income of revenue. Revenue to businesses and sales tax revenue is increased as the natural amenity will attract fisherman and tourism to the area. Fish and other aquatic life also provide a source of low cost sustenance for the people within the surrounding communities. Final water quality-based effluent limits for total ammonia nitrogen is a requirement of this permit. A schedule of compliance is given with the final limits so that the permittee has time to secure funding and update their treatment plant, if necessary. Further information can be found in the Water Protection Program fact sheet titled "Changes to the Water Quality Standard for Ammonia" at https://dnr.mo.gov/document-search/ammonia-criteria-new-epa-recommended-criteria-pub2481/pub2481.

Nutrient Limits

Nutrients are mineral compounds that are required for organisms to grow and thrive. Of the six (6) elemental macronutrients, nitrogen and phosphorus are generally not readily available and limit growth of organisms. Excess nitrogen and phosphorus will cause a shift in the ecosystem's food web. Once excess nitrogen and phosphorus are introduced into a waterbody, some species' populations will dramatically increase, while other populations will not be able to sustain life. Competition and productivity are two factors in which nutrients can alter aquatic ecosystems and the designated uses of a waterbody. For example, designated uses, such as drinking water sources and recreational uses, become impaired when algal blooms take over a waterbody. These blooms can cause foul tastes and odors in the drinking water, unsightly appearance, and fish mortality in the waterbody. Some algae also produce toxins that may cause serious adverse health conditions such as liver damage, tumor promotion, paralysis, and kidney damage. The effluent limits for nitrogen and phosphorus have been added to the permit to protect the health of the receiving stream's aquatic life. A healthy ecosystem is beneficial as it provides reduced impacts on human and aquatic health as well as recreational opportunities.

TMDL Limits

Effluent limits have been added or revised in the permit to protect the health of the receiving stream. These limits have been established based on the approved total maximum daily load (TMDL) for the receiving stream. The TMDL is the calculation of the maximum amount of a specific pollutant that a water body can absorb and still meet water quality standards. Missouri's water quality standards establish pollutant limits to protect drinking water supply, fishing, swimming, aquatic life and other designated uses. When waterbodies fail to meet the water quality standards, they are considered impaired waters. The federal Clean Water Act requires states

to develop TMDLs for all waters on the 303(d) List of Impaired Waters. The calculated TMDL is allocated among the various pollutant sources in the watershed and becomes the goal to restore water quality. Each TMDL document includes allocations of the acceptable load for all pollutant sources. The portion of the load distributed to point sources (e.g., sewage treatment plants) is the wasteload allocation (WLA). Point source discharges are controlled by including water quality-based effluent limits (WQBEL) in permits issued to point source entities. WQBELs are calculated based on the WLAs in the TMDLs.

(4) Inclusion of ongoing costs of operating and maintaining the existing wastewater collection and treatment system, including payments on outstanding debts for wastewater collection and treatment systems when calculating projected rates:

The community reported that their outstanding debt for their current wastewater collection and treatment systems is \$590,000. The community reported that each user pays \$48.77 monthly, of which, \$29.52 is used toward payments on the current outstanding debt.

- (5) An inclusion of ways to reduce economic impacts on distressed populations in the community, including but not limited to low and fixed income populations. This requirement includes but is not limited to:
 - (a) Allowing adequate time in implementation schedules to mitigate potential adverse impacts on distressed populations resulting from the costs of the improvements and taking into consideration local community economic considerations.
 - A schedule of compliance will be provided based on the results of this cost analysis. The schedule of compliance is provided to ensure that the entity has time to reasonably plan for compliance with the new permit requirements. The time provided ensures the entity has time to hire an engineer, develop facility plans, hold community meetings, seek an appropriate funding source, and construct the facility. If it is determined by the permittee that a longer schedule of compliance is necessary due to financial reasons, please contact the Department and request modification of the compliance schedule.
 - An integrated plan may be an appropriate option if the community needs to meet other environmental obligations as well as the new requirements within this permit. The integrated plan needs to be well thought out with specific timeframes built into the management plan in which the municipality can reasonably commit. The plan should be designed to allow the municipality to meet Clean Water Act obligations by maximizing infrastructure improvement dollars through the appropriate sequencing of work. For further information on how to develop an integrated plan, please see the Department publication, "Missouri Integrated Planning Framework," at https://dnr.mo.gov/document-search/missouri-integrated-planning-framework-pub2684/pub2684.
 - If the permittee can demonstrate that the proposed pollution controls result in substantial and widespread economic and social impact, they may use Factor 6 of the Use Attainability Analysis (UAA) 40 CFR 131.10(g)(6) in the form of a variance. This process is completed by determining the treatment type with the highest attainable effluent quality that would not result in a socio-economic hardship. For more information on variance requests, please visit the Department's water quality standards webpage at https://dnr.mo.gov/water/what-were-doing/water-planning/quality-standards-impaired-waters-total-maximum-daily-loads/standards/variances.
 - (b) Allowing for reasonable accommodations for regulated entities when inflexible standards and fines would impose a disproportionate financial hardship in light of the environmental benefits to be gained.
 - The permittee may apply for State Revolving Fund (SRF) financial support in order to help fund a capital improvements plan. Other loans and grants also exist for which the facility may be eligible. More information can be found on the Department's FAC website at https://dnr.mo.gov/water/business-industry-other-entities/financial-opportunities/financial-assistance-center/wastewater.

The following table characterizes the current overall socioeconomic condition of the community as compared to the overall socioeconomic condition of Missouri. The following information was compiled using the latest U.S. Census data.

Criterion 5 Table. Socioeconomic Data ^{2,4-8} for the City of Fremont Hills

Table 1.5	Table 1. Socioeconomic Data for the Current Year			
No.	Administrative Unit	Fremont Hills City	Missouri State	
1	Population (2021)	1,087	6,141,534	
2	Percent Change in Population (2000-2021)	82.1%	9.8%	
3	2021 Median Household Income (in 2022 Dollars)	\$121,310	\$65,928	
4	Percent Change in Median Household Income (2000-2021)	-21.4%	-1.1%	
5	Median Age (2021)	45.0	38.8	
6	Change in Median Age in Years (2000-2021)	2.0	2.7	
7	Unemployment Rate (2021)	1.9%	4.5%	
8	Percent of Population Below Poverty Level (2021)	3.0%	12.8%	
9	Percent of Household Received Food Stamps (2021)	0.7%	10.1%	
10	(Primary) County Where the Community Is Located	Christian County		

(6) An assessment of other community investments and operating costs relating to environmental improvements and public health protection;

The community did not report any other investments relating to environmental improvements.

(7) An assessment of factors set forth in the United States Environmental Protection Agency's guidance, including but not limited to the "Combined Sewer Overflow Guidance for Financial Capability Assessment and Schedule Development" that may ease the cost burdens of implementing wet weather control plans, including but not limited to small system considerations, the attainability of water quality standards, and the development of wet weather standards;

The following table characterizes the community's overall financial capability to raise the necessary funds to meet the new permit requirements.

Criterion 7A Table. Financial Capability Indicator

Indicators	Strong (3 points)	Mid-Range (2 points)	Weak (1 point)	Score
Bond Rating Indicator	Above BBB or Baa	BBB or Baa	Below BBB or Baa	N/A
Overall Net Debt as a % of Full Market Property Value	Below 2%	2% - 5%	Above 5%	3
Unemployment Rate (2021)	Beyond 1% below Missouri average of 4.5%	± 1% of Missouri average of 4.5%	Beyond 1% above Missouri average of 4.5%	3
2021 Median Household Income (in 2022 Dollars)	Beyond 25% above Missouri MHI (\$65,928)	± 25% of Missouri MHI (\$65,928)	Beyond 25% below Missouri MHI (\$65,928)	3
Percent of Population Below Poverty Level (2021)	Beyond 10% below Missouri average of 12.8%	± 10% of Missouri average of 12.8%	Beyond 10% above Missouri average of 12.8%	2
Percent of Household Received Food Stamps (2021)	Beyond 5% below Missouri average of 10.1%	± 5% of Missouri average of 10.1%	Beyond 5% above Missouri average of 10.1%	3
Property Tax Revenues as a % of Full Market Property Value	Below 2%	2% - 4%	Above 4%	3
Property Tax Collection Rate	Above 98%	94% - 98%	Below 94%	3
Total Average Score (Financial Capability Indicator)				2.8

The **Financial Capability Indicator** and the **Residential Indicator** are considered jointly in the Financial Capability Matrix to determine the financial burden that could occur from compliance with the new requirements of the permit.

	nancial Capability Indicator (from Criterion 7):	
• Me	echanical Plant Residential Indicator (from Criterion 2):	1.66

Criterion 7B Table. Financial Capability Matrix

Financial Capability	Residentia	l Indicator (User Rate as a ⁹	% of MHI)
Indicator	Low (Below 1%)	Mid-Range (1.0% to 2.0%)	High (Above 2.0%)
Weak (Below 1.5)	Medium Burden	High Burden	High Burden
Mid-Range (1.5 – 2.5)	Low Burden	Medium Burden	High Burden
Strong (Above 2.5)	Low Burden	Medium Burden	High Burden

Resulting Financial Burden for Mechanical Plant:	Medium Burdern
--	----------------

(8) An assessment of any other relevant local community economic conditions.

The community did not report any other relevant local economic conditions.

Conclusion and Finding

As a result of new regulations, the Department is proposing modifications to the current operating permit that may require the permittee to upgrade the facility and construct new control technologies and to increase monitoring. The Department has considered the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with the new permit requirements.

The Department finds that a <u>BNR treatment system with UV disinfection is the most practical and affordable option</u> for the City of Fremont Hills. The construction and operation of a BNR treatment system with UV disinfection will ensure that the individuals within the community will not be required to make unreasonable sacrifices in their essential lifestyle or spending patterns or undergo hardships in order to make the projected monthly payments for sewer connections.

In accordance with 40 CFR 122.47(a)(1) and 10 CSR 20-7.031(11), compliance must occur as soon as possible; therefore, based on this analysis, the permit holder has received an **twelve (12)** year schedule of compliance for the design and construction of a BNR treatment system with UV disinfection. The following suggested milestones can be used by the permittee as a timeline toward compliance with new permit requirements. Once the permit holder's engineer has completed facility design with actual costs associated with permit compliance, it may be necessary for the permit holder to request additional time within the schedule of compliance. The Department is committed to review all requests for additional time in the schedule of compliance where adequate justification is provided.

Suggested Milestones during the 12 Year Schedule of Compliance

Year	Milestone(s)
1	Hire engineer and conduct rate survey, submit application for Engineering Report Grant for I&I evaluations
2	Implement rate survey recommendations, optimization, I&I work
3	Optimization, I&I work
4	Optimization, I&I work. Annual report shall detail the permittee's compliance approach to meet final limits (i.e. installation of technology, purchase TN credits, or hybrid including installation of technology and purchase of TN credits)
5	Submit renewal application, hold bond election, I&I work
6	Submit funding application, submit facility plan/Antidegradation, develop construction permit application, I&I work
7	Submit construction permit application, operating permit modification application, technical plans and specifications and summary of design
8	Construction permit application review, start construction
9	Construction

10	Construction, submit renewal application
11	Construction
12	Construction complete, submit Statement of Work Complete, meet limits

The Department is committed to reassessing the cost analysis for compliance at renewal to determine if the initial schedule of compliance will accommodate the socioeconomic data and financial capability of the community at that time. Because each community is unique, the Department wants to make sure that each community has the opportunity to consider all options and tailor solutions to best meet their needs. The Department understands the economic challenges associated with achieving compliance, and is committed to using all available tools to make an accurate and practical finding of affordability for Missouri communities. If the community is interested in the funding options available to them, please contact the Financial Assistance Center for more information. https://dnr.mo.gov/water/business-industry-other-entities/financial-opportunities/financial-assistance-center/wastewater.

This determination is based on readily available data and may overestimate the financial impact on the community. The community's facility plan that is submitted as a part of the construction permit process includes a discussion of community details, what the community can afford, existing obligations, future growth potential, an evaluation of options available to the community with cost information, and a discussion on no-discharge alternatives. The cost information provided through the facility plan process, which is developed by the community and their engineer, is more comprehensive of the community's individual factors in relation to selected treatment technology and costing information.

References

- 1. http://www.hydromantis.com/
- (A) 2021 MHI in 2021 Dollar: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B19013: Median Household Income in the Past 12 Months (in 2021 Inflation-Adjusted Dollars). https://data.census.gov/cedsci/table?q=B19013&tid=ACSDT5Y2021.B19013.
 - (B) 2000 MHI in 1999 Dollar: (1)For United States, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-1 Part 1. United States Summary, Table 5. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf.
 - (2) For Missouri State, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-27, Missouri, Table 10. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf.
 - (C) 2022 CPI, 2021 CPI and 1999 CPI: U.S. Department of Labor Bureau of Labor Statistics (2022) Consumer Price Index All Urban Consumers, U.S. City Average. All Items. 1982-84=100 (unadjusted) CUUR0000SAO. https://data.bls.gov/cgi-bin/surveymost?bls.
 (D) 2021 MHI in 2022 Dollar = 2021 MHI in 2021 Dollar x 2022 CPI /2021 CPI; 2000 MHI in 2021 Dollar = 2000 MHI in 1999 Dollar x 2022 CPI /1999 CPI.
 - (E) Percent Change in Median Household Income (2000-2021) = (2021 MHI in 2022 Dollar 2000 MHI in 2022 Dollar) / (2000 MHI in 2022 Dollar).
- 3. (\$167.71/(\$121,310/12))100% = 1.66% (mechanical + sampling + debt payment)
- 4. (A) Total Population in 2021: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B01003: Total Population Universe: Total Population. https://data.census.gov/cedsci/table?q=B01003&tid=ACSDT5Y2021.B01003.
 - (B) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC.
 - https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf.
 - (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC. https://www2.census.gov/library/publications/2003/dec/phc-2-1-pt2.pdf.
 - (C) Percent Change in Population (2000-2021) = (Total Population in 2021 Total Population in 2000) / (Total Population in 2000).
- 5. Median Age in 2021: United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table B01002: Median Age by Sex Universe: Total population. https://data.census.gov/cedsci/table?q=B01002&tid=ACSDT5Y2021.B01002.
- (B) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC., Page 2. https://www.census.gov/content/dam/Census/library/publications/2003/dec/phc-2-1-pt1.pdf.
 - (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC., Pages 64-92. https://www2.census.gov/library/publications/2003/dec/phc-2-1-pt2.pdf.
 - (C) Change in Median Age in Years (2000-2021) = (Median Age in 2021 Median Age in 2000).
- 6. United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, \$2301: Employment Status for the Population 16 Years and Over Universe: Population 16 years and Over. https://data.census.gov/cedsci/table?q=unemployment&tid=ACSST5Y2021.S2301.
- 7. United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table S1701: Poverty Status in the Past 12 Months. https://data.census.gov/cedsci/table?q=S1701&tid=ACSST5Y2021.S1701.
- 8. United States Census Bureau. 2017-2021 American Community Survey 5-Year Estimates, Table S2201: Food Stamps/Supplemental Nutrition Assistance Program (SNAP) Universe: Households. https://data.census.gov/cedsci/table?q=S2201&tid=ACSST5Y2021.S2201.

MISSOURI DEPARTMENT OF NATURAL RESOURCES FACT SHEET FOR THE PURPOSE OF RENEWAL OF MO-0106151 FREMONT HILLS WASTEWATER TREATMENT PLANT

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollutant Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)(A)2.], a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Minor facility.

Part I – Facility Information

Facility Type: POTW

<u>Facility Description</u>: The use or operation of this facility shall be by or under the supervision of a Certified "C" Operator. Bar screen / extended aeration / chemical addition for phosphorus removal / tertiary filtration / UV disinfection / sludge disposal by contract hauler.

Have any changes occurred at this facility or in the receiving water body that affects effluent limit derivation? ✓ No.

Application Date: 3/12/19 Expiration Date: 9/30/19

OUTFALL(S) TABLE:

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	0.273	Tertiary	Domestic

Facility Performance History:

This facility was last inspected on June 21, 2018. The inspection showed the following unsatisfactory features: The City failed to properly operate and maintain the WWTF to ensure compliance with the MSOP effluent limits and conditions. Laboratory procedures did not conform to the MSOP Standard Conditions Part I, Section A. The City has not developed a written program for maintenance and repair of the collection system in accordance with the requirements in Special Condition 11 of MSOP. The operation test for Non Filterable Rsidue also known as Totatl Suspended Solids (TSS) was not being performed weekly at the influent as required in Missouri Clean Water Commission Regulation 10 CSR 20-9.010(5). Failure to comply with this regulation is a violation of Special Condition 10 of the MSOP. The facility returned to compliance on August 20, 2018.

A review of discharge monitoring reports submitted by the permittee since June 2016 indicate the following:

- DMR Non-Receipt: June 2016.
- Final Effluent Exceedances:
 - o E. coli: November 2018 and May 2018.
 - o Oil & Grease: December 2016.

Comments:

Changes in this permit include the recalculation of Ammonia as N final effluent limits, the addition of influent monitoring for Total Phosphorus and Total Nitrogen (Speciated) and the removal of Acute WET Test requirements, removal of monitoring for Iron, Total Recoverable and the removal of monitoring for Nitrate as N. Total Nitrogen was speciated as regulations have been updated. See Part

Fremont Hills WWTP Fact Sheet Page #2

VI of the Fact Sheet for further information regarding the addition, revision, and removal of effluent parameters. Special conditions include updates to reporting of Non-detects, bypass reporting requirements and the removal of general criteria as a special condition as the permit writer evaluated each narrative statement in Part VI – Effluent Limits Determination for reasonable potential to cause or contribute to an excursion of the criteria and established numeric effluent limitations where necessary;

Part II - Operator Certification Requirements

✓ This facility is required to have a certified operator.

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], the permittee shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.020(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Owned or operated by ☐ - Municip ☐ - County ☐ - Public So		 □ - State agency □ - Public Water Supply Districts □ - Private Sewer Company regulated by the Public Service Commission
Each of the above entities	are only applicable if they	have a Population Equivalent greater than two hundred (200).
	•	a <u>C</u> Certification Level. Please see Appendix - Classification Worksheet . lity may cause the classification to be modified.
Operator's Name:	Robert O. Dver	

Certification Number: 3205 Certification Level: WW-A

The listing of the operator above only signifies that staff drafting this operating permit have reviewed appropriate Department records and determined that the name listed on the operating permit application has the correct and applicable Certification Level.

Part III - Operational Control Testing Requirements

Missouri Clean Water Commission regulation 10 CSR 20-9.010 requires certain publically owned treatment works and privately owned facilities regulated by the Public Service Commission to conduct internal operational control monitoring to further ensure proper operation of the facility and to be a safeguard or early warning for potential plant upsets that could affect effluent quality. This requirement is only applicable if the publically owned treatment works and privately owned facilities regulated by the Public Service Commission has a Population Equivalent greater than two hundred (200).

10 CSR 20-9.010(3) allows the Department to modify the monitoring frequency required in the rule based upon the Department's judgement of monitoring needs for process control at the specified facility.

- ✓ As per [10 CSR 20-9.010(4))], the facility is required to conduct operational monitoring.
 - ✓ The facility is a mechanical plant and is required to conduct operational control monitoring as follows:

Operational Monitoring Parameter	Frequency
Precipitation	Daily (M-F)
Flow – Influent or Effluent	Daily (M-F)
pH – Influent	Daily (M-F)
Temperature (Aeration basin)	Daily (M-F)
TSS – Influent	Weekly
TSS – Mixed Liquor	Weekly
Settleability – Mixed Liquor	Daily (M-F)
Dissolved Oxygen – Mixed Liquor	Daily (M-F)

Part IV – Receiving Stream Information

RECEIVING STREAM(S) TABLE: OUTFALL #001

WATER-BODY NAME	CLASS	WBID	DESIGNATED USES*	12-Digit HUC	DISTANCE TO CLASSIFIED SEGMENT (MI)
8-20-13 MUDD V1.0	С	3960	AQL, WBC-B, SCR, HHP,		0.0
8-20-13 MUDD V1.0	С	3960	IRR, LWW	11010002-0304	0.5 (losing)
James River	Р	2362	AQL, CLF, WBC-A, SCR, HHP, IRR, LWW,		2.47

^{*}As per 10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(C)].

Uses found in the receiving streams table, above:

10 CSR 20-7.031(1)(C)1.:

AQL = Protection of aquatic life (Current narrative use(s) are defined to ensure the protection and propagation of fish shellfish and wildlife, which is further subcategorized as: WWH = Warm Water Habitat; **CDF** = Cold-water fishery (Current narrative use is cold-water habitat.); **CLF** = Cool-water fishery (Current narrative use is cool-water habitat);

EAH = Ephemeral Aquatic Habitat; MAH = Modified Aquatic Habitat; LAH = Limited Aquatic Habitat. This permit uses AQL effluent limitations in 10 CSR 20-7.031 Table A for all habitat designations unless otherwise specified.)

10 CSR 20-7.031(1)(C)2.: Recreation in and on the water

WBC = Whole Body Contact recreation where the entire body is capable of being submerged;

WBC-A = Whole body contact recreation that supports swimming uses and has public access;

WBC-B = Whole body contact recreation that supports swimming;

SCR = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(C)3. to 7.:

HHP (formerly HHF) = Human Health Protection as it relates to the consumption of fish;

IRR = Irrigation for use on crops utilized for human or livestock consumption;

LWW = Livestock and wildlife watering (Current narrative use is defined as LWP = Livestock and Wildlife Protection);

DWS = Drinking Water Supply;

IND = Industrial water supply

10 CSR 20-7.031(1)(C)8-11.: Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)

WSA = Storm- and flood-water storage and attenuation; WHP = Habitat for resident and migratory wildlife species;

WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses; WHC = Hydrologic cycle maintenance.

10 CSR 20-7.031(6): **GRW** = Groundwater

RECEIVING STREAM(S) LOW-FLOW VALUES:

DECERTING STREAM	Low-Flow Values (CFS)			
RECEIVING STREAM	1Q10	7Q10	30Q10	
8-20-13 MUDD V1.0	0	0	0	

MIXING CONSIDERATIONS TABLE:

MIXING ZONE (CFS) [10 CSR 20-7.031(5)(A)4.B.(I)(a)]			ZONE OF INITIAL DILUTION (CFS) [10 CSR 20-7.031(5)(A)4.B(I)(b)]		
1Q10 7Q10 30Q10		, , , , -	1Q10	7Q10	30Q10
0	0	0	0	0	N/A

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Receiving Water Body's Water Quality

The Department conducted a stream survey on September 3, 2014, at three locations near this facility: at the outfall, approximately 25 yards downstream of the outfall and approximately 10 yards upstream of the outfall. No use designations of the receiving stream were impaired.

Part V – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream, and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

✓ The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(40)] & [10 CSR 20-7.031(1)(O)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(o); 40 CFR Part 122.44(l)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- ✓ Limitations in this operating permit for the reissuance of this permit conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 CFR Part 122.44.
- ✓ Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance.
 - <u>Ammonia as N</u>. Effluent limitations were re-calculated for Ammonia based on new information derived from discharge monitoring reports and on the current Missouri Water Quality Standards for Ammonia. The newly established limitations are still protective of water quality.
 - Acute Whole Effluent Toxicity (WET) test. The previous permit included requirements to conduct an Acute WET test once during the permit cycle. The permit writer has conducted reasonable potential determinations for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists. Also, the facility has passed previous Acute WET tests. Therefore, the permit writer has made a reasonable potential determination which concluded the facility does not have reasonable potential to exceed narrative water quality standards for acute toxicity at this time and the acute WET testing requirements have been removed from this permit. This determination will be reevaluated during the next permit renewal.
 - <u>Iron, Total Recoverable.</u> Monitoring requirements removed. DMR data indicates that the facility has consistently reported 0 mg/L in the effluent; therefore, there is no reasonable potential to violate the water quality standard. This determination will be reassessed at renewal.
 - <u>Nitrate as N.</u> The previous permit contained monitoring requirements to determine whether reasonable potential to cause an excursion of the water quality standard existed. During the drafting of this permit, the permit writer has made a Reasonable Potential Determination that the discharge is not reasonably expected to impact specific drinking water wells. Therefore, the monitoring requirements for Nitrate have been removed from this permit. The permit is still protective of water quality and this determination will be reassessed at the time of renewal.
 - ✓ The Department determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
 - The previous permit indicated "There Shall Be No Discharge of Floating Solids or Visible Foam in Other Than Trace Amounts" under each table. The statement was not evaluated against actual site conditions therefore, this general criteria was re-assessed. It was determined that this facility does not discharge solids or foam in amounts which would indicate reasonable potential, therefore the statement was removed. Each general criteria was assessed for this facility.
 - ✓ The Department determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
 - General Criteria. The previous permit contained a special condition which described a specific set of prohibitions related to general criteria found in 10 CSR 20-7.031(4). In order to comply with 40 CFR 122.44(d)(1), the permit writer has conducted reasonable potential determinations for each general criterion and established numeric effluent limitations where reasonable potential exists. While the removal of the previous permit special condition creates the appearance of backsliding, since this permit establishes numeric limitations where reasonable potential to cause or contribute to an excursion of the general criteria exists the permit maintains sufficient effluent limitations and monitoring requirements in order to protect water quality, this permit is equally protective as compared to the previous permit. Therefore, given this new information, and the fact that the previous permit special condition was not consistent with 40 CFR 122.44(d)(1), an

error occurred in the establishment of the general criteria as a special condition of the previous permit. Please see Part VI – Effluent Limits Determination for more information regarding the reasonable potential determinations for each general criterion related to this facility.

ANTIDEGRADATION:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)], for domestic wastewater discharge with new, altered, or expanding discharges, the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the Department prior to establishing, altering, or expanding discharges. See http://dnr.mo.gov/env/wpp/permits/antideg-implementation.htm

✓ No degradation proposed and no further review necessary. Facility did not apply for authorization to increase pollutant loading or to add additional pollutants to their discharge.

For stormwater discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

✓ The facility does not have stormwater discharges or the stormwater outfalls onsite have no industrial exposure.

AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(2)(C)], ... An applicant may utilize a lower preference continuing authority by submitting, as part of the application, when a higher level authority is available, must submit information to the Department for review and approval, provided it does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the Department.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

✓ Permittee is not authorized to land apply biosolids. Sludge/biosolids are removed by contract hauler.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

✓ The facility is not currently under Water Protection Program enforcement action.

CONTINUING AUTHORITY:

Each application for an operating permit shall identify the person, as that term is defined in section 644.016(15), RSMo, that is the owner of, operator of, or area-wide management authority for a water contaminant source, point source, wastewater treatment facility, or sewer collection system. This person shall be designated as the continuing authority and shall sign the application. By doing so, the person designated as the continuing authority acknowledges responsibility for compliance with all permit conditions.

10 CSR 20-6.010(2) establishes preferential levels for continuing authorities: Levels 1 through 5 (with Level 1 as the highest level), and generally requires permits to be issued to a higher preference continuing authority if available. A Level 3, 4, or 5 applicant may constitute a continuing authority by showing that Level 1 and Level 2 authorities are not available; do not have jurisdiction; are forbidden by state statute or local ordinance from providing service to the person; or that the Level 3, 4, or 5 applicant has met one of the requirements listed in paragraphs (2)(C)1.–7. of 10 CSR 20-6.010(2). The seven options in paragraphs (2)(C)1.–7. for a lower-level authority to demonstrate that it is the valid continuing authority are:

- A waiver from the existing higher authority declining the offer to accept management of the additional wastewater or stormwater:
- 2. A written statement or a demonstration of non-response from the higher authority;
- 3. A to-scale map showing all parts of the legal boundary of the facility's property are beyond 2000 feet from the collection (sewer) system operated by the higher preference authority;

Fremont Hills WWTP Fact Sheet Page #6

- 4. A proposed connection or adoption charge by the higher authority that would equal or exceed what is economically feasible for the applicant, which may be in the range of one hundred twenty percent (120%) of the applicant's cost for constructing or operating a wastewater treatment system;
- 5. A proposed service fee on the users of the system by the higher authority that is above what is affordable for existing homeowners in that area;
- 6. Terms for connection or adoption by the higher authority that would require more than two (2) years to achieve full sewer service; or
- 7. A demonstration that the terms for connection or adoption by the higher authority are not viable or feasible to homeowners in the area.

Permit applicants that are Levels 3, 4, and 5 must, as part of their application, identify their method of compliance with this regulation. The following are the methods to comply.

- o No higher level authorities are available to the facility;
- o No higher level authorities have jurisdiction;
- o Higher level authorities are forbidden by state statute or local ordinance from providing service to the person;
- The existing higher level authority is available to the facility, however the facility has proposed the use of a lower preference continuing authority and has submitted one of the following as part of their application provided it does not conflict with any area-wide management plan approved under section 208 of the Clean Water Act or by the Missouri Clean Water Commission. (See Fact Sheet Appendix Continuing Authority for more information on these options):
 - A waiver from the existing higher authority;
 - A written statement or a demonstration of non-response from the higher authority;
 - A to-scale map showing all parts of the legal boundary of the facility's property are beyond 2000 feet from the collection (sewer) system operated by the higher preference authority;
 - Documentation that the proposed connection or adoption charge by the higher authority would equal or exceed what is economically feasible for the applicant, which may be in the range of one hundred twenty percent (120%) of the applicant's cost for constructing or operating a wastewater treatment system;
 - Documentation that the proposed service fee on the users of the system by the higher authority is above what is affordable for existing homeowners in that area;
 - Documentation that the terms for connection or adoption by the higher authority would require more than two (2) years to achieve full sewer service:
 - A demonstration that the terms for connection or adoption by the higher authority are not viable or feasible to homeowners in the area;
- ✓ The continuing authority listed on the application is a municipality, and therefore a Level 3 Authority. There is no approved Clean Water Act Section 208 plan in Webster County. The applicant has shown that:
 - ✓ A higher level authority is not available to the facility.

ELECTRONIC DISCHARGE MONITORING REPORT (EDMR) SUBMISSION SYSTEM:

The U.S. Environmental Protection Agency (EPA) promulgated a final rule on October 22, 2015, to modernize Clean Water Act reporting for municipalities, industries, and other facilities by converting to an electronic data reporting system. This final rule requires regulated entities and state and federal regulators to use information technology to electronically report data required by the National Pollutant Discharge Elimination System (NPDES) permit program instead of filing paper reports. To comply with the federal rule, the Department is requiring all permittees to begin submitting discharge monitoring data and reports online. In an effort to aid facilities in the reporting of applicable information electronically, the Department has created several new forms including operational control monitoring forms and an I&I location and reduction form. These forms are optional and found on the Department's website at the following locations:

Operational Monitoring Lagoon: http://dnr.mo.gov/forms/780-2801-f.pdf
Operational Monitoring Mechanical: http://dnr.mo.gov/forms/780-2800-f.pdf

I&I Report: http://dnr.mo.gov/forms/780-2690-f.pdf

Per 40 CFR 127.15 and 127.24, permitted facilities may request a temporary waiver for up to 5 years or a permanent waiver from electronic reporting from the Department. To obtain an electronic reporting waiver, a permittee must first submit an eDMR Waiver Request Form: http://dnr.mo.gov/forms/780-2692-f.pdf. Each facility must make a request. If a single entity owns or operates more than one facility, then the entity must submit a separate request for each facility based on its specific circumstances. An approved waiver is non-transferable.

Fremont Hills WWTP Fact Sheet Page #7

The Department must review and notify the facility within 120 calendar days of receipt if the waiver request has been approved or rejected [40 CFR 124.27(a)]. During the Department review period as well as after a waiver is granted, the facility must continue submitting a hard-copy of any reports required by their permit. The Department will enter data submitted in hard-copy from those facilities allowed to do so and electronically submit the data to the EPA on behalf of the facility.

✓ The permittee/facility is currently using the eDMR data reporting system.

NUMERIC LAKE NUTRIENT CRITERIA

✓ This facility discharges into a lake watershed where numeric lake nutrient criteria are applicable, per 10 CSR 20-7.031(5)(N), and has a design flow greater than 0.1 MGD. Should the lake within this watershed be identified as impaired due to nutrient loading, the Department will conduct watershed modeling to determine if this facility has reasonable potential to cause or contribute to the impairment. Consequently, effluent limitations may be established at a later date based on the modeling results. For more information, please see the Department's Nutrient Criteria Implementation Plan at:

https://dnr.mo.gov/env/wpp/rules/documents/nutrient-implementation-plan-final-072618.pdf

See Part VI. Effluent Limits Determination, below for more information.

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users.
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation
- ✓ The permittee, at this time, is not required to have a Pretreatment Program or does not have an approved pretreatment program.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(1)(iii)] if the permit writer determines that any given pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

✓ An RPA was conducted on appropriate parameters. Please see APPENDIX – RPA RESULTS.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD_5) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals.

✓ Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(12)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur. The permit also contains requirements for permittees to develop and implement a program for maintenance and repair of the collection system. The permit requires that the permittee submit an annual report to the Department for the previous calendar year that contains a summary of efforts taken by the permittee to locate and eliminate sources of excess I & I, a summary of general maintenance and repairs to the collection system, and a summary of any planned maintenance and repairs to the collection system for the upcoming calendar year.

✓ At this time, the Department recommends the US EPA's Guide for Evaluating Capacity, Management, Operation and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems (Document # EPA 305-B-05-002) or the Departments' CMOM Model located at http://dnr.mo.gov/env/wpp/permits/docs/cmom-template.doc. For additional information regarding the Departments' CMOM Model, see the CMOM Plan Model Guidance document at http://dnr.mo.gov/pubs/pub2574.htm. The CMOM identifies some of the criteria used to evaluate a collection system's management, operation, and maintenance and was intended for use by the EPA, state, regulated community, and/or third party entities. The CMOM is applicable to small, medium, and large systems; both public and privately owned; and both regional and satellite collection systems. The CMOM does not substitute for the Clean Water Act, the Missouri Clean Water Law, and both federal and state regulations, as it is not a regulation.

SCHEDULE OF COMPLIANCE (SOC):

Per 644.051.4 RSMo, a permit may be issued with a Schedule of Compliance (SOC) to provide time for a facility to come into compliance with new state or federal effluent regulations, water quality standards, or other requirements. Such a schedule is not allowed if the facility is already in compliance with the new requirement, or if prohibited by other statute or regulation. A SOC includes an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. *See also* Section 502(17) of the Clean Water Act, and 40 CFR §122.2. For new effluent limitations, the permit may include interim monitoring for the specific parameter to demonstrate the facility is not already in compliance with the new requirement. Per 40 CFR § 122.47(a)(1), 10 CSR 20-7.031(11), and 10 CSR 20-7.015(9), compliance must occur as soon as possible. If the permit provides a schedule for meeting new water quality based effluent limits, a SOC must include an enforceable, final effluent limitation in the permit even if the SOC extends beyond the life of the permit.

A SOC is not allowed:

- For effluent limitations based on technology-based standards established in accordance with federal requirements, if the deadline for compliance established in federal regulations has passed. 40 CFR § 125.3.
- For a newly constructed facility in most cases. Newly constructed facilities must meet applicable effluent limitations when discharge begins, because the facility has installed the appropriate control technology as specified in a permit or antidegradation review. A SOC is allowed for a new water quality based effluent limit that was not included in a previously public noticed permit or antidegradation review, which may occur if a regulation changes during construction.
- To develop a TMDL, UAA, or other study that may result in site-specific criteria or alternative effluent limits. A facility is not prohibited from conducting these activities, but a SOC may not be granted for conducting these activities.

In order to provide guidance to Permit Writers in developing SOCs, and attain a greater level of consistency, on April 9, 2015 the Department issued an updated policy on development of SOCs. This policy provides guidance to Permit Writers on the standard time frames for schedules for common activities, and guidance on factors that may modify the length of the schedule such as a Cost Analysis for Compliance.

✓ This permit does not contain an SOC.

SEWER EXTENSION AUTHORITY SUPERVISED PROGRAM:

In accordance with [10 CSR 20-6.010(6)(A)], the Department may grant approval of a permittee's Sewer Extension Authority Supervised Program. These approved permittees regulate and approve construction of sanitary sewers and pump stations, which are tributary to this wastewater treatment facility. The permittee shall act as the continuing authority for the operation, maintenance, and modernization of the constructed collection system. See http://dnr.mo.gov/env/wpp/permits/sewer-extension.htm.

✓ The permittee does not have a Department approved Sewer Extension Authority Supervised Program.

STORMWATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities: (2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's <u>Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators</u>, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in February 2009], BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of stormwater discharges. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 CFR 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and reevaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. For further guidance, consult the antidegradation implementation procedure (http://dnr.mo.gov/env/wpp/docs/AIP050212.pdf).

Alternative Analysis (AA) evaluation of the BMPs is a structured evaluation of BMPs that are reasonable and cost effective. The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why "no discharge" or "no exposure" is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure* (AIP), Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the Department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs.

Fremont Hills WWTP Fact Sheet Page #10

The request shall be submitted in the form of an operating permit modification; the application is found at: http://dnr.mo.gov/forms/index.html.

✓ At this time, the permittee is not required to develop and implement a SWPPP.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

✓ This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(86)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

✓ Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$Ce = \frac{(Qe + Qs)C - (Qs \times Cs)}{(Qe)}$$
 (EPA/505/2-90-001, Section 4.5.5)

Where C = downstream concentration Ce = effluent concentration

Cs = upstream concentration Qe = effluent flow

Qs = upstream flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

Number of Samples "n":

Additionally, in accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance, which should be, at a minimum, be targeted to comply with the values dictated by the WLA. Therefore, it is recommended that the actual planned frequency of monitoring normally be used to determine the value of "n" for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for "n" must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is "n = 4" at a minimum. For Total Ammonia as Nitrogen, "n = 30" is used.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

✓ A WLA study was either not submitted or determined not applicable by Department staff.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures that the provisions in the 10 CSR 20-6.010(8)(A) and the Water Quality Standards 10 CSR 20-7.031(4)(D),(F),(G),(J)2.A & B are being met. Under [10 CSR 20-6.010(8)(B)], the Department may require other terms and conditions that it deems necessary to assure compliance with the Clean Water Act and related regulations of the Missouri Clean Water Commission. In addition the following MCWL apply: §§§644.051.3 requires the Department to set permit conditions that comply with the MCWL and CWA; 644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits, pretreatment, etc...); and 644.051.5 is the basic authority to require testing conditions. WET test will be required by facilities meeting the following criteria:

	Facility is a designated Major.
X	Facility continuously or routinely exceeds its design flow.
	Facility that exceeds its design population equivalent (PE) for BOD ₅ whether or not its design flow is being exceeded.
	Facility (whether primarily domestic or industrial) that alters its production process throughout the year.
	Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
	Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH ₃)
\boxtimes	Facility is a municipality with a Design Flow $\geq 22,500$ gpd.
	Other – please justify.

✓ At this time, the permittee is not required to conduct WET test for this facility. The previous permit included requirements to conduct an Acute WET test once during the permit cycle. The permit writer has conducted reasonable potential determinations for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists. Also, the facility has passed previous Acute WET tests. Therefore, the permit writer has made a reasonable potential determination which concluded the facility does not have reasonable potential to exceed narrative water quality standards for acute toxicity at this time and the acute WET testing requirements have been removed from this permit. This determination will be reevaluated during the next permit renewal.

40 CFR 122.41(M) - BYPASSES:

The federal Clean Water Act (CWA), Section 402 prohibits wastewater dischargers from "bypassing" untreated or partially treated sewage (wastewater) beyond the headworks. A bypass is defined as an intentional diversion of waste streams from any portion of a treatment facility, [40 CFR 122.41(m)(1)(i)]. Additionally, Missouri regulation 10 CSR 20-7.015(9)(G) states a bypass means the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending, to waters of the state. Only under exceptional and specified limitations do the federal regulations allow for a facility to bypass some or all of the flow from its treatment process. Bypasses are prohibited by the CWA unless a permittee can meet all of the criteria listed in 40 CFR 122.41(m)(4)(i)(A), (B), & (C). Any bypasses from this facility are subject to the reporting required in 40 CFR 122.41(l)(6) and per Missouri's Standard Conditions I, Section B, part 2.b. Additionally, Anticipated Bypasses include bypasses from peak flow basins or similar devices designed for peak wet weather flows.

✓ This facility does not anticipate bypassing.

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

✓ This facility discharges to a stream with an EPA approved TMDL. Fremont Hills WWTF discharges to a tributary to James River, 8-20-13 MUDD V1.0 (C) (3960), which flows to a losing segment after 0.5 miles. The tributary flows 2.4 miles until it meets James River (P) (2362) which is subject to a 2001 TMDL that addresses impairment in James River from point source nutrient loading. Facilty final effluent must meet a monthly average limit of 0.5 mg/L phosphorus. The TMDL was updated April 2004 and shows that there have been load reductions to the stream.

Part VI - Effluent Limits Determination

CATEGORIES OF WATERS OF THE STATE:

As per Missouri's Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall's Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

=	Missouri or Mississippi River [10 CSR 20-7.015(2)]		Special Streams [10 CSR 20-7.015(6)]
	Lakes or Reservoirs [10 CSR 20-7.015(3)]	Ш	Subsurface Waters [10 CSR 20-7.015(7)]
\boxtimes	Losing Streams [10 CSR 20-7.015(4)]	\boxtimes	All Other Waters [10 CSR 20-7.015(8)]
	Metropolitan No-Discharge Streams [10 CSR 20-7.015(5)]		

OUTFALL #001 - MAIN FACILITY OUTFALL

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

EFFLUENT LIMITATIONS TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
Flow	MGD	1	*		*	*/*	1/month	monthly	T
BOD ₅	mg/L	1		15	10	15/10	1/month	monthly	С
TSS	mg/L	1		20	15	20/15	1/month	monthly	С
Escherichia coli**	#/100mL	1, 3	126		*	126/*	1/month	monthly	G
Ammonia as N (Apr 1 –Sep 30)	mg/L	2, 3	4.3		1.4	4.6/1.4	1/month	monthly	С
Ammonia as N (Oct 1 – Mar 31)	mg/L	2, 3	11.6		2.6	8.0/2.8	1/month	monthly	С
Oil & Grease	mg/L	1, 3	15		10	15/10	1/quarter	quarterly	G
Total Phosphorus	mg/L	1	*		0.5	*/0.5	1/quarter	quarterly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	*/*	1/quarter	quarterly	C
Nitrite + Nitrate	mg/L	1	*		*	*/*	1/quarter	quarterly	С
PARAMETER	Unit	Basis for Limits	Minimum		Maximum	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
pН	SU	1	6.5		9.0	6.5-9.0	1/month	monthly	G
PARAMETER	Unit	Basis for Limits	Daily Minimum		Monthly Avg. Min	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type
BOD ₅ Percent Removal	%	1	_	_	85	85	1/quarter	quarterly	M
TSS Percent Removal	%	1			85	85	1/quarter	quarterly	M

^{* -} Monitoring requirement only.

Basis for Limitations Codes:

- 1. State or Federal Regulation/Law
- 2. Water Quality Standard (includes RPA)
- 3. Water Quality Based Effluent Limits
- 4. Antidegradation Review

- 5. Antidegradation Policy
- 6. Water Quality Model
- 7. Best Professional Judgment
- 8. TMDL or Permit in lieu of TMDL
- **** C = 24-hour composite
 - G = Grab
 - T = 24-hr. total
 - E = 24-hr. estimate
 - M = Measured/calculated
- 9. WET Test Policy
- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

• <u>Flow</u>. In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may require the submittal of an operating permit modification.

^{** -} No more than 10% of samples over the course of the calendar

year shall exceed 126 #/100 mL daily maximum

^{*** -} Parameter not previously established in previous state operating permit.

- <u>Biochemical Oxygen Demand (BOD5)</u>. Operating permit retains 15 mg/L as a Weekly Average and 10 mg/L as a Monthly Average from the previous permit. Please see the <u>CATEGORIZATION OF WATERS OF THE STATE</u> sub-section of the <u>Effluent</u> Limits Determination.
- <u>Total Suspended Solids (TSS)</u>. Operating permit retains 20 mg/L as a Weekly Average and 15 mg/L as a Monthly Average from the previous permit. Please see the <u>CATEGORIZATION OF WATERS OF THE STATE</u> sub-section of the <u>Effluent Limits</u> <u>Determination.</u>
- <u>Escherichia coli (E. coli)</u>. Discharges to losing streams shall not exceed 126 per 100 mL as a Daily Maximum at any time, as per 10 CSR 20-7.031(5)(C). Monitoring only for a monthly average. No more than 10% of samples over the course of the calendar year shall exceed 126 #/100 mL daily maximum as per 10 CSR 20-7.015(9)(B)1.G.
- <u>Total Ammonia Nitrogen</u>. Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(5)(B)7.C. & Table B3]. Background total ammonia nitrogen = 0.01 mg/L. No mixing considerations allowed; therefore, WLA = appropriate criterion.

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
Summer	26	7.8	1.5	12.1
Winter	6	7.8	3.1	12.1

<u>Summer: April 1 – September 30</u>

Chronic WLA: Ce = ((0.2728 + 0)1.5 - (0 * 0.01) / 0.2728

Ce = 1.5

Acute WLA: Ce = ((0.2728 + 0)12.1 - (0 * 0.2728) / 0.2728

Ce = 12.1

LTAc = 1.5 mg/L * (0.722) = 1.08 mg/L [CV = 0.8, 99th Percentile, 30 day avg.]

LTAa = 12.1 mg/L * (0.251) = 3.03 mg/L [CV = 0.8, 99th Percentile]

MDL = 1.083 mg/L * (3.99) = 4.3 mg/L [CV = 0.8, 99 th Percentile]

AML = 1.083 mg/L * (1.255) = 1.4 mg/L [CV = 0.8, 95th Percentile, n=30]

Winter: October 1 – March 31

Chronic WLA: Ce = ((0.2728 + 0)3.1 - (0 * 0.01) / 0.2728

Ce = 3.1

Acute WLA: Ce = ((0.2728 + 0)12.1 - (0 * 0.2728) / 0.2728

Ce = 12.1

LTAc = 3.1 mg/L * (0.584) = 1.81 mg/L [CV = 1.36, 99th Percentile, 30 day avg.]

LTAa = 12.1 mg/L * (0.156) = 1.89 mg/L [CV = 1.36, 99th Percentile]

MDL = 1.81 mg/L * (6.4) = 11.6 mg/L [CV = 1.36, 99th Percentile]

AML = 1.81 mg/L * (1.451) = 2.6 mg/L [CV = 1.36, 95th Percentile, n=30]

- Oil & Grease. Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- <u>Total Nitrogen (Speciated)</u>. Effluent monitoring for Total Kjeldahl Nitrogen, and Nitrite + Nitrate are required per 10 CSR 20-7.015(9)(D)8.
- <u>pH</u>. 6.5-9.0 SU. pH limitations of 6.0-9.0 SU [10 CSR 20-7.015] are not protective of the in-stream Water Quality Standard, which states that water contaminants shall not cause pH to be outside the range of 6.5-9.0 SU.
- <u>Biochemical Oxygen Demand (BOD₅) Percent Removal</u>. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for BOD₅.

- <u>Total Suspended Solids (TSS) Percent Removal</u>. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals. This facility is required to meet 85% removal efficiency for TSS.
- <u>Total Phosphorus.</u> Per the James River TMDL, this facility is required to meet a monthly average Phosphorus limit of 0.5 mg/L.
- <u>Aluminum, Total Recoverable</u>. Monitoring requirement only. This facility uses chemicals for phosphorous removal that contain aluminum. Monitoring is required to determine if reasonable potential exists for this facility's discharge to exceed water quality standards for Aluminum (Total Recoverable).

Parameters Removed.

- Acute Whole Effluent Toxicity (WET) test. The previous permit included requirements to conduct an Acute WET test once during the permit cycle. The permit writer has conducted reasonable potential determinations for all anticipated pollutants and established numeric effluent limitations where reasonable potential exists. Also, the facility has passed previous Acute WET tests. Therefore, the permit writer has made a reasonable potential determination which concluded the facility does not have reasonable potential to exceed narrative water quality standards for acute toxicity at this time and the acute WET testing requirements have been removed from this permit. This determination will be reevaluated during the next permit renewal.
- <u>Iron, Total Recoverable.</u> Monitoring requirements removed. DMR data indicates that the facility has consistently reported 0 mg/L in the effluent; therefore, there is no reasonable potential to violate the water quality standard. This determination will be reassessed at renewal.
- <u>Nitrate as N.</u> The previous permit contained monitoring requirements to determine whether reasonable potential to cause an excursion of the water quality standard existed. During the drafting of this permit, the permit writer has made a Reasonable Potential Determination that the discharge is not reasonably expected to impact specific drinking water wells. Therefore, the monitoring requirements for Nitrate have been removed from this permit. The permit is still protective of water quality and this determination will be reassessed at the time of renewal.

<u>Sampling Frequency Justification</u>: Sampling and Reporting Frequency was retained from previous permit. Weekly sampling is required for *E. coli*, per 10 CSR 20-7.015(9)(D)7.A.

<u>Sampling Type Justification:</u> As per 10 CSR 20-7.015, samples collected for mechanical plants shall be a 24 hour composite sample. Grab samples, however, must be collected for pH, *E. coli*, and Oil & Grease in accordance with recommended analytical methods. For further information on sampling and testing methods please review 10 CSR 20-7.015(9)(D) 2.

PERMITTED FEATURE INF - INFLUENT MONITORING

The monitoring requirements established in the below Monitoring Requirements Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including the monitoring requirements listed in this table.

INFLUENT MONITORING TABLE:

PARAMETER	Unit	Basis for Limits	Daily Maximum	Weekly Average	Monthly Average	Previous Permit Limit	Sampling Frequency	Reporting Frequency	Sample Type ****
BOD ₅	mg/L	1			*	***	1/quarter	quarterly	С
TSS	mg/L	1			*	***	1/quarter	quarterly	С
Ammonia as N	mg/L	1	*		*	***	1/quarter	quarterly	С
Total Phosphorus	mg/L	1	*		*	***	1/quarter	quarterly	С
Total Kjeldahl Nitrogen	mg/L	1	*		*	***	1/quarter	quarterly	С
Nitrite + Nitrate	mg/L	1	*		*	***	1/quarter	quarterly	С

^{* -} Monitoring requirement only.

G = Grab

Basis for Limitations Codes:

- 1. State or Federal Regulation/Law
- 2. Water Quality Standard (includes RPA)
- 3. Water Quality Based Effluent Limits
- 4. Antidegradation Review

- 5. Antidegradation Policy
- Water Quality Model
- 7. Best Professional Judgment
- 8. TMDL or Permit in lieu of TMDL
- 9. WET Test Policy
- 10. Multiple Discharger Variance
- 11. Nutrient Criteria Implementation Plan

Influent Parameters

- <u>Biochemical Oxygen Demand (BOD₅)</u> and <u>Total Suspended Solids (TSS)</u>. An influent sample is required to determine the removal efficiency. In accordance with 40 CFR Part 133, removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to BOD₅ and TSS for Publicly Owned Treatment Works (POTWs)/municipals.
- <u>Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia</u>. Influent monitoring for Total Phosphorus, Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia required per 10 CSR 20-7.015(9)(D)8.

<u>Sampling Frequency Justification:</u> The sampling and reporting frequencies for Total Phosphorus and Total Kjeldahl Nitrogen, Nitrite + Nitrate, and Ammonia parameters were established to match the required sampling frequency of these parameters in the effluent, per [10 CSR 20-7.015(9)(D)8.]. The sampling and reporting frequencies for influent BOD $_5$ and TSS have been established to match the required sampling frequency of these parameters in the effluent.

<u>Sampling Type Justification:</u> Sample types for influent parameters were established to match the required sampling type of these parameters in the effluent. Samples should be analyzed as soon as possible after collection and/or properly preserved according to method requirements.

OUTFALL #001 – GENERAL CRITERIA CONSIDERATIONS:

In accordance with 40 CFR 122.44(d)(1), effluent limitations shall be placed into the permit for those pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The rule further states that pollutants which have been determined to cause, have the reasonable potential to cause, or contribute to an excursion above a narrative criterion within an applicable State water quality standard, the permit shall contain a numeric effluent limitation to protect that narrative criterion. In order to comply with this regulation, the permit writer will complete reasonable potential determinations on whether the discharge will violate any of the general criteria listed in 10 CSR 20-7.031(4). These specific requirements are listed below followed by derivation and discussion (the lettering matches that of the rule itself, under 10 CSR 20-7.031(4)). It should also be noted that Section 644.076.1, RSMo as well as Section D – Administrative Requirements of Standard Conditions Part I of this permit states that it shall be unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri that is in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law or any standard, rule or regulation promulgated by the commission.

^{*** -} Parameter not previously established in previous state operating permit.

^{**** -} C = Composite

- (A) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses. The discharge from this facility is made up of treated domestic wastewater. Based upon review of the recent Report of Compliance Inspection for the inspection conducted on June 21,2018, no evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, this facility utilizes secondary treatment technology and is currently in compliance with secondary treatment technology based effluent limits established in this permit and there has been no indication to the Department that the stream has had issues maintaining beneficial uses as a result of this discharge. Based on the information reviewed during the drafting of this permit, these final effluent limitations appear to have protected against the excursion of this criterion in the past. Therefore, the discharge does not have the reasonable potential to cause or contribute to an excursion of this criterion.
- (B) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (C) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses. Please see (A) above as justification is the same.
- (D) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life. This permit contains final effluent limitations which are protective of both acute and chronic toxicity for various pollutants that are either expected to be discharged by domestic wastewater facilities or that were disclosed by this facility on the application for permit coverage. Based on the information reviewed during the drafting of this permit, it has been determined if the facility meets final effluent limitations established in this permit, there is no reasonable potential for the discharge to cause an excursion of this criterion.
- (E) Waters shall provide for the attainment and maintenance of water quality standards downstream including waters of another state. Please see (D) above as justification is the same.
- (F) There shall be no significant human health hazard from incidental contact with the water. Please see (D) above as justification is the same.
- (G) There shall be no acute toxicity to livestock or wildlife watering. Please see (D) above as justification is the same.
- (H) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community. Please see (A) above as justification is the same.
- (I) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247. The discharge from this facility is made up of treated domestic wastewater. No evidence of an excursion of this criterion has been observed by the Department in the past and the facility has not disclosed any other information related to the characteristics of the discharge on their permit application which has the potential to cause or contribute to an excursion of this narrative criterion. Additionally, any solid wastes received or produced at this facility are wholly contained in appropriate storage facilities, are not discharged, and are disposed of offsite. This discharge is subject to Standard Conditions Part III, which contains requirements for the management and disposal of sludge to prevent its discharge. Therefore, this discharge does not have reasonable potential to cause or contribute to an excursion of this criterion.

Part VII – Cost Analysis for Compliance

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

✓ The Department is required to determine "findings of affordability" because the permit applies to a combined or separate sanitary sewer system for a publically-owned treatment works.

Cost Analysis for Compliance - The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

The following table summarizes the results of the cost analysis. See **Appendix – Cost Analysis for Compliance** for detailed information.

Summary Table. Cost Analysis for Compliance Summary for the City of Fremont Hills

New Permit Requirements							
Quarterly Influent Total Phosphorus and Total Nitrogen Sampling							
Estimated Annual Cost	Annual Median Household Income (MHI)	Estimated Monthly User Rate	User Rate as a Percent of MHI				
\$468	\$109,556	\$48.84	0.54%				

Part VIII – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

WATER QUALITY STANDARD REVISION:

In accordance with section 644.058, RSMo, the Department is required to utilize an evaluation of the environmental and economic impacts of modifications to water quality standards of twenty-five percent or more when making individual site-specific permit decisions.

✓ This operating permit does not contain requirements for a water quality standard that has changed twenty-five percent or more since the previous operating permit.

PERMIT SYNCHRONIZATION:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the Department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than 4 years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. With permit synchronization, this permit will expire in the 3rd Quarter of calendar year 2020.

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing. The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit. For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

✓ The Public Notice period for this operating permit was from August 30, 2019 through September 30, 2019. No responses received.

DATE OF FACT SHEET: AUGUST, 9, 2019

COMPLETED BY:

DANIELLE SKOUBY, ENVIRONMENTAL SPECIALIST
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION - DOMESTIC WASTEWATER UNIT
(573) 526-1503
Danielle.Skouby@dnr.mo.gov

Appendices

APPENDIX - CLASSIFICATION WORKSHEET:

Item	Points Possible	Points Assigned
Maximum Population Equivalent (P.E.) served , peak day	1 pt./10,000 PE or major fraction thereof. (Max 10 pts.)	<u> </u>
Design Flow (avg. day) or peak month's flow (avg. day) whichever is larger	1 pt. / MGD or major fraction thereof. (Max 10 pts.)	-
Effluent Discharge		
Missouri or Mississippi River	0	-
All other stream discharges except to losing streams and stream reaches supporting whole body contact recreation	1	-
Discharge to lake or reservoir outside of designated whole body contact recreational area	2	-
Discharge to losing stream, or stream, lake or reservoir area supporting whole body contact recreation	3	3
Direct reuse or recycle of effluent	6	-
Land Application/Irriga	tion	
Drip Irrigation	3	-
Land application/irrigation	5	-
Overland flow	4	-
Variation in Raw Wastes (highes	st level only)	
Variations do not exceed those normally or typically expected	0	-
Reoccurring deviations or excessive variations of 100 to 200 percent in strength and/or flow	2	2
Reoccurring deviations or excessive variations of more than 200 percent in strength and/or flow	4	-
Department-approved pretreatment program	6	-
Preliminary Treatmer	nt	
STEP systems (operated by the permittee)	3	-
Screening and/or comminution	3	3
Grit removal	3	-
Plant pumping of main flow	3	3
Flow equalization	5	-
Primary Treatment		
Primary clarifiers	5	-
Chemical addition (except chlorine, enzymes)	4	-
Secondary Treatmen	t	
Trickling filter and other fixed film media with or without secondary clarifiers	10	-
Activated sludge (including aeration, oxidation ditches, sequencing batch reactors, membrane bioreactors, and contact stabilization)	15	15
Stabilization ponds without aeration	5	-
Aerated lagoon	8	-
Advanced Lagoon Treatment – Aerobic cells, anaerobic cells, covers, or fixed film	10	-
Biological, physical, or chemical	12	
Carbon regeneration	4	-
Total from page ONE (1)		25

APPENDIX - CLASSIFICATION WORKSHEET (CONTINUED):

Ітем	POINTS POSSIBLE	POINTS ASSIGNED						
Solids Handling								
Sludge Holding	5	5						
Anaerobic digestion	10	-						
Aerobic digestion	6	-						
Evaporative sludge drying	2	-						
Mechanical dewatering	8	-						
Solids reduction (incineration, wet oxidation)	12	-						
Land application	6	-						
Disinfection								
Chlorination or comparable	5	-						
On-site generation of disinfectant (except UV light)	5	-						
Dechlorination	2	-						
UV light	4	4						
Required Laboratory Control Performed by Plan	t Personnel (highest level only)							
Lab work done outside the plant	0	-						
Push – button or visual methods for simple test such as pH, settleable solids	3	3						
Additional procedures such as DO, COD, BOD, titrations, solids, volatile content	5	-						
More advanced determinations, such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc.	7	-						
Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph	10	-						
Total from page TWO (2)		12						
Total from page ONE (1)		25						
Grand Total		37						

☐ - A: 71 points and greater
 ☐ - B: 51 points - 70 points
 ☐ - C: 26 points - 50 points
 ☐ - D: 0 points - 25 points

APPENDIX – RPA RESULTS:

Parameter	CMC*	RWC Acute*	CCC*	RWC Chronic*	n**	Range max/min	CV***	MF	RP Yes/No
Total Ammonia as Nitrogen (Summer) mg/L	12.1	0.88	1.5	0.88	36.00	0.5/0.005	0.80	1.75	NO
Total Ammonia as Nitrogen (Winter) mg/L	12.1	4.53	3.1	4.53	38.00	1.9/0.05	1.36	2.38	YES
Aluminum, Total Recoverable (μg/L)	750	335.83	n/a	335.83	17	50/200	0.33	1.679	NO

N/A – Not Applicable

- * Units are (µg/L) unless otherwise noted.
- ** If the number of samples is 10 or greater, then the CV value must be used in the WQBEL for the applicable constituent. If the number of samples is < 10, then the default CV value must be used in the WQBEL for the applicable constituent.
- *** Coefficient of Variation (CV) is calculated by dividing the Standard Deviation of the sample set by the Mean of the same sample set.
- RWC Receiving Water Concentration. It is the concentration of a toxicant or the parameter toxicity in the receiving water after mixing (if applicable).
- n Is the number of samples.
- MF Multiplying Factor. 99% Confidence Level and 99% Probability Basis.
- RP Reasonable Potential. It is where an effluent is projected or calculated to cause an excursion above a water quality standard based on a number of factors including, as a minimum, the four factors listed in 40 CFR 122.44(d)(1)(ii).

Reasonable Potential Analysis is conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request.

APPENDIX – FACILITY OUTFALL:



APPENDIX – COST ANALYSIS FOR COMPLIANCE:

Missouri Department of Natural Resources
Water Protection Program
Cost Analysis for Compliance
(In accordance with RSMo 644.145)

Fremont Hills WWTP, Permit Renewal City of Fremont Hills Missouri State Operating Permit #MO-0106151

Section 644.145 RSMo requires the Department of Natural Resources (Department) to make a "finding of affordability" when "issuing permits under" or "enforcing provisions of" state or federal clean water laws "pertaining to any portion of a combined or separate sanitary sewer system for publicly-owned treatment works." This cost analysis does not dictate how the permittee will comply with new permit requirements.

New Permit Requirements

The permit requires compliance with new influent monitoring requirements for Ammonia as N, Total Kjeldahl Nitrogen, Nitrate + Nitrite, and Total Phosphorus.

Connections

The number of connections was reported by the permittee on the Financial Questionnaire.

Connection Type	Number
Residential	502
Commercial	20
Industrial	
Total	522

Data Collection for this Analysis

This cost analysis is based on data available to the Department as provided by the permittee and data obtained from readily available sources. For the most accurate analysis, it is essential that the permittee provides the Department with current information about the City's financial and socioeconomic situation. The financial questionnaire available to permittees on the Department's website (http://dnr.mo.gov/forms/780-2511-f.pdf) is a required attachment to the permit renewal application. If the financial questionnaire is not submitted with the renewal application, the Department sends a request to complete the form with the welcome correspondence. If certain data was not provided by the permittee to the Department and the data is not obtainable through readily available sources, this analysis will state that the information is "unknown".

Eight Criteria of 644.145 RSMo

The Department must consider the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with new permit requirements.

(4) A community's financial capability and ability to raise or secure necessary funding;

Criterion 1 Table. Current Financial Information for the City of Fremont Hills				
Current Monthly User Rates per 5,000 gallons*	\$48.77			
Median Household Income (MHI) ¹	\$109,556			
Current Annual Operating Costs (excludes depreciation)	\$296,390			

^{*}User Rates were reported by the permittee on the Financial Questionnaire.

(5) Affordability of pollution control options for the individuals or households at or below the median household income level of the community;

The following tables outline the estimated costs of the new permit requirements:

Criterion 2A Table. Estimated Cost Breakdown of New Permit Requirements								
New Requirement	Frequency	Estimated Cost	Estimated Annual Cost					
Total Phosphorus – Influent	Quarterly	\$24	\$96					
Total Kjeldahl Nitrogen - Influent	Quarterly	\$33	\$132					
Nitrate + Nitrite - Influent	Quarterly	\$40	\$160					
Ammonia - Influent	\$80							
Total Estimated Annual Cost of New	\$468							

Crit	Criterion 2B Table. Estimated Costs for New Permit Requirements					
(1)	Estimated Annual Cost	\$468				
(2)	Estimated Monthly User Cost for New Requirements ²	\$0.07				
	Estimated Monthly User Cost for New Requirements as a Percent of MHI ³	0.001%				
(3)	Total Monthly User Cost*	\$48.84				
	Total Monthly User Cost as a Percent of MHI ⁴	0.54%				

^{*} Current User Rate + Estimated Monthly Costs of New Sampling Requirements

Due to the minimal cost associated with new permit requirements, the Department anticipates an extremely low to no rate increase will be necessary, which could impact individuals or households of this community.

(6) An evaluation of the overall costs and environmental benefits of the control technologies;

This analysis is being conducted based on new requirements in the permit, which will not require the addition of new control technologies at the facility. However, the new sampling requirements are being established in order to provide data regarding the health of the receiving stream's aquatic life and to ensure that the existing permit limits are providing adequate protection of aquatic life. Improved wastewater provides benefits such as avoided health costs due to water-related illness, enhanced environmental ecosystem quality, and improved natural resources. The preservation of natural resources has been proven to increase the economic value and sustainability of the surrounding communities. Maintaining Missouri's water quality standards fulfills the goal of restoring and maintaining the chemical, physical, and biological integrity of the receiving stream; and, where attainable, it achieves a level of water quality that provides for the protection and propagation of fish, shellfish, wildlife, and recreation in and on the water.

(9) Inclusion of ongoing costs of operating and maintaining the existing wastewater collection and treatment system, including payments on outstanding debts for wastewater collection and treatment systems when calculating projected rates:

The community reported that their outstanding debt for their current wastewater collection and treatment systems is \$894,000. The community reported that each user pays \$48.77 monthly, of which, \$29.52 is used toward payments on the current outstanding debt.

As shown in Criterion 2, the projected user rate plus the amount of the current user rate used toward payments on outstanding debt is \$48.84.

(10) An inclusion of ways to reduce economic impacts on distressed populations in the community, including but not limited to low and fixed income populations. This requirement includes but is not limited to:

- (c) Allowing adequate time in implementation schedules to mitigate potential adverse impacts on distressed populations resulting from the costs of the improvements and taking into consideration local community economic considerations.
- (d) Allowing for reasonable accommodations for regulated entities when inflexible standards and fines would impose a disproportionate financial hardship in light of the environmental benefits to be gained.

The following table characterizes the current overall socioeconomic condition of the community as compared to the overall socioeconomic condition of Missouri. The following information was compiled using the latest U.S. Census data.

Criterion 5 Table. Socioeconomic Data 1,5-9 for the City of Fremont Hills

No.	Administrative Unit	Fremont Hills City	Missouri State	United States
1	Population (2017)	1,072	6,075,300	321,004,416
2	Percent Change in Population (2000-2017)	79.6%	8.6%	14.1%
3	2017 Median Household Income (in 2018 Dollars)	\$109,556	\$52,801	\$59,060
4	Percent Change in Median Household Income (2000-2017)	-17.3%	-7.7%	-6.7%
5	Median Age (2017)	53.4	38.4	37.8
6	Change in Median Age in Years (2000-2017)	10.4	2.3	2.5
7	Unemployment Rate (2017)	2.9%	5.8%	6.6%
8	Percent of Population Below Poverty Level (2017)	0.7%	14.6%	14.6%
9	Percent of Household Received Food Stamps (2017)	0.0%	12.2%	12.6%
10	(Primary) County Where the Community Is Located	Christian County		

(11) An assessment of other community investments and operating costs relating to environmental improvements and public health protection;

The community did not report any other investments relating to environmental improvements.

(12) An assessment of factors set forth in the United States Environmental Protection Agency's guidance, including but not limited to the "Combined Sewer Overflow Guidance for Financial Capability Assessment and Schedule Development" that may ease the cost burdens of implementing wet weather control plans, including but not limited to small system considerations, the attainability of water quality standards, and the development of wet weather standards;

The new requirements associated with this permit will not impose a financial burden on the community, nor will they require the City of Fremont Hills to seek funding from an outside source.

(13) An assessment of any other relevant local community economic conditions.

The community did not report any other relevant local economic conditions.

The Department contracted with Wichita State University to complete an assessment tool that would allow for predictions on rural Missouri community populations and future sustainability. The purpose of the study is to use a statistical modeling analysis in order to determine factors associated with each rural Missouri community that would predict the future population changes that could occur in each community. A stepwise regression model was applied to 19 factors which were determined as predictors of rural population change in Missouri. The model established a hierarchy of the predicting factors which allowed the model to place a weighted value on each of the factors. A total of 745 rural towns and villages in Missouri received a weighted value for each of the predicting factors. The weighted values for each town / village were then added together to determine an overall decision score. The overall decision scores were then divided into five categories and each town was assigned to a different categorical group based on the overall decision score. The categorical groups were developed from the range of overall scores across all rural towns and villages within Missouri.

Based on the assessment tool, the City of Fremont Hills has been determined to be a category 5 community. This means that the City of Fremont Hills is predicted to be stable over time.

Conclusion and Finding

As a result of new regulations, the Department is proposing modifications to the current operating permit that may require the permittee to increase monitoring. The Department has considered the eight (8) criteria presented in subsection 644.145 RSMo to evaluate the cost associated with the new permit requirements.

Fremont Hills WWTP Fact Sheet Page #24

This analysis examined whether the new sampling requirements affect the ability of an individual customer or household to pay a utility bill without undue hardship or unreasonable sacrifice in the essential lifestyle or spending patterns of the individual or household. After reviewing the above criteria, the Department finds that the new sampling requirements may result in a low burden with regard to the community's overall financial capability and a low financial impact for most individual customers/households; therefore, the new permit requirements are affordable.

References

CPI /1999 CPI.

- 1. (A) 2017 MHI in 2017 Dollar: United States Census Bureau. United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, Table B19013: Median Household Income in the Past 12 Months (in 2017 Inflation-Adjusted Dollars). http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS_17_5YR_B19013&prodType=table.
 - (B) 2000 MHI in 1999 Dollar: (1) For United States, United States Census Bureau (2003) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-1 Part 1. United States Summary, Table 5. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/prod/cen2000/phc-2-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2003) 2000
 - Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-2-27, Missouri, Table 10. Work Status and Income in 1999: 2000, Washington, DC. https://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf. (C) 2018 CPI, 2017 CPI and 1999 CPI: U.S. Department of Labor Bureau of Labor Statistics (2018) Consumer Price Index All Urban
 - Consumers, U.S. City Average. All Items. 1982-84=100. http://data.bls.gov/timeseries/CUUR0000SA0?data_tool=Xgtable.

 (D) 2017 MHI in 2018 Dollar = 2017 MHI in 2017 Dollar x 2018 CPI /2017 CPI; 2000 MHI in 2018 Dollar = 2000 MHI in 1999 Dollar x 2018
 - (E) Percent Change in Median Household Income (2000-2017) = (2017 MHI in 2018 Dollar 2000 MHI in 2018 Dollar) / (2000 MHI in 2018 Dollar)
- 2. (\$468/522)/12 = \$0.07 (Estimated Monthly User Cost for New Requirements)
- 3. (\$0.07/(\$109,556/12))100% = 0.001% (New Sampling Only)
- 4. (\$48.84/(\$109,556/12))100% = 0.54% (Total User Cost)
- 5. (A) Total Population in 2017: United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, Table B01003: Total Population Universe: Total Population.
 - http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS_17_5YR_B01003&prodType=table. (B) Total Population in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC.
 - https://www.census.gov/prod/cen2000/phc-1-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC. http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf.
 - (C) Percent Change in Population (2000-2017) = (Total Population in 2017 Total Population in 2000) / (Total Population in 2000).
- 6. (A) Median Age in 2017: United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, Table B01002: Median Age by Sex Universe: Total population.
 - http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS_17_5YR_B01002&prodType=table.
 - (B) Median Age in 2000: (1) For United States, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Social, Economic, and Housing Characteristics, PHC-1-1 Part 1. United States Summary, Table 1. Age and Sex: 2000, Washington, DC., Page 2. https://www.census.gov/prod/cen2000/phc-1-pt1.pdf. (2) For Missouri State, United States Census Bureau (2002) 2000 Census of Population and Housing, Summary Population and Housing Characteristics, PHC-1-27, Missouri, Table 2. Age and Sex: 2000, Washington, DC., Pages 64-92. http://www.census.gov/prod/cen2000/phc-2-27-pt1.pdf.
 - (C) Change in Median Age in Years (2000-2017) = (Median Age in 2017 Median Age in 2000).
- United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, B23025: Employment Status for the Population 16
 Years and Over Universe: Population 16 years and Over.
 http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS 17 5YR B23025&prodType=table.
- 8. United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, Table S1701: Poverty Status in the Past 12 Months. http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS_17_5YR_S1701&prodType=table.
- 9. United States Census Bureau. 2013-2017 American Community Survey 5-Year Estimates, Table B22003: Receipt of Food Stamps/SNAP in the Past 12 Months by Poverty Status in the Past 12 Months for Households Universe: Households. http://factfinder.census.gov/faces/tableservices/jsf/pages/productview.xhtml?pid=ACS 17 5YR B22003&prodType=table



THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION REVISED AUGUST 1, 2014

These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions Section A – Sampling, Monitoring, and Recording

1. Sampling Requirements.

- Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.

2. Monitoring Requirements.

- a. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The individual(s) who performed the sampling or measurements;
 - iii. The date(s) analyses were performed;
 - iv. The individual(s) who performed the analyses;
 - v. The analytical techniques or methods used; and
 - vi. The results of such analyses.
- b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
- Sample and Monitoring Calculations. Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
- Test Procedures. The analytical and sampling methods used shall conform to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is "sufficiently sensitive" when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility's discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
- 5. Record Retention. Except for records of monitoring information required by the permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

Illegal Activities.

- a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or both.
- b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B – Reporting Requirements

1. Planned Changes.

- a. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
 - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
- iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.

2. Non-compliance Reporting.

a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION REVISED AUGUST 1, 2014

- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
- c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
- Anticipated Noncompliance. The permittee shall give advance notice to the
 Department of any planned changes in the permitted facility or activity
 which may result in noncompliance with permit requirements. The notice
 shall be submitted to the Department 60 days prior to such changes or
 activity.
- 4. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
- 5. Other Noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
- 6. Other Information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

7. Discharge Monitoring Reports.

- a. Monitoring results shall be reported at the intervals specified in the
- b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
- Monitoring results shall be reported to the Department no later than the 28th day of the month following the end of the reporting period.

Section C – Bypass/Upset Requirements

1. **Definitions.**

- a. Bypass: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
- Severe Property Damage: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- c. Upset: an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

2. Bypass Requirements.

a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

b. Notice.

- Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
- ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).

c. Prohibition of bypass.

- i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 - Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - The permittee submitted notices as required under paragraph 2.
 b. of this section.
- ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.

3. Upset Requirements.

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
- Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

Section D – Administrative Requirements

- Duty to Comply. The permittee must comply with all conditions of this
 permit. Any permit noncompliance constitutes a violation of the Missouri
 Clean Water Law and Federal Clean Water Act and is grounds for
 enforcement action; for permit termination, revocation and reissuance, or
 modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION REVISED AUGUST 1, 2014

imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class II penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- It is unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

2. Duty to Reapply.

- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission

- for applications to be submitted later than the expiration date of the existing permit.)
- c. A permittees with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- Need to Halt or Reduce Activity Not a Defense. It shall not be a defense
 for a permittee in an enforcement action that it would have been necessary to
 halt or reduce the permitted activity in order to maintain compliance with the
 conditions of this permit.
- Duty to Mitigate. The permittee shall take all reasonable steps to minimize
 or prevent any discharge or sludge use or disposal in violation of this permit
 which has a reasonable likelihood of adversely affecting human health or the
 environment.
- 5. Proper Operation and Maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

6. Permit Actions.

- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
 - i. Violations of any terms or conditions of this permit or the law;
 - Having obtained this permit by misrepresentation or failure to disclose fully any relevant facts;
 - A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
 - iv. Any reason set forth in the Law or Regulations.
- The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

7. Permit Transfer.

- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
- 8. Toxic Pollutants. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- Property Rights. This permit does not convey any property rights of any sort, or any exclusive privilege.



THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION REVISED AUGUST 1, 2014

- 10. Duty to Provide Information. The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
- 11. Inspection and Entry. The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
 - Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.

12. Closure of Treatment Facilities.

- a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
- b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.

13. Signatory Requirement.

- All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
- b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
- c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
- 14. Severability. The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.



THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION REVISED MAY 1, 2013

PART II - SPECIAL CONDITIONS – PUBLICLY OWNED TREATMENT WORKS
SECTION A – INDUSTRIAL USERS

1. Definitions

Definitions as set forth in the Missouri Clean Water Laws and approved by the Missouri Clean Water Commission shall apply to terms used herein.

Significant Industrial User (SIU). Except as provided in the *General Pretreatment Regulation* 10 CSR 20-6.100, the term Significant Industrial User means:

- 1. All Industrial Users subject to Categorical Pretreatment Standards; and
- 2. Any other Industrial User that: discharges an average of 25,000 gallons per day or more of process wastewater to the Publicly-Owned Treatment Works (POTW) (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process wastestream which makes up 5 percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the Control Authority on the basis that the Industrial User has a reasonable potential for adversely affecting the POTW's or for violating any Pretreatment Standard or requirement.

Clean Water Act (CWA) is the the federal Clean Water Act of 1972, 33 U.S.C. § 1251 et seq. (2002).

2. Identification of Industrial Discharges

Pursuant to 40 CFR 122.44(j)(1), all POTWs shall identify, in terms of character and volume of pollutants, any Significant Industrial Users discharging to the POTW subject to Pretreatment Standards under section 307(b) of the CWA and 40 CFR 403.

3. Application Information

Applications for renewal or modification of this permit must contain the information about industrial discharges to the POTW pursuant to 40 CFR 122.21(j)(6)

4. Notice to the Department

Pursuant to 40 CFR 122.42(b), all POTWs must provide adequate notice of the following:

- 1. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging these pollutants; and
- 2. Any substantial change into the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- 3. For purposes of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW, and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

For POTWs without an approved pretreatment program, the notice of industrial discharges which was not included in the permit application shall be made as soon as practicable. For POTWs with an approved pretreatment program, notice is to be included in the annual pretreatment report required in the special conditions of this permit. Notice may be sent to:

Missouri Department of Natural Resources Water Protection Program Attn: Pretreatment Coordinator P.O. Box 176 Jefferson City, MO 65102

THE MISSOURI DEPARTMENT OF NATURAL RESOURCES MISSOURI CLEAN WATER COMMISSION August 1, 2019

PART III - BIOSOLIDS AND SLUDGE FROM DOMESTIC TREATMENT FACILITIES

SECTION A – GENERAL REQUIREMENTS

- 1. PART III Standard Conditions pertain to biosolids and sludge requirements under the Missouri Clean Water Law and regulations for domestic and municipal wastewater and also incorporates federal sludge disposal requirements under 40 CFR Part 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR Part 503 for domestic biosolids and sludge.
- 2. PART III Standard Conditions apply only to biosolids and sludge generated at domestic wastewater treatment facilities, including public owned treatment works (POTW) and privately owned facilities.
- 3. Biosolids and Sludge Use and Disposal Practices:
 - a. The permittee is authorized to operate the biosolids and sludge generating, treatment, storage, use, and disposal facilities listed in the facility description of this permit.
 - b. The permittee shall not exceed the design sludge/biosolids volume listed in the facility description and shall not use biosolids or sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
 - c. For facilities operating under general operating permits that incorporate Standard Conditions PART III, the facility is authorized to operate the biosolids and sludge generating, treatment, storage, use and disposal facilities identified in the original operating permit application, subsequent renewal applications or subsequent written approval by the department.
- 4. Biosolids or Sludge Received from other Facilities:
 - a. Permittees may accept domestic wastewater biosolids or sludge from other facilities as long as the permittee's design sludge capacity is not exceeded and the treatment facility performance is not impaired.
 - b. The permittee shall obtain a signed statement from the biosolids or sludge generator or hauler that certifies the type and source of the sludge
- 5. Nothing in this permit precludes the initiation of legal action under local laws, except to the extent local laws are preempted by state law.
- 6. This permit does not preclude the enforcement of other applicable environmental regulations such as odor emissions under the Missouri Air Pollution Control Lawand regulations.
- 7. This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable biosolids or sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
- 8. In addition to Standard Conditions PART III, the Department may include biosolids and sludge limitations in the special conditions portion or other sections of a site specific permit.
- 9. Exceptions to Standard Conditions PART III may be authorized on a case-by-case basis by the Department, as follows:
 - a. The Department may modify a site-specific permit following permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR § 124.10, and 40 CFR § 501.15(a)(2)(ix)(E).
 - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR Part 503.

SECTION B - DEFINITIONS

- 1. Best Management Practices are practices to prevent or reduce the pollution of waters of the state and include agronomic loading rates (nitrogen based), soil conservation practices, spill prevention and maintenance procedures and other site restrictions.
- 2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
- 3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food, feed or fiber. The facility includes any structures necessary to store the biosolids until soil, weather, and crop conditions are favorable for land application.
- 4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR Part 503.
- 5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with 40 CFR Part 503.
- 6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
- 7. Feed crops are crops produced primarily for consumption by animals.
- 8. Fiber crops are crops such as flax and cotton.
- 9. Food crops are crops consumed by humans which include, but is not limted to, fruits, vegetables and tobacco.
- 10. Industrial wastewater means any wastewater, also known as process wastewater, not defined as domestic wastewater. Per 40 CFR Part 122.2, process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product. Land application of industrial wastewater, residuals or sludge is not authorized by Standard Conditions PART III.
- 11. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological contact systems, and other similar facilities. It does not include wastewater treatment lagoons or constructed wetlands for wastewater treatment.
- 12. Plant Available Nitrogen (PAN) is nitrogen that will be available to plants during the growing seasons after biosolids application.
- 13. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
- 14. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs), sewage sludge incinerator ash, or grit/screenings generated during preliminary treatment of domestic sewage.
- 15. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen or concrete lined basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
- 16. Septage is the sludge pumped from residential septic tanks, cesspools, portable toilets, Type III marine sanitation devices, or similar treatment works such as sludge holding structures from residential wastewater treatment facilities with design populations of less than 150 people. Septage does not include grease removed from grease traps at a restaurant or material removed from septic tanks and other similar treatment works that have received industrial wastewater. The standard for biosolids from septage is different from other sludges. See Section H for more information.

SECTION C - MECHANICAL WASTEWATER TREATMENT FACILITIES

- 1. Biosolids or sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and the requirements of Standard Conditions PART III or in accordance with Section A.3.c., above.
- 2. The permittee shall operate storage and treatment facilities, as defined by Section 644.016(23), RSMo, so that there is no biosolids or sludge discharged to waters of the state. Agricultural storm water discharges are exempt under the provisions of Section 644.059, RSMo.
- 3. Mechanical treatment plants shall have separate biosolids or sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove biosolids or sludge from these storage compartments on the required design schedule is a violation of this permit.

SECTION D - BIOSOLIDS OR SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR BY CONTRACT HAULER

- 1. Permittees that use contract haulers, under the authority of their operating permit, to dispose of biosolids or sludge, are responsible for compliance with all the terms of this permit. Contract haulers that assume the responsibility of the final disposal of biosolids or sludge, including biosolids land application, must obtain a Missouri State Operating Permit unless the hauler transports the biosolids or sludge to another permitted treatment facility.
- 2. Testing of biosolids or sludge, other than total solids content, is not required if biosolids or sludge are hauled to a permitted wastewater treatment facility, unless it is required by the accepting facility.

SECTION E - INCINERATION OF SLUDGE

- Please be aware that sludge incineration facilities may be subject to the requirements of 40 CFR Part 503 Subpart E, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or, if the ash is determined to be hazardous, with 10 CSR 25.
- 3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, mass of sludge incinerated and mass of ash generated. Permittee shall also provide the name of the ash disposal facility and permit number if applicable.

SECTION F – SURFACE DISPOSAL SITES AND BIOSOLIDS AND SLUDGE LAGOONS

- 1. Please be aware that surface disposal sites of biosolids or sludge from wastewater treatment facilities may be subject to other laws including the requirements in 40 CFR Part 503 Subpart C, Missouri Air Conservation Commission regulations under 10 CSR 10, and solid waste management regulations under 10 CSR 80, as applicable.
- 2. Biosolids or sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain biosolids or sludge storage lagoons as storage facilities, accumulated biosolids or sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of biosolids or sludge removed will be dependent on biosolids or sludge generation and accumulation in the facility. Enough biosolids or sludge must be removed to maintain adequate storage capacity in the facility.
 - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of biosolids or sludge on the bottom of the lagoon, upon prior approval of the Department; or
 - b. Permittee shall close the lagoon in accordance with Section I.

SECTION G - LAND APPLICATION OF BIOSOLIDS

- 1. The permittee shall not land apply biosolids unless land application is authorized in the facility description, the special conditions of the issued NPDES permit, or in accordance with Section A.3.c., above.
- 2. This permit only authorizes "Class A" or "Class B" biosolids derived from domestic wastewater to be land applied onto grass land, crop land, timber, or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
- 3. Class A Biosolids Requirements: Biosolids shall meet Class A requirements for application to public contact sites, residential lawns, home gardens or sold and/or given away in a bag or other container.
- 4. Class B biosolids that are land applied to agricultural and public contact sites shall comply with the following restrictions:
 - a. Food crops that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
 - b. Food crops below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for four months or longer prior to incorporation into the soil.
 - c. Food crops below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than four months prior to incorporation into the soil.
 - d. Animal grazing shall not be allowed for 30 days after application of biosolids.
 - e. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
 - f. Turf shall not be harvested for one year after application of biosolids if used for lawns or high public contact sites in close proximity to populated areas such as city parks or golf courses.
 - g. After Class B biosolids have been land applied to public contact sites with high potential for public exposure, as defined in 40 CFR § 503.31, such as city parks or golf courses, access must be restricted for 12 months.
 - h. After Class B biosolids have been land applied public contact sites with low potential for public exposure as defined in 40 CFR § 503.31, such as a rural land application or reclamation sites, access must be restricted for 30 days.

5. Pollutant limits

- a. Biosolids shall be monitored to determine the quality for regulated pollutants listed in Table 1, below. Limits for any pollutants not listed below may be established in the permit.
- b. The number of samples taken is directly related to the amount of biosolids or sludge produced by the facility (See Section J, below). Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to achieve pollutant concentration below those identified in Table 1, below.
- c. Table 1 gives the ceiling concentration for biosolids. Biosolids which exceed the concentrations in Table 1 may not be land applied.

TABLE 1

Biosolids ceiling concentration					
Pollutant	Milligrams per kilogram dry weight				
Arsenic	75				
Cadmium	85				
Copper	4,300				
Lead	840				
Mercury	57				
Molybdenum	75				
Nickel	420				
Selenium	100				
Zinc	7,500				

d. Table 2 below gives the low metal concentration for biosolids. Because of its higher quality, biosolids with pollutant concentrations below those listed in Table 2 can safely be applied to agricultural land, forest, public contact sites, lawns, home gardens or be given away without further analysis. Biosolids containing metals in concentrations above the low metals concentrations but below the ceiling concentration limits may be land applied but shall not exceed the annual loading rates in Table 3 and the cumulative loading rates in Table 4. The permittee is required to track polluntant loading onto application sites for parameters that have exceeded the low metal concentration limits.

TABLE 2

IABLE Z					
Biosolids Low Metal Concentration					
Pollutant Milligrams per kilogram dry weig					
Arsenic	41				
Cadmium	39				
Copper	1,500				
Lead	300				
Mercury	17				
Nickel	420				
Selenium	100				
Zinc	2,800				

e. Annual pollutant loading rate.

Table 3

Biosolids Annual Loading Rate					
Pollutant	Kg/ha (lbs./ac) per year				
Arsenic	2.0 (1.79)				
Cadmium	1.9 (1.70)				
Copper	75 (66.94)				
Lead	15 (13.39)				
Mercury	0.85 (0.76)				
Nickel	21 (18.74)				
Selenium	5.0 (4.46)				
Zinc	140 (124.96)				

f. Cumulative pollutant loading rates.

Table 4

Biosolids Cumulative Pollutant Loading Rate			
Pollutant	Kg/ha (lbs./ac)		
Arsenic	41 (37)		
Cadmium	39 (35)		
Copper	1500 (1339)		
Lead	300 (268)		
Mercury	17 (15)		
Nickel	420 (375)		
Selenium	100 (89)		
Zinc	2800 (2499)		

- 6. Best Management Practices. The permittee shall use the following best management practices during land application activities to prevent the discharge of biosolids to waters of the state.
 - a. Biosolids shall not be applied to the land if it is likely to adversely affect a threatened or endangered species listed under § 4 of the Endangered Species Act or its designated critical habitat.
 - $b. \quad Apply \ biosolids \ only \ at the \ agronomic \ rate \ of \ nitrogen \ needed \ (see \ 5.c. \ of \ this \ section).$
 - c. The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop

nitrogen removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.

- i. PAN can be determined as follows:
 - (Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor 1).

 Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis.
- ii. Crop nutrient production/removal to be based on crop specific nitrogen needs and realistic yield goals. NO TE: There are a number of reference documents on the Missouri Department of Natural Resources website that are informative to implement best management practices in the proper management of biosolids, including crop specific nitrogen needs, realistic yields on a county by county basis and other supporting references.
- iii. Biosolids that are applied at agronomic rates shall not cause the annual pollutant loading rates identified in Table 3 to be exceeded.
- d. Buffer zones are as follows:
 - i. 300 feet of a water supply well, sinkhole, water supply reservoir or water supply intake in a stream;
 - 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstandingstate resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
 - iii. 150 feet of dwellings or public use areas;
 - iv. 100 feet (35 feet if biosolids application is down-gradient or the buffer zone is entirely vegetated) of lake, pond, wetlands or gaining streams (perennial or intermittent);
 - v. 50 feet of a property line. Buffer distances from property lines may be waived with written permission from neighboring property owner.
 - vi. For the application of dry, cake or liquid biosolids that are subsurface injected, buffer zones identified in 5.d.i. through 5.d.iii above, may be reduced to 100 feet. The buffer zone may be reduced to 35 feet if the buffer zone is permanently vegetated. Subsurface injection does not include methods or technology reflective of combination surface/shallow soil incorporation.
- e. Slope limitation for application sites are as follows:
 - i. For slopes less than or equal to 6 percent, no rate limitation;
 - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels;
 - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
 - iv. Dry, cake or liquid biosolids that are subsurface injected, may be applied on slopes not to exceed 20 percent. Subsurface injection does not include the use of methods or technology reflective of combination surface/shallow soil incorporation.
- f. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- g. Biosolids may be land applied to sites with soil that are snow covered, frozen, or saturated with liquid when site restrictions or other controls are provided to prevent pollutants from being discharged to waters of the state during snowmelt or stormwater runoff. During inclement weather or unfavorable soil conditions use the following management practices:
 - A maximum field slope of 6% and a minimum 300 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be utilized for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not include the use of mthods or technology refletive of combination surface/shallow soil incorporation;
 - ii. A maximum field slope of 2% and 100 feet grass buffer between the application site and waters of the state. A 35 feet grass buffer may be used for the application of dry, cake or liquid biosolids that are subsurface injected. Subsurface injection does not included the use of methods or technology refletive of combination surface/shallow soil incorporation;
 - iii. Other best management practices approved by the Department.

SECTION H - SEPTAGE

- 1. Haulers that land apply septage must obtain a state permit. An operating permit is not required for septage haulers who transport septage to another permitted treatment facility for disposal.
- 2. Do not apply more than 30,000 gallons of septage per acre per year or the volume otherwise stipulated in the operating permit.
- 3. Septic tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to mechanical treatment facilities.
- 4. Septage must comply with Class B biosolids regarding pathogen and vector attraction reduction requirements before it may be applied to crops, pastures or timberland. To meet required pathogen and vector reduction requirements, mix 50 pounds of hydrated lime for every 1,000 gallons of septage and maintain a septage pH of at least 12 pH standard units for 30 minutes or more prior to application.
- 5. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.
- 6. As residential septage contains relatively low levels of metals, the testing of metals in septage is not required.

SECTION I— CLOSURE REQUIREMENTS

- 1. This section applies to all wastewater facilities (mechanical and lagoons) and sludge or biosolids storage and treatment facilities. It does not apply to land application sites.
- 2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all sludges and/or biosolids. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20 6.010 and 10 CSR 20 6.015.
- 3. Biosolids or sludge that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
 - a. Biosolids and sludge shall meet the monitoring and land application limits for agricultural rates as referenced in Section G, above.
 - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
 - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre. Alternative, site-specific application rates may be included in the closure plan for department consideration.
 - i. PAN can be determined as follows:
 (Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹).

 ¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application. Alternative volitalization factors and mineralization rates can be utilized on a case-by-case basis
- 4. Domestic wastewater treatment lagoons with a design treatment capacity less than or equal to 150 persons, are "similar treatment works" under the definition of septage. Therefore the sludge within the lagoons may be treated as septage during closure activities. See Section B, above. Under the septage category, residuals may be left in place as follows:
 - a. Testing for metals or fecal coliform is not required.
 - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
 - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
- 5. Biosolids or sludge left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, and unless otherwise approved, the lagoon berm shall be demolished, and the site shall be graded and contain ≥70% vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion. Alternative biosolids or sludge and soil mixing ratios may be included in the closure plan for department consideration.
- 6. Lagoon and earthen structure closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200.
- 7. When closing a mechanical wastewater plant, all biosolids or sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
 - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to stormwater per 10 CSR 20-6.200. The site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate

- surface water drainage without creating erosion.
- b. Hazardous Waste shall not be land applied or disposed during mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations pursuant to 10 CSR 25.
- c. After demolition of the mechanical plant, the site must only contain clean fill defined in Section 260.200.1(6) RSMo as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill, reclamation, or other beneficial use. Other solid wastes must be removed.
- 8. If biosolids or sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or I, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for onsite sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR Part 503, Subpart C.

SECTION J – MONITORING FREQUENCY

1. At a minimum, biosolids or sludge shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

TABLE 5

T. I D LL C					
Biosolids or Sludge	Monitoring Frequency (See Notes 1, and 2)				
produced and disposed (Dry Tons per Year)	Metals, Pathogens and Vectors, Total Phosphorus, Total Potassium	Nitrogen TKN, Nitrogen PAN ¹	Priority Pollutants ²		
319 or less	1/year	1 per month	1/year		
320 to 1650	4/year	1 per month	1/year		
1651 to 16,500	6/year	1 per month	1/year		
16,501+	12/year	1 per month	1/year		

Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids. This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

- 2. Permittees that operate wastewater treatment lagoons, peak flow equalization basins, combined sewer overflow basins or biosolids or sludge lagoons that are cleaned out once a year or less, may choose to sample only when the biosolids or sludge is removed or the lagoon is closed. Test one composite sample for each 319 dry tons of biosolids or sludge removed from the lagoon during the reporting year or during lagoon closure. Composite sample must represent various areas at one-foot depth.
- 3. Additional testing may be required in the special conditions or other sections of the permit.
- 4. Biosolids and sludge monitoring shall be conducted in accordance with federal regulation 40 CFR § 503.8, Sampling and analysis.

SECTION K - RECORD KEEPING AND REPORTING REQUIREMENTS

- 1. The permittee shall maintain records on file at the facility for at least five years for the items listed in Standard Conditions PART III and any additional items in the Special Conditions section of this permit. This shall include dates when the biosolids or sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
- 2. Reporting period
 - a. By February 19th of each year, applicable facilities shall submit an annual report for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and biosolids or sludge disposal facilities.
 - b. Permittees with wastewater treatment lagoons shall submit the above annual report only when biosolids or sludge are removed from the lagoon during the report period or when the lagoon is closed.
- 3. Report Form. The annual report shall be prepared on report forms provided by the Department or equivalent forms approved by the Department.
- 4. Reports shall be submitted as follows:
 - Major facilities, which are those serving 10,000 persons or more or with a design flow equal to or greater than 1 million gallons per day or that are required to have an approved pretreatment program, shall report to both the Department and EPA if the facility land applied, disposed of biosolids by surface disposal, or operated a sewage sludge incinerator. All other facilities shall maintain their biosolids or sludge records and keep them available to Department personnel upon request. State reports shall be submitted to the address listed as follows:

DNR regional or other applicable office listed in the permit (see cover letter of permit)

² Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) are required only for permit holders that must have a pre-treatment program. Monitoring requirements may be modified and incorporated into the operating permit by the Department on a case-by-case basis.

Reports to EPA must be electronically submitted online via the Central Data Exchange at: https://cdx.epa.gov/ Additional information is available at: https://www.epa.gov/biosolids/compliance-and-annual-reporting-guidance-about-clean-water-act-laws

- 5. Annual report contents. The annual report shall include the following:
 - a. Biosolids and sludge testing performed. If testing was conducted at a greater frequency than what is required by the permit, all test results must be included in the report.
 - b. Biosolids or sludge quantity shall be reported as dry tons for the quantity produced and/or disposed.
 - c. Gallons and % solids data used to calculate the dry ton amounts.
 - d. Description of any unusual operating conditions.
 - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
 - This must include the name and address for the hauler and sludge facility. If hauled to a municipal
 wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that
 facility.
 - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.

f. Contract Hauler Activities:

If using a contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate biosolids or sludge use permit.

g. Land Application Sites:

- i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as alegal description for nearest ¼, ¼, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kgTN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
- ii. If the "Low Metals" criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
- iii. Report the method used for compliance with pathogen and vector attraction requirements.
- iv. Report soil test results for pH and phosphorus. If no soil was tested during the year, report the last date when tested and the results.

HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY

RECEIVED

MAR 1 2 2019

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM WATER PROTECTION PROGRAM

FORM B2 – APPLICATION FOR AN OPERATING PERMIT FOR Program

CHECK NUMBER FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND

DATE RECEIVED

FOR AGENCY USE ONLY

FEE SUBMITTED

PAF	RTA	- BASIC APPLICATION INFORMATION							
1.	Т	HIS APPLICATION IS FOR:							
		An operating permit for a new or unpermitted facility			Construction Per			- 2 Sty / 1 Sty 2 A SAMM	
	_	(Include completed Antidegradation Review or reque	est to con					tructions	s)
	V	An operating permit renewal: Permit #MO- 0106151			Expiration Date	09/30/20	19		
		An operating permit modification: Permit #MO			Reason:				
1.1	ı	s the appropriate fee included with the application (se	ee instruc	ctions	s for appropriate	fee)?		YES	☑ NO
2.	F	ACILITY							
NAME									WITH AREA CODE
272		remont Hills Wastewater Treatment Facility	ours:				417-725-	0404	L zin cone
		PHYSICAL) e Jay Way	CITY Nixa				MO STATE		ZIP CODE 65714
2.1		LEGAL DESCRIPTION (Facility Site): 1/4, SE 1/4	4, NW 1/4	i, S	ec. 5 , T 27N	, R 21W		Christia	
2.2		UTM Coordinates Easting (X): <u>477174</u> Northir For Universal Transverse Mercator (UTM), Zone 15	ng (Y): _ North re		02900 nced to North Am	erican Da	atum 1983	(NAD8	3)
2.3		Name of receiving stream: Tributary to James Rive	r (U) Iosii	ng					W
2.4		Number of Outfalls: 1 wastewater outfalls, 0	st	ormv	vater outfalls, 0	instre	am monito	oring site	es
3.	C	WNER							
and the street of the street	of F	remont Hills	jo		ADDRESS SE@fremonthillscity.com TELEPHONE NUMBER WITH AREA CODE 417-725-6404				
ADDF 1953	ess Fre	emont Hills Drive	CITY Nixa				MO MO		ZIP CODE 65714
3.1		Request review of draft permit prior to Public Notice	?	V] YES [□ NO			
3.2		Are you a Publically Owned Treatment Works (POT) If yes, is the Financial Questionnaire attached?	N)?		YES [YES [□ NO □ NO			
3.3	-	Are you a Privately Owned Treatment Facility?				☑ NO			
3.4		Are you a Privately Owned Treatment Facility regula	ted by th			mission (PSC)?	YES	I NO
4.		ONTINUING AUTHORITY: Permanent organization		1000		ALCOHOL MANAGEMENT		10.000	auto variables and the sign
NI L L L	(3)///	naintenance and modernization of the facility.	1.6	EMAIL	ADDRESS		TELEBRON	E VILIMOED	WITH AREA CODE
City		remont Hills	1187		s@fremonthillsci	tv.com	417-725-		WITH AREA CODE
ADDE		Technology (1986)	CITY	Ju. 110		-,	STATE	7.77.5	ZIP CODE
		emont Hills Drive	Nixa				MO		65714
		ontinuing Authority is different than the Owner, include ion of the responsibilities of both parties within the ag			e contract agreer	ment betw	een the tv	wo partie	es and a
5.		PERATOR			,				
NAME							R (IF APPLICABLE)		
	Ecologic Environmental LLC/Rob Dyer Operator 3205 EMAIL ADDRESS TELEPHONE NUMBER WITH AREA CODE								
		@yahoo.com	417-840				*		
6.	F	ACILITY CONTACT			W/20 20 P				
	NAME Jeanette Curtiss City Clerk/Finance Officer								
EMAI	ADD	ress Ofremonthillscity.com			TELEPHONE NUMBER WITH AREA CODE 417-725-6404				
ADDF	and the Second	gnoment into ty.com	CITY				STATE		ZIP CODE
		emont Hills Drive	Nixa		1*		МО		65714



MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM

FORM B2 – APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE

	RE	C	EI	VED
AΤ	MAR	1	2	2010
RE	THA Oto	N		2019

91
COUNTY
Christian

APPLICATION OVERVIEW

Form B2 has been developed in a modular format and consists of Parts A, B and C and a Supplemental Application Information (Parts D, E, F and G) packet. All applicants must complete Parts A, B and C. Some applicants must also complete parts of the Supplemental Application Information packet. The following items explain which parts of Form B2 you must complete. Submittal of an incomplete application may result in the application being returned.

BASIC APPLICATION INFORMATION

- Basic application information for all applicants. All applicants must complete Part A.
- B. Additional application information for all applicants. All applicants must complete Part B.
- C. Certification. All applicants must complete Part C.

SUPPLEMENTAL APPLICATION INFORMATION

- D. Expanded Effluent Testing Data. A treatment works that discharges effluent to surface water of the United States and meets one or more of the following criteria must complete Part D - Expanded Effluent Testing Data:
 - Has a design flow rate greater than or equal to 1 million gallons per day.
 - 2. Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- E. Toxicity Testing Data. A treatment works that meets one or more of the following criteria must complete Part E -Toxicity Testing Data:
 - 1. Has a design flow rate greater than or equal to 1 million gallons per day.
 - Is required to have or currently has a pretreatment program.
 - 3. Is otherwise required by the permitting authority to provide the information.
- F. Industrial User Discharges and Resource Conservation and Recovery Act / Comprehensive Environmental Response, Compensation and Liability Act Wastes. A treatment works that accepts process wastewater from any significant industrial users, also known as SIUs, or receives a Resource Conservation and Recovery Act or CERCLA wastes must complete Part F Industrial User Discharges and Resource Conservation and Recovery Act /CERCLA Wastes.

SIUs are defined as:

- All Categorical Industrial Users, or CIUs, subject to Categorical Pretreatment Standards under 40 Code of Federal Regulations 403.6 and 40 Code of Federal Regulations 403.6 and 40 CFR Chapter 1, Subchapter N.
- 2. Any other industrial user that meets one or more of the following:
 - i. Discharges an average of 25,000 gallons per day or more of process wastewater to the treatment works (with certain exclusions).
 - ii. Contributes a process waste stream that makes up five percent or more of the average dry weather hydraulic or organic capacity of the treatment plant.
 - iii. Is designated as an SIU by the control authority.
 - iv. Is otherwise required by the permitting authority to provide the information.
- G. Combined Sewer Systems. A treatment works that has a combined sewer system must complete Part G -Combined Sewer Systems.

FACILITY	City of Fremont Hills WWTP	PERMIT NO. 0106151	OUTFALL NO. 001					
PART	A - BASIC APPLICATION INFORM	ATION						
7.	FACILITY INFORMATION							
7.1								
gpd wi has a i	ty of Fremont Hills WWTP consists of th biological phosphorus removal follo mechanical bar screen, influent pump he tertiary filter units are MWW Xylen	wed by secondary clarification, ter station, chemical phosphorus remo	tiary filtration and ultra-violet disin oval, 2 final clarifiers and an aerat	fection. The facility				
(See A	attached Process Flow Diagram)							
1								

FACILITY City of	Y NAME F Fremont Hills WWTP Facility	PERMIT NO. MO-0106151		001	FALL NO.	
PART	A - BASIC APPLICATION INFORMA	TION				
7.	FACILITY INFORMATION (continued	t)				
7.2	Topographic Map. Attach to this approperty boundaries. This map must sa. The area surrounding the treatmet. The location of the downstream lac. The major pipes or other structure through which treated wastewater applicable. d. The actual point of discharge. e. Wells, springs, other surface water the treatment works, and 2) listed f. Any areas where the sewage sluct. If the treatment works receives were (RCRA) by truck, rail, or special print is treated, stored, or disposed.	show the outline of the part plant, including all andowner(s). (See Ite es through which was ris discharged from the bodies and drinking I in public record or oldge produced by the baste that is classified	te facility and to unit processe and 10.) stewater enters the treatment p g water wells to therwise know treatment work as hazardous	he following inf s. s the treatment plant. Include of hat are: 1) with in to the applicates is stored, tre under the Res	works and the putfalls from bypain 1/4 mile of the ant. ated, or dispose ource Conserva	pipes or other structures bass piping, if property boundaries of ed. ation and Recovery Act
7.3	Facility SIC Code: 1623		Discharge SI 4952 .	C Code:		
7.4	Number of people presently connected	d or population equiv	alent (P.E.):	1,331	Design P.E.	1,758
7.5	Connections to the facility: Number of units presently connected Homes 502 Trailers 0 Number of Commercial Establishmen	Apartments 0	Other (inc	luding industria	ni) <u>0</u>	
7.6	Design Flow 176,000 gpd		Actual Flow 85,000 gpd			
7.7	Will discharge be continuous through to Discharge will occur during the following			No □ ne week will dis	charge occur?	
7.8	Is industrial wastewater discharged to the facility? Yes ☐ No ☑ If yes, describe the number and types of industries that discharge to your facility. Attach sheets as necessary					essary
	Refer to the APPLICATION OVERVIE	:W to determine whet	her additional	information is	needed for Part	F.
7.9	Does the facility accept or process lea	chate from landfills?:		Yes 🗆	No 🗸	
7.10	Is wastewater land applied?			Yes ☐ Yes ☐	No ☑ No □	
7.11	If yes, is Form I attached? Does the facility discharge to a losing	etreem or sinkhole?		Yes 🗸	No 🗆	
ARREST D	Has a wasteload allocation study beel		acility?	Yes 🗌	No 🗸	
7.12	A PARTICIPATION OF THE PROPERTY OF THE PARTICIPATION OF THE PARTICIPATIO	THE PROCESS OF THE PROPERTY OF	acility r	res	140 KT	
8.	LABORATORY CONTROL INFORMA					
	LABORATORY WORK CONDUCTED	BY PLANT PERSO	NNEL		Yes 🗹	No 🗆
						No 🗌
	Additional procedures such as Dissolv Oxygen Demand, titrations, solids, vol	ved Oxygen, Chemica			0	No ☑
	More advanced determinations such a nutrients, total oils, phenols, etc. Highly sophisticated instrumentation,	60			Yes ☐ n. Yes ☐	No ✓ No ✓

FACILITY NA	ME emont Hills WWTP Facility	PERMIT NO. MO- 0106151			OUTFALL NO. DO1		
CARROLL DAVID BY	- BASIC APPLICATION INFO						
Decree States and the Con-	LUDGE HANDLING, USE AND						
9.1 Is	Is the sludge a hazardous waste as defined by 10 CSR 25? Yes ☐ No ☑						
9.2 SI	udge production (Including slud	ge received from ot	hers): Design Dry Tons/Y	ear 35 Act	ual Dry To	ons/Year 28	
9.3 SI	ludge storage provided: 32085	Cubic feet; 75	Days of storage; 2.88 A	verage percent s	olids of sl	udge;	
	No sludge storage is provided	I. ☐ Sludge is store	ed in lagoon.				
9.4 Ty	ype of storage:	☐ Holding Tank ☑ Basin ☐ Concrete Pad	☐ Building ☐ Lagoon ☐ Other (D	escribe)			
9.5 SI	udge Treatment:						
		rage Tank or Heat Drying	☐ Lime Stabilization☐ Composting	☐ Lag		Description)	
9.6 SI	ludge use or disposal:						
	Land Application	oosal Lagoon, Sludg	Hauled to Another Treatn ge Held For More Than Tv		☐ Solid \	Waste Landfill ration	
9.7 Pe	erson responsible for hauling slu By Applicant ✓ By Ot	udge to disposal fac thers (complete belo	ility: ow)				
NAME Active Se	eptic Service			EMAIL ADDRESS N/A			
ADDRESS			CITY		STATE	ZIP CODE	
2597 Her	mlock	141	Ozark		МО	65721	
CONTACT P			TELEPHONE NUMBER WITH AREA CODE		PERMIT NO.		
Rick Trim	nble		417-581-2758		MO- ⁰¹³		
9.8	Sludge use or disposal facility: By Applicant By Oth	ners (Complete belo	w)				
NAME	50.594950	Marine Commission Commission	EMAIL ADDRESS				
ARCHERICAL PRINCES	st WWTF		N/A		Lower	ZIP CODE	
ADDRESS	est Nichols Street		Springfield		MO	ZIP CODE	
14000115100000000000			TELEPHONE NUMBER WITH AREA CODE		PERMIT NO	<u>)</u>	
	John D. Waitman		417-864-1490		MO- 0049522		
9.9 Does the sludge or biosolids disposal comply with Federal Sludge Regulation 40 CFR 503? ☑Yes ☐ No (Explain)							
			END OF PART A				
780-1805 ((09-16)		70-7 71 53 1033 13			Page 5	

FACILITY NAME City of Fremont Hills WWTP Facility	PERMIT NO. MO-0106151	OUTFALL NO.					
PART B - ADDITIONAL APPLICATION INF	ORMATION						
10. COLLECTION SYSTEM							
10.1 Length of sanitary sewer collection system in miles 8.74							
10.2 Does significant infiltration occur in the lift yes, briefly explain any steps under	e collection system? □Yes ☑ No way or planned to minimize inflow and infiltra	ntion:					
11. BYPASSING							
Does any bypassing occur anywhere in the collifyes, explain: Refer to SSO's submitted to the Southwest Refered to the So		Yes ☑ No ☐					
operator, Robert Dyer.	egional Department of Natural Resources for	the past 5 years submitted by the contract					
12. OPERATION AND MAINTENANCE P	ERFORMED BY CONTRACTOR(S)						
Are any operational or maintenance aspects (related to wastewater treatment and effluent quality) of the treatment works the responsibility of the contractor? Yes \(\subseteq \text{No} \text{No} If Yes, list the name, address, telephone number and status of each contractor and describe the contractor's responsibilities. (Attach additional pages if necessary.)							
NAME Rob DyerEcologic Environmental							
MAILING ADDRESS 1144 W. Irene Court Nixa, MO 65714							
TELEPHONE NUMBER WITH AREA CODE 417-840-9258	email address rdyer61@yahoo.com						
RESPONSIBILITIES OF CONTRACTOR							
Day-to-day operation of the plant.							
13. SCHEDULED IMPROVEMENTS AND	SCHEDULES OF IMPLEMENTATION						
Provide information about any uncompleted implementation schedule or uncompleted plans for improvements that will affect the wastewater treatment, effluent quality, or design capacity of the treatment works. If the treatment works has several different implementation schedules or is planning several improvements, submit separate responses for each.							
The Missouri Rural Water Association will be assisting the City of Fremont Hills with smoke testing and I & I collection system infrastructure assessment in 2019.							
ACE Pipe CCTV'd the lines at the lower end of the system.							
Missouri Gas Energy/Laclede Gas CCTV'd all the mains in the infrastructure while installing natural gas service to the City in 2017 and 2018.							
Three buried manholes recently located and v	vill be raised.						

FACILITY NAME	PERMIT NO.	OUTFALL NO.
City of Fremont Hills WWTP Facility	MO-0106151	001

PART B - ADDITIONAL APPLICATION INFORMATION

14. EFFLUENT TESTING DATA

Applicants must provide effluent testing data for the following parameters. Provide the indicated effluent data for each outfall through which effluent is discharged. Do not include information of combined sewer overflows in this section. All information reported must be based on data collected through analysis conducted using 40 CFR Part 136 methods. In addition, this data must comply with QA/QC requirements of 40 CFR Part 136 and other appropriate QA/QC requirements for standard methods for analytes not addressed by 40 CFR Part 136. At a minimum, effluent testing data must be based on at least three samples and must be no more than four and one-half years apart.

Outfall Number

	MAXIMUM DAILY VALUE		AVERAGE DAILY VALUE			
PARAMETER	Value	Units	Value	Units	Number of Samples	
pH (Minimum)	6.9	S.U.		S.U.	30	
pH (Maximum)	7.3	S.U.		S.U.	30	
Flow Rate	0.300	MGD	0.108	MGD	30	

*For pH report a minimum and a maximum daily value

POLLUTANT			MUM DAILY AVERA		AGE DAILY DISCHARGE		ANALYTICAL	ML/MDL
		Conc.	Cone Unite Cone Unite		Number of Samples	METHOD		
Conventional and	Nonconvention	nal Compo	unds					
BIOCHEMICAL OXYGEN	BOD ₅	< 4	mg/L	< 4	mg/L	12	SM 5210 B	
DEMAND (Report One)	CBOD ₅		mg/L		mg/L			
E. COLI		< 10	#/100 mL	<10	#/100 mL	12	SM 9223 B	
TOTAL SUSPEND SOLIDS (TSS)	DED	5	mg/L	<2	mg/L	12		
AMMONIA (as N)		0.9	mg/L	0.3	mg/L	12	EPA 350.1	
CHLORINE* (TOTAL RESIDUAL, TRC)			mg/L		mg/L			N/A
DISSOLVED OXYGEN		6.6	mg/L	6.2	mg/L	30	ASTM D888-12	
OIL and GREASE		<5.2	mg/L	<5.2	mg/L	4	EPA 1664	
OTHER			mg/L		mg/L			

^{*}Report only if facility chlorinates

END OF PART B

780-1805 (09-16)


Page 7


FACILITY NAME	PERMIT NO. MO- 0106151		OUTFALL NO.			
City of Fremont Hills WWTP Facility PART C – CERTIFICATION	MO- 0100191		001			
15. ELECTRONIC DISCHARGE MONITORING REPORT (eDMR) SUBMISSION SYSTEM Per 40 CFR Part 127 National Pollutant Discharge Elimination System (NPDES) Electronic Reporting Rule, reporting of effluent limits and monitoring shall be submitted by the permittee via an electronic system to ensure timely, complete, accurate, and nationally-consistent set of data. One of the following must be checked in order for this application to be considered complete. Please visit http://dnr.mo.gov/env/wpp/edmr.htm to access the Facility Participation Package.						
You have completed and submitted with	this permit application	the required document	tation to participate in the eDMR system.			
	ired documentation to μ	participate in the eDMR	system and/or you are currently using the			
You have submitted a written request fo waivers.	r a waiver from electror	nic reporting. See instr	uctions for further information regarding			
16. CERTIFICATION						
All applicants must complete the Certification applicants must complete all applicable secti applicants confirm that they have reviewed that application is submitted.	ons as explained in the	Application Overview.	By signing this certification statement,			
ALL APPLICANTS MUST COMPLETE THE	FOLLOWING CERTII	FICATION.				
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.						
PRINTED NAME Luke Davis		OFFICIAL TITLE (MUST BE AN Mayor	OFFICER OF THE COMPANY OR CITY OFFICIAL)			
SIGNATURE						
TELEPHONE NUMBER WITH AREA CODE 417-725-6404						
3-7-2019						
Upon request of the permitting authority, you at the treatment works or identify appropriate	ı must submit any othe e permitting requiremer	r information necessary its.	to assess wastewater treatment practices			
Send Completed Form to:						
		atural Resources				
А	Water Protect TTN: NPDES Permits		n			
61	P.O. B	ox 176				
Jefferson City, MO 65102-0176						
END OF PART C REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHICH PARTS OF FORM B2 YOU MUST COMPLETE.						
Do not complete the remainder of this application, unless at least one of the following statements applies to your facility: 1. Your facility design flow is equal to or greater than 1,000,000 gallons per day. 2. Your facility is a pretreatment treatment works. 3. Your facility is a combined sewer system.						
Submittal of an incomplete application may reforeited. Permit fees for applications being	esult in the application processed by the depa	being returned. Permi rtment that are withdra	t fees for returned applications shall be wn by the applicant shall be forfeited.			

FREMONT HILLS WASTEWATER TREATMENT PLANT FLOW DIAGRAM

MAR 2 3 2015

EOPLE x 0.17 LBS BOD/CAP/DAY MECHANICALLY CLEANED BAR SCREEN = 299 LBS BOD/DAY, (1'wide x 3' deep @ Qavg. (175,000 GPD) @ Qpeak (648,000 GPD) H = 0.25' INFLUENT PUMP STATION 2-25 H.P. PUMPS RATED @ 450 GPM (E, REQUIRED Q @ PEAK DESIGN = 450 GPM AERATION BASIN VOL. = 102,528 (EXT)+46,548 (PROP.) RODUCED =149,076 GALLONS BOD/DAY x 0.60 = 179 LBS/DAY DET. TIME @ Qavg. = 20.4 HRS DET. TIME @ Qpeak 5.5 HRS. 25 x 8.34 = 860 GAL/DAY SECONDARY CLARIFIER (TYP. OF 2) TOTAL SURFACE AREA = 831 S.F. S.O.R. @ Qavg. = 210 GPD/S.F. S.O.R. @ Qpeak = 780 GPD/S.F. CHEMICAL FEED CAPACITY BASED ON Qavg=175,000 GPD TE SLUDGE = 64,200 GAL. TERTIARY FILTRATION 860 GAL/DAY 75 DAYS = 64,200 FILTER LOADING W/ONE FILTER OUT OF @ Qavg. = 2.16 GPM/S.F. @ Qpeak = 5.0 GPD/S.F.





SPECIFICATIONS AND BID FOR MAINTENANCE AND OPERATION OF WASTEWATER TREATMENT PLANT

Specifications:

- Contractor agrees to perform the day-to-day operation and maintenance of the sewer collection system (main plant, two lift stations and sewer lines), owned by the City of Fremont Hills in accordance with, and reporting to, the Department of Natural Resources as required by the State of Missouri (operating permit is available for review).
- 2. Contractor is an independent contractor and shall be responsible for his/her own income and employment taxes and insurance (insurance required as per Attachment A--insurance is required with this bid or be able to provide if awarded the bid).
- Contractor must have at least a Class A operator's certificate (a copy of the
 operator's certification is required with this bid)—a Class C operator's certificate for
 any employees working under the supervision of the main operator.
- Contactor must be able to respond to non-maintenance and/or emergency calls to the plant within a reasonable period of time (reasonable period of time defined to be within 15 minutes from time of call).

Bid:	2016	2017	2018
Monthly operation and maintenance fee	\$	\$	\$
Hourly fee for ancillary services beyond the day-to-day operation and maintenance of the sewer collection system and required reporting to the State DNR (fees must be item		\$	\$

Sealed bids will be accepted until 3:30 PM on Thursday, December 17, 2015 at 8406 Interlochen Drive, Nixa-Fremont Hills, MO 65714. All bids received in proper form by the above time and place will be publicly opened and read at 4:30 PM on Thursday, December 17, 2015 at 1953 Fremont Hills Dr. The City has the right to reject any, and all, bids. The City will select the lowest and best bidder as provided for in Ordinance 210-2010. The City also has the right to terminate, for any reason, on 30 days notice.

Note: Bills must be submitted on a monthly basis for approval. We recommend letters of reference (along with contact information) be submitted with this bid—required with this bid is evidence of insurance, or be able to provide if awarded the bid, and a copy of the operator's certification.

Company Name:		
Signature of Perso	n Submitting Bid	

Contact Jeanette Curtiss, City Clerk, City of Fremont Hills, 725-6404 with questions.

ATTACHMENT A

- 1. <u>Insurance</u>: Without limiting CONTRACTOR's indemnification obligations, CONTRACTOR shall procure and maintain, at its sole cost and for the duration of this Agreement, insurance coverage as provided below, against all claims for injuries against persons or damages to property which may arise from or in connection with the performance of the work hereunder by CONTRACTOR, its agents, representatives, employees, and/or subcontractors. In the event Contractor subcontracts any portion of the work as allowed under this Agreement the Contract between the Contactor and such subcontractor shall require the subcontractor to maintain the policies of insurance that the Contractor is required to maintain pursuant to this Agreement.
- 2. <u>CONTRACTOR's Insurance Requirements</u>: CONTRACTOR shall not commence work under this Agreement until they have obtained all insurance required as set forth herein and such insurance has been approved by the OWNER. All policies shall be from companies authorized to issue insurance in the State of Missouri and shall be in amounts, form, and companies satisfactory to the CITY which must carry an A-6 or better rating as listed in the A.M. Best or equivalent rating guide. Insurance limits indicated below may be lowered at the discretion of the CITY.
- 3. Comprehensive General Liability Insurance: CONTRACTOR shall take out and maintain during the life of this Agreement, such comprehensive general liability insurance as shall protect them, and any subcontractor performing work covered by this Agreement, from claims for damages for personal injury including accidental death, as well as from claims for property damages, which may arise from operations under this Agreement, whether such operations be by themselves or for any subcontractor or by anyone directly or indirectly employed by them. The insurance carried by CONTRACTOR shall name the City of Fremont Hills, Missouri, and their respective elected officials and employees, as additional named insureds in amounts sufficient to cover the sovereign immunity limits for CITY and said insurance shall be not less than \$1,000,000.00 per person and \$2,000,000.00 for any one occurrence covering both bodily injury and property damage, including accidental death. If providing Comprehensive General Liability Insurance, then the Proof of Coverage of Insurance shall also be included.
- 4. Workers Compensation Insurance: CONTRACTOR shall take out and maintain during the life of this Agreement, Employee's Liability and Worker's Compensation Insurance for all of their employees employed at the site of work, and in case any work is sublet, CONTRACTOR shall require the subcontractor similarly to provide Worker's Compensation Insurance for all of the latter's employees unless such employees are covered by the protection afforded by CONTRACTOR. Worker's Compensation coverage shall meet Missouri Statutory limits. Employer's Liability limits shall be \$500,000.00 each employee, \$500,000.00 each accident, and \$500,000.00 policy limit. In case any class of employees engaged in hazardous work under this Agreement at the site of the work is not protected under the Worker's Compensation Statute, CONTRACTOR shall provide and shall cause each subcontract to provide Employers' Liability Insurance for the protection of their employees not otherwise protected.
- 5. Commercial Automobile Liability: CONTRACTOR shall maintain during the life of this Agreement, automobile liability insurance in the amount of not less than \$1,000,000.00 per claimant and \$2,000,000.00 for any one occurrence, covering both bodily injury, including accidental death, and property damage to protect themselves from any and all claims arising from the use of CONTRACTOR's own automobiles, teams and trucks; hired automobiles, teams and trucks; and both on and off the site of work.

- 6. <u>Professional Liability (covering errors and omissions)</u>: One Million Dollars (\$1,000,000.00) per claims made.
- 7. Proof of Carriage of Insurance: CONTRACTOR shall furnish the CITY with certificate(s) of Insurance which name the CITY, their elected officials, and employees as additional insureds in an amount as required in this Agreement and sufficient to cover sovereign immunity limits for Missouri public entities (\$409,123.00 per claimant and \$2,727,489.00 per occurrence for 2015) as calculated by the Missouri Department of Insurance financial institutions, professional registration, and published annually in the Missouri Register pursuant to Section 537.610, RSMo. Each party shall require a thirty (30) day mandatory cancellation notice.
- 8. <u>Indemnity Agreement</u>: To the fullest extent permitted by law, CONTRACTOR shall indemnify, hold harmless and defend the CITY, their directors, officers, public office holders, agents and employees from and against all claims, damages, losses and expenses (including but not limited to attorney fees) arising by reason of any act or failure to act, negligent or otherwise, of CONTRACTOR, of any subcontractor (meaning anyone, including but not limited to consultants having a contract with contractor or a subcontract for part of the services), of anyone directly or indirectly employed by CONTRACTOR or by any subcontractor, or of anyone for whose acts CONTRACTOR or its subcontractor may be liability, in connection with providing these services. This provision does not, however, require CONTRACTOR to indemnify, hold harmless, or defend the CITY from its own negligence.
- 9. In no event shall the language or requirements of this Agreement constitute or be construed as a waiver or limitation of the CITY's rights or defenses with regard to the CITY's applicable sovereign, governmental or official immunities and protections as provided by federal and state constitutions, statutes, and laws.

WASTEWATER TREATMENT FACILITY SERVICES CONTRACT

THIS AGREEMENT executed on this 21st day of January, 2016, by and between the CITY OF FREMONT HILLS (hereinafter "City"), and ROB DYER d/b/a ECOLOGIC ENVIRONMENTAL (hereinafter "Contractor").

NOW, THEREFORE, FOR AND IN CONSIDERATION of the mutual promises and agreements contained herein, City hires Contractor, and Contractor agrees to work for City under the terms and conditions hereby agreed upon by the parties:

SECTION 1—WORK TO BE PERFORMED

- 1.1 <u>Term</u>. City agrees to hire Contractor, to perform services and work as stated in section 1.2 of this agreement.
- 1.2 <u>Duties</u>. Contractor agrees to perform work for the City on the terms and conditions set forth in bid specifications attached as a part of this agreement.

SECTION 2 - COMPENSATION

- 2.1 <u>Compensation</u>. In consideration of all services to be rendered by Contractor to the City, the City shall pay to the Contractor according to the bid specifications. Said compensation shall be paid monthly.
- 2.2 Withholding. Contractor is an independent contractor and shall be responsible for his/her own income taxes, worker's compensation/general liability insurance and other employment taxes.

SECTION 3—REPRESENTATIONS OF WARRANTIES OF CONTRACTOR

3.1 Contractor represents that he/she is free to enter into this Agreement, and that this engagement does not violate the terms of any agreement between Contractor and any third party. During the term of the agreement, Contractor shall devote as much productive time, energy and abilities as is needed and necessary to perform the required duties in a timely and productive manner. Contractor is expressly free to perform services for other parties while performing services for City.

SECTION 4—MISCELLANEOUS PROVISIONS

- 4.1 The provisions of this Agreement shall be binding upon and for the benefit of the heirs, personal representatives, successors and assigns of the parties.
- 4.2 Contractor shall keep City's property in a clean and satisfactory condition.

- 4.3 In the event of a default under this Agreement, the defaulted party shall reimburse the non-defaulting party or parties for all costs and expenses reasonably incurred by the non-defaulting party or parties in connection with the default, including without limitation, attorney's fees. Additionally, in the event a suit or action is filed to enforce this Agreement or with respect to this Agreement, the prevailing party or parties shall be reimbursed by the other party for all costs and expenses incurred in connection with the suit or action, including without limitation, reasonable attorney's fees at the trial level and on appeal.
- 4.4 No waiver of any provision of this Agreement shall be deemed, or shall constitute, a waiver of any other provision, whether or not similar, nor shall any waiver constitute a continuing waiver. No waiver shall be binding unless executed in writing by the party making the waiver.
- 4.5 This Agreement shall be governed by and shall be construed in accordance with the laws of the State of Missouri.
- 4.6 This Agreement constitutes the entire agreement between the parties pertaining to its subject matter and it supersedes all prior contemporaneous agreements, representations and understanding of the parties. No supplement, modification or amendment of this Agreement shall be binding unless executed in writing by all parties.
- 4.7 If any provision of this Agreement is held unenforceable, then such provision will be modified to reflect the parties' intention. All remaining provisions of this Agreement shall remain in full force and effect.
- 4.8 Contractor agrees to indemnify, defend, and hold City and his/her/their successors, officers, directors, agents and employees harmless from any and all actions, causes of action, claims, demands, cost, liabilities, expenses and damages (including attorneys' fees) arising out of, or in connection with any work performed by Contractor pursuant to this Agreement.
- 4.9 City may terminate this Agreement at any time by providing 30 days written notice to Contractor. In addition, if Contractor fails or refuses to comply with the policies or reasonable directives of City, is guilty of serious misconduct in connection with his/her/their performance hereunder, or materially breaches any provisions of this Agreement, City may at any time and in its sole discretion terminate the engagement of Contractor immediately and without prior written notice to Contractor.
- 4.10 Contractor shall not assign any of his/her rights under this agreement, or delegate the performance of any of his/her duties hereunder, without the express written prior consent of City.

SECTION 5--DURATION OF CONTRACT

5.1 This contract is effective this 21st day of January, 2016 to the 31st day of December, 2018. The City has the right to extend this contract for one additional year under the same terms, conditions and pricing should the City agree to do so.

ECOLOGIC ENVIRONMENTAL


зу: ___

Robert O. Dyer

CITY OF FREMONT HILLS

Ву: ___

T. Tobin, Jr., Mayor



November 20, 2018 per per

Reologic Environmental 1144 West frene Ct. Nixa, MO 65714 Rob Dyer

Dear Rob;

the right to extend your contract for a one-year interval unfer the unne terran, considered and Under Section 5.0 Duration of Contract for waste mater tracturent plant operator, list fary list pricing should the City agree to do so. At our November 15, 2018 morting, he Board of Aldermen approved extending the wastewater trustment giant operator contract for an additional year (2019).

If this one-year contract extension is agreeable to you, please sugn a copy of this batter and return to me. Please contact me if you have any questions.

Very truly yours,

CITY OF FREMONT HILLS

Jeanette Curtiss

City Clerk/Finance Officer

I, Rob Dyer, am agreeable to the one-year contract extension under the same terms and pricing for the 2019 wastewater treatment plant operator.

ECOLOGIC ENVIRONMENTAL

By:

Date:

953 Fremont Hills Drove Fremont Hills, MO 65/14

417.725.6404



MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM FINANCIAL QUESTIONNAIRE

NOT	FINANCIAL INFORMATION THAT IS NOT PROVIDED THROUGH THIS FORM WILL BE OBTAINED BY THE DEPARTMENT FROM READILY AVAILABLE SOURCES.				
1.	GENE	ERAL INFORMATION	× 11		
	ACILITY NAME ty of Fremont Hills Wastewater Treatment Facility PERMIT NUMBER #MO- 0106151				
CITY					
Nixa			Christian		
2.	GENE	ERAL FINANCIAL INFORMATION (ALL FACILITIES)			
2.1	Numb	per of connections to the facility: Residential 502	Commercial 20	Industrial 0	
2.2	Curre	nt sewer user rate (Based on a 5,000 gallon per month us	age):	\$48.77	
2.3	Curre	nt annual operating costs for the facility (excludes depreci	ation):	\$296,390	
2.4	Bond	rating (if applicable):		Not Been Rated	
2.5	Bondi	ing capacity:		\$5,254,661 (20% of 3.1)	
2.6	Curre	nt outstanding debt relating to wastewater collection and t	reatment:	\$894,000	
2.7		int within the current user rate used toward payments on c id to the current wastewater infrastructure:	outstanding debt	\$29.52	
2.8	Attach any relevant financial statements. Balance Sheet				
3.					
3.1	Munic	cipality's Full Market Property Value:		\$26,273,306	
3.2	Municipality's Overall Net Debt:		\$894,000.00		
3.3	Munic	cipality's Property Tax Revenues (levied) [A]:		\$165,746.44	
3.4	Munic	cipality's Property Tax Revenues (collected) [B]:		\$165,746.44	
3.5	Munic	cipality's Property Tax Collection Rate ([B]/[A]):		100%	
4.	FINA	NCIAL INFORMATION REQUIRED FROM SEWER DIST	RICTS NA		
4.1	Total	connections to the sewer district: Residential	Commercial	Industrial	
4.2	Wher Will th	n facilities require upgrades, how are the costs divided? W ne costs be divided across the sewer district?	ill the homes connecte	ed to the upgraded facility bear the costs?	
5.	ADDI	TIONAL CONSIDERATIONS (ALL FACILITIES)	Salah Sa		
5.1 N	Providindica indica one	de a list of major infrastructure or other investments in env ate any possible overlap or complications (attach sheets as	rironmental projects. Ir s necessary):	nclude project timing and costs and	
5.2 No	requi	de a list of any other relevant local community economic crements (attach sheets as necessary):	conditions that may imp	pact the ability to afford new permit	

6. CERTIFICATION		
FINANCIAL CONTACT Jeanette Curtiss	OFFICIAL TITLE City Clerk/Finance Officer	
EMAIL ADDRESS jcurtiss@fremonthillscity.com	TELEPHONE NUMBER WITH AREA CODE 417-725-6404	

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

OWNER OR AUTHORIZED REPRESENTATIVE
Luke Davis

SIGNATURE

DATE SIGNED

3-7-2619

INSTRUCTIONS FOR COMPLETING THE FINANCIAL QUESTIONNAIRE

The Financial Questionnaire it to be completed by municipalities, sewer districts, and water supply districts when filing for renewal of their Missouri State Operating Permit. The Financial Questionnaire is to be submitted as an attachment to FORM B: APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW LESS THAN OR EQUAL TO 100,000 GALLONS PER DAY and FORM B2: APPLICATION FOR OPERATING PERMIT FOR FACILITIES THAT RECEIVE PRIMARILY DOMESTIC WASTE AND HAVE A DESIGN FLOW MORE THAN 100,000 GALLONS PER DAY.

- GENERAL INFORMATION Provide the name by which the facility is locally known, the Missouri State Operating Permit number, and the city and county where the facility is located.
- GENERAL FINANCIAL INFORMATION (ALL FACILITIES) Municipalities, sewer districts, and water supply districts are to complete.
- 2.1 Self-explanatory.
- 2.2 Provide the rate that a household would be charged for sewer service if they use 5,000 gallons per month.
- 2.3 Provide the cost to operate and maintain the wastewater facility annually.
- 2.4 Bond ratings can be found here:
- 2.5 General obligation bond capacity allowed by constitution: Cities = up to 20% of taxable tangible property; Sewer districts = up to 5% of taxable tangible property.
- 2.6 Provide the amount of debt owed on wastewater collection and treatment. Debt information is typically available from your community's annual financial statements
- 2.7 Provide the amount of a user's monthly sewer bill that is used toward debt owed on wastewater collection and treatment.
 This may be a percentage or dollar amount.
- Self-explanatory.
- 3. FINANCIAL INFORMATION REQUIRED FROM MUNICIPALITIES Municipalities are to complete.
- 3.1 Full Market Property Value is typically available through your community or state assessor's office.
- 3.2 Debt information is typically available from your community's annual financial statements.
- 3.3 Property tax revenues are typically available from your community's annual financial statements. Property tax rates for Missouri communities can be found in the annual auditor's report:
- 3.4 Property Taxes Levied = (Real Property Assessed Value) * (Property Tax Rate).

 This information is typically available through your community or state assessor's office and your community's annual financial statements. Property tax rates for Missouri communities can be found in the annual auditor's report:
- 3.5 Property tax collection rate = (Property Tax Revenues) + (Property Taxes Levied).
- FINANCIAL INFORMATION REQUIRED FROM SEWER DISTRICTS Sewer Districts and Water Supply Districts are to complete.
- 4.1-4.2 Self-explanatory.
- ADDITIONAL CONSIDERATIONS (ALL FACILITIES) Municipalities, sewer districts, and water supply districts are to complete.
- 5.1-5.2 Self-explanatory.
- 6. CERTIFICATION Provide the name and contact information for the individual who can respond to financial information requests for your community. This form must be signed by your community's "owner" or "authorized representative". The owner for a municipality is either the principal executive officer or ranking elected official.

If there are any questions concerning this form or your Missouri State Operating Permit, contact the Department of Natural Resources, Water Protection Program, Operating Permits Section at 800-361-4827 or 573-751-6825.