

# Missouri Department of Natural Resources



## NOTIFICATION OF PERMIT REMOVAL

Date removed: September 1, 2020

Facility Name: Hunters Ridge Subdivision Wastewater Treatment Facility

Permit Number: MO-0109592

County: Pettis

Facility Description: Flow equalization/ extended aeration/ UV disinfection/ sludge holding tank/ sludge disposal by contact hauler.

Design Flow: 27,000

Actual Flow: 21,000

Reason for removal: The Department has terminated Permit # MO-0109592. This facility is now operating under Missouri State Operating Permit # MO-GD00526. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table C** on Page 6 of 15. This facility is subject to the **WBC-B** limits for *E. coli*.

If you have any questions about this permit please contact Myranda Alford at (573)-526-4029 or by email at [Myranda.Alford@dnr.mo.gov](mailto:Myranda.Alford@dnr.mo.gov).