

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: April 1, 2021

Facility Name: Walnut Grove Park WWTF

Permit Number: MO-0124796

County: St. Francois

Facility Description: Bar screen / extended aeration / chlorination / dechlorination / aerated sludge holding / sludge removed by contract hauler

Design Flow: 14,400 gpd

Actual Flow: 9,000 gpd

Reason for removal: The Department has terminated Permit # MO-0124796. This facility is now operating under Missouri State Operating Permit # MO-GD00560. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table C** on Page 6 of 15. This facility is subject to the **WBC-B** limits for *E. coli*.

If you have any questions about this permit please contact Ashley Keely at (573)-751-7326 or by email at Ashley.Keely@dnr.mo.gov.