

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: September 1, 2021

Facility Name: Oakledge Subdivision WWTF

Permit Number: MO-0125768

County: Camden

Facility Description: Septic Tanks/Recirculating Sand Filter/Chlorination/Dechlorination/Sludge removed by contract hauler

Design Flow: 2,775 gpd

Actual Flow: 800 gpd

Reason for removal: The Department has terminated Permit # MO-0125768. This facility is now operating under Missouri State Operating Permit # MO-GD00594. The Master General Permit template can be found on the Department's website at: <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/wastewater/mogd-non-publically-owned-treatment-works-potw-discharging-50000-gallons-day>.

The applicable table for this facility is **Table D** on Page 7 of 15. This facility is subject to the **WBC-B** limits for *E. coli*.

If you have any questions about this permit please contact Joshua Brown at (573)-526-2415 or by email at joshua.brown@dnr.mo.gov.