

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: May 1, 2021

Facility Name: Lion Point Subdivision Wastewater Treatment Facility

Permit Number: MO-0129160

County: Camden

Facility Description: Septic tanks / recirculating textile filter system /UV disinfection / sludge removed by contract hauler

Design Flow: 3,000 gallons per day

Actual Flow: 400 gallons per day

Reason for removal: The Department has terminated Permit # MO-0129160. This facility is now operating under Missouri State Operating Permit # MO-GD00568. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table D** on Page 7 of 15. This facility is subject to the **WBC-A** limits for *E. coli*.

If you have any questions about this permit please contact Sam Buckler at (573)-526-0827 or by email at sam.buckler@dnr.mo.gov.