

Missouri Department of Natural Resources



NOTIFICATION OF PERMIT REMOVAL

Date removed: September 1, 2020

Facility Name: Living Word United Methodist Church Wastewater Treatment Facility

Permit Number: MO-0131407

County: St. Louis

Facility Description: Septic Tanks / recirculating sand filter / UV disinfection / sludge removed by contract hauler.

Design Flow: 2,200 gpd

Actual Flow: 1,100 gpd

Reason for removal: The Department has terminated Permit # MO-0131407. This facility is now operating under Missouri State Operating Permit # MO-GD00524. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table E** on Page 9 of 15. This facility is subject to the **Losing Stream** limits for *E. coli*.

If you have any questions about this permit please contact Jessica Vitale at (573)-522-2575 or by email at Jessica.Vitale@dnr.mo.gov.