

# Missouri Department of Natural Resources



## NOTIFICATION OF PERMIT REMOVAL

Date removed: January 1, 2022

Facility Name: Myetta Woods Subdivision Wastewater Treatment Facility

Permit Number: MO-0131865

County: Camden

Facility Description: Septic tanks/ recirculating sand filter/ chlorination/ dechlorination/ sludge hauled by contract hauler

Design Flow: 6,200 GPD

Actual Flow: 2,394 GPD

Reason for removal: The Department has terminated Permit # MO-00131865. This facility is now operating under Missouri State Operating Permit # MO-GD00606. The Master General Permit template can be found on the Department's website at: <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/wastewater/mogd-non-publically-owned-treatment-works-potw-discharging-50000-gallons-day>.

The applicable table for this facility is **Table E-1** found on Page 9 of 15. This facility is subject to the **Losing Stream** limits for *E. coli*.

If you have any questions about this permit please contact Lisa Rodgers at (573)-522-2552 or by email at [lisa.rodgers@dnr.mo.gov](mailto:lisa.rodgers@dnr.mo.gov).