

## Missouri Department of Natural Resources



### NOTIFICATION OF PERMIT REMOVAL

Date removed: July 1, 2020

Facility Name: Master Key Place Homeowners Association Wastewater Treatment Facility

Permit Number: MO-0132713

County: Callaway

Facility Description: flow equalization / extended aeration / seasonal chlorination and dechlorination / sludge is removed by a contract hauler.

Design Flow: 20,813 gallons per day

Actual Flow: 7,350 gallons per day

Reason for removal: The Department has terminated Permit # MO-00132713. This facility is now operating under Missouri State Operating Permit # MO-GD00512. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable table for this facility is **Table C** on Page 6 of 15. This facility is subject to the **WBC-B** limits for *E. coli*.

If you have any questions about this permit please contact Sam Buckler at 573-526-0827 or by email at [sam.buckler@dnr.mo.gov](mailto:sam.buckler@dnr.mo.gov)