

# Missouri Department of Natural Resources



## NOTIFICATION OF PERMIT REMOVAL

Date removed: May 1, 2020

Facility Name: Fox Wood Shores WWTF

Permit Number: MO-0133108

County: Stone

Facility Description: Septic tanks / recirculating sand filter / chemical addition to facilitate phosphorus removal / rapid mixing / chlorination / dechlorination / septage disposal by contract hauler

Design Flow: 2,500 gpd

Actual Flow: 720 gpd

Reason for removal: The Department has terminated Permit # MO-0133108. This facility is now operating under Missouri State Operating Permit # MO-GD00485. The Master General Permit template can be found on the Department's website at:

<https://dnr.mo.gov/env/wpp/permits/issued/docs/GD00000.pdf>.

The applicable tables for this facility are **Tables D and D-2** on Page 7 and 8 of 15. This facility is subject to the **WBC-A** limits for *E. coli*.

If you have any questions about this permit please contact Ashley Keely at (573)-751-7326 or by email at [ashley.keely@dnr.mo.gov](mailto:ashley.keely@dnr.mo.gov).