

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

Lori VanLeer
Superintendent
School District of Washington
220 Locust Street
Washington, MO 63090

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

June 19, 2020
Effective Date


Edward B. Galbraith, Director, Division of Environmental Quality

June 18, 2022
Expiration Date


Chris Wieberg, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

A new wastewater treatment plant will be built to serve a new elementary school for the school district of Washington, Missouri. The new site will house a future student base of 600 students and 75 faculty. The proposed wastewater treatment system includes a grease interceptor, bar screen, flow equalization chamber, aeration chamber, clarifiers, MBBR polishing cell, sludge holding chamber, UV disinfection unit, backup generator, etc.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

II. COST ANALYSIS FOR COMPLIANCE

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to make a “finding of affordability”. Per Section 644.145.3, a “finding of affordability” is a statement as to whether or not an individual or household would be required to make unreasonable sacrifices in order to make the projected monthly payments for sewer services. While this facility is a publicly-owned treatment works, the permittee accomplishes capital improvements through an established budget for operation and maintenance and not through the issuance of utility bills to customers for sewer services. Because of this, the Department cannot determine the “affordability” of the new permit requirements.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.
2. All construction shall be consistent with plans and specifications signed and sealed by Jeffery Huck, P.E., of the Gonzalez Companies, LLC, and as described in this permit.

3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).
4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's St. Louis Regional Office per 10 CSR 20-7.015(9)(G).
5. The wastewater treatment facility shall be located at least fifty feet (50') from any dwelling or establishment.
6. The wastewater treatment facility shall be located above the twenty-five (25)-year flood level.
7. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
8. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at dnr.mo.gov/env/wpp/epermit/help.htm. See dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.
9. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See dnr.mo.gov/env/wpp/401/ for more information.
10. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.
 - Flood protection shall apply to new construction and to existing facilities undergoing major modification. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation. 10 CSR 20-8.140 (2) (B)

- Unless another distance is determined by the Missouri Geological Survey or by the Department's Public Drinking Water Branch, the minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300'). 10 CSR 20-8.140 (2) (C) 1.
- No treatment unit with a capacity of twenty-two thousand five hundred gallons per day (22,500 gpd) or less shall be located closer than the minimum distance of 200' to a neighboring residence and 50' to property line for lagoons; 200' to a neighboring residence for open recirculating media filters following primary treatment; and 50' to a neighboring residence for all other discharging facilities. See 10 CSR 20-2.010(68) for the definition of a residence. 10 CSR 20-8.140 (2) (C) 2
- Facilities shall be readily accessible by authorized personnel from a public right-of-way at all times. 10 CSR 20-8.140 (2) (D)
- The alarm shall be activated in cases of high water levels. Follow the provisions in subsection (7)(C) of this rule for alarm systems. 10 CSR 20-8.140 (4) (D)
- The outfall shall be so constructed and protected against the effects of flood water, ice, or other hazards as to reasonably ensure its structural stability and freedom from stoppage. 10 CSR 20-8.140 (6) (A)
- All sampling points shall be designed so that a representative and discrete twenty-four (24) hour automatic composite sample or grab sample of the effluent discharge can be obtained at a point after the final treatment process and before discharge to or mixing with the receiving waters. 10 CSR 20-8.140 (6) (B)
- All outfalls shall be posted with a permanent sign indicating the outfall number (i.e., Outfall #001). 10 CSR 20-8.140 (6) (C)
- All wastewater treatment facilities shall be provided with an alternate source of electric power or pumping capability to allow continuity of operation during power failures. 10 CSR 20-8.140 (7) (A) 1.
- Disinfection and dechlorination, when used, shall be provided during all power outages. 10 CSR 20-8.140 (7) (A) 2.
- An audiovisual alarm or a more advanced alert system, with a self-contained power supply, capable of monitoring the condition of equipment whose failure could result in a violation of the operating permit, shall be provided for all wastewater treatment facilities. 10 CSR 20-8.140 (7) (C)
- No piping or other connections shall exist in any part of the wastewater treatment facility that might cause the contamination of a potable water supply. 10 CSR 20-8.140 (7) (D) 1.
- Where a potable water supply is to be used for any purpose in a wastewater treatment facility other than direct connections, a break tank, pressure pump, and pressure tank or a

reduced pressure backflow preventer consistent with the department's Public Drinking Water Branch shall be provided. 10 CSR 20-8.140 (7) (D) 3. A.

- For indirect connections, a sign shall be permanently posted at every hose bib, faucet, hydrant, or sill cock located on the water system beyond the break tank or backflow preventer to indicate that the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 3. B.
- Where a separate non-potable water supply is to be provided, a break tank will not be necessary, but all system outlets shall be posted with a permanent sign indicating the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 4.
- A means of flow measurement shall be provided at all wastewater treatment facilities. 10 CSR 20-8.140 (7) (E)
- Effluent twenty-four (24) hour composite automatic sampling equipment shall be provided at all mechanical wastewater treatment facilities and at other facilities where necessary under provisions of the operating permit. 10 CSR 20-8.140 (7) (F)
- Adequate provisions shall be made to effectively protect facility personnel and visitors from hazards. The following shall be provided to fulfill the particular needs of each wastewater treatment facility:
 - Fencing. Enclose the facility site with a fence designed to discourage the entrance of unauthorized persons and animals; 10 CSR 20-8.140 (8) (A)
 - Gratings over appropriate areas of treatment units where access for maintenance is necessary; 10 CSR 20-8.140 (8) (B)
 - First aid equipment; 10 CSR 20-8.140 (8) (C)
 - Posted "No Smoking" signs in hazardous areas; 10 CSR 20-8.140 (8) (D)
 - Appropriate personal protective equipment (PPE); 10 CSR 20-8.140 (8) (E)
 - Portable blower and hose sufficient to ventilate accessed confined spaces; 10 CSR 20-8.140 (8) (F)
 - 10 CSR 20-8.140 (8) (G) Portable lighting equipment complying with NEC requirements. See subsection (7)(B) of this rule;
 - 10 CSR 20-8.140 (8) (H) Gas detectors listed and labeled for use in NEC Class I, Division 1, Group D locations. See subsection (7)(B) of this rule;
 - Appropriately-placed warning signs for slippery areas, non-potable water fixtures (see subparagraph (7)(D)3.B. of this rule), low head clearance areas, open service manholes, hazardous chemical storage areas, flammable fuel storage areas, high noise areas, etc.; 10 CSR 20-8.140 (8) (I)
 - Explosion-proof electrical equipment, non-sparking tools, gas detectors, and similar devices, in work areas where hazardous conditions may exist, such as digester vaults and other locations where potentially explosive atmospheres of flammable gas or vapor with air may accumulate. 10 CSR 20-8.140 (8) (K)
 - Provisions for local lockout/tagout on stop motor controls and other devices; 10 CSR 20-8.140 (8) (L)
 - Provisions for an arc flash hazard analysis and determination of the flash protection boundary distance and type of PPE to reduce exposure to major electrical hazards shall be in accordance with NFPA 70E *Standard for Electrical*

Safety in the Workplace (2018 Edition), as approved and published August 21, 2017. 10 CSR 20-8.140 (8) (M)

- The materials utilized for storage, piping, valves, pumping, metering, and splash guards, etc., for chemical handling, shall be specially selected considering the physical and chemical characteristics of each hazardous or corrosive chemical. 10 CSR 20-8.140 (9) (A) 1.
- All pumps or feeders for hazardous or corrosive chemicals shall have guards that will effectively prevent spray of chemicals into space occupied by facility personnel. 10 CSR 20-8.140 (9) (A) 3.
- Piping, labeling, and coupling guard locations. 10 CSR 20-8.140 (9) (A) 4.
- All piping containing or transporting corrosive or hazardous chemicals shall be identified with labels every ten feet (10') and with at least two (2) labels in each room, closet, or pipe chase. 10 CSR 20-8.140 (9) (A) 4. A.
- All connections (flanged or other type), except those adjacent to storage or feeder areas, shall have guards that will direct any leakage away from space occupied by facility personnel. 10 CSR 20-8.140 (9) (A) 4. B.
- Facilities shall be provided for automatic shutdown of pumps and sounding of alarms when failure occurs in a pressurized chemical discharge line. 10 CSR 20-8.140 (9) (A) 5.
- All wastewater treatment facilities must have a screening device, comminutor, or septic tank for the purpose of removing debris and nuisance materials from the influent wastewater. 10 CSR 20-8.150 (2)
- Grease interceptors shall be provided on kitchen drain lines from institutions, hospitals, hotels, restaurants, schools, bars, cafeterias, clubs, and other establishments from which relatively large amounts of grease may be discharged to a wastewater treatment facility owned by the grease producing entity. Grease interceptors are typically constructed from fiberglass reinforced polyester, high density polyethylene (HDPE), or concrete. For corrugated HDPE grease interceptors, follow ASTM F2649 – 14 *Standard Specification for Corrugated High Density Polyethylene (HDPE) Grease Interceptor Tanks*, as approved and published September 1, 2014. For precast concrete grease interceptor tanks, follow ASTM C1613 – 17 *Standard Specification for Precast Concrete Grease Interceptor Tanks*, as approved and published September 1, 2017. 10 CSR 20-8.150 (3)
- All screening devices and screening storage areas shall be protected from freezing. 10 CSR 20-8.150 (4) (A) 1.
- Provisions shall be made for isolating or removing screening devices from their location for servicing. 10 CSR 20-8.150 (4) (A) 2.

- Manually cleaned screen channels shall be protected by guard railings and deck gratings with adequate provisions for removal or opening to facilitate raking. 10 CSR 20-8.150 (4) (A) 3. A. (I)
- Effective flow splitting devices and control appurtenances (*e.g.* gates and splitter boxes) shall be provided to permit proper proportioning of flow and solids loading to each settling unit, throughout the expected range of flows. 10 CSR 20-8.160 (2) (B)
- Overflow weirs shall be readily adjustable over the life of the structure to correct for differential settlement of the tank. 10 CSR 20-8.160 (3) (C) 1.
- Walls of settling tanks shall extend at least six inches (6") above the surrounding ground surface and shall provide not less than twelve inches (12") of freeboard. 10 CSR 20-8.160 (3) (E)
- Safety features shall appropriately include machinery covers, life lines, handrails on all stairways and walkways, and slip resistant surfaces. For additional safety follow the provisions listed in 10 CSR 20-8.140(8). 10 CSR 20-8.160 (5) (A)
- The design shall provide for convenient and safe access to routine maintenance items such as gear boxes, scum removal mechanism, baffles, weirs, inlet stilling baffle areas, and effluent channels. 10 CSR 20-8.160 (5) (B)
- For electrical equipment, fixtures, and controls in enclosed settling basins and scum tanks, where hazardous concentrations of flammable gases or vapors may accumulate, follow the provisions in 10 CSR 20-8.140(7)(B). The fixtures and controls shall be conveniently located and safely accessible for operation and maintenance. 10 CSR 20-8.160 (5) (C)
- The UV dosage shall be based on the design peak hourly flow, maximum rate of pumpage, or peak batch flow. 10 CSR 20-8.190 (5) (A) 1.
- The UV system shall deliver the target dosage based on equipment derating factors and, if needed, have the UV equipment manufacturer verify that the scale up or scale down factor utilized in the design is appropriate for the specific application under consideration. 10 CSR 20-8.190 (5) (A) 3.
- Closed vessel UV systems. The combination of the total number of closed vessels shall be capable of treating the design peak hourly flow, maximum rate of pumpage, or peak batch flow. 10 CSR 20-8.190 (5) (B) 2.
- Closed vessel UV systems utilizing medium-pressure lamps shall be provided with an automatic cleaning system in order to prevent algae growth. 10 CSR 20-8.190 (5) (B) 3.

- The UV system must continuously monitor and display at the UV system control panel the following minimum conditions:
 - The relative intensity of each bank or closed vessel system; 10 CSR 20-8.190 (5) (C) 1. A.
 - The operational status and condition of each bank or closed vessel system; 10 CSR 20-8.190 (5) (C) 1. B.
 - The ON/OFF status of each lamp in the system; 10 CSR 20-8.190 (5) (C) 1. C. and
 - The total number of operating hours of each bank or each closed vessel system. 10 CSR 20-8.190 (5) (C) 1. D.
- The UV system shall include an alarm system. Alarm systems shall comply with 10 CSR 20-8.140(7)(C). 10 CSR 20-8.190 (5) (C) 2.

11. Upon completion of construction:

- A. The Franklin County Public Water District # 3 will become the continuing authority for operation and maintenance of these facilities;
- B. Submit an electronic copy of the as built if the project was not constructed in accordance with previously submitted plans and specifications;
- C. Submit the eDMR permit Holder and Certifier Registration, Form--MO 780-2204 to comply with your operating permit;
- D. Submit the enclosed form Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and request issuing the draft operating permit public noticed between May 20, 2020 to June 19, 2020.

IV. REVIEW SUMMARY

1. CONSTRUCTION PURPOSE

A new wastewater treatment plant will be built to serve a new school for the School District of Washington, Missouri. The new site will house a future student base of 600 students and 75 faculty.

2. FACILITY DESCRIPTION

The proposed wastewater treatment system includes bar screen, flow equalization chamber, aeration chamber, clarifiers, MBBR polishing cells, sludge holding chamber, UV disinfection unit, backup generator, etc.

The South Point Elementary WWTF is located at 100 St. Johns Road, Washington, in Franklin County, Missouri. The facility has a design average flow of 10,000 gpd and serves a hydraulic population equivalent of approximately 675 people.

3. COMPLIANCE PARAMETERS

The proposed project is required to meet final effluent limits as established in the Antidegradation review dated February 2020.

The limits following the completion of construction will be applicable to the facility:

Parameter	Units	Monthly average limit
Biochemical Oxygen Demand ₅	mg/L	10
Total Suspended Solids	mg/L	10
Ammonia as N-summer	mg/L	0.6
Ammonia as N-winter	mg/L	2.1
pH	SU	6.5-9.0
Oil & Grease	mg/L	10
E. Coli	#/100mL	126

4. ANTIDEGRADATION

The Department has reviewed the antidegradation report for this facility and issued the Water Quality and Antidegradation Review dated February 2020 due to a new discharge.

5. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

The proposed new wastewater treatment plant construction will cover the following items:

- Grease interceptor - A grease interceptor (Schier GB-250) is utilized to intercept and collect grease from raw wastewater and prevents grease from clogging downstream components with an actual effective volume of 500 gallons; with a rated capacity of 100 gpm.
- Bar Screen - The manual bar screen will have clear bar spacing of 3/8-inch and be positioned at an angle of 27 degrees from the horizontal to allow for manual raking of the screen.
- Flow Equalization – A flow equalization chamber with a volume of 6,460 gallon (6’x12’x12’) will be provided. The aeration chamber blowers will supply air to the 6 fine bubble diffusers with a capacity of 1 scfm per diffuser. The flow equalization chamber has a gravity overflow to the aeration chamber.
- Aeration Chambers – Two 6 ft x 12 ft x 12 ft sidewater depth aeration chambers operating in series by means of a transfer pipe with a total volume

of 1,728 ft³ will be provided. Aeration by means of duplex 5 hp blowers capable of supplying 124 scfm to 6 fine bubble diffusers per chamber with a capacity of 10.33 scfm per diffuser. The aeration chambers are designed for an average daily loading of 61.5 lbs BOD₅. A transfer pipe and elbow allows wastewater from the second aeration chamber to move by gravity to the clarifier.

- Final Clarifiers – The two hopper type clarifiers (6'x 6') will have a settling volume of 3,531 gallons and a detention time of 8.5 hours with a settling rate of 140 gpd/ft². An airlift surface skimmer is provided to remove grease and floatables and move to the sludge holding chamber. An adjustable v-notch weir provides 11 lf of skimming for 910 gallons per liner feet per day. The clarified effluent will flow by gravity to the MBBR polishing cell. An airlift pump will be provided to move settled sludge from the dual square hopper bottoms to the sludge holding chamber or return to the aeration chamber as return activated sludge.
- Sludge Holding Chamber – The sludge holding chamber (6'x12'x12') will have a volume of 6,463 gallons. The aeration chamber blowers will supply air to the 6 fine bubble diffusers with a capacity of 1 scfm per diffuser. Sludge removal shall be by contract hauler.
- MBBR Polishing cell - The clarifiers' effluent will flow by gravity to the NitrOx™ system. The NitrOx™ system is capable of treating a design average flow of 10,000 gpd. The system is composed of one tank with approximately 7 ft x 7 ft x 11 ft with a sidewater depth of 8 ft. Total volume of the tanks is 2,932 gallons. The design flow hydraulic retention time is 7.0 hours and the peak flow hydraulic retention time is 4.7 hours. A floating insulating cover shall be installed in the tank. An immersion tank heater will be installed to maintain a minimum wastewater temperature of 5°C. The tank shall be filled approximately 32% with high surface area HDPE media. Aeration by means of two tri-lobe positive displacement blowers each capable of supplying 33 scfm with 1.5 HP motors. The effluent from the NitrOx™ will flow by gravity to a effluent lift station prior to disinfection and discharge.
- Effluent Lift Station - Duplex effluent pump station which will pump 0.058 MGD (20 gpm per pump) at 62 ft TDH through two (2) submersible non-clog VFD firm pumps. All pumps running simultaneously will be capable of pumping 0.058 MGD, which is in excess of the 0.04 MGD peak effluent flow. The pump station will transfer effluent from the MBBR polishing cells into UV disinfection system.
- UV Disinfection - A closed vessel (Enaqua M3-U8M), gravity flow, low pressure high intensity UV disinfection system capable of treating a peak flow of 100,800 gpd while delivering a minimum UV intensity of 30 mJ/cm² with

an expected ultraviolet transmissivity of 65% or greater. The closed vessel UV system consists of 8 lamps per reactor. The disinfected effluent will flow by gravity through flow measurement equipment to Outfall No. 001.

- Emergency Power – A 50 kW standby diesel generator and automatic transfer switch will be provided to operate the treatment facility in event of power failure.

6. OPERATING PERMIT


After completion of the construction project, submit the Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N), as-builts if the project was not constructed in accordance with previously submitted plans and specifications, and request the public noticed draft operating permit MO-0139491 to be issued.

V. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

Lei Hou, PE
Engineering Section
lei.hou@dnr.mo.gov



MISSOURI DEPARTMENT OF NATURAL RESOURCES **RECEIVED**
 WATER PROTECTION PROGRAM
APPLICATION FOR CONSTRUCTION PERMIT – 19 2020
WASTEWATER TREATMENT FACILITY

Water Protection Program

FOR DEPARTMENT USE ONLY	
APP NO. AP34474	CP NO. CP0002129
FEE RECEIVED \$1000.00	CHECK NO. 3027
DATE RECEIVED 2-19-20	

APPLICATION OVERVIEW

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. **All applicants must complete Part A.** Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. **Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.**

PART A – BASIC INFORMATION

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?
 YES Date of Approval: 2/5/2020 N/A
- 1.3 Has the department approved the proposed project's facility plan*?
 YES Date of Approval: _____ NO (If No, complete No. 1.4.)
- 1.4 [Complete only if answered No on No. 1.3.] Is a copy of the facility plan* for wastewater treatment facilities included with this application?
 YES NO Exempt because _____
- 1.5 Is a copy of the appropriate plans* and specifications* included with this application?
 YES Denote which form is submitted: Hard copy Electronic copy (See instructions.) NO
- 1.6 Is a summary of design* included with this application? YES NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?
 YES Date of submittal: A form will be submitted at a later date.
 Enclosed is the appropriate operating permit application and fee submittal. Denote which form: A B B2
 N/A: However, In the event the department believes that my operating permit requires revision to permit limitation such as changing equivalent to secondary limits to secondary limits or adding total residual chlorine limits, please share a draft copy prior to public notice? YES NO
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency? YES NO
- 1.9 Is the appropriate fee or JetPay confirmation included with this application? YES NO
 See Section 7.0

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT SDOW South Point Elementary WWTP	2.2 ESTIMATED PROJECT CONSTRUCTION COST \$ 600,000
---	---

2.3 PROJECT DESCRIPTION
New 10,000 gpd facility for a new elementary school.

2.4 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION
on site digester, wasted sludge will be hauled to a licensed facility

2.5 DESIGN INFORMATION
 A. Current population: _____; Design population: 675
 B. Actual Flow: _____ gpd; Design Average Flow: 10,000 gpd;
 Actual Peak Daily Flow: _____ gpd; Design Maximum Daily Flow: 15,000 gpd; Design Wet Weather Event: _____

2.6 ADDITIONAL INFORMATION
 A. Is a topographic map attached? YES NO
 B. Is a process flow diagram attached? YES NO

3.0 WASTEWATER TREATMENT FACILITY

NAME SDLW Southpoint Elementary WWTP		TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
ADDRESS (PHYSICAL) TBD-100 St.John's Rd	CITY Washington	STATE MO	ZIP CODE 63090	COUNTY Franklin
Wastewater Treatment Facility: Mo- (Outfall Of)				
3.1 Legal Description: _____ ¼, _____ ¼, _____ ¼, Sec. _____, T _____, R _____ (Use additional pages if construction of more than one outfall is proposed.) Part of the United States Survey No.1931, Township 44 North, Range 1 West of 5th P.M.				
3.2 UTM Coordinates Easting (X): <u>693681</u> Northing (Y): <u>981925</u> For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)				
3.3 Name of receiving streams: <u>unnamed tributary to Brown's Branch</u>				

4.0 PROJECT OWNER

NAME School District of Washington		TELEPHONE NUMBER WITH AREA CODE 636-231-2000	E-MAIL ADDRESS jhuck@gonzalezcos.com	
ADDRESS 220 Locust Street	CITY Washington	STATE MO	ZIP CODE 63090	

5.0 CONTINUING AUTHORITY: A continuing authority is a company, business, entity or person(s) that will be operating the facility and/or ensuring compliance with the permit requirements.

NAME PWSD 3 of Franklin County		TELEPHONE NUMBER WITH AREA CODE 636-742-5200	E-MAIL ADDRESS bobh@alliancewater.com	
ADDRESS PO Box 160	CITY Villa Ridge	STATE MO	ZIP CODE 63089	

5.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO N/A

5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY.

A. Is a copy of the certificate of convenience and necessity included with this application? YES NO

5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION.


A. Is a copy of the as-filed restrictions and covenants included with this application? YES NOB. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application? YES NOC. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application? YES NOD. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application? YES NO**6.0 ENGINEER**

ENGINEER NAME / COMPANY NAME Jeffrey Huck / Gonzalez Companies, LLC		TELEPHONE NUMBER WITH AREA CODE 314-961-1888	E-MAIL ADDRESS jhuck@gonzalezcos.com	
ADDRESS 1750 S Brentwood Blvd., Suite 700	CITY St. Louis	STATE MO	ZIP CODE 63144	

7.0 APPLICATION FEE CHECK NUMBER JETPAY CONFIRMATION NUMBER

8.0 PROJECT OWNER: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PROJECT OWNER SIGNATURE



PRINTED NAME Lori VanLeer		DATE 2-5-20
TITLE OR CORPORATE POSITION Superintendent	TELEPHONE NUMBER WITH AREA CODE 636.231.2000	E-MAIL ADDRESS lori.vanleer@washington.k12.mo.us

Mail completed copy to:
 MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
 P.O. BOX 176
 JEFFERSON CITY, MO 65102-0176

END OF PART A.**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE.**