STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

William Patterson Owner Sippican LLC P.O. Box 2047 Cashiers, NC 28717

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

September 29, 2020 Effective Date

Edward B. Galbraith, Director, Division of Environmental Quality

September 28, 2022

Expiration Date

Chris Wieberg, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

The scope of work comprises the construction of septic tanks, a preanoxic tank, a recirculation tank, one recirculating sand filter, a polishing filter with recirculation tank, chlorinator, chlorine contact tank, dechlorinator, sampling port, and outfall, and refurbishing two recirculating sand filters.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

II. COST ANALYSIS FOR COMPLIANCE

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to complete a cost analysis for compliance because the facility is not a combined or separate sanitary sewer system for a publically-owned treatment works.

Cost Analysis for Compliance - The Department has made a reasonable search for empirical data indicating the permit is affordable. The search consisted of a review of Department records that might contain economic data on the community, a review of information provided by the applicant as part of the application, and public comments received in response to public notices of this draft permit. If the empirical cost data was used by the permit writer, this data may consist of median household income, any other ongoing projects that the Department has knowledge, and other demographic financial information that the community provided as contemplated by Section 644. 145.3.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.

- 2. All construction shall be consistent with plans and specifications signed and sealed by Lake Professional Engineering and as described in this permit.
- 3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).
- 4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Southwest Regional Office per 10 CSR 20-7.015(9)(G).
- 5. The wastewater treatment facility shall be located at least two hundred feet (200') from any dwelling or establishment.
- 6. The wastewater treatment facility shall be located above the twenty-five (25)-year flood level.
- 7. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
- 8. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at <u>dnr.mo.gov/env/wpp/epermit/help.htm</u>. See <u>dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm</u> for more information.
- 9. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See <u>dnr.mo.gov/env/wpp/401/</u> for more information.
- 10. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.
 - Flood protection shall apply to new construction and to existing facilities undergoing major modification. The wastewater facility structures, electrical equipment, and

mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation. 10 CSR 20-8.140 (2) (B)

- The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300'). 10 CSR 20-8.140 (2) (C) 1.
- No treatment unit with a capacity of twenty-two thousand five hundred gallons per day (22,500 gpd) or less shall be located closer than the minimum distance of 200' to a neighboring residence and 50' to property line for lagoons; 200' to a neighboring residence for open recirculating media filters following primary treatment; and 50' to a neighboring residence for all other discharging facilities. See 10 CSR 20-2.010(68) for the definition of a residence. 10 CSR 20-8.140 (2) (C) 2
- Facilities shall be readily accessible by authorized personnel from a public right–ofway at all times. 10 CSR 20-8.140 (2) (D)
- The alarm shall be activated in cases of high water levels. Follow the provisions in subsection (7)(C) of this rule for alarm systems. 10 CSR 20-8.140 (4) (D)
- The outfall shall be so constructed and protected against the effects of flood water, ice, or other hazards as to reasonably ensure its structural stability and freedom from stoppage. 10 CSR 20-8.140 (6) (A)
- All sampling points shall be designed so that a representative and discrete twenty-four (24) hour automatic composite sample or grab sample of the effluent discharge can be obtained at a point after the final treatment process and before discharge to or mixing with the receiving waters. 10 CSR 20-8.140 (6) (B)
- All outfalls shall be posted with a permanent sign indicating the outfall number (i.e., Outfall #001). 10 CSR 20-8.140 (6) (C)
- All wastewater treatment facilities shall be provided with an alternate source of electric power or pumping capability to allow continuity of operation during power failures. 10 CSR 20-8.140 (7) (A) 1.
- Disinfection and dechlorination, when used, shall be provided during all power outages. 10 CSR 20-8.140 (7) (A) 2.
- An audiovisual alarm or a more advanced alert system, with a self-contained power supply, capable of monitoring the condition of equipment whose failure could result in a violation of the operating permit, shall be provided for all wastewater treatment facilities. 10 CSR 20-8.140 (7) (C)
- No piping or other connections shall exist in any part of the wastewater treatment facility that might cause the contamination of a potable water supply. 10 CSR 20-8.140 (7) (D) 1.

- A means of flow measurement shall be provided at all wastewater treatment facilities. 10 CSR 20-8.140 (7) (E)
- Adequate provisions shall be made to effectively protect facility personnel and visitors from hazards. The following shall be provided to fulfill the particular needs of each wastewater treatment facility:
 - Fencing. Enclose the facility site with a fence designed to discourage the entrance of unauthorized persons and animals; 10 CSR 20-8.140 (8) (A)
 - Gratings over appropriate areas of treatment units where access for maintenance is necessary; 10 CSR 20-8.140 (8) (B)
 - First aid equipment; 10 CSR 20-8.140 (8) (C)
 - Posted "No Smoking" signs in hazardous areas; 10 CSR 20-8.140 (8) (D)
 - Appropriate personal protective equipment (PPE); 10 CSR 20-8.140 (8) (E)
 - Portable blower and hose sufficient to ventilate accessed confined spaces; 10 CSR 20-8.140 (8) (F)
 - 10 CSR 20-8.140 (8) (G) Portable lighting equipment complying with NEC requirements. See subsection (7)(B) of this rule;
 - 10 CSR 20-8.140 (8) (H) Gas detectors listed and labeled for use in NEC Class I, Division 1, Group D locations. See subsection (7)(B) of this rule;
 - Appropriately-placed warning signs for slippery areas, non-potable water fixtures (see subparagraph (7)(D)3.B. of this rule), low head clearance areas, open service manholes, hazardous chemical storage areas, flammable fuel storage areas, high noise areas, etc.; 10 CSR 20-8.140 (8) (I)
 - Ventilation shall include the following:
 - Isolate all pumping stations and wastewater treatment components installed in a building where other equipment or offices are located from the rest of the building by an air-tight partition, provide separate outside entrances, and provide separate and independent fresh air supply; 10 CSR 20-8.140 (8) (J) 1.
 - Force fresh air into enclosed screening device areas or open pits more than four feet (4') deep. 10 CSR 20-8.140 (8) (J) 2.
 - Dampers are not to be used on exhaust or fresh air ducts. Avoid the use of fine screens or other obstructions on exhaust or fresh air ducts to prevent clogging; 10 CSR 20-8.140 (8) (J) 3.
 - Where continuous ventilation is needed (e.g., housed facilities), provide at least twelve (12) complete air changes per hour. Where continuous ventilation would cause excessive heat loss, provide intermittent ventilation of at least thirty (30) complete air changes per hour when facility personnel enter the area. Base air change demands on one hundred percent (100%) fresh air; 10 CSR 20-8.140 (8) (J) 4.
 - Electrical controls. Mark and conveniently locate switches for operation of ventilation equipment outside of the wet well or building. Interconnect all intermittently operated ventilation equipment with the respective wet well, dry well, or building lighting system. The manual lighting/ventilation switch is expected to override the automatic controls. For a two (2) speed ventilation system with automatic switch over where gas detection equipment is installed, increase the ventilation rate automatically in

response to the detection of hazardous concentrations of gases or vapors; 10 CSR 20-8.140 (8) (J) 5.

- Fabricate the fan wheel from non-sparking material. Provide automatic heating and dehumidification equipment in all dry wells and buildings. 10 CSR 20-8.140 (8) (J) 6.
- Explosion-proof electrical equipment, non-sparking tools, gas detectors, and similar devices, in work areas where hazardous conditions may exist, such as digester vaults and other locations where potentially explosive atmospheres of flammable gas or vapor with air may accumulate. 10 CSR 20-8.140 (8) (K)
- Provisions for local lockout/tagout on stop motor controls and other devices; 10 CSR 20-8.140 (8) (L)
- Provisions for an arc flash hazard analysis and determination of the flash protection boundary distance and type of PPE to reduce exposure to major electrical hazards shall be in accordance with NFPA 70E *Standard for Electrical Safety in the Workplace* (2018 Edition), as approved and published August 21, 2017. 10 CSR 20-8.140 (8) (M)
- The materials utilized for storage, piping, valves, pumping, metering, and splash guards, etc., for chemical handling, shall be specially selected considering the physical and chemical characteristics of each hazardous or corrosive chemical. 10 CSR 20-8.140 (9) (A) 1.
- All wastewater treatment facilities must have a screening device, comminutor, or septic tank for the purpose of removing debris and nuisance materials from the influent wastewater. 10 CSR 20-8.150 (2)
- A septic tank must have a minimum capacity of at least one thousand (1,000) gallons. 10 CSR 20-8.180 (2) (A)
- The septic tank shall be baffled. 10 CSR 20-8.180 (2) (B)
- Recirculating media filters with a capacity of twenty-two thousand five hundred gallons per day (22,500 gpd) or less shall be located closer than the minimum distance of 200' to a neighboring residence and 50' to property line for lagoons; 200' to a neighboring residence for open recirculating media filters following primary treatment; and 50' to a neighboring residence for all other discharging facilities. See 10 CSR 20-2.010(68) for the definition of a residence. 10 CSR 20-8.180 (3) (A)
- A minimum of two (2) recirculating media filter beds and a diversion box are required for all design flows. 10 CSR 20-8.180 (3) (B)
- Dosing. Both timer and float switch controls are required; timers are the primary method of operation and the float switch control is a back-up. 10 CSR 20-8.180 (3) (C)
- The media is any of a number of physical structures whose sole purpose is to provide a surface to support biological growth. Commonly used media includes rock, gravel, and sand of various sizes, textile media, and peat. Finely crushed limestone, dolomite, slag,

any clay, limestone, or appreciable amounts of organic material is not acceptable. 10 CSR 20-8.180 (3) (E)

- Manufactured and synthetic trickling filter media material shall-
 - Be used in accordance with all manufacturer's recommendations; 10 CSR 20-8.180 (4) (B) 3. A.
 - Be insoluble in wastewater and resistant to flaking, spalling, ultraviolet degradation, disintegration, erosion, aging, common acids and alkalis, organic compounds, and biological attack; 10 CSR 20-8.180 (4) (B) 3. B.
 - Be evaluated to determine the suitability based on experience with an installation treating wastewater under similar hydraulic and organic loading conditions (include a relevant case history involving the use of the synthetic media); 10 CSR 20-8.180 (4) (B) 3. C.
 - Have a structure able to support the synthetic media, water flowing through or trapped in voids, and the maximum anticipated thickness of the wetted biofilm; 10 CSR 20-8.180 (4) (B) 3. D.
 - Support the maintenance activities, unless a separate provision is made for maintenance access to the entire top of the trickling filter media and to the distributor; 10 CSR 20-8.180 (4) (B) 3. E. and
 - Be placed with the edges matched as nearly as possible to provide consistent hydraulic conditions within the trickling filter. 10 CSR 20-8.180 (4) (B) 3. F.
- Emergency Power. Disinfection and dechlorination processes, when used, shall be provided during all power outages. 10 CSR 20-8.190 (2) (A)
- The materials utilized for storage, piping, valves, pumping, metering, and splash guards, etc., for chemical handling, shall be specially selected considering the physical and chemical characteristics of each hazardous or corrosive chemical. 10 CSR 20-8.140 (9) (A) 1.
- Alarm System for chlorination and dechlorination systems. The applicant shall conform to 10 CSR 20-8.140(7)(C) and be responsible for specifying what the alarm requirements are necessary to assure consistent disinfection in compliance with the applicable bacteria limits and the disinfection residual limit in the effluent. 10 CSR 20-8.190 (3) (C)
- Effluent twenty-four (24) hour composite automatic sampling equipment shall be provided at all mechanical wastewater treatment facilities and at other facilities where necessary under provisions of the operating permit. 10 CSR 20-8.190 (3) (D)
- Solid dechlorination systems shall not be located in the chlorine contact tank. 10 CSR 20-8.190 (4) (B) 1.
- Contact time. A minimum of thirty (30) seconds for mixing and contact time of dechlorination systems shall be provided at the design peak hourly flow or maximum rate of pumpage. 10 CSR 20-8.190 (4) (B) 2.

- The media for cloth/disc filters shall:
 - Follow the manufacturer's recommendations; 10 CSR 20-8.210 (3) (E) 1. B. and
 - Be chemical-resistant if the filter will be exposed to chemicals, such as chlorine or disinfectants. 10 CSR 20-8.210 (3) (E) 1. C.
- Filtration Rates and Hydraulics for cloth/disc filters shall be able to treat the design flow rate with one (1) filter unit in backwash mode. 10 CSR 20-8.210 (3) (E) 2. B.
- 11. Upon completion of construction:
 - A. L. Horizons Homeowners, Inc. will become the continuing authority for operation and maintenance of these facilities;
 - B. Submit an electronic copy of the as builts if the project was not constructed in accordance with previously submitted plans and specifications;
 - C. Submit the eDMR permit Holder and Certifier Registration, Form--MO 780-2204 to comply with your operating permit; and
 - D. Submit the enclosed form Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and submit a Form B Application for an Operating Permit for Domestic or Municipal Wastewater (≤100,000 gallons per day) and fee of \$300 to the Engineering Section of the Water Protection Program 60 days prior to operation. Identify that the application is for a General Permit for Discharging Less Than or Equal to 50,000 GPD of Domestic Wastewater, MO-GD00000.

IV. REVIEW SUMMARY

1. CONSTRUCTION PURPOSE

The Lake Horizons WWTF is being constructed to treat domestic wastewater from a residential subdivision in Gravois Mills, MO. The Lake Horizons WWTF will treat approximately 6,600 gpd and a 89 PE and will discharge to the Lake of the Ozarks.

2. FACILITY DESCRIPTION

The Lake Horizons WWTF is located at Lake Horizons Road, Gravois Mills, in Camden County, Missouri. The facility has a design average flow of 6,600 gpd and serves an organic population equivalent of approximately 89 people. The scope of work comprises the construction of septic tanks, a preanoxic tank, a recirculation tank, one recirculating sand filter, a polishing filter with recirculation tank, chlorinator, chlorine contact tank, dechlorinator, sampling port, and outfall. Two existing recirculating sand filters at the site will be refurbished for the Lake Horizons WWTF.

Permit No. CP0002132

3. <u>COMPLIANCE PARAMETERS</u>

The proposed project is required to meet the requirements of MOGD - New Table E-1 with an expiration date of June 30, 2024. The facility will be required to meet the effluent limits identified in the following table.

Parameter	Units	Daily Maximum	Weekly Average	Monthly Average	BASIS FOR LIMIT (NOTE 1)	Monitoring Frequency
FLOW	GPD	*		*	FSR	ONCE/QUARTER
BIOCHEMICAL OXYGEN DEMAND5 **	MG/L		15	10	PEL	ONCE/QUARTER
TOTAL SUSPENDED SOLIDS **	MG/L		20	15	PEL	ONCE/QUARTER
ΡΗ	SU	6.5–9.0		6.5–9.0	FSR	ONCE/QUARTER
Ammonia as N (Apr 1 – Sept 30)	MG/L	3.6		1.4	PEL	ONCE/QUARTER
Ammonia as N (Oct 1 – Mar 31)	MG/L	7.5		2.9	PEL	ONCE/QUARTER
TOTAL RESIDUAL CHLORINE (NOTE 3)	μG/L	17 (<130)		8 (<130)	FSR	ONCE/QUARTER
DISSOLVED OXYGEN (NOTE 3)	MG/L	*		*	FSR	ONCE/QUARTER
TOTAL PHOSPHORUS (NOTE 2)	MG/L	*		0.5	FSR	ONCE/QUARTER
ESCHERICHIA COLIFORM (E. COLI)	#/ 100мL	630)***	126	FSR	ONCE/QUARTER

Lake Horizons MOGD - New Effluent Limits Table E-1 – Outfalls to Lakes

* Monitoring requirements only.

** Publicly owned treatment works will be required to meet a removal efficiency of 85% or more for BOD₅ and TSS. Influent BOD₅ and TSS data should be reported to ensure removal efficiency requirements are met.

*** Publicly owned treatment works will receive a weekly average *E. coli* limit and private facilities will receive a daily maximum *E. coli* limit.

NOTE 1 – Preferred Alternative Effluent Limit – PEL; or Federal/State Regulation – FSR. Water Quality-Based Effluent Limitation – WQBEL Also, please see the **GENERAL ASSUMPTIONS OF THE WQAR #4 & #5.**

NOTE 2 – Total Phosphorus limits are only applicable to discharges to a lake or watershed of a lake that is a water of the state and has an area of at least ten acres during normal pool conditions

NOTE 3 – Disinfection. Total Residual Chlorine (TRC) and Dissolved Oxygen (DO). The calculated effluent limits for TRC are below th Minimum Quantification Level (ML) of the most common and practical U.S. Environmental Protection Agency (EPA) approved CLTRC methods. The Department has determined the current acceptable ML for TRC to be 130 μg/L when using the DPD Colorimetric Method #4500 – CL G, from Standard Methods for the Examination of Waters and Wastewater. The facility will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the ML of 130 μg/L will be considered violations of the permit and values less than the ML of $130 \,\mu g/L$ will be considered to be in compliance with the permit limitation. The ML does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.

4. ANTIDEGRADATION

The Department has reviewed the antidegradation report for this facility and issued the Water Quality and Antidegradation Review dated February 3, 2020, due to the permitted new construction of a wastewater treatment facility. See **APPENDIX** – **ANTIDEGRADATION**.

5. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

Construction will cover the following items:

- Components are designed for a Population Equivalent of 89 based on organic loading to the system.
- Septic Tank A septic tank provides passive primary treatment as the settleable solids in raw wastewater settle onto the bottom of the tank. Raw wastewater will flow by gravity to a minimum 1,000 gallon septic tank for each lot. The septic tanks provide approximately 2.7 days of detention at design average flow. The pumped wastewater shall discharge into the pre-anoxic tank. Settled solids in the septic tank shall be removed by a contract hauler.
 - Pre-Anoxic Tank Construction of one anoxic tank to receive primary treated wastewater from the septic tanks before the recirculating media filter recirculation tank. The anoxic tank is 10 ft x 20 ft x 7 ft deep with a water level depth of 6 ft for a wastewater volume of approximately 8,976 gallons. Gravity transfers wastewater from the anoxic tank to the first zone of the recirculating media filter by means of a 4-inch SDR 35 PVC pipe.
 - Recirculation Tank Construction of one recirculation tank to pump primary treated wastewater to the recirculating media filter. The recirculation tank is 10 ft x 20 ft x 6 ft deep with a minimum water level depth of 22 inches for a total wastewater volume of approximately 8,976 gallons and a minimum water level volume of 2,743 gallons. Effective flow equalization volume of 4,114 gallons between the low water level and the high water "on" level. The recirculation tank has 3 1 HP submersible pumps each capable of 25 gpm at 48.9 ft TDH. Each pump transfers wastewater to one of three separate zones of the recirculating media filter by means of a 1.5-inch PVC distribution manifold which splits the flow into 12, 1.5-inch PVC laterals per zone.
- Recirculating Media Filter The concrete lined recirculating media filter is split into three filter beds with common walls. Two existing filters will be refurbished and one new filter will be constructed. Each filter bed is approximately 36 ft x 24 ft x 4.8 ft deep each for a total surface area of 2,592 ft² which gives a total hydraulic loading of 2.57 gpd/ft² at design average flow. The PVC laterals spaced 2-ft apart with 18, 1/8-inch shielded orifices per lateral. The laterals are located in the bottom 2 inches of the top 10-inch layer of 1/2-inch washed creek rock. The

filter media layer is 2.5 ft deep containing media with an effective size of 1.5 mm to 3 mm and a uniformity coefficient less than 3.0. The underdrain layer has a | 2-inch layer of 3/8-inch washed creek rock on top of a 3-inch layer of 5/8-inch washed creek rock on top of a 3-inch layer of 1-inch washed creek rock on top of a 8-inch layer of 2-inch washed creek rock to cover the drain lines. Each filter bed contains 2 underdrains comprised of 4-inch slotted PVC piping with approximately 4 inch spacing. In each filter bed, 2 underdrains flow by gravity to the recirculation valve with 80% of the flow returning to the recirculation tank and 20% flows by gravity to the Stage II Recirculation Tank achieving a 4:1 recirculation ratio.

- Stage II Recirculation Tank Construction of one recirculation tank to pump secondary treated wastewater to the Orenco Advantex AX100 Polishing Filter. The recirculation tank is 2,000 gallons. The recirculation tank has a submersible pump capable of 50 gpm. The pump transfers wastewater to the Orenco AdvanTex AX100 Polishing Filter by means of a 1.5-inch PVC schedule 40 pipng.
- Orenco AdvanTex AX100 Polishing Filter Installation of a Orenco AdvanTex AX100 Polishing Filter. The unit is capable of treating an average design flow of 6,600 gpd. The unit has a textile filter assembly with a total filtration area of 100 ft². Polishing filtration shall follow clarification prior to disinfection.
- Disinfection Disinfection is the process of removal, deactivation, or killing of pathogenic microorganisms.
 - Tablet Chlorinator Installation of a tablet Norweco 2000 Chlorinator chamber receiving clarified effluent and prior to the chlorine contact tank. The tablet chlorinator shall have a design flow of 6,660 gpd and a maximum flow of 26,640 gpd. The system will dispense hypochlorite as the wastewater comes into contact with the tablets.
 - Chlorine Contact Tank Installation of a pre-cast concrete tank approximately 7.4 ft x 7.4 ft x 6.1 ft with 7 end-around baffles allowing for a 40:1 length to width ratio. This tank will allow for a 15 minute contact time during a peak flow of 26,640 gpd.
 - Tablet Dechlorinator Installation of a tablet Norweco 2000 dechlorination chamber receiving the chlorinated effluent and prior to Outfall No. 001. The tablet dechlorinator shall have a design flow of 6,660 gpd and a maximum flow of 26,640 gpd. The system will dispense sodium sulfite as the wastewater comes into contact with the tablets.

6. OPERATING PERMIT

After completion of construction project submit: statement of work completed, asbuilts if the project was not constructed in accordance with previously submitted plans and specifications, and ensure that Application Form B, and fee of \$300 has been submitted. Missouri State Operating Permit, General Permit MOGD - New, will be issued after receipt of the above documents.

V. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission U.S. Post Office Building, Third Floor 131 West High Street, P.O. Box 1557 Jefferson City, MO 65102-1557 Phone: 573-751-2422 Fax: 573-751-5018 Website: https://ahc.mo.gov

Steven Hamm, P.E. Engineering Section steven.hamm@dnr.mo.gov

Cindy LePage, P.E., Chief Engineering Section <u>cindy.lepage@dnr.mo.gov</u>

<u>Appendix</u> Antidegradation



FEB 0 3 2020

James O. Jackson, Jr., P.E. Lake Professional Engineering Services, Inc. PO Box 27 Camdenton, MO 65020

RE: Water Quality and Antidegradation Review Preliminary Determination for Lake Horizons Wastewater Treatment Facility

Dear James Jackson, Jr., P.E.:

Enclosed please find the finalized Water Quality and Antidegradation Review (WQAR) for the Lake Horizons Wastewater Treatment Facility in Gravois Mills, Missouri, in Camden County. The WQAR contains pertinent antidegradation review information for the facility discharge. It was developed in accordance with 10 CSR 20-7.031, the Clean Water Commission approved Missouri Antidegradation Implementation Procedure (AIP) dated July 13, 2016, U.S. Environmental Protection Agency (US EPA) guidance, the applicant-supplied antidegradation review documentation, and the State of Missouri's effluent regulations (10 CSR 20-7.015). Please refer to the General Assumptions of the Water Quality and Antidegradation Review section of the enclosed WQAR. The WQAR is preliminary and subject to change as new information becomes available during future permit application processing.

Based on the Missouri Department of Natural Resources' (department's) initial review, preliminary determination is that the applicant-supplied antidegradation review documentation satisfies the requirements of the AIP. This WQAR/preliminary determination may be appealed within 30 days of this letter in accordance with the AIP Section ILF.4.

The WQAR does not specify a specific treatment technology, but instead, allows you to pursue construction of a treatment option that will meet the effluent limits provided in the review. If you choose to install a treatment system that is considered a new technology, your construction permit must address the approvability of the design in accordance with the factsheet Approval Process for Innovative Technology available at http://dnr.mo.gov/pubs/pub2453.htm. With a new technology you will need to work with the construction permit review engineer to ensure equipment is sized properly and that the technology will consistently achieve the proposed effluent limits. The Department encourages the use of new methods and treatment innovations. If you have any questions regarding the new technology factsheet, please contact the engineering section of the Water Protection Program.

You may proceed with submittal of an engineering report/facility plan for this project. Upon completion of that review the next step will be to submit a complete application for a construction permit. An operating permit application will also be required 180 days prior to expected discharge. These submittals must reflect the design flow, facility description, and general treatment components of this WQAR or this preliminary determination may have to be revisited. In addition to one set of paper copies (two sets of paper copies for projects seeking Department funding under 10 CSR 20-4), the regulation now requires all



> Lake Horizons Wastewater Treatment Plant Page Two

materials to be submitted electronically as well. This is typically done via compact disc or other removable electronic media.

Following the department's public notice of a draft Missouri State Operating Permit including the antidegradation review findings and preliminary determination, the department will review any public notice comments received. If significant comments are made, the project may require another public notice and potentially another antidegradation review. If no comments are received or comments are resolved without another public notice, these findings and determinations will be considered final.

Following issuance of the construction permit and completion of the actual facility construction, the department will proceed with the issuance of the operating permit.

If you should have questions regarding the enclosed WQAR, please contact Steve Hamm by telephone at (573) 526-1002 by e-mail at steven.hamm@dnr.mo.gov, or by mail at the Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, Missouri 65102-0176.

Sincerely,

WATER PROTECTION PROGRAM

Refart Mofskis

Refaat Mefrakis, P.E., Chief Engineering Section

RM:sht

 William Patterson: Sippican, LLC Kevin Hess, Southwest Regional Office Missouri Department of Natural Resources Water Protection Program Water Pollution Control Branch Engineering Section

Water Quality and Antidegradation Review

Department's Alternatives Analysis for Domestic Wastewater Facilities with Design Flow Less Than 50,000 Gallons per Day

For Protection of Water Quality and Determination of Effluent Limits

at Lake Horizons Wastewater Treatment Facility in Gravois Mills, Missouri

January, 2020



Department's Alternatives Analysis -- Lake Horizons WWTF Page 2

Table of Contents

1.	WATER QUALITY INFORMATION
2.	APPLICABILITY
3.	TIER DETERMINATION
TABI	E 1. POLLUTANTS OF CONCERN AND TIER DETERMINATION
4.	DEMONSTRATION OF NECESSITY AND SOCIAL AND ECONOMIC IMPORTANCE4
4.1.	NO DISCHARGE EVALUATION
4.2.	DEMONSTRATION OF NECESSITY
FIGU	RE 1. DESIGN FLOW VS. PRESENT WORTH COST VS. AMMONIA LIMITS7
Figu	RE 2. DESIGN FLOW VS. PRESENT WORTH COST VS. BOD & TSS LIMITS
TABI	E 2. DESIGN FLOW VS. PRESENT WORTH COST
4.3.	DESIGN FLOW DETERMINATION
4.4.	REGIONALIZATION ALTERATIVE
4.5.	LOSING STREAM ALTERATIVE DISCHARGE LOCATION
4.6.	SOCIAL AND ECONOMIC IMPORTANCE EVALUATION
5.	GENERAL ASSUMPTIONS OF THE WATER QUALITY AND ANTIDEGRADATION REVIEW
6.	PERMIT LIMITS AND MONITORING INFORMATION
TABI	LE 3. EFFLUENT LIMITS – ALL OUTFALLS
TABI	E 4. EFFLUENT LIMITS – OUTFALLS TO LAKES
7.	RECEIVING WATER MONITORING REQUIREMENTS
8.	DERIVATION AND DISCUSSION OF LIMITS
8.1.	LIMIT DERIVATION
9.	ANTIDEGRADATION REVIEW PRELIMINARY DETERMINATION
APPE	NDIX A: MAP OF DISCHARGE LOCATION
APPE	NDIX B: NATURAL HERITAGE REVIEW
APPE	ENDIX C: ANTIDEGRADATION REVIEW SUMMARY FORMS

Department's Alternatives Analysis – Lake Horizons WWTF Page 3

1. WATER QUALITY INFORMATION

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(3)] and federal antidegradation policy at Title 40 Code of Federal Regulation (CFR) Section 131.12 (a), the Missouri Department of Natural Resources (Department) developed a statewide antidegradation policy and corresponding procedures to implement the policy. A proposed discharge to a water body will be required to undergo a level of Antidegradation Review that documents that the use of a water body's available assimilative capacity is justified. Effective August 30, 2008, and revised July 13, 2016, a facility is required to use *Missouri's Antidegradation Implementation Procedure (AIP)* for new and expanded wastewater discharges.

2. APPLICABILITY

This Water Quality and Antidegradation Review is for facilities that produce primarily domestic wastewater and discharge less than 50,000 gallons per day. This General Antidegradation Review is not applicable to facilities where the receiving waterbody, or downstream waterbodies, have a Total Maximum Daily Load (TMDL) or are 303(d) or 305(b) listed for the pollutants of concern (POCs) addressed in this alternatives analysis, with an exception for waterbodies that are listed for *E. coli* since disinfection will be required. For receiving waters that are impaired for pollutants other than *E. coli*, the Antidegradation Implementation Procedure requires a Tier 1 approach and the applicant must demonstrate that the discharge will not "cause or contribute" to the impairment. For these site-specific mixed tier reviews (where some POCs are Tier 1 and others are Tier 2) applicants may use the alternative analysis presented in this document for the Tier 2 pollutants.

Facilities that are currently under enforcement will need to coordinate with the Water Protection Program's compliance and enforcement section to determine applicability for the Department's Alternatives Analysis. No mixing will be included in this review for receiving waterbodies. If the applicant would like to have effluent limitation derivation include mixing considerations, a site-specific alternatives analysis will need to be completed.

3. TIER DETERMINATION

Below is a list of pollutants of concern reasonably expected to be in the discharge for a domestic wastewater treatment facility. Pollutants of concern are defined as those pollutants "proposed for discharge that affects beneficial use(s) in waters of the state. POCs include pollutants that create conditions unfavorable to beneficial uses in the water body receiving the discharge or proposed to receive the discharge" (AIP, Page 7). No existing water quality data is required because all POCs were considered to be Tier 2 and significantly degrading in the absence of existing water quality. Assumed uses for the receiving waterbody are General Criteria, Protection of Warm Water Aquatic Life (AQL), Human Health Protection (HHP), Irrigation (IRR), and Livestock & Wildlife Protection (LWP). If any Tier 1 Pollutants of Concern not addressed in this alternatives analysis will be discharged, the applicant must submit the *Path D: Tier 1 Preliminary Review Request form* for those pollutants.

POLLUTANTS OF CONCERN	TIER*	DEGRADATION	COMMENT****
Biochemical Oxygen Demand (BOD5)/DO	2	Significant	
Total Suspended Solids (TSS)	**	Significant	
Ammonia	2	Significant	
pH	***	Significant	Permit limits applied
Escherichia coli (E. coli)	2	Significant	
Total Phosphorus (TP)	2	Significant	

Table 1. Pollutants of Concern and Tier Determination

* Tier assumed.

** Tier determination not possible: No in-stream standard for this parameter.

*** The standard for this parameter is a range.

> Department's Alternatives Analysis - Lake Horizons WWTF Page 4

**** Permit limits for other parameters including Oil & Grease, Total Residual Chlorine, and Nitrates will be applied based on water quality standards and criteria as applicable.

Total Residual Chlorine (TRC) effluent limits of 0.017 mg/L daily maximum, 0.008 mg/L monthly average are recommended if chlorine is used as a disinfectant. Standard compliance language for TRC, including the minimum level (ML), may be included in the operating permit.

4. DEMONSTRATION OF NECESSITY AND SOCIAL AND ECONOMIC IMPORTANCE

Missouri's Antidegradation Implementation Procedures (AIP) specify that if the proposed activity results in significant degradation then a demonstration of necessity (i.e., alternatives analysis) and a determination of social and economic importance are required. The applicant must submit the Antidegradation Review Submittal: Voluntary Tier 2 – Significant Degradation for Domestic Wastewater Facilities with Design Flow Less Than 50,000 Gallons per Day form. This analysis will serve as the applicant's alternatives analysis to fulfill the requirements of the AIP.

A Geohydrologic Evaluation must be submitted with the Antidegradation Review Request.

A Missouri Department of Conservation Natural Heritage Review Report must be obtained by the applicant. The applicant should review the Natural Heritage Review and contact the U.S. Fish and Wildlife Service and the Missouri Department of Conservation for further coordination if necessary.

4.1. NO DISCHARGE EVALUATION

According to 10 CSR 20-6.010(4)(A)5.B., facility plans must include an evaluation of the feasibility of constructing and operating a facility with no discharge to waters of the state if the report is for a new or modified wastewater treatment facility. Per the Antidegradation Implementation Procedure Section II.B.1, for discharges likely to cause significant degradation, applicants must provide an analysis of non-degrading alternatives. No-discharge alternatives may include surface land application, subsurface land application, and connection to a regional treatment facility.

The applicant must submit the Antidegradation: Regionalization and No-Discharge Evaluation form to demonstrate that a no-discharge facility is not feasible for this site. If the information provided on the form is not sufficient to demonstrate that a no-discharge facility is not feasible, a more detailed evaluation of no discharge options will be required before the Department can complete its determination.

4.2. DEMONSTRATION OF NECESSITY

The Department has used available data to complete an alternatives analysis of previously evaluated treatment technologies and expected performance. Data from fifty-four Water Quality and Antidegradation Reviews (WQARs) completed between March 2011 and April 2018 was evaluated and results are presented in Figure 1, Figure 2, and Table 2 below.

The data include eleven facilities designed to provide a high level of treatment to meet more stringent potential future ammonia as N effluent limits based on the 2013 EPA Ammonia criteria for the protection of mussels and gill-breathing snails. The data available to date indicates that the cost of facilities of this size range designed to meet these more stringent ammonia criteria is not substantively higher than other facilities designed to meet the current ammonia criteria.

The data include sixteen facilities designed to meet BOD and TSS effluent limits of 10 mg/L monthly average and 15 mg/L daily maximum or weekly average. The data available to date indicates that the cost of facilities designed to meet BOD and TSS effluent limits of 10 mg/L monthly average and 15 mg/L daily maximum or weekly average is not substantively higher than other facilities of this size range designed to meet less stringent BOD and TSS effluent limits.

Department's Alternatives Analysis – Lake Horizons WWTF Page 5

The data include 28 facilities that will discharge to lakes. Of those facilities, 12 received ammonia limits in line with water quality based effluent limits for discharges to streams without mixing of around 3.7 mg/L summer daily maximum, 1.4 mg/L summer monthly average and 7.5 mg/L winter daily max, 2.9 mg/L winter monthly average. Two of the lake-discharging facilities received more stringent ammonia limits of 1.7 mg/L daily maximum, 0.6 mg/L monthly average; and one received ammonia limits of 1.7 mg/L daily maximum, 0.6 mg/L summer monthly average; and one received ammonia limits of 1.7 mg/L winter daily maximum, 0.6 mg/L summer monthly average and 5.6 mg/L winter daily max, 2.1 mg/L winter monthly average. The data available indicate that the cost for facilities designed to meet ammonia limits in line with water quality based effluent limits for streams without mixing (3.7/1.4, 7.5/2.9) is not higher than other facilities of this size range designed to meet less stringent ammonia limits. These limits are more protective than existing water quality based effluent limits for discharges to lakes where the acute criteria is used to determine the baseline (12.1 mg/L daily maximum, 4.6 mg/L monthly average).

Facilities that were designed to meet limits based on the 2013 EPA ammonia criteria included a membrane bioreactor, extended aeration package plant, recirculating textile filter, recirculating sand filter, recirculating sand filter with moving bed biofilm reactor, sequencing batch reactor, integrated fixed film activated sludge system, and a proprietary aeration system.

Membrane bioreactor (MBR) systems combine a suspended growth biological reactor with solids removal via filtration across a membrane. The membranes can be designed for and operated in small spaces and with high removal efficiency of contaminants such as nitrogen, phosphorus, bacteria, biochemical oxygen demand, and total suspended solids. Membrane filtration allows a higher biomass concentration to be maintained in the treatment tank, thereby allowing smaller bioreactors to be used for a smaller footprint. MBR systems provide operational flexibility with respect to flow rates, as well as the ability to readily add or subtract units as needed, but that flexibility has limits. Membranes typically require that the water surface be maintained above a minimum elevation so that the membranes remain wet during operation. Throughput limitations are dictated by the physical properties of the membrane, and the result is that peak design flows generally should be no more than 1.5 to 2 times the average design flow. If peak flows exceed that limit, additional membranes may be needed to process the peak flow, or equalization may need to be included in the design. MBR systems typically have higher capital and operating costs than conventional systems.

The extended aeration process is a modification of the activated sludge process that provides biological treatment for the removal of biodegradable organic wastes under aerobic conditions. Wastewater in the aeration tank is mixed and oxygen is provided to the microorganisms. The mixed liquor then flows to a clarifier or settling chamber where most microorganisms settle to the bottom of the clarifier and a portion are pumped back to the beginning of the plant. The clarified wastewater flows over a weir and into a collection channel before being disinfected and discharged. Extended aeration is often used in smaller prefabricated package-type plants where lower operating efficiency is offset by mechanical simplicity and minimized design costs. In comparison to traditional activated sludge, longer mixing time with aged sludge and light loading (low F:M) offers a stable biological ecosystem better adapted for effectively treating waste load fluctuations from variable occupancy situations. Although the process is stable and easier to operate, extended aeration systems may discharge higher effluent suspended solids than found under conventional loadings.

Moving Bed Biofilm reactor (MBBR) systems may be a single aerated reactor, or several in series, with a buoyant free-moving plastic biofilm carrier media. MBBR systems can be designed to be capable of meeting more stringent total nitrogen limits. They produce a significantly reduced solids loading to the liquid-solids separation unit, the biofilm improves process stability, they offer flexibility to meet specific treatment objectives, and they are well suited for retrofit into existing treatment systems. MBBR systems require a smaller tank volume than a conventional activated sludge system and therefore have a smaller footprint. Adequate mixing must be provided to ensure that free-floating media remains uniformly distributed and screens must be provided to retain the media within the reactors.

Department's Alternatives Analysis – Lake Horizons WWTF Page 6

Integrated fixed film activated sludge (IFAS) systems add fixed or free-floating media to an activated sludge basin. The process gets its name from combining a conventional activated sludge process with a fixed film system. This treatment system is similar to an MBBR; however MBBR systems do not recycle sludge. IFAS systems are often installed as a retrofit solution to conventional activated sludge systems. They require a smaller tank volume than a conventional activated sludge system and therefore have a smaller footprint. The biofilm combines aerobic, anaerobic, and anoxic zones promoting better nitrification compared to conventional activated sludge systems and the biofilm improves process stability. Adequate mixing must be provided to ensure that free-floating media remains uniformly distributed and to slough biomass from the media. Higher dissolved oxygen concentrations may be required as compared to conventional activated sludge. Screens must be provided to retain the media within the reactors.

Recirculating sand filters (RSF) remove contaminants in wastewater through physical, chemical, and, most importantly, biological processes. The three common components are a pretreatment unit (generally a septic tank), a recirculation tank, and a sand filter. In the recirculation tank, raw effluent from the septic tank and the sand filter filtrate are mixed and pumped back to the sand filter bed. RSFs are effective in applications with high levels of BOD and can provide a good effluent quality with 85 - 95% removal of BOD and TSS. They can be designed to provide nitrification, but this requires increased surface area. Treatment is affected by extremely cold weather. Treatment capacity can be expanded through modular design. RSFs require routine maintenance, although the complexity of maintenance is generally minimal.

Recirculating textile filters systems are configured similar to an RSF except the filter media is an engineered fabric textile. They can be configured to provide nitrification, but this may require additional treatment units. They have a small operating footprint, are more aesthetically pleasing than some other treatment options, produce minimal noise, have the ability to handle variable flows, and have simple maintenance.

In addition to the treatment technologies listed above, all of which had previous WQARs that established advanced ammonia limits, there are other technology alternatives that can meet the advanced ammonia limits including conventional activated sludge, oxidation ditch, and lagoon retrofits. To obtain this level of performance, all technologies must be properly designed to accommodate nitrification and denitrification and they must be properly and actively operated.

The above treatment system descriptions were adapted from EPA technology fact sheets and Design of Municipal Wastewater Treatment Plants: WEF Manual of Practice No. 8 ASCE Manuals and Reports on Engineering Practice No. 76; Fifth Edition, as well as other readily available sources and previous Water Quality and Antidegradation Reviews.

Less Stringent (mixing)

Department's Alternatives Analysis -- Lake Horizons WWTF Page 7



		Design Flow (GPD)						
LECEND		Summer Ar	nmonia (mg/L)	Winter Am	imonia (mg/L)			
LEGEND	Daily Max	Monthly Avg.	Daily Max	Monthly Avg.				
2013 EPA Criteria		≤1.7	≤0.6	≤5.6	≤2.1			
Existing Aquatic Life Criteria (no mixing)	٠	approx. 3.7	approx. 1.4	approx. 7.5	approx. 2.9			

>3.7

۲

>7.5

>2.9

>1.4

FIGURE 1. DESIGN FLOW VS. PRESENT WORTH COST VS. AMMONIA LIMITS

50,000

Department's Alternatives Analysis - Lake Horizons WWTF Page 8



Design Flow (GPD)

LECEND	BOD) (mg/L)	TSS	(mg/L)
LEGEND	Daily Max	Monthly Avg.	Daily Max	Monthly Avg.
	15	10	15	10
•	15	10	>15	>10
•	>15	>10	>15	>10

	pd6/Md \$	149	113	113	113	120	159	75	162	73	73	96	78	79	180	74	31	31	75	34	30	43	23	25	22	23
Present Worth Cost (\$)	F	66.838	62,506	62,506	62,506	66,838	127,427	61,240	162,007	91,000	102,174	170,879	170,879	198,000	485,000	220,915	92,604	115,668	283,000	132,185	133,676	203,060	114,058	127,000	123.224	130,000
nmonla (L)	Monthly Average	2.9	4.6	4.6	8	2.9	2.9	4.6	2.9	60	2.9	0.6	0.6	2.9	2.1	4.6	2.9	2.8	4.6	2.9	4.6	4.6	2.9	3.2	2.1	2.9
Winter Au (mg	Daily Maximum	7.5	12.1	12.1	7.8	7.5	7.7	12.1	7.5	9	7.6	1.7	1.1	7.5	5.6	12.1	7.5	7.3	12.1	7.5	12.1	12.1	7.5	8.2	5.6	7.5
ummonia (L)	Monthly Average	1.4	4.6	4.6	•	1.4	1.5	4.6	1.4	•	1.4	9.0	0.6	1.4	0.6	4.6	1.4	2.8	4.6	1.4	4.6	4.6	1.4	22	0.6	1.4
Summer A (mg/	Daily Maximum	3.7	12.1	12.1	7.8	3.7	4	12.1	3.7	9	3.7	1.1	1.7	3.7	1.7	12.1	3.7	7.3	12.1	3.7	12.1	12.1	3.5	5.7	1.1	3.7
(J)B(Monthly Average	15	15	15	15	15	15	20	10	15	15	20	20	10	10	10	15	20	15	10	15	20	15	30	15	10
TSS (n	Daily Max or Weekly Average	20	20	20	22.5	20	30	30	15	22	23	30	30	15	15	15	20	30	20	15	23	30	20	45	20	15
(J)Gu	Monthly Average	10	10	10	10	10	15	20	10	10	10	20	20	10	10	10	10	20	10	10	10	20	10	30	10	10
BOD (n	Daily Max or Weekdy Average	15	15	15	15	15	30	30	15	15	15	30	30	15	15	15	15	30	15	15	15	30	15	45	15	15
Technology		Recirculating Textile Filter	Recirculating Textile Filter	Recirculating Textile Filter	Extended Aeration Package Plant	Recirculating Textile Filter	Recirculating Textile Filter	Membrane Bioreactor	Recirculating Textle Filter	Recirculating Textile Filter	Recirculating Textile Filter	Recirculating Textile Filter	Recirculating Textile Filter	Extended Aeration	New Technology Primary Tank with Aeration	Recirculating Textile Filter	Extended Aeration Package Plant	Recirculating Rock Filter	Recirculating Textile Filter	Recirculating Sand Filter	Recirculating Sand Filter	Recirculating Sand Filter	Recirculating Sand Filter	Moving Bed Biofilm Reactor	Recirculating Sand Filter	Extended Aeration with Filtration and Aerated Holding Tanks
Design	(MGD)	+0.000450	*0.000555	*0.000555	*0.000555	*0.000555	0.000800	*0.000821	0.001000	*0.001240	*0.001400	*0.001800	*0.002200	0.002500	0.002700	*0.003000	0.003000	*0.003700	*0.003750	*0.003885	*0.004500	*0.004718	•0.004950	0.005000	0.005500	0.005600
DATE		4/16/2018	5/2/2012	4/2/2013	10/1/2014	4/17/2017	4/4/2012	12/1/2013	9/2/2012	7/6/2011	1/1/2015	9/8/2017	9/5/2017	5/5/2011	8/31/2017	9/1/2011	3/1/2012	2/22/2016	7/4/2011	4/1/2014	12/1/2012	6/3/2013	11/2/2011	6/4/2011	8/22/2017	9/6/2012

TABLE 2. DESIGN FLOW VS. PRESENT WORTH COST

100	BOD (I	(1)6u	TSS (r Daily Max	ng/L)	Summer A (mg/	mmonte	Winter Au (mg	nmonia (L)	Present Worth Cost (5)	pd6/Md \$
5 € ₹	Weekly	Monthly Average	or Weekly Average	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Monthly Average		
	15	10	15	10	3.7	1.4	7.5	2.9	176,239	26
	30	20	30	20	3.7	1.4	7.5	2.9	285,780	ž
	15	10	15	10	2.6	1	2.6	1	61,240	~
2	10	10	20	15	3.1	1.2	7.5	2.9	203,698	23
5	15	10	15	10	1.6	0.6	5.5	2.1	217,739	24
	ų.	10	20	15	3.7	1.4	7.5	2.9	222,160	24
	30	20	30	20	3.7	1.5	6.5	2.5	163,681	18
	2	22	33	22	1.7	0.6	5.6	2.1	941,800	94
4	5	30	45	30	8	1.1	6	2.3	189,985	14
15	10	10	15	10	3.7	1.4	7.5	2.8	188,208	13
23	-	15	23	15	3.9	1.5	7.8	3	450,986	58
15		10	20	15	7.8	2.5	7.8	2.5	226,969	4
4	10	30	45	30	3.7	1.4	7.5	2.9	187,967	÷
1	10	10	20	15	3.7	1.4	7.5	2.9	317,750	4
4	10	30	45	30	1.4	0.6	2.9	2.1	507,618	25
-	10	10	15	10	3.7	1.4	6.5	2.1	320,318	16
	10	10	20	15	3.7	1.4	7.5	2.9	130,000	
	10	10	15	10	9	2.3	9	2.3	222,901	1
	10	10	15	10	3.7	1.4	6.5	2.1	343,816	14
	10	10	20	15	1.7	0.6	5.6	2.1	1,157,390	38
	10	30	45	30	3.7	1.4	7.5	2.9	4,309,665	11:

Department's Alternatives Analysis - Lake Horizons WWTF Page 10

Sippican, LLC Lake Horizons WWTF, MOGD-New Page 24

Department's Alternatives Analysis – Lake Horizons WWTF Page 11

onthiv rerage Daily Maximum Monthiv Average Daily Monthiv Average Monthiv Average Monthiv Average 15 3.7 1.4 7.5 2.9 2.963,181 15 3.7 1.4 7.5 2.9 2.963,181 15 3.7 1.4 7.5 2.9 2.963,181 15 3.7 1.4 7.5 2.9 2.963,181 15 3.7 1.4 7.5 2.9 479,343 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 15 3.7 1.4 7.5 2.9 942,050 16 3.7 1.4 7.5 2.9 7.373	g/L) Summer (m	TSS (mg		17/Du	BOD (mg/L)
15 3.7 1.4 7.5 2.9 2.963,181 15 3.7 1.4 7.5 2.9 2.963,181 30 1.7 1 5.6 2.1 1,812,000 30 1.7 0.6 5.6 2.1 816,367 10 1.7 0.6 5.6 2.1 816,364 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 11 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 15 3.7 1.4 7.5 2.9 942,050 10 3.7 1.4 7.5 2.9 1,357,506	Monthiy Daily Average Maximum	Daily Max or Weekly Average	de A	Montl	Daily Max Montl or Weekly Avera Average
15 3.7 1 5.6 2.1 1,612,000 30 1.7 0.6 5.6 2.1 816,367 10 1.7 0.6 5.6 2.1 816,367 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 11 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 15 3.7 1.4 7.5 2.9 942,050 10 3.7 1.4 7.5 2.9 1,357,506	15 3.7	20	9		15
30 1.7 0.6 5.6 2.1 816,367 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 20 7.5 2.9 7.5 2.9 942,050 15 3.7 1.4 7.5 2.9 942,050 10 3.7 1.4 7.5 2.9 733 73	15 3.7	20	2	F	15
10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 10 1.7 0.6 5.6 2.1 479,344 20 7.5 2.9 2.1 479,344 15 7.5 2.9 242,050 16 3.7 1.4 7.5 2.9 1,357,506 10 3.7 1.4 7.5 2.9 733,733	30 1.7	45	0	2	30 2
10 1.7 0.6 5.6 2.1 479,344 20 7.5 2.9 7.5 2.9 942,050 15 3.7 1.4 7.5 2.9 1,357,506 10 3.7 1.4 7.5 2.9 733,733	10 1.7	15		+	15 1
20 7.5 2.9 7.5 2.9 942,050 15 3.7 1.4 7.5 2.9 1,357,506 10 3.7 1.4 7.5 2.9 733 723	10 1.7	15	0	-	15 1
15 3.7 1.4 7.5 2.9 1,357,506 10 3.7 1.4 7.5 2.9 733 723	20 7.5	30	•	N	30 2
10 3.7 1.4 7.5 2.9 733723	15 3.7	20	-	4	15 10
	10 3.7	15		÷	15 11

Lake Dischargers

Sippican, LLC Lake Horizons WWTF, MOGD-New Page 25

> Department's Alternatives Analysis – Lake Horizons WWTF Page 12

Additionally, the table of wastewater treatment technologies in the *Ammonia Criteria: New EPA Recommended Criteria* factsheet includes several technologies that have demonstrated capability in meeting ammonia effluent limits of less than 0.7 mg/L when designed appropriately.

The EPA has approved the nutrient water quality standards at 10 CSR 20-7.031. Numeric water quality standards for specific lakes are listed in Table N of 10 CSR 20-7.031. Nutrient standards at 10 CSR 20-7.031(5)(N) apply to all other lakes that are waters of the state and have an area of at least ten acres during normal pool conditions, with the exception of the lakes located in the Big River Floodplain ecoregion (see 10 CSR 20-7.031(5)(N)2.). Waters that are 303(d) listed for nutrients will need to complete a site-specific antidegradation review to determine appropriate limits.

The base case treatment option for total phosphorus to ensure that water quality standards will be protected is assumed to be conventional secondary treatment. Total phosphorus effluent levels from conventional secondary treatment typically range from 1 to 4 mg/L. Three less degrading options that were considered are chemical addition for precipitation and settling, biological nutrient removal (BNR), and enhanced nutrient removal (ENR). Chemical addition is a common practice for phosphorus removal and has been used for a number of years in Southwest Missouri for discharges to lakes that are subject to the 0.5 mg/L effluent limits required at 10 CSR 20-7.015. An effluent limit of 0.5 mg/L was therefore determined to be a reasonable and economically efficient treatment level for the Department's Alternatives Analysis. The cost to treat beyond this level may not be economically efficient for facilities with a design flow less than 50,000 gallons per day.

As a result of this alternatives analysis, the Department has determined that for a facility that discharges less than 50,000 gallons per day, depending on site-specific conditions, there are technologies available that may be economically efficient and practicable, and that are capable of meeting the effluent limitations in Table 3 or Table 4. If the facility owners do not believe that there is a treatment technology that is both economically efficient and practicable for their facility to meet the limits in Table 3 or Table 4, a site-specific alternatives analysis may be required.

4.3. DESIGN FLOW DETERMINATION

As part of the Department's alternatives analysis, facilities up to 50,000 gallons per day were evaluated. A design flow maximum of 50,000 gallons per day was chosen for applicability of this alternatives analysis for a variety of reasons. As facilities increase in size, site-specific factors may require a more site-specific alternatives analysis. For example, larger facilities are more likely to have wet weather flows that must be addressed and are more likely to need Whole Effluent Toxicity testing or nutrient monitoring. Larger facilities are also more likely to discharge a larger variety of pollutants of concern, which may not be addressed in this review. Larger facilities also benefit from an economy of scale; smaller facilities tend to have a higher cost per gallon of wastewater treated, which is distributed over fewer paying customers. Finally, as we are working with a limited amount of data, limiting the design flow applicability for the Department's alternatives analysis ensures a factor of safety in our review.

4.4. REGIONALIZATION ALTERATIVE

Within Section II B 1. of the AIP, discussion of the potential for discharge to a regional wastewater collection system is mentioned. The applicant must provide justification for not pursuing regionalization on the *Regionalization and No-Discharge Evaluation* form. If the information provided on the form is not sufficient to demonstrate that a regionalization alternative is not feasible, a more detailed evaluation will be required before the Department can complete its determination.

The applicant needs to fully evaluate regionalization and consolidation options when deciding on ways to comply with existing and future regulatory requirements. This includes evaluating connecting or selling their utility to a larger public or private utility. With the rising costs of compliance and often-limited resources

Department's Alternatives Analysis – Lake Horizons WWTF Page 13

available to smaller facilities, not owning and operating a small utility may be the most beneficial and costeffective alternative for achieving consistent compliance.

4.5. LOSING STREAM ALTERATIVE DISCHARGE LOCATION

Under 10 CSR 20-7.015(4)(A), prior to discharging to a losing stream, alternatives such as relocating the discharge to a gaining stream, and connection to a regional wastewater treatment facility are to be evaluated and determined to be unacceptable for environmental and/or economic reasons. Information provided by the applicant on the No Discharge Evaluation form must include evaluation and justification for why the owner is not pursuing land application, or connection to a regional facility.

4.6. SOCIAL AND ECONOMIC IMPORTANCE EVALUATION

Missouri's antidegradation implementation procedures specify that if the proposed activity results in significant degradation then a determination of social and economic importance is required.

Information provided by the applicant in the Antidegradation Review Submittal: Voluntary Tier 2– Significant Degradation for Domestic Wastewater Facilities with Design Flow Less Than 50,000 Gallons per Day form must include a detailed social and economic importance evaluation. If the information provided on the form is not sufficient to demonstrate important social and economic importance, then a more detailed evaluation will be required before the Department can complete its determination.

5. GENERAL ASSUMPTIONS OF THE WATER QUALITY AND ANTIDEGRADATION REVIEW

- A Water Quality and Antidegradation Review (WQAR) assumes that [10 CSR 20-6.010(2) Continuing Authorities and 10 CSR 20-6.010(4)(A)5.B., evaluation of no discharge] has been or will be addressed in a Missouri State Operating Permit or Construction Permit Application.
- A WQAR does not indicate approval or disapproval of alternative analysis as per [10 CSR 20-7.015(4) Losing Streams], and/or any section of the effluent regulations.
- Changes to Federal and State Regulations made after the drafting of this WQAR may alter Water Quality Based Effluent Limits (WQBEL).
- Effluent limitations derived from Federal or Missouri State Regulations (FSR) may be WQBEL or Effluent Limit Guidelines (ELG).
- WQBEL supersede ELG only when they are more stringent. Mass limits derived from technology based limits are still appropriate.
- A WQAR does not allow discharges to waters of the state, and shall not be construed as a National Pollution Discharge Elimination System or Missouri State Operating Permit to discharge or a permit to construct, modify, or upgrade.
- Limitations and other requirements in a WQAR may change as Water Quality Standards, Methodology, and Implementation procedures change.
- Nothing in this WQAR removes any obligations to comply with county or other local ordinances or restrictions.
- 9. If the proposed treatment technology is not covered in 10 CSR 20-8 Minimum Design Standards, the treatment process may be considered a new technology. As a new technology, the permittee will need to work with the review engineer to ensure equipment is sized properly. The operating permit may contain additional requirements to evaluate the effectiveness of the technology once the facility is in operation. This Antidegradation Review is based on the information provided by the facility and is not a comprehensive review of the proposed treatment technology. If the review engineer determines the proposed technology will not consistently meet proposed effluent limits, the permittee will be required to revise their Antidegradation Report.

Department's Alternatives Analysis – Lake Horizons WWTF Page 14

6. PERMIT LIMITS AND MONITORING INFORMATION

TABLE 3. EFFLUENT LIMITS – ALL OUTFALLS

Paran	AETER.	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	BASIS FOR LIMIT (NOTE 1)	MONITORING FREQUENCY
FLO	ow.	MGD	*		*	FSR	ONCE/QUARTER
BIOCHEMICAL OXY	GEN DEMAND5 **	MG/L		15	10	PEL	ONCE/QUARTER
TOTAL SUSPEN	DED SOLIDS **	MG/L		15	10	PEL	ONCE/QUARTER
P	н	SU	6.5-9.0		6.5-9.0	FSR	ONCE/QUARTER
AMMONIA AS N (Apr 1 - Sept 30)	MG/L	1.7		0.6	PEL	ONCE/QUARTER
Ammonia as N (Oct 1 – Mar 31)		MG/L	5.6		2.1	PEL	ONCE/QUARTER
TOTAL PHOSPH	ORUS (NOTE 2)	MG/L	*		0.5	PEL	ONCE/QUARTER
ESCHERICHIA	WBC(A) AND ESCHERICHIA WBC (B) (NOTE 3) #/		630	***	126	FSR	ONCE/QUARTER
COLIFORM (E. COLI)	LOSING STREAM (NOTE 4)	#/100мL	126	;***	+	FSR	ONCE/QUARTER

TABLE 4. EFFLUENT LIMITS - OUTFALLS TO LAKES

PARAMETER	Units	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	BASIS FOR LIMIT (NOTE 1)	MONITORING FREQUENCY
FLOW	MGD	*		•	FSR	ONCE/QUARTER
BIOCHEMICAL OXYGEN DEMAND5 **	MG/L		15	10	PEL	ONCE/QUARTER
TOTAL SUSPENDED SOLIDS **	MG/L		20	15	PEL	ONCE/QUARTER
PH	SU	6.5-9.0		6.5-9.0	FSR.	ONCE/QUARTER
Ammonia as N (Apr 1 – Sept 30)	MG/L	3.6		1.4	PEL	ONCE/QUARTER
Ammonia as N (Oct 1 – Mar 31)	MG/L	7.5		2.9	PEL	ONCE/QUARTER
TOTAL PHOSPHORUS (NOTE 2)	MG/L	+		0.5	PEL	ONCE/QUARTER
ESCHERICHIA COLIFORM (E. COLI)	#/100mL	630	***	126	FSR	ONCE/QUARTER

Monitoring requirements only.

** Publicly owned treatment works will be required to meet a removal efficiency of 85% or more for BOD₅ and TSS. Influent BOD₅ and TSS data should be reported to ensure removal efficiency requirements are met.
 *** Publicly owned treatment works will receive a weekly average E. coli limit and private facilities will receive a

*** Publicly owned treatment works will receive a weekly average E. coli limit and private facilities will receive a daily maximum E. coli limit.

NOTE 1 – Preferred Alternative Effluent Limit – PEL; or Federal/State Regulation – FSR. Water Quality-Based Effluent Limitation – WQBEL Also, please see the GENERAL ASSUMPTIONS OF THE WQAR #4 & #5.

NOTE 2- Total Phosphorus limits are only applicable to discharges to a lake or watershed of a lake that is a water of the state and has an area of at least ten acres during normal pool conditions

NOTE 3 - Effluent limitations and monitoring requirements for E. coli for WBC(A) and WBC(B) are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for E. coli is expressed as a geometric mean. The Weekly Average for E. coli will be expressed as a geometric mean if more than one (1) sample is collected during a calendar week (Sunday through Saturday).

NOTE 4 – Effluent limits and monitoring requirements for *E. coli* are applicable year round for designated losing streams. No more than 10% of samples over the course of a calendar year shall exceed the 126 #/100 mL daily maximum.

Permit limits or monitoring requirements for other applicable parameters, including Oil & Grease, Total Residual Chlorine, Dissolved Oxygen, Nitrates, Total Recoverable Aluminum, and Total Recoverable Iron, may be included in the operating permit based on water quality standards and criteria as applicable.

Department's Alternatives Analysis - Lake Horizons WWTF Page 15

7. RECEIVING WATER MONITORING REQUIREMENTS

No receiving water monitoring requirements recommended at this time.

8. DERIVATION AND DISCUSSION OF LIMITS

Water quality-based - Using water quality criteria or water quality model results and the dilution equation below:

$$C = \frac{(C_s \times Q_s) + (C_e \times Q_e)}{(Q_e + Q_s)}$$
 (EPA/505/2-90-001, Section 4.5.5)

Where C = downstream concentration

 $C_s = upstream$ concentration

 Q_s = upstream flow C_e = effluent concentration Q_e = effluent flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration).

Water quality-based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

Note: Under 40 CFR 133.105, permitting authorities shall require more stringent limitations than equivalent to secondary treatment limitations for 1) existing facilities if the permitting authority determines that the 30-day average and 7-day average BOD₅ and TSS effluent values that could be achievable through proper operation and maintenance of the treatment works, and 2) new facilities if the permitting authority determines that the 30-day average and 7-day average BOD₅ and TSS effluent values that could be achievable through proper operation and maintenance of the treatment works, and 2) new facilities if the permitting authority determines that the 30-day average and 7-day average BOD₅ and TSS effluent values that could be achievable through proper operation and maintenance of the treatment works, considering the design capability of the treatment process.

8.1. LIMIT DERIVATION

- <u>Flow</u>. In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each
 outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to
 obtain effluent flow, then it is the responsibility of the permittee to inform the Department, which may
 require the submittal of an operating permit modification.
- <u>Biochemical Oxvgen Demand (BOD5</u>). BOD5 limits of 10 mg/L monthly average and 15 mg/L average weekly were determined by the Department to be achievable and protective of beneficial uses and existing water quality.

As per the DO Modeling & BOD Effluent Limit Development Administrative Guidance for the Purpose of Conducting Water Quality Assistance Reviews, facilities less than 100,000 gallons per day, and proposing BOD treatment less than or equal to an average monthly of 10 mg/L and average weekly of 15 mg/L as demonstrated by performance specifications from a manufacturer or effluent sampling of an existing facility with the same treatment facility are exempt from the DO modeling requirement. Department's Alternatives Analysis - Lake Horizons WWTF Page 16

Influent monitoring may be required for this facility in its Missouri State Operating Permit.

Total Suspended Solids (TSS).

<u>Table 3</u>: TSS limits of 10 mg/L monthly average and 15 mg/L average weekly were determined by the Department to be achievable and protective of beneficial uses and existing water quality. According to EPA, because TSS and BOD are closely correlated, we apply the same limits for TSS as BOD.

<u>Table 4</u>: For lake discharging facilities, TSS limits of 15 mg/L monthly average and 20 mg/L average weekly were determined by the Department to be achievable and protective of beneficial uses and existing water quality for discharges to lakes where mixing would apply. These limits are more protective than the TSS limitations designated at 10 CSR 20-7.015(3)(A)1.A. for lakes and reservoirs.

Influent monitoring may be required for this facility in its Missouri State Operating Permit.

- <u>pH</u>. 6.5-9.0 SU. Technology based effluent limitations of 6.0-9.0 SU [10 CSR 20-7.015] are not
 protective of the Water Quality Standard, which states that water contaminants shall not cause pH to be
 outside the range of 6.5-9.0 SU. No mixing zone is allowed when using the Department's Alternatives
 Analysis, therefore the water quality standard must be met at the outfall.
- <u>Total Ammonia Nitrogen for Table 3</u>. The Department has determined that the alternatives analysisbased technology limits of 0.6 mg/L monthly average and 1.7 mg/L daily maximum in summer, and 2.1 mg/L monthly average and 5.6 mg/L daily maximum in winter are achievable by some treatment technologies. Because these limits are more protective than the water quality-based limits calculated below for a stream with no mixing, the technology-based limits were used.

In choosing to use the Department's alternatives analysis, the facility is electing to build a treatment plant that provides a high level of treatment that meets potential future limits based on the 2013 EPA Ammonia criteria and will potentially reduce the need to upgrade in the near future. If the facility owners do not believe that there is a treatment technology that is both economically efficient and practicable for their facility to meet these limits, a site-specific alternatives analysis may be required.

Water Quality-Based Effluent Limits (WQBEL):

Early Life Stages Present Total Ammonia Nitrogen criteria apply

[10 CSR 20-7.031(5)(B)7.C. & Table B1 and Table B3]. Background total ammonia nitrogen = 0.01 mg/L

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg N/L)	Total Ammonia Nitrogen CMC (mg N/L)
Summer	26	7.8	1.5	12.1
Winter	6	7.8	3.1	12.1

Summer: April 1 - September 30

 $C_e = (((Q_e+Q_s)*C) - (Q_s*C_s))/Q_e$

Chronic WLA: Ce = ((Qe + 0.0)1.5 - (0.0 * 0.01))/Qe = 1.5 mg/L

Acute WLA: $C_e = ((Q_e + 0.0)12.1 - (0.0 * 0.01))/Q_e = 12.1 \text{ mg/L}$

 $LTA_c = 1.5 \text{ mg/L} (0.780) = 1.17 \text{ mg/L}$

[CV = 0.6, 99th Percentile, 30 day avg.]

LTA _a = 12.1 mg/L (0.321) = 3.89 mg/L	[CV = 0.6, 99 th Percentile]
MDL = 1.17 mg/L (3.11) = 3.6 mg/L AML = 1.17 mg/L (1.19) = 1.4 mg/L	$\begin{tabular}{l} [CV = 0.6, 99^{th} Percentile] \\ [CV = 0.6, 95^{th} Percentile, n = 30] \end{tabular}$
$\frac{\text{Winter: October 1 - March 31}}{\text{Chronic WLA: } C_e = ((Q_e + 0.0)3.1 - (0.0 * 0.01))/Q_e = 3.1}$	mg/L
Acute WLA: $C_e = ((Q_e + 0.0)12.1 - (0.0025 * 0.01))/Q_e$	= 12.1 mg/L
$LTA_c = 3.1 \text{ mg/L} (0.780) = 2.42 \text{ mg/L}$ $LTA_s = 12.1 \text{ mg/L} (0.321) = 3.89 \text{ mg/L}$	[CV = 0.6, 99 th Percentile, 30 day avg.] [CV = 0.6, 99 th Percentile]
MDL = 2.42 mg/L (3.11) = 7.5 mg/L AML = 2.42 mg/L (1.19) = 2.9 mg/L	$[CV = 0.6, 99^{th} Percentile]$ $[CV = 0.6, 95^{th} Percentile, n = 30]$

Sature Da Parajao Las	Maximu Limit (m Daily (mg/l)	Average Limit	Monthly (mg/l)
A Standard State State	Summer	Winter	Summer	Winter
WQBEL	3.6	7.5	1.4	2.9
Alternatives Analysis Limits	1.7	5.6	0.6	2.1

 Total Ammonia Nitrogen for Table 4. The Department has determined that the alternatives analysisbased technology limits for lake discharging facilities of 3.6 mg/L summer daily maximum, 1.4 mg/L summer monthly average and 7.5 mg/L winter daily max, 2.9 mg/L winter monthly average are achievable by some treatment technologies. Because these proposed limits are more protective than the water quality-based limits calculated below for a lake with mixing where acute criteria would be applicable for determining the baseline limits, the alternatives analysis limits were used.

Water Quality-Based Effluent Limits (WQBEL):

Early Life Stages Present Total Ammonia Nitrogen criteria apply

[10 CSR 20-7.031(5)(B)7.C. Table B1 & Table B3]. Background total ammonia nitrogen = 0.01 mg/L

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg N/L)	Total Ammonia Nitrogen CMC (mg N/L)
Summer	26	7.8	1.5	12.1
Winter	6	7.8	3.1	12.1

 $C_e = (((Q_e+Q_s)*C) - (Q_s*C_s))/Q_e$ Acute WLA: $C_e = ((Q_e+0)12.1 - (0*0.01))/Q_e$ $C_e = 12.1 \text{ mg/L}$

LTA₃ = 12.1 mg/L (0.321) = **3.88 mg/L** MDL = 3.88 mg/L (3.11) = 12.1 mg/L AML = 3.88 mg/L (1.19) = 4.6 mg/L
$$\label{eq:cv} \begin{split} & [CV = 0.6, 99^{th} \ Percentile] \\ & [CV = 0.6, 99^{th} \ Percentile] \\ & [CV = 0.6, 95^{th} \ Percentile, n = 30] \end{split}$$

A Star The second second second	Maximu Limit	m Daily (mg/l)	Average Limit	Monthly (mg/l)
A STATE AND A STATE AND A STATE	Summer	Winter	Summer	Winter
WQBEL	12.1	12.1	4.6	4.6
Alternatives Analysis Limits	3.6	7.5	1.4	2.9

Department's Alternatives Analysis - Lake Horizons WWTF Page 18

- Total Phosphorus. Total Phosphorus limits are only applicable to discharges to a lake or watershed of a lake that is a water of the state and has an area of at least ten acres during normal pool conditions. Monthly average of 0.5 mg/L and monitoring only for daily maximum were determined by the Department to be achievable and an appropriate target for the discharge to not cause or contribute to an instream water quality standard excursion or impairment should future modeling by the department occur.
- <u>Escherichia coli (E. coli)</u>. Limits will be applied based on the receiving stream designated use.

Whole Body Contact: Monthly average of 126 per 100 mL as a geometric mean and Daily Maximum or Weekly Average as a geometric mean of 630 per 100 mL during the recreational season (April 1 – October 31), to protect Whole Body Contact Recreation designated use of the receiving water body, as per 10 CSR 20-7.031(5)(C) and 10 CSR 20-7.015 (9)(B)1. An effluent limit for both monthly average and daily maximum or weekly average is required by 40 CFR 122.45(d). Publicly owned treatment works will receive weekly average limits, while non-publicly owned treatment works will receive daily maximum limits.

Losing Stream: Discharges to losing streams shall not exceed 126 per 100 mL as a Daily Maximum at any time, as per 10 CSR 20-7.031(5)(C). Monitoring only for a monthly average. No more than 10% of samples over the course of the calendar year shall exceed 126 #/100 mL daily maximum as per 10 CSR 20-7.015(9)(B)1.G.

Per the effluent regulations, the *E. coli* sampling/monitoring frequency for facilities less than 100,000 gallons per day shall be set to match the monitoring frequency of wastewater and sludge sampling program for the receiving water category in 7.015(1)(B)3. during the recreational season (April 1 – October 31), with compliance to be determined by calculating the geometric mean of all samples collected during the reporting period (samples collected during the calendar week for the weekly average, and samples collected during the calendar month for the monthly average). Please see GENERAL ASSUMPTIONS OF THE WQAR #7

 <u>Total Residual Chlorine (TRC)</u>. These limits will apply to facilities that chlorinate. Warm-water Protection of Aquatic Life CCC = 10 μg/L, CMC = 19 μg/L [10 CSR 20-7.031, Table A1]. Background TRC = 0.0 μg/L.

 $C_e = (((Q_e+Q_s)*C) - (Q_s*C_s))/Q_e$

 Chronic WLA:
 $C_e = ((Q_e + 0.0)10 - (0.0 * 0.0))/Q_e = 10 \ \mu g/L$

 Acute WLA:
 $C_e = ((Q_e + 0.0)19 - (0.0 * 0.0))/Q_e = 19 \ \mu g/L$

 LTA_c = 10 \ \mu g/L (0.527) = **5.3 \ \mu g/L** $[CV = 0.6, 99^{th} \ Percentile]$

 LTA_e = 19 \ \mu g/L (0.321) = 6.1 \ \mu g/L
 $[CV = 0.6, 99^{th} \ Percentile]$

 MDL = **5.3 \ \mu g/L** (3.11) = 16.5 \ \mu g/L
 $[CV = 0.6, 99^{th} \ Percentile]$

 AML = **5.3 \ \mu g/L** (1.55) = 8.2 \ \mu g/L
 $[CV = 0.6, 95^{th} \ Percentile]$

Total Residual Chlorine effluent limits of 0.017 mg/L daily maximum, 0.008 mg/L monthly average are recommended if chlorine is used as a disinfectant. Standard compliance language for TRC, including the minimum level (ML), should be included in the permit.

Department's Alternatives Analysis - Lake Horizons WWTF Page 19

- <u>Aluminum, Total Recoverable</u>. Monitoring only. The facility may use chemicals for phosphorous removal that contain aluminum. Monitoring may be included in the operating permit to determine if reasonable potential exists for this facility's discharge to exceed water quality standards for Aluminum (Total Recoverable).
- <u>Iron, Total Recoverable.</u> Monitoring only. This facility may use chemicals for phosphorous removal that contain iron. Monitoring may be included in the operating permit to determine if reasonable potential exists for this facility's discharge to exceed water quality standards for Iron (Total Recoverable).
- Oil & Grease. These limits will apply to publicly owned treatment works and may apply to other facilities as appropriate. Conventional pollutant, [10 CSR 20-7.031, Table A1]. Effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.

Permit limits for any other applicable parameters may be included in the operating permit based on water quality standards and criteria as applicable.

9. ANTIDEGRADATION REVIEW PRELIMINARY DETERMINATION

The proposed new or expanded facility discharge is assumed to result in significant degradation of the receiving waterbody. The Department has used available data to complete a review of available treatment technologies and expected performance. As a result of this review, the Department has determined that, depending on site specific conditions, there may be technologies available which are economically efficient and practicable for a facility that are capable of meeting the effluent limits in Table 3 or Table 4. If the facility owners do not believe that there is a treatment technology that is both economically efficient and practicable for their facility to meet the limits in Table 3 or Table 4, a site specific WQAR may be requested.

Any treatment option designed to meet these effluent limits may be considered a reasonable alternative in moving forward with the appropriate facility plan, construction permit application, or other future submittals.

If the proposed treatment system is not covered in 10 CSR 20-8 Minimum Design Standards and is considered a new treatment technology, your construction permit application must address approvability of the technology in accordance with the *New Technology Definitions and Requirements* factsheet. If you have any questions regarding the new technology factsheet, please contact Cindy LePage of the Water Protection Program. The permittee will need to work with the review engineer to ensure equipment is sized properly and that the technology will consistently achieve the proposed effluent limits. The operating permit may contain additional requirements to evaluate the effectiveness of the technology once the facility is in operation.

Per the requirements of the AIP, the effluent limits in this review were developed to be protective of beneficial uses and to attain the highest statutory and regulatory requirements. The Department has determined that the submitted review is sufficient and meets the requirements of the AIP. No further analysis is needed for this discharge.

Department's Alternatives Analysis - Lake Horizons WWTF Page 20

Appendix A: Map of Discharge Location

(A USGS topographic map can be obtained on the web at the department's map viewer.)



The National Map Advanced Viewer

Eautore Ean HERE, Gamis Internati, Antonem F. Corp., contecto Fabli Alfo, 180044, Genderse Kiti, Kalanen H., Ondeante Surve, En Japon ARTI, Ed Otea Prog. Kargi, Lo Derröset/Mai contecture, arche Gil Une Commune.

0.25

0.8

USSS risk. | USSS The Futures Map

1 844

. US65 The Islan Audite: Dhemosey (Dark), C.F. Kater, D.R. (1985) tankes Mar. 10 Denter Propert (DDP) (US61 Tell). 20 Lineator Propert (DDP). Distribution (Propert (DDP))

> Department's Alternatives Analysis - Lake Horizons WWTF Page 21



August 01, 2019

Jim Jackson, Jr PO Box 27 Camdenton, MO 65020

RE: Lake Horizons WWTP

Dear Jim Jackson, Jr:

On June 28, 2019, the Missouri Geological Survey received a request to perform a geohydrologic evaluation for the above referenced project located in Camden County. Included with this letter is a report that details the geologic and hydrologic conditions at the site and the potential for groundwater contamination in the event of wastewater treatment failure.

Thank you for the evaluation request. If you are in need of further assistance or have questions regarding the report, please contact our office at P.O Box 250, Rolla, Mo 65402-0250, by telephone at 573-368-2100 or gspgeol@dnr.mo.gov.

Sincerely,

MISSOURI GEOLOGICAL SURVEY

-Molly a. Starkey

Molly Starkey Geologist Environmental Geology Section

e: Sippican, LLC WPP Southwest Regional Office



08/01/2019

.

Department's Alternatives Analysis - Lake Horizons WWTF Page 22

Missou Missou Geolog Environ	ri Department O ri Geological Surv ical Survay Progra mental Geology S	f Natural R ay am Section	lesources			Project ID N LWE19097 County Camden	lumber
Request Details							
	Project: Leke	Horizons V	WWTP	L	egal Description	34 T40N R18	w
					Quadrangle:	Bollinger Cree	ek
					Latitude:	38 11 4.43	
					Longitude:	-92 54 28.01	
Organizat	ion Official				Property		
	Name: Sipple	can, LLC			Name:	Jim Jackson,	Jr
	Address: PO B	ox 2047			Address:	PO Box 27	
	City: Cash	iers			City:	Camdenton	
	State: NC Z	lp: 28717			State:	MO Zip: 6502	0
	Phone: 999-9	99-9999			Phone:	573-873-3896	1
	Email:				Email:		
roject Dataile							
R	port Date: 08/01	/2019		Pre	vious Reports:	Not Applicable	8
Date of	Field Visit: 07/11	/2019					
Facility Type			Type of	Wasto	E	nding Source	
	treatment plant		[]Animi		×.	IWI I	
X Recirculation	g filter bed		Huma	in		WWL-SRF	
Land applic	stion		Proce	as or industrial			
Lagoon or s	torage basin		Lead	iste	Ad	dilional Inform	mation
Subsurface	soli absorption sy	stem	Other	waste type	Ő	Plans were sub	protited
Lagoon or s	torage basin W/L	and App				Site was invest	igated by NRCS
Lagoon or s	torage basin W/S	SAS				Soil or geotech	nical data ware
Other type of	a facility						
eologic Stream G	lassification: 🕅	Galoing	Losing	No discharge			
Oversil Geolo	gic Limitations	Collsose X Not ap	Potential plicable	Tenesciphy	1_40 [] 6	discipe Positi iroad uplands	Fioodplain
Moderate		Slight		4% to 8%		lidgetop	Altuvial plair
Severe		[] Moden	ate	8% to 15%	×	lillslope	Terrace
		Sevene		[2] >15%		arrow ravine	Sinkhole
edrock:	Ordovician-age	Gasconad	a Dolomite				
Phil Men-							

GN	Missouri Department Of Natural Rea Missouri Geological Survey Geological Survey Program Environmental Geology Section	ources	Project ID Number LWE19097 County Camden
	Recommended Construction Procedures for Earthen Facility	Determine Overburden Properties	Datamine Hydrologic Conditions
	Installation of day pad and Compaction	Atterberg limits	Direction of groundwater flow
	Diversion of subsurface flow	95% Max. dry density test method	25-Year flood level
	Artificial sealing	Overburden thickness	100-Year flood level
	Rock excavation	Permeability coefficient-undisturbed	
	Limit excavation depth	Permeability coefficient-remolded	

Remarks:

On July 11, 2019 a geologist with the Missouri Geological Survey (MGS) performed a geolydrologic evaluation for a proposed recirculating filter bed system in Camden County at Lake of the Ozarks. The proposed wastewater treatment facility will reportedly discharge into an unnamed tributary which flows southwest immediately into Lake of the Ozarks. The purpose of the evaluation was to determine the groundwater contamination potential in the event of treatment failure.

Uppermost bedrock at the site was identified as Ordovician-age Gasconade Dolomite, including chert replaced 'crypt reef' algal structures, which serve as a local marker bed approximately 6 feet above the Gunter Sandstone Member. The Gasconade Dolomite in this area has moderate to high permeability.

Surficial materials were a thin layer of very gravely residuum derived from the dolomite bedrock with high permeability. The observed thickness of surficial materials at the site ranged from 6 inches to approximately 1 foot.

Lake of the Ozarks is considered gaining for discharge purposes. There are no known strikholes or springs within one mile of the proposed facility.

Based on the geologic and hydrologic characteristics observed, the site receives a slight geologic fimilations rating. In the event of treatment failure the local, shellow groundwater aquifer and the surface waters of the Lake of the Ozarks may be adversally impacted.

> Department's Alternatives Analysis – Lake Horizons WWTF Page 24

Appendix B: Natural Heritage Review

(Applicant must check for rare and endangered aquatic species that may be affected by the discharge. The Department of Conservation maintains a "Missouri Natural Heritage Review Website" where you can request the necessary information. The results of the survey must indicate whether there are known endangered species on the site.)



Missouri Department of Conservation Missouri Department of Conservation's Mission is to protect and manage the forest, fish, and wildlife resources of the state and to facilitate and provide opportunities for all citzens to use, enjoy and learn about these resources.

Natural Heritage Review Level One Report: No Known Records

Foreword: Thank you for accessing the Missouri Natural Heritage Review Website developed by the Missouri Department of Conservation with assistance from the U.S. Fish and Wildfile Service, the U.S. Army Corps of Engineers, Missouri Department of Transportation and NatureServe. The purpose of this website is to provide information to federal, state and local agencies, organizations, municipalities, corporations and consultants regarding sensitive fish, wildlife, plants, natural communities and habitats to assist in planning, designing and permitting stages of projects.

PROJECT INFORMATION

Project Name and ID Number: Lake Horizons Waste Water Treatment Facility #6764 User Project Number: ACT671 Project Description: , 38 11 4.43/-92 54 28.01, Tributary to Lake of the Ozarks, Camden Project Type: Waste Transfer, Treatment, and Disposal, Liquid waste/Effluent, Wastewater treatment plant, Construction or expansion Contact Person: Steven Hamm Contact Information: steven.hamm@dnr.mo.gov or 573-526-1002

Missouri Department of Conservation

Page 1 of 5

Department's Alternatives Analysis – Lake Horizons WWTF Page 25

Disclaimer: The NATURAL HERITAGE REVIEW REPORT produced by this website identifies if a species tracked by the Natural Heritage Program is known to occur within or near the area submitted for your project, and shares suggested recommendations on ways to avoid or minimize project impacts to sensitive species or special habitats. If an occurrence record is present, or the proposed project might affect federally listed species, the user must contact the Department of Conservation or U.S. Fish and Wildlife Service for more information. The Natural Heritage Program tracks occurrences of sensitive species and natural communities where the species or natural community has been found. Lack of an occurrence record does not mean that a sensitive plant, animal or natural community is not present on or near the project area. Depending on the project, current habitat conditions, and geographic location in the state, surveys may be necessary. Additionally, because land use conditions change and animals move, the existence of an occurrence record does not mean the species/habitat is still present. Therefore, Reports include information about records near but not necessarily on the project site.

The Natural Heritage Report is not a site clearance letter for the project. It provides an indication of whether or not public lands and sensitive resources are known to be (or are likely to be) located close to the proposed project. Incorporating information from the Natural Heritage Program into project plans is an important step that can help reduce unnecessary impacts to Missouri's sensitive fish, forest and wildlife resources. However, the Natural Heritage Program is only one reference that should be used to evaluate potential adverse project impacts. Other types of information, such as wetland and soils maps and on-site inspections or surveys, should be considered. Reviewing current landscape and habitat information, and species' biological characteristics would additionally ensure that Missouri Species of Conservation Concern are appropriately identified and addressed in planning efforts.

U.S. Fish and Wildlife Service – Endangered Species Act (ESA) Coordination: Lack of a Natural Heritage Program occurrence record for federally listed species in your project area does not mean the species is not present, as the area may never have been surveyed. Presence of a Natural Heritage Program occurrence record does not mean the project will result in negative impacts. The information within this report is not intended to replace Endangered Species Act consultation with the U.S. Fish and Wildlife Service (USFWS) for listed species. Direct contact with the USFWS may be necessary to complete consultation and it is required for actions with a federal connection, such as federal funding or a federal permit; direct contact is also required if ESA concurrence is necessary. Visit the USFWS Information for Planning and Conservation (IPaC) website at hittps://ecos.fws.gov/lipac/ for further information. This site was developed to help streamline the USFWS envices Office may be reached at 573-234-2132, or by mail at 101 Park Deville Drive, Suite A, Columbia, MO 65203.

Transportation Projects: If the project involves the use of Federal Highway Administration transportation funds, these recommendations may not fulfill all contract requirements. Please contact the Missouri Department of Transportation at 573-526-4778 or <u>www.modot.mo.gov/ehp/index.htm</u> for additional information on recommendations.

Permit No. CP0002132

Missouri Department of Conservation

Page 2 of 5

> Department's Alternatives Analysis - Lake Horizons WWTF Page 26





Missouri Department of Conservation

Page 3 of 5

Department's Alternatives Analysis - Lake Horizons WWTF Page 27

Species or Communities of Conservation Concern within the Area:

There are no known records for Species or Natural Communities of Conservation Concern within the defined Project Area.

Other Special Search Results:

No results have been identified for this project location.

Project Type Recommendations:

Waste Transfer, Treatment and Disposal -Wastewater treatment plant: New or Maintenance; <u>Clean Water Act</u> permits issued by other agencies regulate both construction and operation of wastewater systems, and provide many important protections for fish and wildlife resources throughout the project area and at some distance downstream. Fish and wildlife almost always benefit when unnatural pollutants are removed from water, and concerns are minimal if construction is managed to minimize erosion and sedimentation/runoff to nearby streams and lakes, including adherence to any "Clean Water Permit" conditions.

Revegetation of disturbed areas is recommended to minimize erosion, as is restoration with of native plant species compatible with the local landscape and for wildlife needs. Annuals like ryegrass may be combined with native perennials for quicker green-up. Avoid aggressive exotic perennials such as crown vetch and sericea lespedeza. Management Recommendations for Construction Projects Affecting Missouri Streams and Rivers is a Conservation Department publication available at http://mdc.mo.gov/sites/default/files/resources/2013/02/constprojnearstreams_2013.pdf

Project Location and/or Species Recommendations:

Endangered Species Act Coordination - Indiana bats (*Myotis sodalis*, federal- and state-listed endangered) and Northern long-eared bats (*Myotis septentrionalis*, federal-listed threatened) may occur near the project area. Both of these species of bats hibernate during winter months in caves and mines. During the summer months, they roost and raise young under the bark of trees in wooded areas, often ripartan forests and upland forests near perennial streams. During project activities, avoid degrading stream quality and where possible leave snags standing and preserve mature forest canopy. Do not enter caves known to harbor Indiana bats or Northern long-eared bats, especially from September to April. If any trees need to be removed for your project, please contact the U.S. Fish and Wildlife Service (Ecological Services, 101 Park Deville Drive, Suite A, Columbia, Missouri 65203-0007; Phone 573-234-2132 ext. 100 for Ecological Services) for further coordination under the Endangered Species Act.

The project location submitted and evaluated is within the geographic range of nesting Bald Eagles in Missouri. Bald Eagles (*Haliaeelus leucocephalus*) may nest near streams or water bodies in the project area. Nests are large and fairly easy to identify. Adults begin nesting activity in late December and January and young birds leave the nest in late spring to early summer. While no longer listed as endangered, eagles continue to be protected by the federal government under the Bald and Golden Eagle Protection Act. Work managers should be alert for nesting areas within 1500 meters of project activities, and follow federal guidelines at: http://www.fws.gov/midwest/Midwest/Midwest/Bird/EaglePermits/index.html if eagle nests are seen.

The project location submitted and evaluated is within the range of the Gray Myotis (i.e., Gray Bat) in Missouri. Depending on habitat conditions of your project's location, Gray Myotis (*Myotis grisescens*, federal and state-listed endangered) could occur within the project area, as they forage over streams, rivers, lakes, and reservoirs. Avoid entry or disturbance of any cave inhabited by Gray Myotis and when possible retain forest vegetation along the stream and from the cave opening to the stream. See <u>http://mdc.mo.gov/104</u> for best management recommendations.

Missouri Department of Conservation

Page 4 of 5

Department's Alternatives Analysis – Lake Horizons WWTF Page 28

Invasive exotic species are a significant issue for fish, wildlife and agriculture in Missouri. Seeds, eggs, and larvae may be moved to new sites on boats or construction equipment. Please inspect and clean equipment thoroughly before moving between project sites. See <u>http://mdc.mo.gov//9633</u> for more information.

- Remove any mud, soil, trash, plants or animals from equipment before leaving any water body or work area.
- Drain water from boats and machinery that have operated in water, checking motor cavities, live-well, blige and transom wells, tracks, buckets, and any other water reservoirs.
- When possible, wash and rinse equipment thoroughly with hard spray or HOT water (?140° F, typically available at do-it-yourself car wash sites), and dry in the hot sun before using again.

Streams and Wetlands – Clean Water Act Permits: Streams and wetlands in the project area should be protected from activities that degrade habitat conditions. For example, soil erosion, water pollution, placement of fill, dredging, in-stream activities, and riparian corridor removal, can modify or diminish aquatic habitats. Streams and wetlands may be protected under the Clean Water Act and require a permit for any activities that result in fill or other modifications to the site. Conditions provided within the U.S. Army Corps of Engineers (USACE) Clean Water Act Section 404 permit (<u>http://www.mwk.usace.army.mil/Missions/RegulatoryBranch.aspx</u>) and the Missouri Department of Natural Resources (DNR) issued Clean Water Act Section 401 Water Quality Certification (<u>http://dnr.mo.gov/env/wpp/401/index.html</u>), if required, should help minimize impacts to the aquatic organisms and aquatic habitat within the area. Depending on your project type, additional permits may be required by the Missouri Department of Natural Resources, such as permits for stormwater, waslewater treatment facilities, and confined animal feeding operations. Visit <u>http://dnr.mo.gov/env/wpp/emits/index.html</u> for more information on DNR permits. Visit both the USACE and DNR for more information on Clean Water Act permitting.

For further coordination with the Missouri Department of Conservation and the U.S. Fish and Wildlife Services, please see the

contact information below. MDC Natural Heritage Review Resource Science Division P.O. Box 180 Jefferson City, MO 65102-0180 Phone: 573-522-4115 ext. 3182 Natural HeritageReview@mdc.mo.gov

U.S. Fish and Wildlife Service Ecological Service 101 Park Deville Drive Suite A Columbia, MO 65203-0007 Phone: 573-234-2132

Miscellaneous Information

FEDERAL Concerns are species/habitats protected under the Federal Endangered Species Act and that have been known near enough to the project site to warrant consideration. For these, project managers must contact the U.S. Fish and Wt/dife Service Ecological Services (101 Park Deville Drive Suite A, Columbia, Missouri 65203-0007; Phone 573-234-2132; Fax 573-234-2181) for consultation.

STATE Concerns are species/habitats known to exist near enough to the project site to warrant concern and that are protected under the Wildlife Code of Missouri (RSMo 3 CSR 1 0). "State Endangered Status" is determined by the Missouri Conservation Commission under constitutional authority, with requirements expressed in the Missouri Wildlife Code, rule 3CSR 1 0-4.111. Species tracked by the Natural Heritage Program have a "State Rank" which is a numeric rank of relative rarity. Species tracked by this program and all native Missouri wildlife are protected under rule 3CSR 10-4.110 General Provisions of the Wildlife Code.

Additional information on Missouri's sensitive species may be found at http://mdc.mo.go/discover-nature/field-guide/endangered-species. Detailed information about the animals and some plants mentioned may be accessed at http://mdc4.mdc.mo.gov/applications/motwis_search1.aspx. If you would like printed copies of best management practices cited as internet URLs, please contact the Missouri Department of Conservation.

Missouri Department of Conservation

Page 5 of 5

Department's Alternatives Analysis – Lake Horizons WWTF Page 29

Appendix C: Antidegradation Review Summary Forms

The forms that follow contain summary information provided by the applicant.

Department staff determined that the following changes must be made to the information contained within these forms:

- 1) Antidegradation Review Summary / Request form: No changes.
- Antidegradation Review Submittal: Voluntary Tier 2 Significant Degradation for Domestic Wastewater Facilities with Design Flow Less Than 50,000 Gallons Per Day:
 - Regionalization and No Discharge Form, Geohydrologic Evaluation, and Missouri Natural Heritage Review were used in this Antidegradation Review.
- 3) Antidegradation: Regionalization and No-Discharge Evaluation: No changes

G		OURI DEPA	TMENT OF	NATURAL I	RESOURCES		ACTO
1	ANT TIER	DETERM	ATION RE	AND EFFI	RRARY LUENT LIMIT SUM	Water Protection Pr	ogram
1.77	CLITY						and the state of
1000	Alada and Marine	-				TELEPHO	HE HUNBER WITH ASLES CO
ADDRE	BLOHPUCALI	<u> </u>			CITY	828-74	3-3223
Lake	Horizons Drive				Gravois Mills	MO	65037
2. RE	CEIVING WA	TER BODY	SEGMENT	r #H	A STATES		de.
Leke	of the Ozerka						
2.1	UPPER END	OF SEGMENT	(Location of o	decharge)	W22*EUUO!		
2.2	LOWER END	OF SEGMENT	Lat 1150	1 I Q LONG	24.42		
Per 24	UTM	OR Bits and b	Let	Long	P. the definition of a second in	account is a section of motor it	and in bound of a printer of
ogn-o	ant autoling sources	and confluences	with other agent	icant water bodi	a."		
3. W	ATER BODY 8	SEGIMENTS	2 (IF APPI	JCABLE)		1101	
3.1	UPPER END	OF SEGMENT					
3.2	LOWER END	OF BEGMENT		, Long			
4. W/	ATER BODY S	SEGMENT	S (IF APPL	ICABLE)	The American	210	10.00
NAME							
*1	UTM	OR	Lat	Long			
4.2	LOWER END	OF SEGMENT					
	D IECT INEO	DHATION	1.81	Long			
le the	receiving wate	r body en O	utstanding	National Re	source Water, an Outsi	anding Siste Resource	Water, or drainage
there	to?	THE NO.			,		18
		LE NO					
In Tab Per th unies	e Antidegradations the discharge of the second seco	10 CSR 20-7. on Implement	031, Outstar stion Process temporary of	tions Nation ture Section	al Resource Waters and 1.B.3, "ony degradation "Therefore, if decredation	Outstanding State Resou of water quality is prohibit on is algorithms or minima	rce Water are listed ted in these waters
Ravia	w will be denied						
CONCI	he proposed de intration of the	echarge of a receiving w	il pollutants ater after m	i of concern Ixing?	, or POCs, result in no	net increase in the ambi	lent water quality
	Yes Yes	No No	1.46.0600.00				
If you	submit a summ	arv table sho	wing the leve	ais of each o	cilutent of concern befor	and after the proceed	discharge in the
recelv	ing water and th	en completa	Attachment	B for the first	downstream cleasified	valer body segment.	onor ange at ano
Will B	ne discharge re	suit in temp	orary degra	dation?			
	1100	(0) NO					
If yes.	complete Attac	hment C.		and the set			
Mas 1	Yes	No No	as non-deg	prading7			
lf yes, Submi	complete No D	egradation Ev	aluation - C	conclusion of	Antidegradation Review	form.	
Hum	to one of the	above que	allana aki	in to Reatly	B Mat Westberg	THE REPORT OF	

1

Department's Alternatives Analysis - Lake Horizons WWTF Page 31

6. EXISTING WATER QUALITY DATA OR MODEL SUMMARY Obtaining Existing Water Quality is possible by three methods according to the Antidegradetion Implementation Procedure Section II.A.1.: (1) using previously collected data with an appropriate Quality Assurance Project Plan, or QAPP (2) collecting water quality data by approved the Missouri Department of Natural Resources methodology or (3) using an appropriate water quality model. QAPPs must be submitted to the department for approval well in edvance (exit months) of the proposed exitvity. Provide all the appropriate corresponding data and reports which were approved by the department Water Quality Monitoring and Assessment. Section. Date addsting water quality data was provided by the Water Quality Monitoring and Assessment Section: Approval date of the QAPP by the Water Quality Monitoring and Assessment Section: Approval data of the project sampling plan by the Water Quality Monitoring and Assessment Section: Approval data of the data collected for all appropriate pollutanta of concern by the Water Quality Monitoring and Assessment Section: Commente/Discussion: None 7. POLLUTANTS OF CONCERN AND TIER DETERMINATION(S) Prolutions of Concern to be considered include those pollutarits researching expected to be present in the discharge par the Antidegradation Implementation Procedure Section II.S. The tier protection levels are apacitiad and defined in rule at 10 CSR 29-7.031 (2). Water Body Segment One Pollutants of Concern and Tier Determination(s) Tier 2 with Minimal Degradation Tier 2 with Significant Degradation Tier 1 00' Facal Ammonis* TSS" BOD-5* Note: Add an asterisk to items that you only assume are Tier 2 with significant degradation. Water Body Segment Two Pollutants of Concern and Tier Determination(s) Tier 1 Tier 2 with Minimal Degradation Tier 2 with Significant Degradation For pollutants of concern that are Tier 2 with significant degradation, complete Attachment A. For pollutants of concern that are Tier 2 with minimal degradation, complete Attachment B. · For pollutants of concern that are Tier 1, complete Attachment D. Additionally, a Tier 2 review must be conducted for each pollutant of concern on the appropriate water body segment 8. WET WEATHER ANTICIPATIONS If an applicant anticipates excessive inflow or infitmation and pursues approval from the department to bypess secondary treatment, a feasibility analysis is required. The feasibility analysis must comply with the criteria of all applicable state and federal regulations including 40 CFR 122.41(m)(4). Attach the feasibility analysis to this report. What is the Wet Weether Flow Peaking Factor in relation to design flow? Wet Weather Design Summary: No Infilmation

Department's Alternatives Analysis – Lake Horizons WWTF Page 32

terminant me proposet possenti a co	costs and deel undercone surrant naute	And has related to the state of the state	FLUERI LIMITS	1999	Tables, Statements South
		a na na mana na mana sa sa sa sa sa sa	and and		
Polulant of Concern	Units	Westeload Allocation	Average Monthly	Limit	Delly Maximum Lim
8005	mo/L		10		
TSS	mo/L		15		
Dissolved Oxygen	mg/L		5		
Ammonia			4.6/4.6		
Bacteria (E. Coli)	#CoV100mg		126		
Fecal	accov 100mg		400	-	
				_	
These proposed limits must re regulatory requirements.	st violate water quality stande	nda, be protocitive of baneficial u	aes and achieve the h	ighest stak	Acry and
Attach the Antidegradation Re	view report and all supporting	o documentation			
CONSULTANT: I have p	repared or reviewed this f	shopen benasits he bna and	and documentation	The con	olusion proceed is
consistent with the Anadag	tacaeon antifermouration t	PTOCEGUNE AND CHEVER STORE	and redecim regulation	n.	
amark	X-DO/02	26		7	12019
Jmes O. Jackson, Jr., PE		V			
COMPANY NAME	6				
Lake Professional Enginee	ring Services				
ADDREBS		OTTY	BTA	E	20P 0008
PO Box 27		Camdenton	MC)	65020
TELEPHONE NUMBER WITH AREA CO 573-873-3898	20E	8-MAR ADDRESS			
OWNER: I have road an	d reviewed the prepare	d documents and agree v	vith this submittel.	2	
W. O. Pathin	My. Mar. Si	HICAN, LLC		6/1.	2/ 2019
Bill Patherson					
ADDRESS		OTY	STA:		ZP CODE
PO Box 2047		Cashiers	NO		28717
TRUEPHONE HUSING WITH AREA OF	000	E46AE ACORDES			
828-743-5225					
CONTINUING AUTHOR maintenance and moderniz	STY: Continuing Authority ation of the facility. The re ble at www.acs.mo.gov/ad he prepared documents at	y is the permanent organizat squietory requiritment regard invies/carcoment/10car/10c2 nd agree with this submittal	ion that will be respo ling continuing auth 0-6a.pdf	ansible for arity is fou	the operation. nd in
10 CSR 20-6.010(3) availa- I have read and reviewed th				DATE	1
10 CSR 20-6 010(3) availa I have read and reviewed it schwrune W. G. P. A.	- Myr. Mon, S	IPPICED, LIC		6/12	12019
10 CSR 20-6 010(3) evaluation I have read and reviewed to sometime and reviewed to www.e.wo.christen Bill Patterson	- My. Mon, 5	IPPICED, LIC		6/12	1209
10 CSR 20-5 010(3) availa I have read and reviewed it sonature W. C. P. A. W. B. P. C. Bill Patterson ADDESSS	-, Mze. Men, 5	IPPICE, LC	- et A1	6//2	2019

 ${\mathcal A}^{(i)}$

Department's Alternatives Analysis - Lake Horizons WWTF Page 33

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH ANTIDEGRADATION REVIEW SUMMARY FOR PUBLIC NOTICE ATTACHMENT A: TIER 2 - SIGNIFICANT DEGRADATION

ake Horizone WWTP		(828) 74	E M, MBER WITH AREA CO 3-5225
ADDRESS (PHYSICAL)	CITY	STATE	1 ZP 000E
ake Horizons Road	Gravois Milts	MO	65037
OWNER-	Charles and a second second second	The state of the state	
HAVE AND OFFICIAL TITLES			
lippican, LLC			
DORESS	OILA	STATE	ZIP 0006
O Box 2047	Ceshiers	NC	28717
BLEPHONE NUMBER WETLAREA COOK 328) 743-5225	E-MAIL ADORESS		
CONTINUES ANTWORMY The regulatory IB	guirement regarding continuing authority 56, pdf.	ls found in 10 CSR 20	-5-010(3) available
ake Horizons Homeowners Assocition			
00%010	OTY	STATE	ZIP CODE
D Box 2047	Cashiers	MO	28717
ELEPHONE NUMBER WITH AREA CODE	B-MAIL ADDRESS		
28) 743-5225			
RECEIVING WATER BODY SEGMENT #1	D11.16 92D54.42		
UPPER END OF SEGMENT (Location of dia UTM OR Let <u>N38°]</u> LOWER END OF SEGMENT UTM OR Let	charge) .] (c ['] Long <u>W92</u> 54.47 Long <u>Long</u> (AP, the defailon of a segment, 's segment is a segment.	action of weller that as bound,	el a minimum, by signalic
WATER BOLY SEGMENT #2 (IF APPLICABL	E. Use another form it a third segmen	t is needed)	
UPPER END OF SEGMENT UTM OR Let LOWER END OF SEGMENT	Long		
UTM OR Lat	Long		
WET WEATHER ANTICIPATIONS			1.1
and a second	ration and pursues approval from the de	pertment to bypass sec applicable state and fer	condary treatment.
en applicant anticipates excessive inflow or Infili asibility analysis is required. The feasibility ana cluding 40 CFR 122.41(m)(4). Attach the feasib	lysis must comply with the criteria of all ility analysis to the antidegradation revie	w report.	orer regulations
en applicant anticipates excessive inflow or inflit asibility analysis is required. The feasibility ana cluding 40 CFR 122.41(m)(4). Attach the feasib hat is the Wet Weather Flow Peaking Factor in	ilysis must comply with the criteria of all kity energysis to the antidegradation revie relation to design flow? 1	w report.	oner regulatorne
en applicant anticipates excessive inflow or inflit asibility analysis is required. The feasibility and cluding 40 CFR 122.41(m)(4). Attach the feasib hat is the Wet Weather Flow Peaking Factor in et Weether Design Summary;	lysis must comply with the criteria of all lity energies to the antidegradation revie relation to design flow? 1	w report.	Joner regulatoria

[Type text]

Department's Alternatives Analysis -- Lake Horizons WWTF Page 34

it s≛

Level Head WATER QUALITY DATA OR MODEL SUMMARY
 Obtaining Existing Water Quality is possible by three methods according to the Antidegradation Implementation Procedure Section
 II.A.1.: (1) using previously collected data with an appropriate Quality Assumance Project Plan, or QAPP (2) collecting water quality
 data approved by the Missouri Department of Natural Resources methodology or (3) using an appropriate water quality model.
 QAPPs must be submitted to the department for approval well in advance (six months) of the proposed activity. Provide all the
 appropriate corresponding date and reports which were approved by the desamined Protection Section. Additional
 Information needed with the EWQ data includes: 1) Date existing water quality date was provided by the Wistershed Protection
 Section, 2) Approval date by the Watershed Protection Section of the QAPP, project sempling piss, and data collected for all
 appropriate Proce.

Comments/Discussion:

& SUMMARY OF THE POLLUTANTS OF CONCERN AND THE PROPOSED EFFLUENT LIMITS

Pollutants of Concern to be considered include those pollutants reasonably expected to be present in the discharge per the Antidegradation Implementation Procedure Section II A, and assumed or demonstrated to cause significant degradation. The tier protection levels are specified and defined in rule at 10 CSR 20-7.031 (2).

What are the proposed pollutants of concern and their respective effluent [mits that the selected trostment option will comply with:

MG/L M/GA		10	
M/24		19	
and the second s		15	
MGAL		5	
MGAL		4.6/4.6	
CFUS		126	
water quality stands	ards, be protective of baneficial uses.	, and achieve the highest statut	ory and regulatory
	MGAL MGAL MGAL CFUS water quality stands	MG/L MG/L CFUS water quality standards, be protective of baneficial uses	MGR_ 15 MGR_ 5 MGR_ 6 CFUS 128 water quality standards, be protective of baneficial uses, and achieve the highest status

*Assumed Tior 2.

9. IDENTIFYING ALTERNATIVES Supply a summary of the alternatives considered and the level of insetment attainable with regards to the alternative. "For Discharges Risky to cause significant degradation, an analysis of non-degrading and less-degrading alternatives must be provided," as stated in the Antidegradation implementation Procedure Section II.B.1. Per 10 CSR 20-6.010(4)(D)1., the feasibility of a no-discharge system must be considered. Attach all supportive documentation in the Antidegradation Raview report.

Applicants choosing to use a new wastewater technology that are considered an "unproven inchnology" in Missouri in their Teer 2 Reviews with alternative analysis must comply with the regularmonis set forth in the New Technology Definitions and Requirements Fectaheet that can be found at. http://dnr.mo.gow/pubs/pub2453.edf.

Non-degrading alternatives: Land Application; On-site Septic System

Atternatives ranging from less-degrading to degrading including Preferred Alternative Alternatives ranging non-more ways at a minimum meet water quality standards): (All treatment levels for POCs must at a minimum meet water quality standards):

Alternatives	Layer or Fra	Statistic Analysis of	e for bech Ponular	t of Concern		
	B0D5	TSS	AMIMONIA AS N	E Coli	00	
	(HIG/L)	MGA.	MGA.	#/100mL	mg/L	
Dolta EcoPOD	20	20	4.5/4.5	126	5	
Bio-Microbics	20	20	4.8/4.8	126	5	
Extended Aeration	20	20	4 6/4.6	126	5	
Sand Filter	10	15	4.6/4.6	126	5	
Zabel SCAT	10	15	4.6/4.6	126	5	
Orenco Advantex	10	15	4.6/4.8	126	5	
Membrane Reactor	1	2	1.0/2.5	126	5	
NO 190-2021 (2013)	100 00 00 00 00 00 00 00 00 00 00 00 00	-				Date 2

Page 2

10. DETERMINATION OF THE REASONABLE ALTERNATIVE
Per the Antidegradation Implementation Procedure Section II.8.2, "a reasonable alternative is one that is practicable, economically efficient and affordable." Provide basis and supporting documentation in the Antidegradation Review report. Please do not write "See Report" for any box below.
Practicability Summary:
"The practicability of an alternative is considered by evaluating the effectiveness, reliability, and potential environmental impacts," according to the Antidegradation implementation Procedure Section II.B.2.a. Examples of factors to consider, including secondary environmental impacts, are given in the Antidegradation Implementation Procedure Section II.B.2.a.
Land application, on-site treatment, subsurface irrigation, and subsurface treatment were found to be not technically feasible. EcoPOD and Microfest were elso found to be not technically feasible. Fabric fitter, sand filter, and extended seration were all found to meet effective and reliability issues as well as environmental factors.
Economic Efficiency Summary:
Alternatives that are deemed practicable must undergo a direct cost comparison in order to determine economic efficiency. Means to determine economic efficiency are provided in the Antidegradation Implementation Procedure Section II.B.2.b.
Present worth economic analysis showed the cost effective alternative to be a Sand Filter.
Affordebility Summary:
Atternatives identified as most practicable and economically efficient are considered affordable if the applicant does not supply an affordability analysis. An affordability analysis per the Antidegradation Implementation Procedure Section II.8.2.c, "may be used to determine if the alternative is too expensive to reasonably implement."
lot Performed
Preferred Chosen Altamative:
and filter
tessons for Rejecting the other Evaluated Alternatives:
treatructure already installed from previous permit. Recirculation tank and sand filter bed structure already installed from previous ermit.
Somments/Discussion:
il alternatives are capable of meeting water quality atanderds.
R YMC MAL ANALY

HO 780-2001 (02/10)

e - 1

	ion, then it must be demonstrated that it will allow important economic a
social development in accordance to the Anädegradistion in is defined as the social and sconomic benefits to the commissionarge.	replanantation Procedure Section II.E. Social and Economic Importanc runity that will occur from any activity involving a new or expending
icialidity the pillaciad community:	
The affected community is defined in 10 CSR 20-7.031(2 are located.: Per the Antidsgradetion Implementation Pn living near the site of the proposed project as well as tho from the project."	2)(B) as the community "in the geographical area in which the waters ocedure Section II.E.1, "the affected community should include these as in the community that are expected to directly or indirectly benefit.
Vacationens and people who enjoy the Lake of the Ozarks a Ozarks.	is well as the landowners adjoining and surrounding the Laka of the
Identify relevant lisetore that characterize the eoclel and	d economic conditions of the affactual community:
Examples of social and economic factors are provided in specific community examples are encouraged.	the Antidegradation implementation Procedure Section II.E.1., but
Maintaining and possibly increasing the tax base to the com	vmunity.
Describe the important social and economic developme Determining banefits for the community and the environm Implementation Procedure Section II.E.1	ent seeoclated with the project: sent should be also specific and in accordance with the Antidegradation
Higher Heikesson Processon & Cesson Inco. 1.	
The lots being served by this processed treatment facility are	located on your steep lots with your shellow acie. The use of on-site
septic avalants under these conditions are likely to fall. Failu	ure of an on-aite sentic system will more than tirely discharge unmediat
eewege into the Lake of the Ozarks	
DOODDED DOO KOT BUILBADY	
FILT DES FILDEST OF THE PLT	
Provide treatment for 8t houses for working class families.	Provide monitored aswege treatment at acceptable discharge levels
Provide treatment for 8t houses for working class families. Utilizing a sand #ter. At	Provide monitored sewege treatment at acceptable discharge levels
Provide treatment for 8t houses for working class families. utilizing a sand Rter, 24	Provide monitored sewege treatment at acceptable discharge levels
Provide treatment for 82 houses for working class families. utilizing a sand Risr. H	Provide monitored servege treatment at acceptable discharge levels
Provide treatment for 8t houses for working class families. utilizing a sand filter. H	Provide monitored sewege treatment at acceptable discharge levels
Provide treatment for 82 houses for working class families. utilizing a sand filler. If	Provide monitored aswege treatment at acceptable discharge levels
Provide treatment for 8t houses for working class families. utilizing a sand filter. At	Provide monitored sewage treatment at acceptable discharge levels documentation. This is a technical document, which must be signed, litesouri.
Attach the Antidegradation Review report and all supporting essied and dided by a registered professional engineer of b CONSULTART: I have proposed or reviewed this form and consistent with the Antidegradation Imposer	Provide monitored aswege treatment at acceptable discharge levels a documentation. This is a technical document, which must be signed, discourt. All statistics response and closumentation. The construinon proposed is tarBation Propertie and cument state and factored regulations.
Attach the Antidegradation Review report and all supporting excision and dated by a registered professional engineer of b CONSEQUITANT: I have prepared or reviewed this form and consistent with the Antidegradation Implier Solutions	Provide monitored servege treatment at acceptable discharge levels documentation. This is a technical document, which must be signed, descurt. Based response and decumentation. The construion proposed is tarbation Properties and decument state and factorial regulations.
Attach the Antidegradation Review report and all supporting seeled and duted by a registered professional engineer of b CONSIGNUT ANT 1 have prepared or reviewed this form and consistent with the Antidegradation Import consistent with the Antidegradation Import Review Technology (Constant) (Consistent with the Antidegradation Import Review Technology (Constant)	Provide monitored servege treatment at acceptable discharge levels documentation. This is a technical document, which must be signed, lissouri. all statched reports and documentistics. The conclusion proposed is harbetion Properties and comment state and tectorial applications. Lake Professional Engineering Services, Inc.
Attach the Antidegradation Review report and all supporting cessed and dated by a registered professional engineer of h CORRECT ANT: I have prepared or reviewed this form and consistent with the Antidegradation Inspect of the CORRECT ANT: I have prepared or reviewed this form and consistent with the Antidegradation Inspect of the CORRECT ANT: I have prepared or reviewed this form and consistence, trutes (uclimbe a sector of the Correct o	Provide monitored servege treatment at acceptable discharge levels documentation. This is a technical document, which must be signed, iteracuri. all statistics reports and document state and factorel egylicitons. Date 1 2009 Conver reset Lifke Professional Engineering Services, Inc. Cnv Camdenton Braze
Attach the Antidegradation Review report and all supporting seeled and ditied by a registered professional engineer of h CONSIDULTANT: I have prepared or reviewed this form and consistent with the Antidegradation Import consistent with the Antidegradation Import consistence PO Box 27 TELEPHONE MANDER WITH AREA CODE	Provide monitored servege treatment at acceptable discharge levels a documentation. This is a technical document, which must be signed, assouri. all statistics response and closument state and todans proposed is tarbation Properties and closument state and todans gravitations. Conversional Engineering Services, Inc. Conv Camdenton EAVE 2002 EAVELADOREDE
Attach the Antidegradation Review report and all supporting seeled and doted by a registered professional engineer of h consistent with the Antidegradation Ingineer of h consistent with the Antidegradation Ingineer of h consistent with the Antidegradation Ingineer of h seawnune www.exano.org.com.it., PE PE-2003014984 Aponese PO Box 27 TELEPHONE HANDER WITH AREA CODE 573) 873-3898	Provide monitored servege treatment at acceptable discharge levels adocumentation. This is a technical document, which must be signed, assouri. all statistics response and closument state and todonsi responded is hardstoin Propedure and current state and todonsi regulations. Convert wass Life Professional Engineering Services, Inc. Conv Camdenton EMD EMML ADDRESS
Attach the Antidegradation Review report and all supporting seeled and doted by a registered professional engineer of b construct TANT: I have prepared or reviewed the form and construct TANT: I have prepared or reviewed the form and construct TANT: I have prepared or reviewed the form and construct TANT: I have prepared or reviewed the form and construct TANT: I have prepared or reviewed the form and construct the Antidegradation Imposer pownume Net no orneow, thus runned and provided Aconese PO Box 27 TELEPHONE Have read and reviewed the propered documents	Provide monitored servege treatment at acceptable discharge levels documentation. This is a technical document, which must be signed, itesouri. all statistical response and document state and factorial angulations. Date 1 2019 Comment state and factorial angulations. Conv Camdenion Romeering Services, Inc. City Camdenion Romeering Services, Inc. City City City City City City City City
Attach the Antidegradation Review report and all supporting easied and filter. H Attach the Antidegradation Review report and all supporting easied and disted by a registered professional engineer of h CD36504, TANKT I have prepared or reviewed the form and in consistent with the Astidegradation Imposer scenarios of the second state of the	Provide monitored servege treatment at acceptable discharge levels advourmentation. This is a technical document, which must be signed, descuri. all statistical response and decoursements. The construinon proposed is terflaction Procedure and current state and tectonic eguidations. Conv Note Long Professional Engineering Services, Inc. Conv No Example Cemidention Example Services Example Ser
Provide treatment for 82 houses for working class families, utilizing a sand filter. If Attach the Antidegradation Review report and all supporting seeled and duted by a registered professional engineer of b CORRELIVANET 1 have prepared or roviewed this form and consistent with the Astidegradation Imposer seven the Antidegradation Review Polessional engineer of b Consistent with the Astidegradation Imposer seven the Antidegradation Review Polessional engineer of b Consistent with the Astidegradation Imposer seven the Antidegradation Review of the Astidegradation Imposer seven the Antidegradation Imposer seven the Antidegradation PE-2003014984 Appears 0. Jackson, Jr., PE PE-2003014984 Appears 0	Provide monitored servege treatment at acceptable discharge levels a documentation. This is a technical document, which must be signed, assount. a of statistical response and closumentation. The construction proposed is tartistion Procedure and current state and factorial regulations. Convert was Linus Professional Engineering Services, Inc. Convert was Linus Professional Engineering Services, Inc. Convert WAD E-MAIL ADORESE a and agree with this submittal. Transol LLC Date () 12/ 2019 () 12/
Provide treatment for 82 houses for working class families, utilizing a sand filter. If Attach the Antidegradation Review report and all supporting seeled and dubed by a registered professional engineer of b CONSIGNUL TART 1 have prepared or reviewed the form and consistent with the Antidegradation Import consistent with the Antidegradation Import consistent with the Antidegradation Import consistent with the Antidegradation Import annes O. Jackson, Jr., PE PE-2003014984 Aconese PO Box 27 TELEPHONE IMMERIAL FOR PE-2003014984 Aconese PO Box 27 TELEPHONE IMMERIA and good reviewed the propared document EDWAY Distribution AUTHORITY: I have read and reviewed the f sover the Constitution of the propared document EDWAY	Provide monitored servege treatment at acceptable discharge levels a documentation. This is a technical document, which must be signed, assount. all statistical response and closument state and factorial regulations. Convert was Linus Professional Engineering Services, Inc. City Cemidenton E-MAL Aborese a and agree with this submittal. Instical Linus Auditation Centre and agrees with this submittal. Centre and agrees with this subm

Department's Alternatives Analysis - Lake Horizons WWTF Page 37

RECEIVED

ANTIDEGRADATION REVIEW SUBALITAL, VOLUNTARY TIER 2 – SIGNIFICANT DEGRADATION FOR DOMESTIC WASTEWATER FACILITIES WITH DESIGN FLOW LESS THAN 50,000 GALLONS PER DAY 1. APPLICABILITY If you answer "Yes" to any of the below questions, a sile-specific alternatives analysis may be required. The Missouri Department of Natural Resources' alternatives analysis is not applicable to facilities that have a Total Maximu Daily Load (TMDL) or are 303(d) or 305(b) listed for the politutants of concern addressed in this alternatives analysis, w	an
WASTEWATER FACILITIES WITH DESIGN FLOW LESS THAN 50,000 GALLONS PER DAY A APPLICABILITY If you answer "Yes" to any of the below questions, a sile-specific alternatives analysis may be required. The Missouri Department of Natural Resources' alternatives analysis is not applicable to facilities that have a Total Maximu Daily Load (TMDL) or are \$43(d) or 305(b) listed for the politications of concern addressed in this alternatives analysis, w	an
 APPLICABILITY If you answer "Yes" to any of the below questions, a site-specific alternatives analysis may be required. The Missouri Department of Natural Resources' elternatives analysis is not applicable to facilities that have a Total Maximu Daily Load (TMDL) or are \$03(d) or 305(b) listed for the politications of concern addressed in this alternatives analysis, w 	CHE
If you answer "Yes" to any of the below questions, as its specific alternatives analysis may be required. The Missouri Department of Natural Resources' alternatives analysis is <i>not</i> applicable to facilities that have a Total Maximu Daily Load (TMDL) or are \$83(d) or 365(b) listed for the pollutants of concern addressed in this alternatives analysis, w	
The Missouri Department of Natural Resources' alternatives analysis is not applicable to facilities that have a Total Maximu Daily Load (TMDL) or are 303(d) or 305(b) listed for the pollutants of concern addressed in this alternatives analysis, w	
exception for E. coli since disinfection will be required.	m Ith an
Facilities currently under enforcement will need to coordinate with the Water Protection Program's compliance and enforcement section to determine applicability for the department's alternatives analysis.	
1.1 Does the receiving waterbody or downstream waterbody have a Total Maximum Daily Load (TMCL)?	No
1.2 is the receiving waterbody or dow natream waterbody 303(d) or 306(b) listed as impaired	No
1.3 is the facility currently under enforcement with the department, or the U.S. Environmental Protection Agency? Yes 7	No
1.4 is the design flow 50,000 gallons per day or more? Yes V No	
15 is a non-discharging system a visible online? If Yes II No	
Salamit the rollowing with this form:: Regionalization and No Discharge Extlusion Form - Available on the department's website Copy of the Geological Survey website	
Submit the rollowing with this form:: Regionalization and No Discharge Excluation Form - Available on the department's website Copy of the Geohydrologic Evaluation - Submit request through the Mesouri Geological Survey website Copy of the Mesouri Natural Heritage Review from the Mesouri Department of Conservation website EACH REV	
Submit the roleowing with this form: Regionalization and No Dischargo Exclusion Form - Available on the department's website Copy of the Geohydrologic Evaluation - Submit request through the Mesouri Geological Survey website Copy of the Mesouri Natural Heritage Review from the Missouri Department of Conservation website FACILITY	_
Statem it the roleowing with this form:	
Statem it the rollowing with this form: Regionalization and No Discharge Evaluation Form - Available on the department's website Copy of the Geohydrologic Evaluation - Submit request through the Mesouri Geological Survey website Copy of the Mesouri Natural Heritage Review from the Mesouri Department of Conservation website 2. FACILITY Name Lake Horizons WWTP County Coun	
Station it the roleowing with this form:	
Statem it the roleowing with this form: Regionalization and No Discharge Excluation Form – Available on the department's website Copy of the Geohydrologic Evaluation – Submit request through the Mesouri Geological Survey website Copy of the Mesouri Natural Heritage Review from the Missouri Department of Conservation website 2. FACILITY NAME Lake Horizons WWTP Common State Lake Horizons Road 3. OWWER	
Statem it the roleowing with this form: Regionalization and No Dischargo Exclusion Form – Available on the department's website Copy of the Geohydrologic Evaluation – Submit request through the Mesouri Geological Survey website Copy of the Mesouri Natural Heritage Review from the Missouri Department of Conservation website FACILITY NAME Lake Horizons WWTP Representation Road COUNTY Camdon Representation Road COUNTY Camdon County County Camdon County County County Camdon County County County County County County County County County County County County	
Statem it the rollowing with this torns:	

Department's Alternatives Analysis - Lake Horizons WWTF Page 38

Unnemed Tributary to the Lake of the Ozarks \$8011.16 @2054.42						*
5.1 Upper and of segment - Location of discharge	111 16			20 130		
UTINE X#, Y@ URL at	/11.10		.ong _	21204.42		
UTM: X= Y=OR Lat			ong	-		Per the
Missouri Antidegradation Instanzatation Procedure (AP), the datavian of a minimum, by significant activity sources and confluences with other significa	and water	t is: "A se budise."	ction of	water that	t is boun	nd, at e
6. WATER BODY SEGMENT #2 (If Nocessary)						
1 Upper and of second as End of Second #1				_		
UTM: X= Y= OR Lat	33	Long				
5.2 Lower and of segment -				1		
UTM: X* Y* OR	Lat			Long	-	
7. SOCIAL AND ECONOMIC IMPORTANCE OF THE PREFERRED ALTER	NATIVE					
This section must be completed with adequate and thorough descriptions of proposed project in accordance with the Antidegradation implementation. Pro	the acclude to	and acc Section Lt	norric à	mportance ischarge to	be allo	aled with ti wed.
Social and economic importance is defined as the social and economic bene involving a new or expanding discharge. 7.1 Identify the sifected cosessually:	sfilm to the	e commun	ty that	wäeccur	from ere	у асбиіку
(The affected community is defined in 10 CSR 20-7.031(2)(8) as the co are located." For the Antidegradation trajtementation Procedure Section living near the site of the proposed project as well as those in the commu- from the project.")	a LE1, " unity the	"In the ge the all ech t are expe	ognepho edicome cited to	cal area in numity sho directly or	suld Inclu	the waters ude those ly benefit
(The affected community is defined in 10 CSR 20-7.031(2)(8) as the oo are located." Per the Antidegradation Implamantation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationars and people who enjoy the Lake of the Ozarks as well as the land	emunity a KE1, " antly that sowners i	Th the ge The affect t ans expe	egraphic ad come cled to and sun	cal arms in nunity sho directly or rounding t	the Lake	the waters ude those by benefit
(The affected community is defined in 10 CSR 20-7.031(2)(B) as the co are located. " Per the Antidegradation Implementation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationers and people who enjoy the Lake of the Ozarks as well as the land /2 identify the important social and economic developm entassociate With the second of incharging activity.	emunity a KE1, ~ antity the sowners a	In the ge the alfact and expe	egraphic ad come clied to and sum	cal area in nunity sho directly or rounding t	the Leke	the waters ude those by benefit of the Ozz
(The affected community is defined in 10 CSR 20-7.031(2)(B) as the co are located." Per the Antidegradation Implamantation Procedure Section Bring mean the size of the proposed project as well as those in the comm from the project.") (acationars and people who enjoy the Lake of the Ozarks as well as the land cationars and people who enjoy the Lake of the Ozarks as well as the land (2) Identify the important social and economic developm entassociate Nit the proposed discharging activity:	emunity a KE1, ~ antly the sources a	The the ge the alf each and expe	egniptic ad come ched to and come	cal area in nunity sho directly or rounding t	the Lake	The waters use those by benefit of the Ozz
(The affected community is defined in 10 CSR 20-7.031(2)(B) as the co are located." Per the Antidegradation Implamantation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationars and people who enjoy the Lake of the Ozarks as well as the land /2 identify the important social and economic developm entessociate With the proposed discharging activity: Cresta or expand employment?	emunity a KE1, ~ antly that sowners i sowners i	The the ge the affect t are expe adjoining a dijoining a Yes	egraphic ed com ched to ond son to No	Col arms in nunity sho descript or rounding to	Incirect	The waters use those by benefit of the Ozz
(The affected community is defined in 10 CSR 20-7.031(2)(B) as the co are located." Per the Antidegradation Implementation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people who enjoy the Lake of the Ozarks as well as the land // acationars and people at a social and economic developm entessociate // with the propose of discharging activity: // Crestia or expend employment? // horeese median family income?	emunity a KE1, ~ anity that sowners i sowners i 	The Be get The affect t are expe solicining a solicining a Yes	l: No No	Col arms in nunity sho descript or rounding to Don't	Incirect Incirect the Lake	The waters use those by benefit of the Ozz
(The affected community is defined in 10 CSR 20-7.031(2)(B) as the co are located." Per the Antidegradation Implamantation Procedure Section living mean the size of the proposed project as well as those in the comm from the project.") (acationers and people who enjoy the Lake of the Ozarks as well as the land "2 identity the important social and economic developmentes sociate Volt the proposed discharging activity: Crestia or expend employment? Increase median family income? Reduce the number of households below the poverty live?	emunity a KE1, ~ antly the sowners i conners i	The Beachers	t: No No No	Col area is sunity sho descily or rounding to rounding to Don't Don't	Incirect Incirect Incirect Incirect Incirect Incirect Incire Incire Incire Incire Incire Incire Incirect Incire	I've where use those by benefit of the Ozz of the Ozz NYA
(The affected community is defined in 10 CSR 20-7.031(2)(8) as the co are located. Per the Autidegradation Implementation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationers and people who enjoy the Lake of the Ozarka as well as the land /.2 Identify the important social and economic developmentes sociate With the proposed discharging activity: Crests or expend employment? Increase median family income? Reduce the number of households below the poverty live? Increase the community tax base?	emunity a KE1, " antly the sowners i sowners i g	Yes Yes Yes	t: No No No No	Col arms in nunity sho descript or rounding to Don't Don't Don't	Isnow Isnow Isnow Isnow Isnow	Ine waters use those by benefit of the Ozz of the Ozz of the Ozz NVA
(The affected community is defined in 10 CSR 20-7.031(2)(8) as the co are located.* Per the Autidegradation Implementation Procedure Section living meet the aix of the proposed project as well as those in the comm from the project.") /acationers and people who enjoy the Lake of the Ozarka as well as the land /.2 Identify the important social and economic developmentes sociate With the proposed discharging activity: Cresis or expend employment? Increase median family incoms? Reduce the number of households below the poverty live? Increase the community tax base? Increase needed housing supply?	emunity a KE1, " antly the sowners i sowners i g g g g g g g g	The Beach of the affects to affect t	t: No No No No	Cal area is sunity sho descily or rounding to rounding to Don't Don't Don't Don't	Isnow Isnow Isnow Isnow Isnow Isnow Isnow	Ine waters use those by benefit of the Ozz of the Ozz of the Ozz NVA

7.3 Describe the Important social and economic: The applicant must describe the expected change provide Information on any additional items demo describe the extering condition of the affected co- (benefit) in social and economic condition after it not constitute a comprehensive fait. Each elaution economic factors in accordance with the Anildegr The lots being served by this proposed treatment facilit septic systems under these conditions are likely to fail servege into the Lake of the Ozarko.	deverlopment as socie/od with the project: is in the factors identified in question 7.2 that are associated with the project and metrolog important acciel and economic development. The applicant should first mmunity. This base condition should then be compared to the predicted change the discharge is aboved. The social and economic measures identified above do in and community is different and will require an analysis of unique accial and radiation implementation. Procedure Section LE1, by are located on very steep lots with very shellow soils. The use of on-site Failure of an on-site septic system will more than likely discharge untreated
7.4 Is any other written correspondence or docum social and e-conomic importance:	rentation included with this application to provide further evidence of
Letter(s) from the mayor or community in Rezoning approval Other:	support of the proposed project
NO DISCHARGE ALTERNATIVES EVALUATION According to the Antidegradation Implementation Proce organizered. No-discharge alternatives may include and application, and recycle or reuse.	dure Sections LB, and LB.1., the feasibility of no-discharge alternatives must connection to a regional treatment facility, surface and application, subsurface
iternative is not feasible. If sufficient information is lischarging facility is not feasible, a more detailed evalu	ange ziverantion rom (roezaco) to even cestrate that a non-oscenarging not provided on the Mo-Discharge Eveluation Form to demonstrate that a non- etion of no discharge options must be submitted.
). IDENTIFY PREFERRED TREATMENT ALTER bescribe your proferred treatment alternative that has a practice in Masouri. The preferred treatment alternative fails form.	REVATIVE been recommended or approved by a registered protocolous angineer looneed we must be capable of meeting the offluent limits in the table under item 10 of
Applicants choosing to use a new waslewater technology te requirements set forth in the twovative Technology fa and filter with an Advantex AX100 polishing filter	ogy considered an "unproven technology" in Niteouri must comply with the ctsheet found on the department's website.
NGNEERING CONSULTANT NAME	COMPANY NAME Lake Professional Engineering Services

Department's Alternatives Analysis - Lake Horizons WWTF Page 40

18. SUMMARY OF THE POLLUTANTS OF CONCERN AND EFFLUENT LIMITS

Pollutants of concern to be considered include those pollutants reasonably expected to be present in the discharge per the Autidegradation by service and the section LA, and assumed or demandersied to cause styleticant degradation. The tier protection tends are specified and defined in rule at 10 CSR 20-7.031(2). All POOs in this elematives analysis were considered to be Tier 2 and standbardy degrading in the scenario of estating water quality.

As a result of this shortadives analysis review, the department leas detarmined, departing on eits specific consistent, there are treatment technologies available that may be economically efficient and practicable, which are capable of meeting the effluent (initialized below.) If the facility owners do not believe there is a treatment technology that is accommically efficient, effortiable, or practicable for their facility to meet these brits, a site-specific sitemetives makes will be required.

	EFFU	UENT LIMITS	-OUTFALLSTOL	KES	
Pojiutan	of Concern*	Units	Daily Stationum	Weekly Average	Si onthly Averag
	BODs	MGL		15	10
	TSS	MOA		20	15
	pH	SU	6.5-9.0		6.5-9.0
Ammonia	as N Summer	Na	3.6		1.4
Ammonia	a as N Winter	MGA	7.5		2.9
Total Phosphorus		MGA.	•		0.5
Escherichis coli (E. coli)		#/100x4.	630***		126
	EFFLU	ENT LIMITS	-ALLOTHER OUTF	ALLS	
	80Dş	mgñ.	1	15	10
	TSS	mpit.		15	10
	pH	SU	8.5-9.0		6.5-9.0
Ammonies as N Summer		mg/L	1.7		0.6
Armonia as N Winter		mgiL	5.6		2.1
Total Phoephorue****		mg/L.	•		0.5
Eacharichia coli	WBC(A) AND WBC (B)	\$100 ML	63	10 ^{mm}	126
(E. coll)	Losing Streem**	#100 ML	12	15***	Monitoring only

* Ramit limits for other parameters, inducing oil and grease, total residual chlorine and nitrates, will be included in the oparising permit based on applicable water quality standards and criteria.

Total residuel childrine (TRC) effluent links of 0.017 mpl. dolly maximum, 0.008 mpl. monthly swerage are recommended if childrine is used as a disinfectant. Standard compliance isinguisge for TRC, including the minimum level (ML), may be included in the operating permit.

** For any facility that will discharge to a waterbody designated as a losing stream or within two more flow cistance upstream of a losing stream.

** Publicly owned treatment works will receive a weekly average (mit and private facilities will receive a daily medmum Shit,

**** Total Phosphorus limits are only applicable to discharges to a lake or watershed of a lake that is a water of the state and has an area of at least 10 acres during normal pool conditions

If any Tier 1 Rolutante of Concern not addressed in this elementives analysis withe discharged, the opplicant must submit Attachment D: Ther 1 Review for those colutants.

.

Department's Alternatives Analysis - Lake Horizons WWTF Page 41

CHECK NUMBER	LETTINY CONFIRMATION HUMB	IER .	
12. SIGNATURE			
I am authorized and hereby certify that I am and belief such information is true, complete	familiar with the information contained in this and accurate.	document and to the	beat of my knowledge
W, O.P. Then Mer	Binnad LLC	DATE 1 Z/4	1204
WATTERSON, MER,	SIEPARN, LAC	MARNA	a suc
IN EASE IDENTIFY WHID STATIS OND T	HIS PROJECT: LOWMER L/CONTINUE	ING AUTHORITY	CONSULTANT

Department's Alternatives Analysis - Lake Horizons WWTF Page 42

MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH ANTIDEGRADATION: REGIONALIZATION AND NO-DISCHARGE EV	ALUATION
REGIONALIZATION AND NO-DISCHARGE EVALUATION	R In the second
According to the Antidegradation Implementation Procedure Sections I.B. and II.B.1., the feasibility of be considered. No-discharge alternatives may include connection to a regional treatment facility, sur land application, and recycle or reuse.	of no-discharge alternatives must face land application, subsurface
Please refer to the No-Discharge Alternative Evaluation fact sheet for examples of information to pro for not pursuing regionalization or no-discharge land application. If sufficient information is not provid that these alternatives are not feasible, a more detailed evaluation of no-discharge options may have	ovide to justify common reasons ded on this form to demonstrate e to be submitted.
Additional pages may be attached if more room is needed.	
1. FACILITY:	COUNTY
Lake Horizons WWTF	Camden
2. EVALUATION OF REGIONALIZATION (Complete all applicable reasons why regionalization wa	as not pursued)
2.1 Regionalization Feasibility:	
A. What is the distance to connect to the closest municipality's line or other facility's line? 8 miles	5
B. List facilities contacted about possible regionalization. None since it was 8 miles to the close	st regionalization.
C. Is there any planning or zoning in the area regarding development and services? Camden C	ounty Planning and Zoning
D. Who would have the responsibility to maintain the sewer connection line? Lake Horizons HC	A
E. What is the estimated cost for piping and pumps to regionalize? \$1,337,200	
 F. Explain any engineering challenges with the regionalization connection – topography, rivers, hig Topography would require pressure System. Having to get easements from 58 Land Owners. G. Does a regional facility have the capacity to treat the additional effluent from this project? Y 	ghways, or other issues. 'es
H. Were land owners contacted for rights to an easement?	
I. Describe the easement issues:	
City of Laurie won't accept 8 miles of pressure sewer line ownership. Therefore the HOA would have sewer line is privately owned the Missouri Department of Transportation won't allow the sewer line to Therefore the sewer line will have to be place on private property. Easements from 58 different prop acquired. If any of them refuse to grant an easement then the thirty-two residential lots will not be at	e to keep ownership. Because the b be placed in the easement. verty owners would have to be ble to connect to the city.
2.2 Summarize why regionalization was not a practicable or economically efficient alternative in order for this development to use the existing regional treatment plant of the City of Laurie, it woul accept the sewage of a development located approximately 8 miles out of the city limits. The city of so the sewar line will need to remain privately owned. Therefore, the sewage line cannot be placed roads serving the area and in the Missouri Department of Transportation's right of way of Highway13 the developer would need to receive easements from approximately 58 land owners. Of these 58 la refuses to grant an easement, the thirty-two residential lots will not be able to connect to the City of the regionalization is determined to be impracticable	a d first need the city to agree to Laurie will not annex the property in the right of way of the county 55 and Highway 5. Because of this, nd owners, if any one of them .aurie treatment plant. Due to this
780-2805 (82-19)	Page 1

Department's Alternatives Analysis - Lake Horizons WWTF Page 43

3. EVALUATION OF NO-DISCHARGE LAND APPLICATION		
Check all applicable reasons why no-discharge land application was not pursued:		
 □ 3.1 Land Availability and Cost: A. Is land available for land application? □ Yes ☑ No If not, explain: Limit available space all land is adjacent to the Lake of the Ozarks. If yes, answer the following: B. How many acres are required for land application of the effluent? 5 acres plus setbacks C. Provide a breakdown of the capital cost for any necessary additional land, piping, pumps, and irrij Lake front lots sell for approx \$1/sql ft. 5 Acres needed could cost \$217,800 for the land plus soll to cover the D. Were long-term costs evaluated and compared for upgrading to a mechanical plant with future W changes (i.e. mussel ammonia, bacteria, TP, TN) versus cost for a land application system? E. Were land owners contacted for rights to an easement? F. Describe the easement issues:	ation equipme bedrock ater Quality Str [∠] Yes [_] Yes	ant? andards ⊡No ⊡No
 3.2 Zoning or Suitability of Site in Proximity to Neighboring Sites or Waterbodies: Was drip or subsurface irrigation evaluated as opposed to surface application? Does the county ordinance specifically restrict land application, surface and subsurface? Can a vegetated buffer be installed to reduce necessary buffer distances? Are there other steps or considerations that can be made? Most of the area has bedrock outcroppings. Any type of land application either surface or subsurface will require help 	Ves Yes Yes Yes uire soil to be b	No No No rought in to
 3.3 Unsuitability of Geology or Solis A. Is a geohydrologic evaluation, county soils survey map, or other resource showing suitability and ap with this application? B. Is it cost-effective to bring in additional soils? C. Can the application rate be decreased to a suitable rate? D. Were subsurface application alternatives (e.g. low pressure pipe, drip) considered? E. If collapse potential is a concern, was using a liner or alternative site evaluated? 	plication rates Ves Yes Yes Yes Yes	included V No No No No No
3.4 Summarize why no-discharge land application was not a practicable or economically efficient alte The topography of the area is very steep with bedrock outcroppings. The site will have to have soil hauled in application bed or an irrigation bed would have to be constructed. In addition this is mostly lake front property approximately \$1/sq ft. Because of the size of the land needed for land application, it would remove well over bottom line of the project. This difference would cause the project to no longer be viable.	mative to the site and Lake lots are \$217,000 from	a land selling for the

Department's Alternatives Analysis - Lake Horizons WWTF Page 44

4. DOCU	MENTATION
4.1 Is any not p	y other written correspondence or documentation included with this application to provide further justification for ursuing a no-discharge option or regionalization?
🗆 No	
🖌 Yes:	
	A letter from an existing higher preference continuing authority waiving preferential status where service is not available in accordance with 10 CSR 20-6.0 10 (2) or if capacity is not available.
	A letter from the existing higher preference continuing authority stating that the regional facility has no interest in taking flow from the new or expanded facility.
	A letter from the regional municipality stating that the project area is outside city limits and annexation would be required.
	Council meeting minutes.
	Correspondence with land owners regarding easement rights.
	Correspondence with land owners regarding land for sale or lease.
	Letters from the community or a consulting engineer regarding availability, proximity, and location of suitable land and the reasonable cost of such land.
	Documentation of recent land sales or appraisals.
2	Calculations for sizing a land application system.
	Detailed cost estimates for a land application system or regionalization including lift stations, piping, easements, liners, and/or connection costs.
Z	Geohydrologic evaluation or other soils report.
	Copy of a county or city ordinance.
	Verification of funding from State Revolving Fund, which does not fund projects outside city limits.
	Other:
These iten	is were included with the original application.
80-2605 (82-1)	Pege 3