

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

City of Perry
127 E. Main St.
Perry, MO 63462

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

October 22, 2020
Effective Date

March 16, 2022
Modification Date

June 15, 2023
Expiration Date


Chris Wieberg, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

The City of Perry is doing collection system work and installing a Moving Bed Biofilm Reactor (MBBR) system between lagoon cells #2 and #3 to meet final ammonia effluent limits. With the collection system, construction will include installation of approximately 4134 lf of 8-inch PVC SDR-26 replacement lines with approximately 11 manholes. For the MBBR between cell #2 and #3, two MBBR tanks will be installed, with a total volume of 27,811 gallons, providing hydraulic retention time of 7.12 hours. The facility is also installing a new dechlorination tank and an ultrasonic flow sensor. The design average flow will remain at 93,800 gpd.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

II. COST ANALYSIS FOR COMPLIANCE

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to determine Cost Analysis for Compliance because the permit contains no new conditions or requirements that convey a new cost to the facility.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.
2. All construction shall be consistent with plans and specifications signed and sealed by Klinger & Associates, Inc. and as described in this permit.
3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).

4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Northeast Regional Office per 10 CSR 20-7.015(9)(G).
5. The wastewater treatment facility shall be located above the twenty-five (25)-year flood level.
6. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
7. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at dnr.mo.gov/env/wpp/epermit/help.htm. See dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.
8. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See dnr.mo.gov/env/wpp/401/ for more information.
9. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.
 - Rain water from roofs, streets, and other areas and groundwater from foundation drains shall be excluded from all new sewers. 10 CSR 20-8.120 (2)
 - Service connections to the gravity sewer main shall be watertight and cannot protrude into the sewer. 10 CSR 20-8.120 (3) (C) 1.
 - Leakage tests shall be specified for gravity sewers except polyvinyl chloride (PVC) pipe with a diameter of twenty-seven inches (27") or less. 10 CSR 20-8.120 (3) (C) 2.
 - The leakage exfiltration or infiltration for gravity sewers shall not exceed one hundred (100) gallons per inch of pipe diameter per mile per day for any section between manholes of the system. An exfiltration or infiltration test shall be performed with a minimum positive head of two feet (2'). The exfiltration or infiltration test shall conform to the test procedure described in ASTM C969 – 17 *Standard Practice for*

Infiltration and Exfiltration Acceptance Testing of Installed Precast Concrete Pipe Sewer Lines, as approved and published April 1, 2017, for precast concrete pipe. 10 CSR 20-8.120 (3) (C) 2. A.

- The air test for sewers shall, conform to the test procedure described in ASTM C1103 – 14 *Standard Practice for Joint Acceptance Testing of Installed Precast Concrete Pipe Sewer Lines*, as approved and published November 1, 2014, for concrete pipe twenty-seven inches (27") or greater in diameter, and ASTM F1417 – 11a(2015) *Standard Practice for Installation Acceptance of Plastic Non-pressure Sewer Lines Using Low-Pressure Air*, as approved and published August 1, 2015, for plastic, composite, and ductile iron pipe. 10 CSR 20-8.120 (3) (C) 2. B.
- Location. Manholes shall be installed—10 CSR 20-8.120 (4) (A)
 - At the end of each line;
 - At all changes in grade, size, or alignment;
 - At all sewer pipe intersections; and
 - At distances appropriate to allow for sufficient cleaning and maintenance of sewer lines.
- Vacuum testing, if specified for concrete sewer manholes, shall conform to the test procedures in ASTM C1244 – 11(2017) *Standard Test Method for Concrete Sewer Manholes by the Negative Air Pressure (Vacuum) Test Prior to Backfill*, as approved and published April 1, 2017, or the manufacturer's recommendation. 10 CSR 20-8.120 (4) (F) 1.
- Exfiltration testing, if specified for concrete sewer manholes, shall conform to the test procedures in ASTM C969 – 17 *Standard Practice for Infiltration and Exfiltration Acceptance Testing of Installed Precast Concrete Pipe Sewer Lines*, as approved and published April 1, 2017. 10 CSR 20-8.120 (4) (F) 2.
- There shall be no physical connections between a public or private potable water supply system and a sewer or appurtenance that would permit the passage of any wastewater or polluted water into the potable supply. 10 CSR 20-8.120 (5) (A)
- Sewers shall be laid at least fifty feet (50') in a horizontal direction from any existing or proposed public water supply well or other water supply sources or structures. Sewers must also comply with 10 CSR 23-3.010. 10 CSR 20-8.120 (5) (B)
- Flood protection shall apply to new construction and to existing facilities undergoing major modification. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation. 10 CSR 20-8.140 (2) (B)
- Unless another distance is determined by the Missouri Geological Survey or by the department's Public Drinking Water Branch, the minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300'). 10 CSR 20-8.140 (2) (C) 1.
- Facilities shall be readily accessible by authorized personnel from a public right-of-way at all times. 10 CSR 20-8.140 (2) (D)
- All sampling points shall be designed so that a representative and discrete twenty-four (24) hour automatic composite sample or grab sample of the effluent

- discharge can be obtained at a point after the final treatment process and before discharge to or mixing with the receiving waters. 10 CSR 20-8.140 (6) (B)
- All outfalls shall be posted with a permanent sign indicating the outfall number (i.e., Outfall #001). 10 CSR 20-8.140 (6) (C)
 - All wastewater treatment facilities shall be provided with an alternate source of electric power or pumping capability to allow continuity of operation during power failures. 10 CSR 20-8.140 (7) (A) 1.
 - Disinfection and dechlorination, when used, shall be provided during all power outages. 10 CSR 20-8.140 (7) (A) 2.
 - Electrical systems and components in raw wastewater or in enclosed or partially enclosed spaces where hazardous concentrations of flammable gases or vapors that are normally present, shall comply with the NFPA 70 *National Electric Code (NEC)* (2017 Edition), as approved and published August 24, 2016, requirements for Class I, Division 1, Group D locations. 10 CSR 20-8.140 (7) (B)
 - An audiovisual alarm or a more advanced alert system, with a self-contained power supply, capable of monitoring the condition of equipment whose failure could result in a violation of the operating permit, shall be provided for all wastewater treatment facilities. 10 CSR 20-8.140 (7) (C)
 - No piping or other connections shall exist in any part of the wastewater treatment facility that might cause the contamination of a potable water supply. 10 CSR 20-8.140 (7) (D) 1.
 - For indirect connections, a sign shall be permanently posted at every hose bib, faucet, hydrant, or sill cock located on the water system beyond the break tank or backflow preventer to indicate that the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 3. B.
 - Where a separate non-potable water supply is to be provided, a break tank will not be necessary, but all system outlets shall be posted with a permanent sign indicating the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 4.
 - A means of flow measurement shall be provided at all wastewater treatment facilities. 10 CSR 20-8.140 (7) (E)
 - Effluent twenty-four (24) hour composite automatic sampling equipment shall be provided at all mechanical wastewater treatment facilities and at other facilities where necessary under provisions of the operating permit. 10 CSR 20-8.140 (7) (F)
 - Adequate provisions shall be made to effectively protect facility personnel and visitors from hazards. The following shall be provided to fulfill the particular needs of each wastewater treatment facility:
 - Fencing. Enclose the facility site with a fence designed to discourage the entrance of unauthorized persons and animals; 10 CSR 20-8.140 (8) (A)
 - Gratings over appropriate areas of treatment units where access for maintenance is necessary; 10 CSR 20-8.140 (8) (B)
 - First aid equipment; 10 CSR 20-8.140 (8) (C)
 - Posted “No Smoking” signs in hazardous areas; 10 CSR 20-8.140 (8) (D)
 - Appropriate personal protective equipment (PPE); 10 CSR 20-8.140 (8) (E)

- Portable blower and hose sufficient to ventilate accessed confined spaces; 10 CSR 20-8.140 (8) (F)
- 10 CSR 20-8.140 (8) (G) Portable lighting equipment complying with NEC requirements. See subsection (7)(B) of this rule;
- 10 CSR 20-8.140 (8) (H) Gas detectors listed and labeled for use in NEC Class I, Division 1, Group D locations. See subsection (7)(B) of this rule;
- Appropriately-placed warning signs for slippery areas, non-potable water fixtures (see subparagraph (7)(D)3.B. of this rule), low head clearance areas, open service manholes, hazardous chemical storage areas, flammable fuel storage areas, high
- The materials utilized for storage, piping, valves, pumping, metering, and splash guards, etc., for chemical handling, shall be specially selected considering the physical and chemical characteristics of each hazardous or corrosive chemical. 10 CSR 20-8.140 (9) (A) 1.
- Moving Bed Bioreactor (MBBR). A MBBR secondary treatment system shall provide upstream preliminary treatment units capable of—
 - Screening to reduce pass-through and suspended solids; 10 CSR 20-8.180 (8)(A)
 - Grit removal; 10 CSR 20-8.180 (8)(B) and
 - Oil and grease removal; 10 CSR 20-8.180 (8)(C)
- Minimum freeboard shall be two feet (2'). 10 CSR 20-200(4)(A)3.
- The lagoon shall be sealed to ensure that seepage loss is as low as possible and has a design permeability not exceeding 1.0×10^{-7} cm/sec. 10 CSR 20-200(4)(C)1.
- Seep collars shall be provided on drainpipes where they pass through the lagoon seal. 10 CSR 20-200(4)(C)4.
- Contact time. A minimum of thirty (30) seconds for mixing and contact time of dechlorination systems shall be provided at the design peak hourly flow or maximum rate of pumpage. 10 CSR 20-8.190 (4) (B) 2.

10. Upon completion of construction:

- A. The City of Perry will become the continuing authority for operation and maintenance of these facilities;
- B. Submit an electronic copy of the as builts if the project was not constructed in accordance with previously submitted plans and specifications; and
- C. Submit the enclosed form Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) with a request for the operating permit modification to be issued.

IV. REVIEW SUMMARY

1. CONSTRUCTION PURPOSE

The purpose of construction is to meet final ammonia effluent limits that go into effect in March 2021.

2. FACILITY DESCRIPTION

The Perry WWTF is located along Highway 154, Perry, in Ralls County, Missouri. The facility has a design average flow of 93,800 gpd and serves a hydraulic population equivalent of approximately 920 people. The existing Perry WWTF is a three-cell aerated lagoon with chlorine disinfection and dechlorination.

3. COMPLIANCE PARAMETERS

The proposed project is required to meet final ammonia effluent limits established in Operating Permit MO-0111821 dated July 1, 2016. With the proposed changes, the facility no longer qualifies for equivalent to secondary limits, and the BOD and TSS effluent limits have been adjusted to reflect secondary effluent limits.

The limits following the completion of construction will be applicable to the facility:

Parameter	Units	Monthly average limit
Biochemical Oxygen Demand ₅	mg/L	30
Total Suspended Solids	mg/L	30
Ammonia as N-January	mg/L	3.1
Ammonia as N-February	mg/L	3.1
Ammonia as N-March	mg/L	2.7
Ammonia as N-April	mg/L	2.1
Ammonia as N-May	mg/L	2.1
Ammonia as N-June	mg/L	1.3
Ammonia as N-July	mg/L	0.9
Ammonia as N-August	mg/L	0.9
Ammonia as N-September	mg/L	1.2
Ammonia as N-October	mg/L	1.8
Ammonia as N-November	mg/L	2.4
Ammonia as N-December	mg/L	2.7
pH	SU	6.5-9.0
Total Residual Chlorine	µg/L	9 (130 ML)
<i>E. coli</i>	#/100mL	206

4. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

The current design guides, 10 CSR 20-8, do not contain design parameters for this configuration of technology or for moving bed biological reactors (MBBR).

Existing major components which will remain in use include the following:

- The existing facultative lagoons were installed in the 1960s and upgraded in 1995.
 - Lagoon Cell No. 1 has a surface area of 4.88 acres
 - Lagoon Cell No. 2 has a surface area of 1.37 acres
 - Lagoon Cell No. 3 has a surface area of 0.7 acres
- Chlorine disinfection and dechlorination. The disinfection system was installed under Construction Permit #25-2918 issued on October 30, 2008 by the Northeast Regional Office (NERO). There are 2 tablet feeders, each capable of treating 200,000 gpd.
 - The chlorine contact basin has interior dimensions of 27 ft x 7 ft x 7.5 ft.
 - The total detention time in the existing chlorine contact basin is about 65 minutes at a peak flow of 281,400 gallons per day.

Construction will cover the following items:

- Collection System Work - Construction of approximately 4134 lf of 8-inch PVC SDR-26 replacement lines with approximately 11 manholes.
- Moving Bed Biofilm Reactor (MBBR) – The lagoon treated effluent will flow by gravity from the second cell to the 2 tanks, which contain the moving bed biofilm reactor, a Triplepoint Water Technologies, LLC NitrOx™. It is capable of treating a design average flow of 93,800 gpd.
 - The system is composed of two tanks with each approximately 14 ft x 13 ft x 13 ft with a sidewater depth of 11 ft. Total volume of the two tanks is 27,811 gallons.
 - The average flow hydraulic retention time is 7.12 hours and the peak flow hydraulic retention time is 3.21 hours.
 - A floating insulating cover shall be installed in each tank. An immersion tank heater will be installed to maintain a temperature rise of 2.5°C.
 - Each tank shall be filled with high surface area HDPE media. Each media piece shall be 1 inch diameter, with a total surface area of 152 ft²/ft³ and 113 ft²/ft³ protected surface area for bacteria growth.
 - Aeration by means of two tri-lobe or bi-lobe positive displacement blowers each capable of supplying 205 scfm.
 - The effluent from the NitrOx™ will flow by gravity to Lagoon Cell No. 3 for polishing prior to disinfection and discharge.
- Tablet Dechlorinator – Installation of a Norweco #XT4000-S or equal dechlorination chamber receiving the chlorinated effluent and prior to Outfall No. 001, in additional support to the existing dechlorination system. The Norweco #XT4000-S can handle peak flows up to 200,000 gpd.

- Flow Measurement – Installation of accurate flow measurement devices will give the treatment facility a means of improved data analysis.
 - An ultrasonic flow sensor shall measure secondary treated and disinfected wastewater prior to discharge at Outfall No. 001, it shall be installed in the H-flume manhole.

5. OPERATING PERMIT

Operating permit MO-0011821 will require a modification to reflect the construction activities. The modified operating permit was successfully public noticed from August 21 to September 21, 2020 with no comments received. Submit the Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and request the operating permit modification be issued.

With your CP application, an operating permit modification was submitted for public notice to reflect the change in your operating permit. Your operating permit application for a renewal will be due before your CP is expired. The modification action does not fulfill the renewal application obligation. A renewal application was submitted.

6. CONSTRUCTION PERMIT MODIFICATION

This construction permit is being modified upon the request of the facility owner to extend the construction permit schedule. The construction permit will now expire on June 15, 2023.

V. NOTICE OF RIGHT TO APPEAL


If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:


Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

Leasue Meyers, EI
Engineering Section
leasue.meyers@dnr.mo.gov

Cindy LePage, P.E.
Engineering Section
cindy.lepage@dnr.mo.gov

APPENDIX A: Process Flow Diagram





MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
APPLICATION FOR CONSTRUCTION PERMIT
WASTEWATER TREATMENT FACILITY

RECEIVED

MAY 12 2020

Water Protection Program

FOR DEPARTMENT USE ONLY	
APP NO.	CP NO.
FEE RECEIVED 4000.00	CHECK NO. 20622
DATE RECEIVED 5-12-20	

APPLICATION OVERVIEW

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. **All applicants must complete Part A.** Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. **Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.**

PART A – BASIC INFORMATION

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: USDA-RD Project #: _____
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?
 YES Date of Approval: _____ N/A
- 1.3 Has the department approved the proposed project's facility plan*?
 YES Date of Approval: _____ NO (If No, complete No. 1.4.)
- 1.4 [Complete only if answered No on No. 1.3.] Is a copy of the facility plan* for wastewater treatment facilities included with this application?
 YES NO Exempt because _____
- 1.5 Is a copy of the appropriate plans* and specifications* included with this application?
 YES Denote which form is submitted: Hard copy Electronic copy (See instructions.) NO
- 1.6 Is a summary of design* included with this application? YES NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?
 YES Date of submittal: _____
 Enclosed is the appropriate operating permit application and fee submittal. Denote which form: A B B2
 N/A: However, In the event the department believes that my operating permit requires revision to permit limitation such as changing equivalent to secondary limits to secondary limits or adding total residual chlorine limits, please share a draft copy prior to public notice? YES NO
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency? YES NO
- 1.9 Is the appropriate fee or JetPay confirmation included with this application? YES NO
 See Section 7.0

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT Perry Sewer System Improvements	2.2 ESTIMATED PROJECT CONSTRUCTION COST \$ 3.1 million
2.3 PROJECT DESCRIPTION The project includes addition of TriplePoint Nitrox treatment between lagoon cells 2 and 3 and related appurtenances as well as replacement/lining/point repairs, manhole replacement/lining and lateral grouting for approximately 2/3 of the sewer collection system.	
2.4 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION Sludge retained in lagoon	
2.5 DESIGN INFORMATION A. Current population: <u>666</u> ; Design population: <u>938</u> B. Actual Flow: <u>92.3k</u> gpd; Design Average Flow: <u>93.8k</u> gpd; Actual Peak Daily Flow: <u>140k</u> gpd; Design Maximum Daily Flow: <u>312k</u> gpd; Design Wet Weather Event: <u>N/A</u>	
2.6 ADDITIONAL INFORMATION A. Is a topographic map attached? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO B. Is a process flow diagram attached? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

3.0 WASTEWATER TREATMENT FACILITY

NAME Perry Wastewater Treatment Facility		TELEPHONE NUMBER WITH AREA CODE 573-565-3131	E-MAIL ADDRESS ppu@cityofperrymo.com	
ADDRESS (PHYSICAL) Highway 154	CITY Perry	STATE MO	ZIP CODE 63462	COUNTY Ralls
Wastewater Treatment Facility: Mo- 0111821 (Outfall 1 Of 1)				
3.1 Legal Description: <u> </u> ¼, <u> NW </u> ¼, <u> NW </u> ¼, Sec. <u> 27 </u> , T <u> 54N </u> , R <u> 7W </u> (Use additional pages if construction of more than one outfall is proposed.)				
3.2 UTM Coordinates Easting (X): <u> 614055 </u> Northing (Y): <u> 4366145 </u> For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)				
3.3 Name of receiving streams: <u> Trib. to Lick Creek </u>				

4.0 PROJECT OWNER

NAME City of Perry		TELEPHONE NUMBER WITH AREA CODE 573-565-3131	E-MAIL ADDRESS cityclerk@cityofperrymo.com	
ADDRESS 127 E. Main, P.O. Box 280	CITY Perry	STATE MO	ZIP CODE 63462	

5.0 CONTINUING AUTHORITY: A continuing authority is a company, business, entity or person(s) that will be operating the facility and/or ensuring compliance with the permit requirements.

NAME City of Perry		TELEPHONE NUMBER WITH AREA CODE 573-565-3131	E-MAIL ADDRESS cityclerk@cityofperrymo.com	
ADDRESS 127 E. Main, P.O. Box 280	CITY Perry	STATE MO	ZIP CODE 63462	

5.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO N/A

5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY.

A. Is a copy of the certificate of convenience and necessity included with this application? YES NO

5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION.

A. Is a copy of the as-filed restrictions and covenants included with this application? YES NO

B. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application? YES NO

C. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application? YES NO

D. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application? YES NO

6.0 ENGINEER

ENGINEER NAME / COMPANY NAME Mark C. Bross, PE/Klingner & Associates, PC		TELEPHONE NUMBER WITH AREA CODE 573-221-0020	E-MAIL ADDRESS mcb@klingner.com	
ADDRESS 4510 Paris Gravel Road	CITY Hannibal	STATE MO	ZIP CODE 63401	

7.0 APPLICATION FEE

CHECK NUMBER JETPAY CONFIRMATION NUMBER

8.0 PROJECT OWNER: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PROJECT OWNER SIGNATURE


PRINTED NAME
Chad Williams

DATE
3/3/2020

TITLE OR CORPORATE POSITION
Mayor

TELEPHONE NUMBER WITH AREA CODE
573-565-3131

E-MAIL ADDRESS
cityclerk@cityofperrymo.com

Mail completed copy to:
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
P.O. BOX 176
JEFFERSON CITY, MO 65102-0176

END OF PART A.

REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE.