

**STATE OF MISSOURI**  
**DEPARTMENT OF NATURAL RESOURCES**  
**MISSOURI CLEAN WATER COMMISSION**



**CONSTRUCTION PERMIT**

The Missouri Department of Natural Resources hereby issues a permit to:

Dennis Kallash, Member  
Lincoln County Sewer and Water, LLC  
360 E. Cherry Street  
Troy, MO 63379

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

July 21, 2020  
Effective Date

  
Edward B. Galbraith, Director, Division of Environmental Quality

July 21, 2022  
Expiration Date

  
Chris Wieberg, Director, Water Protection Program

## **CONSTRUCTION PERMIT**

### **I. CONSTRUCTION DESCRIPTION**

Proposed construction activities consist of installing new tablet feeders and a precast concrete chlorine contact chamber for chlorination and dechlorination to meet *E. Coli* and total residual chlorine (TRC) effluent limitations.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

### **II. COST ANALYSIS FOR COMPLIANCE**

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to complete a cost analysis for compliance because the facility is not a combined or separate sanitary sewer system for a publically-owned treatment works.

### **III. CONSTRUCTION PERMIT CONDITIONS**

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.
2. All construction shall be consistent with plans and specifications signed and sealed by the Scheer Design Group, LLC and as described in this permit.
3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).
4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department’s St. Louis Regional Office per 10 CSR 20-7.015(9)(G).

5. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
6. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at [dnr.mo.gov/env/wpp/epermit/help.htm](http://dnr.mo.gov/env/wpp/epermit/help.htm). See [dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm](http://dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm) for more information.
7. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See [dnr.mo.gov/env/wpp/401/](http://dnr.mo.gov/env/wpp/401/) for more information.
8. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.
  - Contact period for Chlorine Disinfection. A minimum contact period of fifteen (15) minutes at design peak hourly flow or maximum rate of pumpage shall be provided after thorough mixing. 10 CSR 20-8.190 (3) (A)
  - Alarm System for chlorination and dechlorination systems. The applicant shall conform to 10 CSR 20-8.140(7)(C) and be responsible for specifying what the alarm requirements are necessary to assure consistent disinfection in compliance with the applicable bacteria limits and the disinfection residual limit in the effluent. 10 CSR 20-8.190 (3) (C)
  - Solid dechlorination systems shall not be located in the chlorine contact tank. 10 CSR 20-8.190 (4) (B) 1.
  - Contact time. A minimum of thirty (30) seconds for mixing and contact time of dechlorination systems shall be provided at the design peak hourly flow or maximum rate of pumpage. 10 CSR 20-8.190 (4) (B) 2.
9. Upon completion of construction:
  - A. The Lincoln County Sewer and Water LLC will become the continuing authority for operation and maintenance of these facilities;

- B. Submit an electronic copy of the as builts if the project was not constructed in accordance with previously submitted plans and specifications;
- C. Submit the eDMR permit Holder and Certifier Registration, Form--MO 780-2204 to comply with your operating permit; and
- D. Submit the enclosed form Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and request the draft operating permit (MO-0122971) be issued. The permit was placed on public notice on July 10, 2020.

#### **IV. REVIEW SUMMARY**

##### **1. CONSTRUCTION PURPOSE**

Proposed construction activities consist of installing new tablet feeders and a precast concrete chlorine contact chamber for chlorination and dechlorination to meet *E. Coli* effluent limitations as required by the Missouri State Operating Permit MO-0122971 issued December 1, 2018.

##### **2. FACILITY DESCRIPTION**

The existing wastewater treatment plant is comprised of a flow equalization, extended aeration, aerobic sludge digester. The sludge is land applied or removed by a contract hauler. The purpose of this project is to construct a new chlorination/dechlorination disinfection system to meet the *E. Coli* limits in its current operating permit.

The Bennington WWTF is located at Bennington Drive, Tory, in Lincoln County, Missouri. The facility has a design average flow of 24,000 gpd and serves a hydraulic population equivalent of approximately 282 people.

##### **3. COMPLIANCE PARAMETERS**

The proposed project is required to meet final effluent *E. coli* limits of 1030 colonies per 100 mL weekly average and 206 colonies per 100 mL monthly average as established in Operating Permit MO-0122971 and meet final effluent TRC limits of 8 (130 ML) µg/L weekly average and monthly average as established in draft Operating Permit MO-0122971 public noticed on July 10, 2020.

The limits following the completion of construction will be applicable to the facility:

Parameter	Units	Monthly average limit
Total Residual Chlorine	µg/L	8 (130 ML)
<i>E. Coli</i>	#/100mL	206

#### **4. REVIEW of MAJOR TREATMENT DESIGN CRITERIA**

The facility proposed to modify an existing wastewater treatment plant by the installation of a chlorinator (Norweco tablet feeder Model IT 2000S) and a dechlorinator (Norweco tablet feeder Model IT 2000S), a contact chamber, and all the necessary appurtenances to make the facilities complete and usable to treat the waste from a population equivalent of 282.

The Design flow for this facility is 24,000 GPD with a peak hourly flow of 96,000 GPD based on a peaking factor of 4. The facility will use 1,000 gallon baffled basin (8.5'x5.0'x5.8') as its chlorine contact tank. Sizes of chlorinator, contact tank and dechlorinator are able to treat its hourly peak design flow. Both chlorinator and dechlorinator will be installed outside of the contact tank.

#### **5. OPERATING PERMIT**


Operating permit MO-0122971 will require a modification to reflect the construction activities. The modified operating permit of the Bennington WWTF, MO-0122971, was successfully public noticed from July 10, 2020 to August 9, 2020 to add TRC limits. Submit the Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and request the operating permit modification be issued.

#### **V. NOTICE OF RIGHT TO APPEAL**

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission  
U.S. Post Office Building, Third Floor  
131 West High Street, P.O. Box 1557  
Jefferson City, MO 65102-1557  
Phone: 573-751-2422  
Fax: 573-751-5018  
Website: <https://ahc.mo.gov>

Lei Hou, P.E.  
Engineering Section  
[lei.hou@dnr.mo.gov](mailto:lei.hou@dnr.mo.gov)



RECEIVED  
MAY 04 2020  
Water Protection Program

FOR DEPARTMENT USE ONLY	
APP NO.	CP NO.
FFF RECEIVED \$300.00	CHECK NO. 2045
DATE RECEIVED 5-4-20	

**APPLICATION OVERVIEW**

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. All applicants must complete Part A. Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.

**PART A – BASIC INFORMATION**

**1.0 APPLICATION INFORMATION** (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project?  YES  N/A Funding Agency: \_\_\_\_\_ Project #: \_\_\_\_\_
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?  
 YES Date of Approval: \_\_\_\_\_  N/A
- 1.3 Has the department approved the proposed project's facility plan\*?  
 YES Date of Approval: \_\_\_\_\_  NO (If No, complete No. 1.4.)
- 1.4 [Complete only if answered No on No. 1.3.] Is a copy of the facility plan\* for wastewater treatment facilities included with this application?  
 YES  NO  Exempt because Addition of disinfection to existing system
- 1.5 Is a copy of the appropriate plans\* and specifications\* included with this application?  
 YES Denote which form is submitted:  Hard copy  Electronic copy (See instructions.)  NO
- 1.6 Is a summary of design\* included with this application?  YES  NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?  
 YES Date of submittal: \_\_\_\_\_  
 Enclosed is the appropriate operating permit application and fee submittal. Denote which form:  A  B  B2  
 N/A: However, In the event the department believes that my operating permit requires revision to permit limitation such as changing equivalent to secondary limits to secondary limits or adding total residual chlorine limits, please share a draft copy prior to public notice?  YES  NO
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency?  YES  NO
- 1.9 Is the appropriate fee or JetPay confirmation included with this application?  YES  NO  
See Section 7.0

\* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

**2.0 PROJECT INFORMATION**

2.1 NAME OF PROJECT Disinfection system for Bennington WWTF	2.2 ESTIMATED PROJECT CONSTRUCTION COST \$ 12,000
--	--

2.3 PROJECT DESCRIPTION  
Addition of two tablet feeders and a chlorine contact chamber to provide disinfection to the WWTF effluent prior to discharge.

2.4 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION  
contract hauler

2.5 DESIGN INFORMATION

A. Current population: \_\_\_\_\_; Design population: 282

B. Actual Flow: 3600 gpd; Design Average Flow: 3 k gpd;  
Actual Peak Daily Flow: \_\_\_\_\_ gpd; Design Maximum Daily Flow: 24 k gpd; Design Wet Weather Event: \_\_\_\_\_

2.6 ADDITIONAL INFORMATION

A. Is a topographic map attached?  YES  NO

B. Is a process flow diagram attached?  YES  NO

**3.0 WASTEWATER TREATMENT FACILITY**

NAME Bennington WWTF		TELEPHONE NUMBER WITH AREA CODE (636) 528-6180	E-MAIL ADDRESS	
ADDRESS (PHYSICAL) Bennington Dr. 0.03 Mi. S. of inter. Benningt	CITY Troy	STATE MO	ZIP CODE 63379	COUNTY Lincoln
Wastewater Treatment Facility: Mo- 0122971 (Outfall 1 Of 1 )				
3.1 Legal Description: _____ ¼, _____ ¼, _____ ¼, Sec. 32, T 49N, R 1W (Use additional pages if construction of more than one outfall is proposed.)				
3.2 UTM Coordinates Easting (X): 669351 Northing (Y): 4315909 For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)				
3.3 Name of receiving streams: Tributary to Spring Creek				

**4.0 PROJECT OWNER**

NAME Lincoln County Sewer and Water LLC		TELEPHONE NUMBER WITH AREA CODE (636) 528-6180	E-MAIL ADDRESS	
ADDRESS 360 E. Cherry St.	CITY Troy	STATE MO	ZIP CODE 63379	

**5.0 CONTINUING AUTHORITY:** A continuing authority is a company, business, entity or person(s) that will be operating the facility and/or ensuring compliance with the permit requirements.

NAME See Above		TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
ADDRESS	CITY	STATE	ZIP CODE	

5.1 A letter from the continuing authority, if different than the owner, is included with this application.  YES  NO  N/A

5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY.

A. Is a copy of the certificate of convenience and necessity included with this application?  YES  NO

5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION.

- A. Is a copy of the as-filed restrictions and covenants included with this application?  YES  NO
- B. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application?  YES  NO
- C. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application?  YES  NO
- D. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application?  YES  NO

**6.0 ENGINEER**

ENGINEER NAME / COMPANY NAME Kirby Scheer / Scheer Design Group, LLC		TELEPHONE NUMBER WITH AREA CODE 573 459-2611	E-MAIL ADDRESS kirbs@fidnet.com	
ADDRESS 8584 HWY YY	CITY New Haven	STATE MO	ZIP CODE 63068	

**7.0 APPLICATION FEE**

CHECK NUMBER  JETPAY CONFIRMATION NUMBER

**8.0 PROJECT OWNER:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PROJECT OWNER SIGNATURE PRINTED NAME Lincoln County Sewer & Water LLC DATE 4-24-20TITLE OR CORPORATE POSITION MEMBER TELEPHONE NUMBER WITH AREA CODE 636-528-6180 E-MAIL ADDRESS NONEMail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES  
WATER PROTECTION PROGRAM  
P.O. BOX 176  
JEFFERSON CITY, MO 65102-0176**END OF PART A.**  
**REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE.**