

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

Teresa Alumbaugh
Owner
From the Farm LLC
545 West Highway 6
Trenton, MO 64683

For the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

February 4, 2021
Effective Date


Edward B. Galbraith, Director, Division of Environmental Quality

February 3, 2023
Expiration Date


Chris Wieberg, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

The From the Farm meat processing facility is located at 545 West Highway 6, Trenton in Grundy County, Missouri. The facility has a design average dry weather flow of 1,159 gallons per day (gpd), and a wet weather design flow of approximately 2,698 gpd, which includes the 1-in-10 year rainfall minus evaporation. Construction will include a wastewater storage lagoon with a surface area of approximately 0.44 acres, a manhole structure prior to the lagoon entrance, and 4-inch PVC gravity flow influent piping to the lagoon. The storage lagoon will have approximately 124 days of storage at the 1-in-10 year wet weather design flow. The land application site is located approximately 1.5 miles south of the lagoon site and is currently used for hay and pasture. There are 52 total acres available for land application of wastewater. A gasoline powered pump and portable piping will be used to pump down the lagoon into a mobile land application tank with distribution piping. The wastewater will be land applied at an application rate of 0.25 inch per acre per day.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

II. COST ANALYSIS FOR COMPLIANCE

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a “finding of affordability” on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to complete a cost analysis for compliance because the facility is not a combined or separate sanitary sewer system for a publically-owned treatment works.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.

2. All construction shall be consistent with plans and specifications signed and sealed by John Mann, P.E. of Rhodes Engineering Co., Inc. and as described in this permit.
3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).
4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Northeast Regional Office per 10 CSR 20-7.015(9)(G).
5. The wastewater treatment facility shall be located at least two hundred feet (200') from any dwelling or establishment and fifty feet (50') from the property line per 10 CSR 20-8.140(C)(2)
6. The wastewater treatment facility shall be located above the twenty-five (25)-year flood level.
7. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
8. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at dnr.mo.gov/env/wpp/epermit/help.htm. See dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.
9. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See dnr.mo.gov/env/wpp/401/ for more information.

10. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.

- Flood protection shall apply to new construction and to existing facilities undergoing major modification. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation. 10 CSR 20-8.140 (2) (B)
- Unless another distance is determined by the Missouri Geological Survey or by the department's Public Drinking Water Branch, the minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300'). 10 CSR 20-8.140 (2) (C) 1.
- No treatment unit with a capacity of twenty-two thousand five hundred gallons per day (22,500 gpd) or less shall be located closer than the minimum distance of 200' to a neighboring residence and 50' to property line for lagoons. See 10 CSR 20-2.010(68) for the definition of a residence. 10 CSR 20-8.140 (2) (C) 2
- Facilities shall be readily accessible by authorized personnel from a public right-of-way at all times. 10 CSR 20-8.140 (2) (D)
- All sampling points shall be designed so that a representative and discrete twenty-four (24) hour automatic composite sample or grab sample of the effluent discharge can be obtained at a point after the final treatment process and before discharge to or mixing with the receiving waters. 10 CSR 20-8.140 (6) (B)
- All outfalls shall be posted with a permanent sign indicating the outfall number (i.e., Outfall #001). 10 CSR 20-8.140 (6) (C)
- An audiovisual alarm or a more advanced alert system, with a self-contained power supply, capable of monitoring the condition of equipment whose failure could result in a violation of the operating permit, shall be provided for all wastewater treatment facilities. 10 CSR 20-8.140 (7) (C)
- No piping or other connections shall exist in any part of the wastewater treatment facility that might cause the contamination of a potable water supply. 10 CSR 20-8.140 (7) (D) 1.
- Where a potable water supply is to be used for any purpose in a wastewater treatment facility other than direct connections, a break tank, pressure pump, and pressure tank or a reduced pressure backflow preventer consistent with the department's Public Drinking Water Branch shall be provided. 10 CSR 20-8.140 (7) (D) 3. A.
- For indirect connections, a sign shall be permanently posted at every hose bib, faucet, hydrant, or sill cock located on the water system beyond the break tank or backflow preventer to indicate that the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 3. B.
- Where a separate non-potable water supply is to be provided, a break tank will not be necessary, but all system outlets shall be posted with a permanent sign indicating the water is not safe for drinking. 10 CSR 20-8.140 (7) (D) 4.
- A means of flow measurement shall be provided at all wastewater treatment facilities. 10 CSR 20-8.140 (7) (E)

- Adequate provisions shall be made to effectively protect facility personnel and visitors from hazards. The following shall be provided to fulfill the particular needs of each wastewater treatment facility:
 - Fencing. Enclose the facility site with a fence designed to discourage the entrance of unauthorized persons and animals; 10 CSR 20-8.140 (8) (A)
 - Gratings over appropriate areas of treatment units where access for maintenance is necessary; 10 CSR 20-8.140 (8) (B)
 - First aid equipment; 10 CSR 20-8.140 (8) (C)
 - Posted “No Smoking” signs in hazardous areas; 10 CSR 20-8.140 (8) (D)
 - Appropriate personal protective equipment (PPE); 10 CSR 20-8.140 (8) (E)
 - Portable blower and hose sufficient to ventilate accessed confined spaces; 10 CSR 20-8.140 (8) (F)
 - 10 CSR 20-8.140 (8) (G) Portable lighting equipment complying with NEC requirements. See subsection (7)(B) of this rule;
 - 10 CSR 20-8.140 (8) (H) Gas detectors listed and labeled for use in NEC Class I, Division 1, Group D locations. See subsection (7)(B) of this rule;
 - Appropriately-placed warning signs for slippery areas, non-potable water fixtures (see subparagraph (7)(D)3.B. of this rule), low head clearance areas, open service manholes, hazardous chemical storage areas, flammable fuel storage areas, high noise areas, etc.; 10 CSR 20-8.140 (8) (I)
 - Explosion-proof electrical equipment, non-sparking tools, gas detectors, and similar devices, in work areas where hazardous conditions may exist, such as digester vaults and other locations where potentially explosive atmospheres of flammable gas or vapor with air may accumulate. 10 CSR 20-8.140 (8) (K)
 - Provisions for local lockout/tagout on stop motor controls and other devices; 10 CSR 20-8.140 (8) (L)
- The minimum berm width shall be eight feet (8') to permit access of maintenance vehicles. 10 CSR 20-8.200 (4) (A) 2.
- Minimum freeboard shall be two feet (2'). 10 CSR 20-8.200 (4) (A) 3.
- An emergency spillway shall be provided. 10 CSR 20-8.200 (4) (A) 4.
- An emergency spillway must have the ability for a representative sample to be collected if a discharge occurs. 10 CSR 20-8.200 (4) (A) 4. C.
- Soil shall be compacted with the moisture content between two percent (2%) below and four percent (4%) above the optimum water content and compacted to at least ninety-five percent (95%) maximum dry density test method. 10 CSR 20-8.200 (4) (B).
- Unlined corrugated metal pipe shall not be used for influent lines due to corrosion problems. 10 CSR 20-8.200 (4) (D) 1.
- A manhole shall be installed with its invert at least six inches (6") above the maximum operating level of the lagoon, prior to the entrance into the primary cell, and provide sufficient hydraulic head without surcharging the manhole. 10 CSR 20-8.200 (4) (D) 2.

- The influent line(s) shall be located along the bottom of the lagoon so that the top of the pipe is just below the average elevation of the lagoon seal; however, there shall be an adequate seal below the pipe. 10 CSR 20-8.200 (4) (D) 3.
- The wetted application area of a surface irrigation system must be located
 - Outside of flood-prone areas having a flood frequency greater than once every ten (10) years; 10 CSR 20-8.200 (6) (B) 1.
 - At least one hundred fifty feet (150') from existing dwellings or public use areas, excluding roads or highways; 10 CSR 20-8.200 (6) (B) 2. A.
 - At least fifty feet (50') inside the property line; 10 CSR 20-8.200 (6) (B) 2. B.
 - At least three hundred feet (300') from any sinkhole, losing stream, or other structure or physiographic feature that may provide direct connection between the ground water table and the surface; 10 CSR 20-8.200 (6) (B) 2. C.
 - At least three hundred feet (300') from any existing potable water supply well not located on the property. Adequate protection shall be provided for wells located on the application site; 10 CSR 20-8.200 (6) (B) 2. D.
 - One hundred feet (100') to wetlands, ponds, gaining streams (classified or unclassified; perennial or intermittent); 10 CSR 20-8.200 (6) (B) 2. E. and
 - If an established vegetated buffer or the wastewater is disinfected, the setbacks established in subsections (A)–(E) above may be decreased if the applicant demonstrates the risk is mitigated. 10 CSR 20-8.200 (6) (B) 2. F.
- The wetted application area of a surface irrigation system must be fenced, or if not fenced, provide in the construction permit application or the facility plan, the-
 - Method of disinfection being utilized; 10 CSR 20-8.200 (6) (B) 3. A.
 - Suitable barriers in place, 10 CSR 20-8.200 (6) (B) 3. B. or
 - Details on how public access is limited and not expected to be present. 10 CSR 20-8.200 (6) (B) 3. C.
- At a minimum, treatment prior to irrigation shall provide performance equivalent to that obtained from a primary wastewater lagoon cell and include 120 days wastewater storage in addition to the primary volume. 10 CSR 20-8.200 (6) (C)
- The public shall not be allowed into an area when irrigation is being conducted; 10 CSR 20-8.200 (6) (F) 2.

11. Upon completion of construction:

- A. Teresa Alumbaugh, owner, will become the continuing authority for operation and maintenance of these facilities;
- B. Submit an electronic copy of the as built if the project was not constructed in accordance with previously submitted plans and specifications; and
- C. Submit the enclosed form Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and request issuance of operating permit.

IV. REVIEW SUMMARY

1. CONSTRUCTION PURPOSE

The purpose of this project is to construct a new land application wastewater treatment system for the From the Farm LLC meat processing facility.

2. FACILITY DESCRIPTION

The From the Farm meat processing facility is located at 545 West Highway 6, Trenton in Grundy County. The plant will process approximately 900 beef cattle per year, operating 6 day per week and 50 weeks per year. Wastewater treatment for the meat processing facility will consist of a storage lagoon and land application. The facility has a dry weather design flow of 1,159 gallons per day (gpd). Including the 1-in-10 year rainfall minus evaporation of approximately 15.3 inches for Grundy County, the wet weather design flow is 2,698 gpd. The lagoon will have a surface area of approximately 0.44 acres and a storage volume of 334,500 gallons. Wastewater from the lagoon will be land applied at an application rate of 0.25 inch per acre per day on a nearby field during appropriate weather conditions.

3. COMPLIANCE PARAMETERS

The proposed project is required to meet the requirements of MO-G822 General Permit for the Land Application of Food Processing Wastewater with an expiration date of May 22, 2022.

The limits following the completion of construction will be applicable to the facility:

Process Wastewater for SIC Code 2011		
<i>Parameter</i>	<i>Units</i>	<i>Limit</i>
Total Kjeldahl Nitrogen (TKN)	mg/L	Monitoring
Total Phosphorus as P	mg/L	Monitoring
Total Sodium	mg/L	Monitoring
Total Suspended Solids	mg/L	Monitoring
Total Chlorine as Cl	mg/L	Monitoring
pH	Standard Units	6.0 – 9.0
Oil and Grease	mg/L	Monitoring
Land Application (Surface) Rate Limits		
Total Kjeldahl Nitrogen	lbs./acre/year	150
Oil and Grease	lbs./acre/year	1,000
pH	Standard Units	6.0 - 9.0 in applied wastes
Earthen Storage Basin Operational Monitoring		
Storage Basin Freeboard	Feet	Monitoring
Precipitation	Inches	Monitoring

Land Application Area Operational Monitoring (Daily)		
Irrigation Period	Hours	Monitoring
Volume Irrigated	Gallons	Monitoring
Application Area	Acres	Monitoring
Application Rate	Inches	0.5

Land application rates shall not exceed any of the following limitations

- a) Sludge shall not exceed 10 dry tons per acre per year.
- b) Wastewater shall not exceed 0.2 inches/hour; 0.5 inches/day; 1.0 inches/week; 24 inches/year.

4. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

Construction will cover the following items:

- Storage Lagoon – Lagoon will be constructed and sealed with a 16 in clay liner. Based on the Geohydrologic Evaluation conducted on November 9, 2020, the site received a slight overall geologic limitations rating and a slight collapse potential rating. A 4-inch PVC SDR 35 sewer line will transfer wastewater from the processing facility to a manhole prior to the lagoon entrance. The basin will have 3:1 side slopes and a depth from the top of the berm to the lagoon floor of 11 ft, with 2 ft for sludge depth, 2 ft of freeboard and 1.5 ft above the emergency spillway. The operating depth is 5.5 ft. The basin is non-aerated, has a surface area of approximately 0.44 acres, and has a storage volume of 334,500 gallons. This provides approximately 288 days of retention at the proposed design flow and 124 days of retention including the 1-in-10 year rainfall minus evaporation for the proposed storage period. This meets the minimum storage requirement of 120 days for Grundy County. The berm width will be 8 ft. This lagoon site is going to be fenced.
- Land Application Site – The land application site is located approximately 1.5 miles south on the lagoon on a ridgetop in Grundy County. The purchased land application site is approximately 52 acres and is currently used for hay and pasture. This site is fenced.
- Wastewater Irrigation – Wastewater irrigation equipment will include a portable pump with a rated capacity of 25 to 50 gallons per minute, portable suction piping, portable pump discharge piping, and a mobile “honey wagon” type trailer with storage tank and distribution piping. Maximum application rates are 0.2 inches/hour, 0.5 inches/day, 1.0 inches/week, and 24 inches/year.

5. OPERATING PERMIT

After completion of construction project submit: statement of work completed, as-built if the project was not constructed in accordance with previously submitted plans and specifications, and ensure that operating permit application forms and fee

have been submitted. Missouri State Operating Permit, General Permit MO-G822284, will be issued after receipt of the above documents.

V. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

Ellen Modglin, E.I.
Engineering Section
Ellen.Modglin@dnr.mo.gov

Cailie Carlile, P.E. , Unit Chief
Engineering Section
cailie.carlile@dnr.mo.gov



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
**APPLICATION FOR CONSTRUCTION PERMIT –
 WASTEWATER TREATMENT FACILITY**

RECEIVED

OCT 28 2020

Water Protection Program

FOR DEPARTMENT USE ONLY	
APP NO.	CP NO.
FEE RECEIVED \$1,000.00	CHECK NO. 1006
DATE RECEIVED 10-28-20	

APPLICATION OVERVIEW

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. **All applicants must complete Part A.** Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. **Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.**

PART A – BASIC INFORMATION


1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?
 YES Date of Approval: _____ N/A
- 1.3 Has the department approved the proposed project's facility plan*?
 YES Date of Approval: _____ NO (If No, complete No. 1.4.)
- 1.4 [Complete only if answered No on No. 1.3.] Is a copy of the facility plan* for wastewater treatment facilities included with this application?
 YES NO Exempt because _____
- 1.5 Is a copy of the appropriate plans* and specifications* included with this application?
 YES Denote which form is submitted: Hard copy Electronic copy (See instructions.) NO
- 1.6 Is a summary of design* included with this application? YES NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?
 YES Date of submittal: _____
 Enclosed is the appropriate operating permit application and fee submittal. Denote which form: A B B2
 N/A: However, In the event the department believes that my operating permit requires revision to permit limitation such as changing equivalent to secondary limits to secondary limits or adding total residual chlorine limits, please share a draft copy prior to public notice? YES NO
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency? YES NO
- 1.9 Is the appropriate fee or JetPay confirmation included with this application? YES NO
 See Section 7.0

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT From the Farm Wastewater Treatment Facility	2.2 ESTIMATED PROJECT CONSTRUCTION COST \$
2.3 PROJECT DESCRIPTION Wastewater lagoon with a 120-day storage capacity of 201,428 gallons	
2.4 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION N/A	
2.5 DESIGN INFORMATION A. Current population: <u>N/A</u> ; Design population: <u>N/A</u> B. Actual Flow: _____ gpd; Design Average Flow: <u>1,159</u> gpd; Actual Peak Daily Flow: _____ gpd; Design Maximum Daily Flow: <u>1,350</u> gpd; Design Wet Weather Event: _____	
2.6 ADDITIONAL INFORMATION A. Is a topographic map attached? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO B. Is a process flow diagram attached? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

3.0 WASTEWATER TREATMENT FACILITY				
NAME From the Farm, LLC		TELEPHONE NUMBER WITH AREA CODE 660-654-0496		E-MAIL ADDRESS Fromthefarm@outlook.com
ADDRESS (PHYSICAL) 545 West Highway 6		CITY Trenton	STATE MO	ZIP CODE 64683
COUNTY Grundy				
Wastewater Treatment Facility: Mo- (Outfall Of) N/A -- No Discharge				
3.1 Legal Description: <u>NW</u> ¼, <u>NW</u> ¼, <u>SE</u> ¼, Sec. <u>27</u> , T <u>61</u> , R <u>25</u> (Use additional pages if construction of more than one outfall is proposed.)				
3.2 UTM Coordinates Easting (X): _____ Northing (Y): _____ (X): 440580.80mE (Y): 4433865.97mN For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)				
3.3 Name of receiving streams: _____				
4.0 PROJECT OWNER				
NAME Teresa Alumbaugh		TELEPHONE NUMBER WITH AREA CODE 660-654-0496		E-MAIL ADDRESS
ADDRESS 545 West Highway 6		CITY Trenton	STATE MO	ZIP CODE 64683
5.0 CONTINUING AUTHORITY: A continuing authority is a company, business, entity or person(s) that will be operating the facility and/or ensuring compliance with the permit requirements.				
NAME Same as above		TELEPHONE NUMBER WITH AREA CODE		E-MAIL ADDRESS
ADDRESS		CITY	STATE	ZIP CODE
5.1 A letter from the continuing authority, if different than the owner, is included with this application. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A				
5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY. N/A				
A. Is a copy of the certificate of convenience and necessity included with this application? <input type="checkbox"/> YES <input type="checkbox"/> NO				
5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION. N/A				
A. Is a copy of the as-filed restrictions and covenants included with this application? <input type="checkbox"/> YES <input type="checkbox"/> NO				
B. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application? <input type="checkbox"/> YES <input type="checkbox"/> NO				
C. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application? <input type="checkbox"/> YES <input type="checkbox"/> NO				
D. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application? <input type="checkbox"/> YES <input type="checkbox"/> NO				
6.0 ENGINEER				
ENGINEER NAME / COMPANY NAME Rhodes Engineering Co., Inc.		TELEPHONE NUMBER WITH AREA CODE 660-258-7745		E-MAIL ADDRESS rhodeseng@classicnet.net
ADDRESS 401 West Helm, PO Box 365		CITY Brookfield	STATE MO	ZIP CODE 64628
7.0 APPLICATION FEE				
<input checked="" type="checkbox"/> CHECK NUMBER <input type="checkbox"/> JETPAY CONFIRMATION NUMBER				
8.0 PROJECT OWNER: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				
PROJECT OWNER SIGNATURE 				
PRINTED NAME Teresa Alumbaugh			DATE 22 Oct 20	
TITLE OR CORPORATE POSITION Owner		TELEPHONE NUMBER WITH AREA CODE 660-654-0496		E-MAIL ADDRESS Fromthefarm@outlook.com
Mail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM P.O. BOX 176 JEFFERSON CITY, MO 65102-0176				
END OF PART A.				
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE.				