

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

Bert Westbrook
Owner
Memory Lane Events LLC
78 Walnut Grove Road
Eldon, MO 65026

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

May 17, 2021
Effective Date


Edward B. Galbraith, Director, Division of Environmental Quality

May 16, 2023
Expiration Date


Chris Wieberg, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

The Event Center will have a 4,500 gallon equalization basin and flow to a 1,500 gallon tank with a MicroFast 0.75 treatment system sized to treat a minimum of 750 gallons per day. The cabins and RV parking shall use a total of four 500 gallon septic tanks and flow to a 1,500 gallon treatment tank with a separate MicroFast 0.75 treatment system. This unit will be able to treat a minimum of 750 gallons per day. A 2,000 gallon dosing tank is required to ensure storage of one day's flow above the pump-on float. A drip irrigation system will be used to irrigate 4,038 gpd of effluent.

This project will also include general site work appropriate to the scope and purpose of the project and all necessary appurtenances to make a complete and usable wastewater treatment facility.

II. COST ANALYSIS FOR COMPLIANCE

Pursuant to Section 644.145, RSMo, when issuing permits under this chapter that incorporate a new requirement for discharges from publicly owned combined or separate sanitary or storm sewer systems or publicly owned treatment works, or when enforcing provisions of this chapter or the Federal Water Pollution Control Act, 33 U.S.C. 1251 et seq., pertaining to any portion of a publicly owned combined or separate sanitary or storm sewer system or [publicly owned] treatment works, the Department of Natural Resources shall make a "finding of affordability" on the costs to be incurred and the impact of any rate changes on ratepayers upon which to base such permits and decisions, to the extent allowable under this chapter and the Federal Water Pollution Control Act. This process is completed through a cost analysis for compliance. Permits that do not include new requirements may be deemed affordable.

The Department is not required to complete a cost analysis for compliance because the facility is not a combined or separate sanitary sewer system for a publically-owned treatment works.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.
2. All construction shall be consistent with plans and specifications signed and sealed by R. Miller Companies LLC and as described in this permit.
3. The Department must be contacted in writing prior to making any changes to the plans and specifications that would directly or indirectly have an impact on the capacity, flow,

system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(11).

4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Southwest Regional Office per 10 CSR 20-7.015(9)(G).
5. The wastewater treatment facility shall be located at least fifty feet (50') from any dwelling or establishment per 10 CSR 20-8.140(C)(2).
6. The wastewater treatment facility shall be located above the twenty-five (25)-year flood level.
7. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation per 10 CSR 20-8.140(2)(B). The minimum distance between wastewater treatment facilities and all potable water sources shall be at least three hundred feet (300') per 10 CSR 20-8.140(2)(C)1.
8. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of 1 acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the Department's ePermitting system available online at dnr.mo.gov/env/wpp/epermit/help.htm. See dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.
9. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See dnr.mo.gov/env/wpp/401/ for more information.
10. All construction must adhere to applicable 10 CSR 20-8 (Chapter 8) requirements listed below.
 - Rain water from roofs, streets, and other areas and groundwater from foundation drains shall be excluded from all new sewers. 10 CSR 20-8.120 (2)
 - Service connections to the gravity sewer main shall be watertight and cannot protrude into the sewer. 10 CSR 20-8.120 (3) (C) 1.

- There shall be no physical connections between a public or private potable water supply system and a sewer or appurtenance that would permit the passage of any wastewater or polluted water into the potable supply. Sewers shall be laid at least fifty feet (50') in a horizontal direction from any existing or proposed public water supply well or other water supply sources or structures. Sewers must also comply with 10 CSR 23-3.010. 10 CSR 20-8.120 (5)
- Flood protection shall apply to new construction and to existing facilities undergoing major modification. The wastewater facility structures, electrical equipment, and mechanical equipment shall be protected from physical damage by not less than the one hundred- (100-) year flood elevation. 10 CSR 20-8.140 (2) (B)
- Facilities shall be readily accessible by authorized personnel from a public right-of-way at all times. 10 CSR 20-8.140 (2) (D)
- No piping or other connections shall exist in any part of the wastewater treatment facility that might cause the contamination of a potable water supply. 10 CSR 20-8.140 (7) (D) 1.
- The septic tank shall be baffled. 10 CSR 20-8.180 (2) (B)
- Subsurface systems shall—
 - Exclude unstabilized fill and soils that have been highly compacted and/or disturbed, such as old road beds, foundations, or similar things; 10 CSR 20-8.200 (7) (A) 1. A.
 - Provide adequate surface drainage where slopes are less than two percent (2%); 10 CSR 20-8.200 (7) (A) 1. B.
 - Provide surface and subsurface water diversion where necessary, such as a curtain or perimeter drain; 10 CSR 20-8.200 (7) (A) 1. C. and
 - Have a ten foot (10') buffer from the property line. 10 CSR 20-8.200 (7) (A) 1. D.
- The vertical separation between the bottom of the drip lines and/or the trench and a limiting layer, including but not limited to, bedrock; restrictive horizon; or seasonal high water table, shall be no less than:
 - Twenty-four inches (24"); 10 CSR 20-8.200 (7) (A) 2. A. or
 - Twelve inches (12") for systems dispersing secondary or higher quality effluent; 10 CSR 20-8.200 (7) (A) 2. B. or
 - Forty-eight inches (48") where karst features are present unless the site can be reclassified. 10 CSR 20-8.200 (7) (A) 2. C.
- Subsurface systems shall be, at a minimum, preceded by preliminary treatment. 10 CSR 20-8.200 (7) (B)
- Loading rates shall not exceed the values assigned by the site and soil evaluation. 10 CSR 20-8.200 (7) (C)

- All network piping and low pressure distribution piping and fittings with polyvinyl chloride (PVC) shall meet ASTM Standard D 1785 *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, or 120* as approved and published August 1, 2015, or equivalent rated to meet or exceed ASTM D2466 *Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings* as approved and published August 1, 2017. These standards shall hereby be incorporated by reference into this rule, as published by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959. This rule does not incorporate any subsequent amendments or additions. 10 CSR 20-8.200 (8) (A) 2.
- The location and size of the drains and buffers must be factored into the total area required for the drip dispersal system. 10 CSR 20-8.200 (9) (A) 1.
- The drip dispersal lines shall be placed at a minimum depth of six inches (6") below the surface. 10 CSR 20-8.200 (9) (B) 1.
- Emitters and drip dispersal lines shall be placed at a minimum on a two foot (2') spacing to achieve even distribution of the wastewater and maximum utilization of the soil. 10 CSR 20-8.200 (9) (B) 2.

11. Upon completion of construction:

- A. Memory Lane Events LLC will become the continuing authority for operation and maintenance of these facilities;
- B. Submit an electronic copy of the as built's if the project was not constructed in accordance with previously submitted plans and specifications; and
- C. Submit the enclosed Form MO 780-2155, Wastewater Construction Statement of Work Completed to the Department in accordance with 10 CSR 20-6.010(5)(N) and as-built's if the project was not constructed in accordance with previously submitted plans and specifications.

IV. REVIEW SUMMARY

1. CONSTRUCTION PURPOSE

This Wastewater Irrigation System (WWIS) will be constructed to treat domestic wastewater from an events center, cabins, kitchen area, and RV parking area. A drip irrigation system is being proposed as a subsurface, non-discharging alternative.

2. FACILITY DESCRIPTION

The existing events center, cabins, and RV parking area will have a new collection and irrigation system. The cabins and RV Parking will have Septic Tanks that feed a MicroFast 0.75 Treatment Unit and the Events Center will have a Storage Basin that will feed a second MicroFast 0.75 Treatment Unit. Treated wastewater will be dosed through a drip irrigation system. The irrigation system is sized to the Events Center operating one day per week, the campgrounds operating 2.5 days per week, and the irrigation system operating 7 days per week.

The Memory Lane Events WWIS is located at 78 Walnut Grove Road, Eldon, in Miller County, Missouri. The facility has a design average flow of 4,038 gpd and serves a hydraulic population equivalent of approximately 514 people.

3. COMPLIANCE PARAMETERS

The permitted project in CP0002206 shall meet the requirements of Missouri State Operating Permit MO-0139653. The facility shall follow the monitoring requirements identified in Table A-1: Irrigation System Limitations and Monitoring Requirements for Permitted Feature #001, Storage Basin.

| Storage Basin Parameters | Units | Daily Total | Monthly Total | Measurement Frequency |
|---------------------------------|--------------|--------------------|----------------------|------------------------------|
| Storage Basin Freeboard | feet | * | | once/week |
| Precipitation | inches | * | * | daily |

* Monitoring Only

4. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

Existing major components that will remain in use include the following:

- Septic Tanks have been installed during the cabin area construction. The Septic Tank descriptions and specifications are described below in the Septic Tank section.

Construction will cover the following items:

- Components are designed for a Population Equivalent of 514 based on organic loading to the system.
- **Septic Tanks** – A septic tank provides passive primary treatment as the settleable solids in raw wastewater settle onto the bottom of the tank. Raw wastewater will flow from the cabins to one of four Infiltrator 500 gallon STEP Tanks. The septic tanks provide at least 2.5 days of detention at design average flow (66 gallons per cabin x 3 cabins = 198 gallons per day; 500 gallons/198 gallons = 2.5 days). Settled solids in the septic tank shall be removed by a contract hauler. Septic Tank effluent will flow by gravity to one of the two MicroFast 0.75 Treatment Systems.

- **Storage Basin** – The 4,500 gallon Storage Basin for the Events Center has the dimensions of 188” x 82” x 92” (l x w x d). The Storage Basin provides 1.26 days of detention from the Events Center flow. The Storage Basin discharges by gravity to one of two MicroFast 0.75 Treatment Systems.
- **MicroFast 0.75 Treatment System** – Two MicroFast 0.75 Treatment Systems (MFTS) will be installed with matching specifications. Each MFTS will be installed in an Infiltrator 1,500 gallon tank. The first MFTS will be installed downstream of the Storage Basin. The second MFTS will be installed downstream of the Cabin Septic Tanks. Effluent from both MFTS will flow and combine in the Dosing Tank. Each MFTS is 44.25” x 67.5” x 57.625” (w x l x h) with a flow equalization chamber. Each MFTS will be capable of treating a design average flow of 750 gpd. The MFTS shall come equipped with a regenerative type blower capable of delivering 17-25 CFM. The control panel is equipped with an alarm system consisting of a visual and audible alarm capable of signaling blower circuit failure and high water conditions. The flow rate shall not exceed 5 gpm with a maximum hourly flow not to exceed 10% of the design daily flow (75 gph).
- **Subsurface Soil Dispersal System** – The soils at this site are rated for 0.1 - 0.3 gpd/sqft. The facility decided to use a conservative design loading rate of 0.2 gpd/sqft for the entire system. Soil morphology review was conducted during the engineering report and construction permit application review. On site soils were determined to be acceptable for this system. The soil investigation was completed by Melissa Bettles, Certified Soil Scientist with MB Soil and Septic Consulting, LLC on October 15, 2020. In the soils investigation, there were two pits dug over the proposed irrigation site and one pit dug near the cabins.
 - **Soil Test Pit #1** – located in the irrigation area, had a surface soil that was described as gravelly silt loam with an application rating of at least 0.2 gallons per square foot per day. Soils in this area were classified as provisionally suitable for alternative systems.
 - **Soil Test Pit #2** – located in the irrigation area, had a surface soil that was described as gravelly silt loam with an application rating of at least 0.2 gallons per square foot per day. Soils in this area were classified as provisionally suitable for alternative systems.
 - **Soil Test Pit #3** – located in the vicinity of the cabins, had a surface soil that was described as gravelly silt loam with an application rating of at least 0.2 gallons per square foot per day. Soils in this area were classified as provisionally suitable for alternative systems.
- **Dosing Tank** – A 2,000 gallon Dosing Tank will collect wastewater from both of the MFTS. The dosing tank will have a high water alarm and timer controls. A 120V/0.5 HP STA RITE Step 20 pump capable of pumping 86 feet of head at 21 gallons per minute will be used in the dosing tank to pressurize the Drip Irrigation System.

- **Drip Irrigation System** – Hydraulic loading rate used in the design was conservative at 0.2 gallons per square foot per day. The 1.25” supply lines and ½” ID GeoFlow lines will be installed 8” deep. The facility has selected the GEOFLOW subsurface drip dispersal system. The system will dose 6 zones at 0.2 gpd/sqft, which provides 10 dosings per day per zone. Each zone is 3,365 sqft, for a total of 20,190 sqft. Six combo air/vacuum release valves will be installed. The drip distributing valve will be a GEOFLOW SVLVB-100, 1 inch solenoid valve. The hydraulic loading of the GEOFLOW drip system is 4,038 gpd and they are designed to treat to BOD₅ and TSS of 20 mg/l prior to the drip field. The drip field area is 20,190 square feet and contains 10,095 linear feet of 1.25 inch tubing fitted with emitters every 2 ft and capable of a loading at peak flow of less than 0.2 gpd/sqft. The silty loam onsite soils have the water storage capacity for this hydraulic loading rate with ample pore space for treating the anticipated organic loading of 1.46 pounds per acre per day.

5. OPERATING PERMIT

After completion of construction project, submit:

- Form MO 780-2155, Wastewater Construction Statement of Work Completed (<https://dnr.mo.gov/forms/780-2155-f.pdf>), and
- As-builts if the project was not constructed in accordance with previously submitted plans and specifications.

Missouri State Operating Permit, MO-0139653, will be issued after receipt of the above documents. Form MO 780-1512, Form B: Application for Operating Permit for Facilities that Receive Primarily Domestic Waste and Have a Design Flow Less Than or Equal to 100,000 gallons per day has been submitted to the Department along with an application fee of \$150.


This facility does not meet the requirements of the MOG823000 expiring on August 24, 2022 due to the setbacks outlined in permit applicability condition 11.(a). This facility is not being converted to a general operating permit at this time. This facility will be re-evaluated at operating permit renewal to determine if it qualifies for a general operating permit.

V. NOTICE OF RIGHT TO APPEAL

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to Section 621.250 RSMo. To appeal, you must file a petition with the AHC within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the AHC. Any appeal should be directed to:

Administrative Hearing Commission
U.S. Post Office Building, Third Floor
131 West High Street, P.O. Box 1557
Jefferson City, MO 65102-1557
Phone: 573-751-2422
Fax: 573-751-5018
Website: <https://ahc.mo.gov>

Steven Hamm, P.E.
Engineering Section
Steven.hamm@dnr.mo.gov



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
**APPLICATION FOR CONSTRUCTION PERMIT –
 WASTEWATER TREATMENT FACILITY**

| FOR DEPARTMENT USE ONLY | |
|-------------------------|-----------|
| APP NO. | CP NO. |
| FEE RECEIVED | CHECK NO. |
| DATE RECEIVED | |

APPLICATION OVERVIEW

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. **All applicants must complete Part A.** Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. **Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.**

PART A – BASIC INFORMATION

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?
 YES Date of Approval: _____ N/A
- 1.3 Has the department approved the proposed project's facility plan*?
 YES Date of Approval: _____ NO (If No, complete No. 1.4.)
- 1.4 [Complete only if answered No on No. 1.3.] Is a copy of the facility plan* for wastewater treatment facilities included with this application?
 YES NO Exempt because _____
- 1.5 Is a copy of the appropriate plans* and specifications* included with this application?
 YES Denote which form is submitted: Hard copy Electronic copy (See instructions.) NO
- 1.6 Is a summary of design* included with this application? YES NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?
 YES Date of submittal: _____
 Enclosed is the appropriate operating permit application and fee submittal. Denote which form: A B B2
 N/A: However, in the event the department believes that my operating permit requires revision to permit limitation such as changing equivalent to secondary limits to secondary limits or adding total residual chlorine limits, please share a draft copy prior to public notice? YES NO
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency? YES NO
- 1.9 Is the appropriate fee or JetPay confirmation included with this application? YES NO
 See Section 7.0

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

| | |
|---|---|
| 2.1 NAME OF PROJECT Memory Lane Events LLC - Onsite Sewer | 2.2 ESTIMATED PROJECT CONSTRUCTION COST \$ 60000 |
| 2.3 PROJECT DESCRIPTION Memory Lane Events LLC will consist of a 500 person event center with 5 cabins and 2 RV spots. It is designed to produce 4038 gallons and will be treated and dosed using a drip irrigation onsite system. | |
| 2.4 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION N/A | |
| 2.5 DESIGN INFORMATION A. Current population: _____; Design population: <u>500</u> B. Actual Flow: _____ gpd; Design Average Flow: <u>4038</u> gpd; Actual Peak Daily Flow: _____ gpd; Design Maximum Daily Flow: _____ gpd; Design Wet Weather Event: _____ | |
| 2.6 ADDITIONAL INFORMATION A. Is a topographic map attached? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO B. Is a process flow diagram attached? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | |

| 3.0 WASTEWATER TREATMENT FACILITY | | | | |
|--|--|---|--------------------|--|
| NAME Memory Lane Events LLC - Onsite Sewer | | TELEPHONE NUMBER WITH AREA CODE 573-216-4204 | | E-MAIL ADDRESS |
| ADDRESS (PHYSICAL) 78 Walnut Grove Road | | CITY Eldon | STATE MO | ZIP CODE 65026 |
| COUNTY Miller | | | | |
| Wastewater Treatment Facility: Mo- (Outfall Of) | | | | |
| 3.1 Legal Description: _____ ¼, _____ ¼, _____ ¼, Sec. _____, T _____, R _____ (Use additional pages if construction of more than one outfall is proposed.) | | | | |
| 3.2 UTM Coordinates Easting (X): _____ Northing (Y): _____ For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83) | | | | |
| 3.3 Name of receiving streams: <u>N/A</u> | | | | |
| 4.0 PROJECT OWNER | | | | |
| NAME Memory Lane Events LLC | | TELEPHONE NUMBER WITH AREA CODE 573-216-4204 | | E-MAIL ADDRESS bert@abpest.net |
| ADDRESS 78 Walnut Grove Road | | CITY Eldon | STATE MO | ZIP CODE 65026 |
| 5.0 CONTINUING AUTHORITY: A continuing authority is a company, business, entity or person(s) that will be operating the facility and/or ensuring compliance with the permit requirements. | | | | |
| NAME Memory Lane Events LLC | | TELEPHONE NUMBER WITH AREA CODE 573-216-4204 | | E-MAIL ADDRESS bert@abpest.net |
| ADDRESS 78 Walnut Grove Rd | | CITY Eldon | STATE MO | ZIP CODE 65026 |
| 5.1 A letter from the continuing authority, if different than the owner, is included with this application. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A | | | | |
| 5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY. | | | | |
| A. Is a copy of the certificate of convenience and necessity included with this application? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | |
| 5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION. | | | | |
| A. Is a copy of the as-filed restrictions and covenants included with this application? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | |
| B. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | |
| C. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | |
| D. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO | | | | |
| 6.0 ENGINEER | | | | |
| ENGINEER NAME / COMPANY NAME Ethan K. Shackelford/R. Miller Companies LLC | | TELEPHONE NUMBER WITH AREA CODE 573-348-9799 | | E-MAIL ADDRESS ethan@themillercos.com |
| ADDRESS PO Box 282 | | CITY Osage Beach | STATE MO | ZIP CODE 65065 |
| 7.0 APPLICATION FEE | | | | |
| <input type="checkbox"/> CHECK NUMBER <input checked="" type="checkbox"/> JETPAY CONFIRMATION NUMBER 20021473 | | | | |
| 8.0 PROJECT OWNER: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. | | | | |
| PROJECT OWNER SIGNATURE  | | | | |
| PRINTED NAME Bert Westbrook | | | DATE 01/26/2021 | |
| TITLE OR CORPORATE POSITION Owner | | TELEPHONE NUMBER WITH AREA CODE 573-216-4204 | | E-MAIL ADDRESS bert@abpest.net |
| Mail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM P.O. BOX 176 JEFFERSON CITY, MO 65102-0176 | | | | |
| END OF PART A. | | | | |
| REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE. | | | | |