STATE OF MISSOURI DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



GENERAL PERMIT for SEWER EXTENSION CONSTRUCTION

The Missouri Department of Natural Resources hereby issues a permit to:

Construction Permit ID:	MOGC00691
Title of Project:	Highway 86 Sanitary Sewer
Owner:	Taney County Regional Sewer District
Address:	6733 E. MO-76
	Kirbyville, MO 65679

The project will also include general site work appropriate to the scope and purpose of the project and will include all the necessary appurtenances to make a complete and usable collection system. The construction of this project will be in the vicinity of the county below and discharge to Receiving Permit ID below:

County: Taney Receiving Permit ID: MO0116041

for the construction of (described construction project):

Highway 86 Sanitary Sewer Project Phase1- Arena Force Main-Construction of approx.: 4,200 lf of 8-in PVC SDR-21 force main with air release valves. This is an additional segment within the Phase 1 project. A pumping lift station and receiving lift station will be constructed under a separate construction permit application.

Project is in the vicinity of State Hwy 86 West of Hwy 65 discharges to an existing Taney Co SD system to be treated at Hollister WWTF, MO-0116041. Arena Force Main will serve an arena event venue, a shooting range and an RV Park. Rick Ziegenfuss, City of Hollister administrator, provided acceptance document dated 12/29/2024. Brad Albritton, Taney County Regional Sewer District administrator signed the application.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department) As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

January 23, 2024 Issue Date

John Hoke, Director Water Protection Program

January 22, 2026 Expiration Date

APPLICABILITY

- 1. This permit authorizes the construction of gravity sewer extensions, force mains, and lift stations. Non-earthen flow equalization storage basins at lift stations and inline storage, which flows back into the lift station or collection system, are also included.
- 2. The Missouri Department of Natural Resources may require a site-specific sewer extension construction permit due to compliance and enforcement actions in accordance with 10 CSR 20-6.010(13)(C).
- 3. This permit does not apply to:
 - A. Earthen storage basins;
 - B. Exempt projects in accordance with 10 CSR 20-6.010(1)(B), 10 CSR 20-6.010(5)(B), and RSMo 644.051 unless requested by the applicant or required by enforcement.

PREREQUISITES:

- 1. The Sewer Extension Construction Permit application, appropriate fee, and documentation in accordance with 10 CSR 20-6.010(5)(G).
- 2. Submit the Sewer Extension Construction Permit application at least sixty (60) days in advance of the start of construction in accordance with 10 CSR 20-6.010(5)(F).
- 3. Submit an electronic copy of the construction permit application and documents to <u>DNR.WPPEngineerSection@dnr.mo.gov</u> in accordance with 10 CSR 20-6.010(5)(G)3.
- 4. The plans and specifications, each signed, sealed, and dated by a professional engineer registered in the State of Missouri in accordance with 10 CSR 20-8 and 10 CSR 20-6.010.
- 5. The Design Certification form, Engineering Report, or Summary of Design, signed, sealed, and dated by a professional engineer registered in the State of Missouri, certifying the design of the system is in accordance with 10 CSR 20-6 and 10 CSR 20-8.
- 6. A statement from the continuing authority, as defined in 10 CSR 20-6.010, accepting the wastewater for treatment and indicating the permitted treatment facility has the available capacity.
- 7. A statement from the continuing authority, as defined in 10 CSR 20-6.010, accepting responsibility for the operation and maintenance of these facilities.

PERMIT CONDITIONS:

- 1. This permit authorizes the activities and scope of work detailed in the plans and specifications submitted with the request.
- 2. The construction must be in accordance with the final plans and specifications received by the Department. Revisions that affect capacity, flow, or system layout must be approved by the Department prior to construction.

PERMIT CONDITIONS: (continued)

- 3. If construction will incorporate minor changes from previously submitted plans and specifications (i.e., changes that do not affect the capacity, flow, or system layout), submit an electronic copy of the as-built plans and specifications in accordance with 10 CSR 20-8.110(11).
- 4. State and Federal Law does not permit bypassing of raw wastewater; therefore, the applicant must take steps to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's regional office per 10 CSR 20-7.015(9)(E) or through the Online Bypass/SSO Reporting service on the Missouri Gateway for Environmental Management (MoGEM) portal found at https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem.

See <u>https://dnr.mo.gov/document-search/missouri-gateway-environmental-management-mogem-frequently-asked-questions-pub2988/pub2988</u> for more information.

- 5. Protection of drinking water supplies must meet the requirements of 10 CSR 20-8.120(5).
 - A. There shall be no physical connections between a public or private potable water supply system and a sewer or appurtenance that would permit the passage of any wastewater or polluted water into the potable supply.
 - B. Lay sewers at least 50 feet (50') in a horizontal direction from any existing or proposed public water supply well or other water supply sources or structures.
- 6. Position manholes so that the top access is at or above grade level.
- 7. In addition to the requirements for a construction permit, see 10 CSR 20-6.200 for land disturbance requirements to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Applicants shall obtain land disturbance permits through the Department's ePermitting system, available online at https://dnr.mo.gov/data-e-services/water/electronic-permitting-epermitting.

See <u>https://dnr.mo.gov/water/business-industry-other-entities/permits-</u> <u>certification-engineering-fees/stormwater/construction-land-disturbance</u> for more information.

8. Entities applying for funding under 10 CSR 20-4, "Grants and Loans" will need to comply with those requirements in addition to the requirements of 10 CSR 20-8.

PERMIT CONDITIONS: (continued)

9. The Department may require a United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) or a permit waiver for the activities described in this permit. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S., then a 404/401 is required. Fulfillment of these requirements is necessary before the permit is considered valid. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Operating Permits Section at 573-522-4502 for more information.

See <u>https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/section-401-water-quality</u> for more information.

- 10. If this project eliminates a wastewater treatment facility under the jurisdiction of the Department, then the applicant shall submit a full closure plan with a Facility Closure Request Form, <u>Form MO 780-2512</u>, to the Department's appropriate <u>regional office</u> for review and approval. In accordance with 10 CSR 20-6.010(12), the closure plan must meet the requirements outlined in Standard Conditions Part III of the Missouri State Operating Permit. Closure shall not commence until the Department approves the submitted closure plan.
- 11. If this project is part of a project to resolve an enforcement action or is receiving funding from the Department, submit a <u>statement of work complete</u> following the completion of construction.
- 12. Applicants may submit, prior to the expiration date of this permit, a written request that additional time is needed in accordance with 10 CSR 20-6.010(5)(H)3.

MISSOURI DEPARTMENT OF NATURAL RESOUR				FOR DEPARTMENT USE ONLY			
		AL RESOURCES		APP NO.	CP NO.		
		CTION PERMIT –		FEE RECEIVED	CHECK NO.		
SEWER EXTENSION			DATE RECEIVED				
				DATE RECEIVED			
NOTE ► Please Read the accompanying i							
1.0 APPLICATION INFORMATION (Note – considered incomplete and returned.)	lf any of th	ne questions in this section	on are answe	ered NO, this appl	cation may be		
1.1 Is this a Federal/State funded project?	YES	🖌 N/A Funding Age	ncy:	Р	roject #:		
1.2 Has the Department of Natural Resource ☑ YES Date of Appr		ed the proposed project's ust 11, 2023 Addendum Attac		g report*?	□ N/A		
1.3 Is a copy of the appropriate plans* and s	pecificatio	ons* included with this ap	plication?	YES NO			
If the project is using standard specificat	ions, nam	e of community: Taney (County Regio	onal Sewer Distric	t		
1.4 Is a summary of design* included with th							
1.5 Is the appropriate fee or JetPay confirma See Section 7.0			YES	□ NO			
* Must be affixed with a Missouri registered p	rofession	al engineer's seal, signat	ure and date	2			
2.0 PROJECT INFORMATION		ar originoor o ocal, oignat					
2.1 NAME OF PROJECT Highway 86 Sanitary Sewer Project - Phase 1		Force Main					
ADDRESS			STATE	ZIP CODE	COUNTY		
Vicinity of State Highway 86 West of Hwy 65	Ridgedal	e	МО	65739	Taney		
2.2 Legal Description: 1/4, 1/2	4,	1⁄4, Sec. 13 ,	Τ ₂₁ ,	R 22			
2.3 Project Components (check all that apply		orce mains 🔲 Alternat	tive sewer sy	vstem ☐ Other	(Describe below.)		
2.4 PROJECT DESCRIPTION							
The project will consist of the construction of requirements to construct a sewer extension							
Phase 1 sewer project has secured a constru	ction pern	nit for Part 1, which inclu	ded the cons	struction of force n	nains and gravity mains.		
Part 1 is currently still under construction. Thi							
overall Highway 86 Phase 1 project. Future c Arena force main within this application) and							
through MOGC00626). This project will be co							
2.5 DESIGN INFORMATION A. Population or number of lots to be served	by this ex	tension: 1 private develo	opment prop	erty			
B. Estimated flow to be contributed by this e	xtension:	Design Average Flow:	gpd	Design Peak Hou	urly Flow: gph		
C. Industrial Wastes: Type: N/A	Flo			-			
D. Receiving Sewer: Size: 12 inches Capacity: 4421 gpm							
E. Does this project (check all that apply):		, , , , , , , , , , , , , , , , , , , ,					
Connect to an existing treatment plant		e enforcement issue	Eliminate or	consolidate an ex	kisting treatment plant		
F. Estimated number of onsite systems bein							
G: Estimated costs associated with piping: \$	-	Estimated costs a	ssociated wi	th lift station(s) [.] \$			
3.0 PROJECT OWNER	733,430						
NAME		TELEPHONE NUMBER WITH AF	REA CODE	EMAIL ADDRESS			
Taney County Regional Sewer District		417-544-0655	1	ballbritton@tcrs	d.org		
ADDRESS 6733 East State Highway 76	CITY Kirbyville	9	STATE MO	ZIP CODE 65679			
CHARTER NUMBER (SECRETARY OF STATE) or REGISTERED	-	•					
MO 780-1632 (10-22)							

4.0 CONTINUING AUTHORITY: A continuing for ensuring compliance with the permit requi Continuing authority should be a relatively perwhen needed, of the permitted facility or active hired by the permittee to sample or operate a analytical laboratory. To access the regulator Water Commission Chapter 6. A continuing a (SoS's) webpage: Missouri Secretary of State required to register with the SoS.	rements a rmanent e vity. A con nd mainta y requiren authority's	nd provide o entity respor tinuing auth in the syste nent regardi name must	continuous s nsible for the ority is not, h m for a defir ng continuin be listed exa	table oversig ongoing ope nowever, an ned time peri- g authority, actly as it ap	ght of the permitted facility or activity. The eration, maintenance and modernization, entity or individual that is contractually od, such as a certified operator or 10 CSR 20-6.010(2), please visit <u>Clean</u> pears on the Missouri Secretary of State's al(s), government entity, or otherwise not	
				REA CODE		
Taney County Regional Sewer District	OITY	417-544-0	655		ballbritton@tcrsd.org	
6733 East State Highway 76	сітү Kirbyville	1		STATE MO	65679	
CHARTER NUMBER (SECRETARY OF STATE)						
4.1 Has appropriate continuing authority accer A letter from the continuing authority acceptin different than the original owner of the constr Treatment Facility Acceptance" Form 780-25	ng respons uction), or	sibility for co a properly e	ntinued maii exec <u>ute</u> d "Co	ntenance of t		
5.0 ENGINEER						
ENGINEER NAME / COMPANY NAME Jacob Dean / Great River Engineering		TELEPHONE 1 417-886-7	NUMBER WITH AF	REA CODE	EMAIL ADDRESS jdean@greatriv.com	
ADDRESS 2826 S. Ingram Mill Rd	CITY Springfie	1	171	STATE MO	ZIP CODE 65804	
6.0 RECEIVING WASTEWATER TREATME						
NAME		TELEPHONE	NUMBER WITH A	REA CODE	EMAIL ADDRESS	
Hollister Wastewater Treatment Facility MISSOURI STATE OPERATING PERMIT #		417-334-3 COUNTY	330		wwtp@cityofhollister.com REMAINING CAPACITY (GPD)	
MO-0116041		Taney			1,210,000	
6.1 If different from the owner, has a letter be						
accept the expanded flow or has a properly e MO 780-2584 form been provided?			uthority and	Receiving V	Vastewater Treatment Facility Acceptance	
6.2 A letter from the receiving wastewater tre ☑ YES □ NO □ N/A		•				
6.3 If the receiving treatment plant or continuin Certificate of Convenience and Necessity has			ted by the Pi Yes – Date		Commission (PSC) for sewer activities, a ☐ No ☑ N/A	
OPTIONAL QUESTIONS REGARDING MILL	TARY SE	RVICE				
Have you or an immediate family member ev U.S. Armed Forces?	er served	in the	☐ Yes		🗹 No	
If yes, would you like information about military-related in Missouri?		services		es	🗹 No	
7.0 Application Fee						
Check Number			🖌 JetPay	Confirmatior	Number	
8.0 PROJECT OWNER: I certify under penal	ty of law tl	his documer	-			
supervision in accordance with a system desi submitted. Based on my inquiry of the persor gathering the information, the information sub aware there are significant penalties for subm violations.	igned to a or persor omitted is,	ssure qualifi ns who man to the best	ed personne age the syst of my knowle	el properly ga em, or those edge and be	ather and evaluate the information persons directly responsible for lief, true, accurate and complete. I am	
PROJECT OWNER SIGNATURE	ite					
PRINTED NAME Brad Allbritton					December 22, 2023	
TITLE OR CORPORATE POSITION		TELEPHONE	NUMBER WITH A	REA CODE	EMAIL ADDRESS	
Administrator - TCRSD		417-544-06	655		ballbritton@tcrsd.org	
Mail completed copy to:			Submit completed electronic copy to:			
MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM PO BOX 176 JEFFERSON CITY, MO 65102-0176			Missouri Department of Natural Resources at DNR.WPPEngineerSection@dnr.mo.gov			

9.0 SEWER EXTENSION CHECKLIS

1 8.110(3)(A) Is the design flow based on actual flow data for an existing system? Image: Control Contro Control Conterve Contend Control Contenter Control Control Conten	9.0 SE	EWER EXTENSIO	N CHECKLIST		
REGULATION VES NA 1. 8.110(3)(A) Is the design flow based on actual flow data for an existing system? □				clearly r	not
2. 8.110(3)(B) Are average design flows, peak hourly flows and I&I contributions for new systems Image: Calculated? 3. 8.110(9)(B) Is there a detailed plan showing tributary area, boundaries, pertinent elevations, topography, existing and proposed faillies? Image: Calculated? 4. 8.120(2) Does the sever exclude water from roots, streets, groundwater from foundation drains and combined watewater? Image: Calculated? 5. 8.120(3)(A) Is the pipe installation, embedment and backfill designed to prevent damage to the pipe and its junts? Image: Calculated? 6. 8.120(3)(A) Is the pipe constructed with a slope to obtain mean velocities of not less than 2 feet and its junts? Image: Calculated? 7. 8.120(3)(A) Is the pipe covered with at least 36° of soil or sufficiently insulated to prevent freezing? Image: Calculated? 8. 8.120(3)(A) Is the pipe covered with at least 36° of soil or sufficiently insulated to prevent freezing? Image: Calculated? 9. 8.120(4)(A) Are manholes located at the end of each line, at all changes in grade, size or alignment and at lintersections? Image: Calculated? 10. 8.120(4)(C) Are manholes suffight constructed and insulated in accordance with the manholes water fight constructed and procedures? Image: Calculated? 11. 8.120(4)(F) Do the specif				YES	N/A
calculated? Image: calculated? Image: calculated? 3. 8.110(9)(B) Is there a detailed plan showing tributary area, boundaries, pertinent elevations. topography, existing and proposed facilities? Image: calculated? 4. 8.120(2) Does the sewer exiculde water from rooks, streets, groundwater from foundation drains and calculate is points? Image: calculated? 5. 8.120(3)(A) Is the pipe installation, embedment and backfill designed to prevent damage to the pipe calculated? Image: calculated? 6. 8.120(3)(A) Is the pipe correct with a least 30° of soil or sufficiently insulated to prevent freezing? Image: calculated? 7. 8.120(3)(B) Is deflection testing specified to ensure no pipe exceeds a deflection of 5% of the inside diameter? Image: calculated? 9. 8.120(4)(C) Are manholes at least 42 inches in diameter with a clear opening of 22 inches on sever in and dat all intergections? Image: calculate ca	1.	8.110(3)(A)	Is the design flow based on actual flow data for an existing system?		\checkmark
topography, existing and proposed facilities? Image: Combined wasterwater? 4. 8.120(2) Does the sever exclude water from roots, streets, groundwater from foundation drains and combined wastewater? Image: Combined wastewater? 5. 8.120(3)(A) Is the pipe installation, embedment and backfill designed to prevent damage to the pipe and its joints? Image: Combined wastewater? Ima	2.	8.110(3)(B)			
combined wastewater? Image: Combined wastewater? 5. 8. 120(3) (A) Is the pipe installation, embedment and backfill designed to prevent damage to the pipe and its joints? 6. 8. 120(3) (A) Is the pipe installation, embedment and backfill designed to prevent freezing? 7. 8. 120(3) (A) Is the pipe constructed with a slope to obtain mean velocities of not less than 2 feet 8. 8. 120(3)(B) Is deflection tosting specified to ensure no pipe exceeds a deflection of 5% of the incide diameter? 9. 8. 120(4)(A) Are manholes located at the end of each line, at all changes in grade, size or alignment and at all intersections? 10. 8. 120(4)(C) Are manholes to least 42 inches in diameter with a clear opening of 22 inches on sewer 11. 8. 120(4)(C) Where cleanouts are used at the end of a lateral instead of a manhole, they are a minimum diameter of 8 inches or larger and equal to the diameter for pipes < 8??	3.	8.110(9)(B)	topography, existing and proposed facilities?	\checkmark	
and its joints? Image: Second? 6. 8. 120(3) (A)1 Is all sever pipe constructed with a slope to obtain mean velocities of not less than 2 feet per second? 7. 8. 120(3)(A)2 Is the pipe covered with at least 36° of soil or sufficiently insulated to prevent freezing? 8. 8. 120(3)(B) It deflection testing specified to ensure no pipe exceeds a deflection of 5% of the ineide diameter? 9. 8. 120(4)(A) Are manholes located at the end of each line, at all changes in grade, size or alignment and at all intersections? 10. 8. 120(4)(C) Are manholes sole stat 42 inches in diameter with a clear opening of 22 inches on sever line larger than 8'? 11. 8. 120(4)(C) Where cleanouts are used at the end of a lateral instead of a manhole, they are a minitum diameter of 8 inches or larger and equal to the diameter for pipes < 8''?	4.	8.120(2)		V	
per second? ✓ 7. 8. 120(3)(A)2 1s the pipe covered with at least 36° of soil or sufficiently insulated to prevent freezing? ✓ 8. 8. 120(3)(B) 1s deflection testing specified to ensure no pipe exceeds a deflection of 5% of the inside diameter? ✓ ✓ 9. 8. 120(4)(C) Are manholes located at the end of each line, at all changes in grade, size or alignment and at all intersections? ✓ ✓ 10. 8. 120(4)(C) Where cleanouts are used at the end of a lateral instead of a manhole, they are a minimum diameter of 8 inches or larger and equal to the diameter for pipes < 8?	5.	8.120(3)(A)		V	
8. 8. 120(3)(B) Is deflection testing specified to ensure no pipe exceeds a deflection of 5% of the inside diameter? 9. 8. 120(4)(A) Are manholes located at the end of each line, at all changes in grade, size or alignment and at all intersections? Image: Comparison of	6.	8.120(3) (A)1		\checkmark	
diameter? Image: Control of the con	7.	8.120(3)(A)2	Is the pipe covered with at least 36" of soil or sufficiently insulated to prevent freezing?	\checkmark	
and at all intersections? □ 10. 8.120(4)(C) Are maholes at least 42 inches in diameter with a clear opening of 22 inches on sewer □ ℤ 11. 8.120(4)(C) Where cleanouts are used at the end of a lateral instead of a manhole, they are a minimum diameter of inches or larger and equal to the diameter for pipes < 8'?	8.	8.120(3)(B)		\checkmark	
11. 8.120(4)(C) Where cleanouts are used at the end of a lateral instead of a manhole, they are a minimum diameter of b inches or larger and equal to the diameter for pipes < 8'?	9.	8.120(4)(A)	and at all intersections?		\checkmark
diameter of 8 inches or larger and equal to the diameter for pipes < 8°?	10.	8.120(4)(C)			
13. 8.120(4)(F) Do the specifications include a requirement for inspection and testing for manholes? □ ✓ 14. 8.120(5)(A) Is the sever free from physical connections to a potable water supply system and no water ✓ ✓ 15. 8.120(5)(B) Are severs and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures? ✓ ✓ 16. 8.125(5)(B) Are severs and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures? ✓ ✓ 17. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 ft/s happen more than once per day? ✓ ✓ 18. 8.125(5)(B) Are appurtenances compatible with the piping system? ✓ ✓ 18. 8.125(5)(B) Are appurtenances compatible with the piping system? ✓ ✓ 19. 8.125(5)(C) Do service line pipes have a minimum diameter of 1.25"? ✓ ✓ ✓ 20. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. ✓ ✓ 21. 8.125(5)(D)1.A Do simplex grinder pump stations owned, operated and maintained by an approved continuing authority? ✓ ✓	11.	8.120(4)(C)			
13. 8.120(4)(F) Do the specifications include a requirement for inspection and testing for manholes? □ ✓ 14. 8.120(5)(A) Is the sewer free from physical connections to a potable water supply system and no water pipes come in contact with a sewer manhole? □ ✓ 15. 8.120(5)(B) Are sewers and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures? ✓ □ 10.0 PRESSURE SEWERS, GRINDER PUMP, STEP AND STEG SEWER CHECKLIST YES N/A 16. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 fl/s happen more than once per day? ✓ □ 17. 8.125(5)(B). Are appurtenances compatible with the piping system? ✓ □ 18. 8.125(5)(B). Are appurtenances compatible with the piping system? ✓ □ 20. 8.125(5)(C) Do service line pipes have a minimum diameter of 1.25°? □ ✓ 21. 8.125(5)(D)1.A. Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. □ ✓ 22. 8.125(5)(D)1.B. Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? ✓ ✓ 23. 8.125(5)(D)3. Is there at lea	12.	8.120(4)(E)	Are the manholes watertight, constructed and installed in accordance with the		\checkmark
14. 8.120(5)(A) Is the sewer free from physical connections to a potable water supply system and no water pipes come in contact with a sewer manhole? Image: Constant of the proposed water supply well, sources, structures? 15. 8.120(5)(B) Are severs and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures? Image: Constant of the proposed water supply well, sources, structures? 10.0 PRESSURE SEWERS, GRINDER PUMP, STEP AND STEG SEWER CHECKLIST YES N/A 16. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 ft/s happen more than once per day? Image: Constant of the pressure sewer main pipe at least 1.5"? Image: Constant of the pressure sewer main pipe at least 1.5"? Image: Constant of the pressure sewer main pipe at least 1.5"? Image: Constant of the pressure sewer main pipe at least 1.5"? Image: Constant of the pressure sewer main pipe at least 1.5"? Image: Constant of the pressure sewer and manhous proper pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? Image: Constant of the pressure a minimum diameter of 1.25"? Image: Constant of the pressure a minimum diameter of 1.25"? Image: Constant of the pressure sever end and no suffer pump time? Image: Constant of the pressure accessible from the ground of system? Image: Constant of the pressure and maintained by an approved continuing authority? Image: Constant of the pressure accessible from the ground sufface? Image: Constant of the pressure accessible from the ground sufface? Ima	13.	8.120(4)(F)			
15. 8.120(5)(B) Are sewers and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures? ✓ 10.0 PRESSURE SEWERS, GRINDER PUMP, STEP AND STEG SEWER CHECKLIST YES N/A 16. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 ft/s happen more than once per day? ✓ ✓ 17. 8.125(5)(A)2. Is the diameter of the pressure sewer main pipe at least 1.5"? ✓ ✓ 18. 8.125(5)(B) Are appurtenances compatible with the piping system? ✓ ✓ 19. 8.125(5)(B)2. Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? ✓ ✓ 20. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. 1 residence – 1 grinder pumpt. ✓ ✓ 21. 8.125(5)(D)1.B Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? ✓ ✓ 22. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? ✓ ✓ 23. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? <t< td=""><td>14.</td><td>8.120(5)(A)</td><td></td><td></td><td></td></t<>	14.	8.120(5)(A)			
10.0 PRESSURE SEWERS, GRINDER PUMP, STEP AND STEG SEWER CHECKLIST YES N/A REGULATION YES N/A 16. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 ft/s happen more than once per day? ✓ 17. 8.125(5)(A)2. Is the diameter of the pressure sewer main pipe at least 1.5"? ✓ ✓ 18. 8.125(5)(B) Are appurtenances compatible with the piping system? ✓ ✓ 19. 8.125(5)(B)2. Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? ✓ ✓ 20. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. ✓ ✓ 21. 8.125(5)(D)1.B Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? ✓ ✓ 23. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? ✓ ✓ 24. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? ✓ ✓ 25. 8.125(5)(D)7. Are units serviceable and replaceable under wet conditions without electrical hazard and is	15.	8.120(5)(B)	Are sewers and manholes located at least 50 feet horizontally from any existing or	V	
16. 8.125(5)(A)1. Does the cleaning velocity of ≥ 2 ft/s happen more than once per day? ✓ 17. 8.125(5)(A)2. Is the diameter of the pressure sewer main pipe at least 1.5"? ✓ 18. 8.125(5)(B) Are appurtenances compatible with the piping system? ✓ ✓ 19. 8.125(5)(B)2. Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? ✓ ✓ 20. 8.125(5)(C) Do service line pipes have a minimum diameter of 1.25"? ✓ ✓ 21. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. ✓ ✓ 22. 8.125(5)(D)1.B Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? ✓ ✓ 23. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? ✓ ✓ 24. 8.125(5)(D)7., 8.125(5)(D)8., 8.125(5)(D)	10.0 P	RESSURE SEWE		J	
17. 8.125(5)(A)2. Is the diameter of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? 18. 8.125(5)(B) Are appurtenances compatible with the piping system? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"? Image: Constraint of the pressure sewer main pipe at least 1.5"?		REGULATION		YES	N/A
18. 8.125(5)(B) Are appurtenances compatible with the piping system? Image: Compatible with the piping system? Image: Compatible with the piping system? 19. 8.125(5)(B)2. Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? Image: Compatible with the piping system? Image: Compatible with t	16.			\checkmark	
19. 8.125(5)(B)2. Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system? Image: Construct of the pipe state of the pipe	17.	8.125(5)(A)2.	Is the diameter of the pressure sewer main pipe at least 1.5"?	\checkmark	
bridge and RR crossings; at terminal end of system? ✓ 20. 8.125(5)(C) Do service line pipes have a minimum diameter of 1.25"? □ ✓ 21. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. 1 residence – 1 grinder pumpt. □ ✓ 22. 8.125(5)(D)1.B Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? □ ✓ 23. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? □ ✓ 24. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? □ ✓ 25. 8.125(5)(D)7., 8.130(3)(B)2. Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? ✓ 26. 8.125(5)(D)8., 8.125(2)(F)6. Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system? □ ✓ 27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard				\checkmark	
21. 8.125(5)(D)1.A Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. 1 residence – 1 grinder pumpt. Image: Continuing authority? 22. 8.125(5)(D)1.B Are multiple unit pump stations owned, operated and maintained by an approved continuing authority? Image: Continuing authority? 23. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? Image: Continuing authority? 24. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? Image: Continuing authority? 25. 8.125(5)(D)7., 8.130(3)(B)2. Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? Image: Context Code Code Class I, Group D, Division 1 location)? 26. 8.125(5)(D)8., 8.125(2)(F)6. Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system? Image: Context Code Class I, Conte	19.	8.125(5)(B)2.		\checkmark	
. 1 residence – 1 grinder pumpt. Image: Construint of the provided state of the provided stat	20.	8.125(5)(C)	Do service line pipes have a minimum diameter of 1.25"?		\checkmark
23. 8.125(5)(D)3. Is there at least 70 gallons of storage in the grinder pump unit? Image: Continuing authority? 24. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? Image: Continuing authority? 25. 8.125(5)(D)7., 8.130(3)(B)2. Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? Image: Context Code, Class I, State Code, Class I, S	21.	8.125(5)(D)1.A			V
24. 8.125(5)(D)4. Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface? □ ✓ 25. 8.125(5)(D)7., 8.130(3)(B)2. Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? □ ✓ 26. 8.125(5)(D)8., 8.125(5)(D)8., 8.125(2)(F)6. Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system? □ ✓ 27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard and ventillation? □ ✓	22.	8.125(5)(D)1.B			
siphoning could occur) that are accessible from the ground surface? □ ✓ 25. 8.125(5)(D)7., 8.130(3)(B)2. Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? □ ✓ 26. 8.125(5)(D)8., 8.125(2)(F)6. Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system? □ ✓ 27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard and ventillation? □ ✓	23.	8.125(5)(D)3.	Is there at least 70 gallons of storage in the grinder pump unit?		
8.130(3)(B)2. electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)? 26. 8.125(5)(D)8., 8.125(2)(F)6. 8.125(2)(F)6. Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system? 27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard and ventillation? Image: Comparison of tank volume dedicatied to freeboard and ventillation?	24.	8.125(5)(D)4.			
8.125(2)(F)6. by providing standby power, storage capacity, or interconnection with another disposal system? 27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard and ventillation?	25.		electrical equipment suitable for hazardous locations (National Electrical Code, Class I,		
27. 8.125(6)(D) In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicatied to freeboard and ventillation? Image: Comparison of tank volume dedicatied to freeboard and ventillation?	26.		Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal		
	27.	8.125(6)(D)	In a STEP system is at least one septic tank (1,000 gallons or more) provided for each		
	28.	8.125(6)(F)	Are duplex pumps provided for the design flow of 1,500 gallons or greater?		\checkmark

28. 8.125(MO 780-1632 (10-22) 8.125(6)(F)

REGULATION 29. 8.125(7)(C) Is the minimum diameter sewer main pipe and service line of STEG sewer at least 4 20. 8.120(2)(A) Is the minimum diameter sewer main pipe and service line of STEG sewer at least 4	YES N/A						
20 $9.120(2)(A)$ le the nume station designed to with stand the 100 \cdots of the do	4"?						
30.8.130(2)(A) 8.140(2)(B)Is the pump station designed to withstand the 100-year flood?							
31. 8.130(3)(A) Is the dry well completely separate from the wet well and is a suitable and safe mea access provided to each?	ans of						
32. 8.130(3)(B) If the design flow is 1,500 gpd or more, are there at least 2 pumps or pneumatic ejectory provided?	ctors						
33 8.130(3)(D) Are valves located outside wet well unless integral to a pump or its housing?							
34. 8.130(3)(F) Do wet and dry wells have separate ventilation systems? 8.140(8)(J) 8.140(8)(J)							
35. 8.130(3)(G) Does all potable water brought to pump stations comply with 8.140(7)(D)?							
36. 8.130(6) Is an alarm system provided with uninterrupted power?							
37.8.130(7)(A)Is there 2 hours retention of the peak hourly flow for a design flow > 100,000 gpd or retention of the peak hourly flow for a design flow < 100,000 gpd?	⁴ hrs						
38. 8.130(7)(B) Are there independent utility substations provided for emergency power capable of s and operating the pump station at its rated capacity?	starting						
39. $8.130(8)(A)$ Is the force main velocity of ≥ 2 ft/s maintained?							
40. 8.130 Are there complete operation instructions for the pumpting stations provided that inc emergency procedures, maintenance schedules, special tools and spare parts that in processary?	clude						
necessary? 12.0 SUCTION LIFT PUMP AND SUBMERSIBLE PUMP STATION CHECKLIST							
REGULATION	YES N/A						
41. 8.130(4) Are the suction lift pumps of the self priming or vacuum priming type?							
42. 8.130(4)(A) Is the combined total of dynamic suction lift at the "pump off" elevation and required positive suction head at design operating conditions less than or equal to 22 feet?							
43. 8.130(4)(B) Are there dual vacuum pumps capable of removing air from the suction lift pump?							
44. 8.130(5)(A) Are submersible pumps readily removable and replaceable without personnel entering	ing or						
disconnecting any pipe in the wet well?							
13.0 SEWER EXTENSION CHECKLIST CERTIFICATION STATEMENT							
For any questions answered "N/A" provide an explanation. Also provide any useful general comments regarding engineer.	ng design for review						
1. The sewer flows will come from a development under construction							
9-13. No gravity mains or manholes proposed in this application 20. no service lines proposed							
21-28. no grinder stations or step systems proposed							
29-44. No pump stations are proposed in this application at this time. Future applications will be provided for the	ne lift stations						
associated with the force mains included in this project thus far.							
A CONTRACTOR							
E OF MISSO							
Execcel (Dema							
JACOBC.							
Missouri Professional Engineer's seal, signature and date:							
NUMBER / 19							
12/22/2023							
STONAL ENSE							
Name: Jacob Dean - Great River Engineering							
Address: 2826 S. Ingram Mill Rd.							
City: Springfield State: MO ZIP Code: 65804							
Telephone Number with Area Code: 417-886-7171 Email:jdean@greatriv.com							

INSTRUCTIONS FOR COMPLETING APPLICATION FOR CONSTRUCTION PERMIT – SEWER EXTENSION

All blanks must be filled in when the application is submitted to the Missouri Department of Natural Resources. This includes the **required signature**. The fee for a sewer extension construction permit is \$300.

In accordance with Missouri State law RSMo 644.051.3.(2), sewer extension projects installing up to a total of 1,000 linear feet of gravity sewer or force main with less than two pump stations are exempt from obtaining a construction permit. Since these projects are exempt, a construction permit will not be issued for this activity and completion of this form is not required.

Note: Use the form Application for Construction Permit – Wastewater Treatment Facility Application for Construction Permit – Sewer Extension MO 780-1632, if any wastewater treatment component(s) are to be constructed.

A land disturbance permit is required if construction will result in the disturbance of one or more acres of land. A land disturbance permit (MO-RA00000) is available through the department's ePermitting system at <u>ePermitting Splash Page</u>. A permit fee in accordance with 10 CSR 20-6.011(2)(E) is required.

After receiving a complete application, the department enters the application information into the Missouri Clean Water Information System. You may search for the status of a construction permit online at <u>MoCWIS Application Search</u>.

- 1.1 Check appropriate box. If the project is funded with federal or state monies, supply the funding agency name and project number.
- 1.2 Check appropriate box and provide the date of department approval. The department has developed a fact sheet to aid in the development of an approvable engineering report, Engineering Report Guidance for Collection Systems, Fact Sheet--PUB2415. This document is available online at Engineering Report Guidance for Collection Systems With a Design Flow of 22,500 Gpd or Greater. Engineering report exemptions are listed in 10 CSR 20-6.010(4)(B). Per 10 CSR 20-8.110(2), engineering reports must be approved by the department prior to the submittal of plans and specifications and a construction permit application.
- 1.3 Check appropriate box. Provide a copy of the appropriate plans and specifications for department review when applying for a construction permit per 10 CSR 20-8.110 and 10 CSR 20-6.010. A Missouri registered professional engineering seal, signature and date is required on each sheet of the plans and the cover of the technical specifications. An electronic copy of the construction permit application and the information listed below in Portable Document Format (PDF) searchable format or department approved equivalent per 10 CSR 20-6.010(5)(G), along with one paper copy for projects not seeking department funding or two paper copies for projects seeking department funding under 10 CSR 20-4. If the project is relying on approved standard specifications is available online at <u>Wastewater Construction Permits and Engineering Regulations</u>
- 1.4 Check appropriate box. A summary of design shall accompany the plans and specifications when applying for a construction permit per 10 CSR 20-8.110. The department has developed a fact sheet to aid in the development of an acceptable summary of design, <u>Summary of Design Guidance, Fact Sheet--PUB2417</u>. This document is available online at <u>Summary of Design Guidance for Wastewater Treatment Facilities PUB2417</u>.
- 1.5 Check the appropriate box. Include fee with application per 10 CSR 20-6.011(2) and <u>Wastewater Treatment Facility Permit</u> Fees -- PUB2564.
- **Note:** The department returns incomplete construction permit applications and related engineering documents and the application forfeits the fees. See 10 CSR 20-6.011(5)(A). The applicant forfeits the fees when the applicant withdraws construction applications. See 10 CSR 20-6.011(5)(B).2.1. Provide the project name and location by street name or address.
- 2.1. Provide the project name and location by street name or address.
- 2.2 Provide the project legal description. The department's mapping system is available online at MAPIT ARCGIS.
- 2.3 Check all of the applicable boxes.

The department considers anything other than a gravity sewer system to be an alternative sewer system. Examples of these systems are grinder pump pressure sewers, septic tank effluent pump, or STEP, sewers, septic tank effluent gravity, or STEG, sewers or small diameter gravity sewers.

- 2.4 Briefly describe the project by providing the following information:
 - A. Total number of manholes.
 - B. Size of sewers and the total linear feet of each size.
 - C. Number of lift stations and design average flow and peak hourly flow capacities of each lift station.
 - D. Size and length of force mains.
 - E. Alternative sewer size and length, plus the number of components (e.g. septic tanks, grinder pumps, etc.)
- 2.5 Provide the project design information and when required in the units specified:
 - A. Provide the population or number of lots to be served by the proposed sewer extension.
 - B. Provide the estimated design flow information in accordance with 10 CSR 20-8.110(4)(C)4.A.
 - **Design average flow** The design average flow is the average of the daily volumes to be received for a continuous 12 month period expressed as a volume per unit time. However, the design average flow for facilities having critical seasonal high hydraulic loading periods (e.g., recreational areas, campuses and industrial facilities) shall be based on the daily average flow during the seasonal period.
 - **Design peak hourly flow** The design peak hourly flow is the largest volume of flow to be received during a one hour period expressed as a volume per unit time.
 - C. Provide the type and flow in gallons per day of industrial wastes received by the propose sewer extension.

- D. Provide the receiving sewer size in inches and capacity in gallons per minute.
- E. Check all of the applicable boxes.
- F. Provide an estimate of the number of onsite systems decommissioned as a result of the project.
- G: Provide estimated cost (design, materials, land, and labor) for installation of piping and pump station(s).
- 3.0 Project Owner Provide the legal name, mailing address, phone number and email address of the owner of the regulated activity or discharge. The owner identified in this section and subsequently reflected on the certificate page of the operating permit should be the owner of the regulated activity/discharge being applied for and is not necessarily the owner of the real property on which the activity or discharge is occurring. Also provide Charter Number of Project Owner from Secretary of State or name of Registered agent to comply with 10 CSR 20-6.010(2)(E) which states: "Private corporations which are not incorporated under the laws of Missouri shall be represented by a registered agent in the state of Missouri before a construction permit or an operating permit will be issued by the department."
- 4.0 Continuing Authority A continuing authority is a company, business, entity, or person(s) that will be legally responsible for ensuring compliance with the permit requirements and provide continuous stable oversight of the permitted facility or activity. The Continuing authority should be a relatively permanent entity responsible for the ongoing operation, maintenance and modernization, when needed, of the permitted facility or activity. A continuing authority is not, however, an entity or individual that is contractually hired by the permittee to sample or operate and maintain the system for a defined time period, such as a certified operator or analytical laboratory. To view the regulatory requirement regarding continuing authority, 10 CSR 20-6.010(2), please visit <u>Department of Natural Resources Division 20-Clean Water Commission Chapter 6-Permits</u>. A continuing authority's name must be listed exactly as it appears on the Missouri Secretary of State's (SoS's) webpage: <u>Missouri Secretary of State Business Entity Search</u>, unless the continuing authority is an individual(s), government entity, or otherwise not required to register with the SoS. Provide charter number listed on SoS's webpage, if applicable. If the Continuing Authority is the same as the Project Owner, write "Same as above".
- 4.1 Check appropriate box. Include a letter signed by the continuing authority (if not the same as the project owner) stating they will "accept, operate, and maintain" the sewer extension. The continuing authority may complete the "Continuing Authority and Receiving Wastewater Treatment Facility Acceptance" form in lieu of a letter. Download the department's form <u>Continuing Authority Receiving Wastewater Treatment Facility Acceptance-Mo 780-2584</u>. If the continuing authority will not accept and agree to operate and maintain the sewer extension, this application will be considered incomplete.
- 5.0 Complete Engineer contact information.
- 6.0 Complete Receiving Wastewater Treatment Facility information. Include the Missouri State Operating Permit number and the available remaining capacity in gallons per day, or gpd.
- 6.1 Check appropriate box. The receiving wastewater treatment facility must be notified and agree to the proposed sewer extension and additional flow, prior to submitting a construction permit to the department. If the receiving wastewater treatment facility will not accept the wastewater, this application will be considered incomplete.
- 6.2 Check appropriate box. Include a letter from the receiving wastewater treatment facility (if not same as the continuing authority) acknowledging and accepting the additional flow from the proposed sewer extension.
- 6.3 Check appropriate box. The Certificate of Convenience and Necessity (CCN) is granted by the Public Service Commission to for-profit companies to provide sewer services. 10 CSR 20-6.010(2)(B)3 requires the CCN be granted prior to applying for a permit from the department.
- 7.0 Check the appropriate box and include check or confirmation number. Applicants can pay fees online by credit card or eCheck through a system called JetPay. See <u>Water Permit Fees</u>. Clicking on the JetPay link you can make a one-time payment by selecting the "Water Protection Program" as the Payment Category and WP 04 Construction Permits as the Payment Type. The system then asks for Wastewater Permit Number (which is "construction") and Facility/Project name (which is the name of this project given in question 2.0). The fee for sewer extension review is \$300.
 - Per Section 37.001, RSMo, a transaction fee will be included. The transaction fee is paid to the third party vendor JetPay, not the Department of Natural Resources.
 - Be sure to select the correct fee type and corresponding URL to ensure your payment is applied appropriately. If you are unsure what type of fee to pay, contact the Water Protection Program's Budget, Fees and Grants Management Unit by phone at 573-522-1485 for assistance.
 - Upon successful completion of your payment, JetPay provides a payment confirmation. Submit this form with a copy of the payment confirmation if requesting a new permit or a permit modification.
 - If you are unable to make your payment online, but want to pay with credit card, you may email your name, phone
 number, and invoice number, if applicable, to <u>WPPFEES@dnr.mo.gov</u>. The Budget, Fees and Grants Management
 Unit will contact you to assist with the credit card payment. Please do not include your credit card information in
 the email.
 - Applicants can find fee rates for various activities in 10 CSR 20-6.011 and <u>Wastewater Treatment Facility Permit</u> <u>Fees-- PUB2564</u>.

8.0 The owner of the construction project must sign the application per 10 CSR 20-6.010(5)(G). Mail the completed form, related construction documents and applicable fee (or JetPay receipt) to the department. Also provide the application, plans and specifications in PDF searchable format via external media drive or email if size allows. Email information to <u>DNR.WPPEngineerSection@dnr.mo.gov.</u>

9.0-13.0 Sewer Extension Checklist

This portion of the application is optional, but completing it is recommended because it can speed review. If designed properly, the engineer preparing the application should be able to answer "Yes" or "Not Applicable" (N/A) for each of the items. If an answer of "N/A" is necessary, section 13.0 provides a place to provide any explanation or useful comments. Section 13.0 also requires those completing the Sewer Extension Checklist (9.0 - 13.0) to properly sign, seal and date the checklist. If there are any questions concerning this form, contact the Department of Natural Resources, Water Protection Program at 800-361-4827 or 573-751-1300, or visit <u>Wastewater</u> Construction Permits and Engineering.