

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



GENERAL PERMIT for SEWER EXTENSION CONSTRUCTION

The Missouri Department of Natural Resources hereby issues a permit to:

Construction Permit ID: MOGC00983
Title of Project: Autumn Creek
Owner: Autumn Creek Development, LLC
Address: P.O. Box 1101
Warrensburg, MO 64093

The project will also include general site work appropriate to the scope and purpose of the project and will include all the necessary appurtenances to make a complete and usable collection system. The construction of this project will be in the vicinity of the county below and discharge to Receiving Permit ID below:

County: Pettis Receiving Permit ID: MO0101567

for the construction of (described construction project):

AutumnCreek-Construction of approximately 1636 lf of 8-inch PVC SDR-26 and 1003 lf of 10-inch PVC SDR-26 gravity sewer lines with approximately 12 manholes to serve 144 units and a design average flow of 53,280 gpd.

Project is in the vicinity 3501 S Limit in Sedalia, Pettis County and discharges to an existing system to be treated at Sedalia Southeast WWTF, MO-0101587. Will Bracken, Utilities Director, with WWTF provided an acceptance form dated December 22,2025.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department). As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features. This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

March 13, 2026
Issue Date


Heather S Peters, Director
Water Protection Program

March 12, 2028
Expiration Date

APPLICABILITY

1. This permit authorizes the construction of gravity sewer extensions, force mains, and lift stations. Non earthen flow equalization storage basins at lift stations and inline storage, which flows back into the lift station or collection system, are also included.
2. The Missouri Department of Natural Resources may require a site-specific sewer extension construction permit due to compliance and enforcement actions in accordance with 10 CSR 20-6.010(13)(C).
3. This permit does not apply to:
 - A. Earthen storage basins;
 - B. Exempt projects in accordance with 10 CSR 20-6.010(1)(B), 10 CSR 20-6.010(5)(B), and RSMo 644.051 unless requested by the applicant or required by enforcement.

PREREQUISITES:

1. The Sewer Extension Construction Permit application, appropriate fee, and documentation in accordance with 10 CSR 20-6.010(5)(G).
2. Submit the Sewer Extension Construction Permit application at least sixty (60) days in advance of the start of construction in accordance with 10 CSR 20-6.010(5)(F).
3. Submit an electronic copy of the construction permit application and documents to DNR.WPPEngineerSection@dnr.mo.gov in accordance with 10 CSR 20-6.010(5)(G)3.
4. The plans and specifications, each signed, sealed, and dated by a professional engineer registered in the State of Missouri in accordance with 10 CSR 20-8 and 10 CSR 20-6.010.
5. The Design Certification form, Engineering Report, or Summary of Design, signed, sealed, and dated by a professional engineer registered in the State of Missouri, certifying the design of the system is in accordance with 10 CSR 20-6 and 10 CSR 20-8.
6. A statement from the continuing authority, as defined in 10 CSR 20-6.010, accepting the wastewater for treatment and indicating the permitted treatment facility has the available capacity.
7. A statement from the continuing authority, as defined in 10 CSR 20-6.010, accepting responsibility for the operation and maintenance of these facilities.

PERMIT CONDITIONS:

1. This permit authorizes the activities and scope of work detailed in the plans and specifications submitted with the request.
2. The construction must be in accordance with the final plans and specifications received by the Department. Revisions that affect capacity, flow, or system layout must be approved by the Department prior to construction.

PERMIT CONDITIONS: (continued)

3. If construction will incorporate minor changes from previously submitted plans and specifications (i.e., changes that do not affect the capacity, flow, or system layout), submit an electronic copy of the as-built plans and specifications in accordance with 10 CSR 20-8.110(11).
4. State and Federal Law does not permit bypassing of raw wastewater; therefore, the applicant must take steps to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's regional office per 10 CSR 20-7.015(9)(E) or through the Online Bypass/SSO Reporting service on the Missouri Gateway for Environmental Management (MoGEM) portal found at <https://dnr.mo.gov/data-e-services/missouri-gateway-environmental-management-mogem>.

See <https://dnr.mo.gov/document-search/missouri-gateway-environmental-management-mogem-frequently-asked-questions-pub2988/pub2988> for more information.

5. Protection of drinking water supplies must meet the requirements of 10 CSR 20-8.120(5).
 - A. There shall be no physical connections between a public or private potable water supply system and a sewer or appurtenance that would permit the passage of any wastewater or polluted water into the potable supply.
 - B. Lay sewers at least 50 feet (50') in a horizontal direction from any existing or proposed public water supply well or other water supply sources or structures.
6. Position manholes so that the top access is at or above grade level.
7. In addition to the requirements for a construction permit, see 10 CSR 20-6.200 for land disturbance requirements to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Applicants shall obtain land disturbance permits through the Department's ePermitting system, available online at <https://dnr.mo.gov/data-e-services/water/electronic-permitting-epermitting>.

See <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/stormwater/construction-land-disturbance> for more information.

8. Entities applying for funding under 10 CSR 20-4, "Grants and Loans" will need to comply with those requirements in addition to the requirements of 10 CSR 20-8.

PERMIT CONDITIONS: (continued)

9. The Department may require a United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) or a permit waiver for the activities described in this permit. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S., then a 404/401 is required. Fulfillment of these requirements is necessary before the permit is considered valid. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Operating Permits Section at 573-522-4502 for more information.

See <https://dnr.mo.gov/water/business-industry-other-entities/permits-certification-engineering-fees/section-401-water-quality> for more information.

10. If this project eliminates a wastewater treatment facility under the jurisdiction of the Department, then the applicant shall submit a full closure plan with a Facility Closure Request Form, [Form – MO 780-2512](#), to the Department's appropriate [regional office](#) for review and approval. In accordance with 10 CSR 20-6.010(12), the closure plan must meet the requirements outlined in Standard Conditions Part III of the Missouri State Operating Permit. Closure shall not commence until the Department approves the submitted closure plan.
11. If this project is part of a project to resolve an enforcement action or is receiving funding from the Department, submit a [statement of work complete](#) following the completion of construction.
12. Applicants may submit, prior to the expiration date of this permit, a written request that additional time is needed in accordance with 10 CSR 20-6.010(5)(H)3.



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
**APPLICATION FOR CONSTRUCTION PERMIT –
SEWER EXTENSION**

FOR DEPARTMENT USE ONLY

APP NO.

CP NO.

FEE RECEIVED

CHECK NO.

DATE RECEIVED

NOTE ► Please Read the accompanying instructions before completing this form

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? ☐ YES ☒ N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Department of Natural Resources approved the proposed project's engineering report*? ☐ YES Date of Approval: _____ ☒ NO ☐ N/A
- 1.3 Is a copy of the appropriate plans* and specifications* included with this application? ☒ YES ☐ NO
If the project is using standard specifications, name of community: Sedalia, MO
- 1.4 Is a summary of design* included with this application? ☒ YES ☐ NO
- 1.5 Is the appropriate fee or JetPay confirmation included with this application? ☒ YES ☐ NO
See Section 7.0

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT

Autumn Creek

ADDRESS

3501 S. Limit

CITY

Sedalia

STATE

MO

ZIP CODE

65301

COUNTY

Pettis

2.2 Legal Description: $\frac{1}{4}$, $\frac{1}{4}$, NE $\frac{1}{4}$, Sec. 17, T 45, R 21

2.3 Project Components (check all that apply):

☒ Gravity sewers ☐ Pumping stations ☐ Force mains ☐ Alternative sewer system ☐ Other (Describe below.)

2.4 PROJECT DESCRIPTION

Construction of a 36 lot, multi- family subdivision including grading, utilities, paving, curb and sidewalk.

Sanitary sewer includes 12-4' diameter concrete manholes, 1636 lf of 8" PVC pipe, 1003 lf of 10" PVC pipe and 144 service wyes with lateral extensions to the right of way.

2.5 DESIGN INFORMATION

A. Population or number of lots to be served by this extension: 36

B. Estimated flow to be contributed by this extension: Design Average Flow: 53k gpd Design Peak Hourly Flow: 8880 gph

C. Industrial Wastes: Type: N/A Flow: gpd

D. Receiving Sewer: Size: 15 inches Capacity: 5793 gpm

E. Does this project (check all that apply):

☒ Connect to an existing treatment plant ☐ Resolve enforcement issue ☐ Eliminate or consolidate an existing treatment plant

F. Estimated number of onsite systems being removed: N/A

G. Estimated costs associated with piping: \$ 250,700 Estimated costs associated with lift station(s): \$

3.0 PROJECT OWNER

NAME

Autumn Creek Development, LLC

TELEPHONE NUMBER WITH AREA CODE

816-898-3155

EMAIL ADDRESS

briancolsonfishing@gmail.com

ADDRESS

P.O. Box 1101

CITY

Warrensburg

STATE

MO

ZIP CODE

64093

CHARTER NUMBER (SECRETARY OF STATE) or REGISTERED AGENT

LC014606424

4.0 CONTINUING AUTHORITY: A continuing authority is a company, business, entity, or person(s) that will be legally responsible for ensuring compliance with the permit requirements and provide continuous stable oversight of the permitted facility or activity. The Continuing authority should be a relatively permanent entity responsible for the ongoing operation, maintenance and modernization, when needed, of the permitted facility or activity. A continuing authority is not, however, an entity or individual that is contractually hired by the permittee to sample or operate and maintain the system for a defined time period, such as a certified operator or analytical laboratory. To access the regulatory requirement regarding continuing authority, 10 CSR 20-6.010(2), please visit Clean Water Commission Chapter 6. A continuing authority's name must be listed exactly as it appears on the Missouri Secretary of State's (SoS's) webpage: Missouri Secretary of State, unless the continuing authority is an individual(s), government entity, or otherwise not required to register with the SoS.

NAME City of Sedalia		TELEPHONE NUMBER WITH AREA CODE 660-827-3000	EMAIL ADDRESS wbracken@sedalia.com
ADDRESS 200 S. Osage	CITY Sedalia	STATE MO	ZIP CODE 65301
CHARTER NUMBER (SECRETARY OF STATE) N/A			

4.1 Has appropriate continuing authority acceptance been provided as follows:
A letter from the continuing authority accepting responsibility for continued maintenance of the sewer (if the continuing authority is different than the original owner of the construction), or a properly executed "Continuing Authority and Receiving Wastewater Treatment Facility Acceptance" Form 780-2584. ☒ YES ☐ NO ☐ N/A

5.0 ENGINEER

ENGINEER NAME / COMPANY NAME Kevin Sterrett/Hg Consult, Inc.		TELEPHONE NUMBER WITH AREA CODE 816-703-7098	EMAIL ADDRESS ksterrett@hgcons.com
ADDRESS 1411 NE Todd George Road	CITY Lee's Summit	STATE MO	ZIP CODE 64086

6.0 RECEIVING WASTEWATER TREATMENT FACILITY

NAME City of Sedalia Wastewater Treatment Plant		TELEPHONE NUMBER WITH AREA CODE 660-827-3000	EMAIL ADDRESS wbracken@sedalia.com
MISSOURI STATE OPERATING PERMIT # MO-0101567		COUNTY Pettis	REMAINING CAPACITY (GPD) 910,000

6.1 If different from the owner, has a letter been provided from the receiving treatment facility demonstrating that they agree to accept the expanded flow or has a properly executed Continuing Authority and Receiving Wastewater Treatment Facility Acceptance MO 780-2584 form been provided? ☒ YES ☐ NO ☐ N/A

6.2 A letter from the receiving wastewater treatment facility, if different than the continuing authority, is included with this application.
☐ YES ☐ NO ☒ N/A

6.3 If the receiving treatment plant or continuing authority is regulated by the Public Service Commission (PSC) for sewer activities, a Certificate of Convenience and Necessity has been received? ☐ Yes - Date: ☐ No ☒ N/A

OPTIONAL QUESTIONS REGARDING MILITARY SERVICE

Have you or an immediate family member ever served in the U.S. Armed Forces?	☐ Yes ☒ No
If yes, would you like information about military-related services in Missouri?	☐ Yes ☐ No

7.0 Application Fee

☐ Check Number	☒ JetPay Confirmation Number
---------------------------------------	--

8.0 PROJECT OWNER: I certify under penalty of law this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PROJECT OWNER SIGNATURE



PRINTED NAME Brian Colson		DATE 1/7/26
TITLE OR CORPORATE POSITION Owner/Developer	TELEPHONE NUMBER WITH AREA CODE 816-898-3155	EMAIL ADDRESS briancolsonfishing@gmail.com

Mail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM PO BOX 176 JEFFERSON CITY, MO 65102-0176	Submit completed electronic copy to: Missouri Department of Natural Resources at DNR.WPPEngineerSection@dnr.mo.gov
--	---

9.0 SEWER EXTENSION CHECKLIST


SEWER EXTENSION DESIGN CERTIFICATION: Answer all questions yes or N/A. Answer N/A only if the question is clearly not applicable to the design of the proposed sewer extension.

	REGULATION		YES	N/A
1.	8.110(3)(A)	Is the design flow based on actual flow data for an existing system?	☐	☒
2.	8.110(3)(B)	Are average design flows, peak hourly flows and I&I contributions for new systems calculated?	☒	☐
3.	8.110(9)(B)	Is there a detailed plan showing tributary area, boundaries, pertinent elevations, topography, existing and proposed facilities?	☒	☐
4.	8.120(2)	Does the sewer exclude water from roofs, streets, groundwater from foundation drains and combined wastewater?	☒	☐
5.	8.120(3)(A)	Is the pipe installation, embedment and backfill designed to prevent damage to the pipe and its joints?	☒	☐
6.	8.120(3) (A)1	Is all sewer pipe constructed with a slope to obtain mean velocities of not less than 2 feet per second?	☒	☐
7.	8.120(3)(A)2	Is the pipe covered with at least 36" of soil or sufficiently insulated to prevent freezing?	☒	☐
8.	8.120(3)(B)	Is deflection testing specified to ensure no pipe exceeds a deflection of 5% of the inside diameter?	☒	☐
9.	8.120(4)(A)	Are manholes located at the end of each line, at all changes in grade, size or alignment and at all intersections?	☒	☐
10.	8.120(4)(C)	Are manholes at least 42 inches in diameter with a clear opening of 22 inches on sewer line larger than 8"?	☒	☐
11.	8.120(4)(C)	Where cleanouts are used at the end of a lateral instead of a manhole, they are a minimum diameter of 8 inches or larger and equal to the diameter for pipes < 8"?	☒	☐
12.	8.120(4)(E)	Are the manholes watertight, constructed and installed in accordance with the manufacturer's recommendations and procedures?	☒	☐
13.	8.120(4)(F)	Do the specifications include a requirement for inspection and testing for manholes?	☒	☐
14.	8.120(5)(A)	Is the sewer free from physical connections to a potable water supply system and no water pipes come in contact with a sewer manhole?	☒	☐
15.	8.120(5)(B)	Are sewers and manholes located at least 50 feet horizontally from any existing or proposed water supply well, sources, structures?	☒	☐

10.0 PRESSURE SEWERS, GRINDER PUMP, STEP AND STEG SEWER CHECKLIST

	REGULATION		YES	N/A
16.	8.125(5)(A)1.	Does the cleaning velocity of ≥ 2 ft/s happen more than once per day?	☐	☐
17.	8.125(5)(A)2.	Is the diameter of the pressure sewer main pipe at least 1.5"?	☐	☐
18.	8.125(5)(B)	Are appurtenances compatible with the piping system?	☐	☐
19.	8.125(5)(B)2.	Are isolation valves located: upstream of major pipe intersections; both sides of stream, bridge and RR crossings; at terminal end of system?	☐	☐
20.	8.125(5)(C)	Do service line pipes have a minimum diameter of 1.25"?	☐	☐
21.	8.125(5)(D)1.A	Do simplex grinder pump stations service only a single equivalent dwelling unit (EDU)? i.e. 1 residence – 1 grinder pump.	☐	☐
22.	8.125(5)(D)1.B	Are multiple unit pump stations owned, operated and maintained by an approved continuing authority?	☐	☐
23.	8.125(5)(D)3.	Is there at least 70 gallons of storage in the grinder pump unit?	☐	☐
24.	8.125(5)(D)4.	Do grinder pump stations have shutoff valves, check valves and anti-siphon valves (where siphoning could occur) that are accessible from the ground surface?	☐	☐
25.	8.125(5)(D)7., 8.130(3)(B)2.	Are units serviceable and replaceable under wet conditions without electrical hazard and is electrical equipment suitable for hazardous locations (National Electrical Code, Class I, Group D, Division 1 location)?	☐	☐
26.	8.125(5)(D)8., 8.125(2)(F)6.	Are provisions in place to avoid interruption of service due to mechanical or power failure by providing standby power, storage capacity, or interconnection with another disposal system?	☐	☐
27.	8.125(6)(D)	In a STEP system is at least one septic tank (1,000 gallons or more) provided for each EDU with 20% of tank volume dedicated to freeboard and ventilation?	☐	☐
28.	8.125(6)(F)	Are duplex pumps provided for the design flow of 1,500 gallons or greater?	☐	☐

MO 780-1632 (10-22)

11.0 PUMP STATION CHECKLIST				
	REGULATION		YES	N/A
29.	8.125(7)(C)	Is the minimum diameter sewer main pipe and service line of STEG sewer at least 4"?	☐	☐
30.	8.130(2)(A) 8.140(2)(B)	Is the pump station designed to withstand the 100-year flood?	☐	☐
31.	8.130(3)(A)	Is the dry well completely separate from the wet well and is a suitable and safe means of access provided to each?	☐	☐
32.	8.130(3)(B)	If the design flow is 1,500 gpd or more, are there at least 2 pumps or pneumatic ejectors provided?	☐	☐
33.	8.130(3)(D)	Are valves located outside wet well unless integral to a pump or its housing?	☐	☐
34.	8.130(3)(F) 8.140(8)(J)	Do wet and dry wells have separate ventilation systems?	☐	☐
35.	8.130(3)(G)	Does all potable water brought to pump stations comply with 8.140(7)(D)?	☐	☐
36.	8.130(6)	Is an alarm system provided with uninterrupted power?	☐	☐
37.	8.130(7)(A)	Is there 2 hours retention of the peak hourly flow for a design flow > 100,000 gpd or 4 hrs retention of the peak hourly flow for a design flow < 100,000 gpd?	☐	☐
38.	8.130(7)(B)	Are there independent utility substations provided for emergency power capable of starting and operating the pump station at its rated capacity?	☐	☐
39.	8.130(8)(A)	Is the force main velocity of ≥ 2 ft/s maintained?	☐	☐
40.	8.130	Are there complete operation instructions for the pumping stations provided that include emergency procedures, maintenance schedules, special tools and spare parts that may be necessary?	☐	☐
12.0 SUCTION LIFT PUMP AND SUBMERSIBLE PUMP STATION CHECKLIST				
	REGULATION		YES	N/A
41.	8.130(4)	Are the suction lift pumps of the self priming or vacuum priming type?	☐	☐
42.	8.130(4)(A)	Is the combined total of dynamic suction lift at the "pump off" elevation and required net positive suction head at design operating conditions less than or equal to 22 feet?	☐	☐
43.	8.130(4)(B)	Are there dual vacuum pumps capable of removing air from the suction lift pump?	☐	☐
44.	8.130(5)(A)	Are submersible pumps readily removable and replaceable without personnel entering, or disconnecting any pipe in the wet well?	☐	☐
13.0 SEWER EXTENSION CHECKLIST -- CERTIFICATION STATEMENT				
For any questions answered "N/A" provide an explanation. Also provide any useful general comments regarding design for review engineer.				
Design flow at point of connection to the existing system is based on the existing pipes capacity, based on Manning's Equation.				
Missouri Professional Engineer's seal, signature and date:				
				
Name: R. Kevin Sterrett				
Address: 1411 NE Todd George Road				
City: Lee's Summit		State: Missouri		ZIP Code: 64086
Telephone Number with Area Code: 816-703-7098			Email: ksterrett@hgcons.com	